Job Name/Location: For: File Resubmit Date: PO No.: ■ Approval ■ Other \_ GC: Architect:

Mech: Engr:

Rep: (Company) (Project Manager)

# ARUN121CTE4

Multi V™ IV Heat Pump 575V 10.0 Ton Outdoor Unit





# Performance:

Cooling Mode:

Nominal Capacity (Btu/h)	119,700
Power Input <sup>1</sup> (kW)	7.83

## Heating Mode:

Nominal Capacity (Btu/h)	135,000
Power Input <sup>1</sup> (kW)	9.21

Nominal Capacity is outside the scope of AHRI Standard 1230 and based on the following conditions:

Indoor: 80°F DB / 67°F WB Indoor: 70°F DB Outdoor 95°F DB Outdoor 47°F DB / 43°F WB

#### **Electrical:**

Power Supply (V/Hz/Ø)	575/60/3
MOP (A)	30
MCA (A)	18.5
Rated Amps (A)	15.3
Compressor A (A)	12.7
Compressor B (A)	-
Fan (A)	2.6

#### Piping:

Refrigerant Charge (lbs)	23.6
Liquid Line (in, OD)	1/2
Vapor Line (in, OD)	1-1/8

#### **Standard Features:**

- •HiPOR (high pressure oil return)
- •Smart Oil Control
- Split Coil Defrost
- Night Quiet Operation
- Fault Detection and Diagnosis

# **Optional Accessories:**

Air Guide - PRAGX3S0 (2 required)

## **Operating Range:**

Tag #:

Cooling (°F WB)	14-122
Heating (°F DB)	-13 - 61

## **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Number of Indoor Units <sup>2</sup>	20
Sound Pressure <sup>3</sup> dB(A)	59.0
Net Unit Weight (lbs)	540
Shipping Weight (lbs)	573
Communication Cable <sup>4</sup> (No x AWG)	2 x 18
Heat Exchanger Coating	GoldFin™

#### Compressor:

Туре	HSS DC Scroll
Quantity	1
Oil/Type	PVE/FVC68D

#### Fan:

Туре	Propeller
Quantity	2
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (CFM)	9,850

#### Notes:

- 1.For AHRI ratings, refer to the AHRI website http://www.ahridirectory.org(will be registered). 2.The combination ratio must be between 50 – 130%.
- 3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.
- 4.All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code.
- 5.Nominal data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination ratio between 95-105%.
- 6.The voltage tolerance is ± 10%
- 7. Power wiring cable size must comply with the applicable local and national code.





# ARUN121CTE4 Multi V™ IV Heat Pump 575V 10.0 Ton Outdoor Unit



Tag #:		
Date:		
PO No.:		

Airflow \$ **Bottom Mounting Holes** Top View Front View M4

Side View					Y Airflow
	L9				

<b>(</b>
II
Center
으
Gravity

tolerance of  $\pm 0.25$  in.

Note - All o	Z	Υ	×
Vote - All dimensions have	29-5/8"	13-1/2"	17-5/8"

Center of Gravity

M4	М3	M2	M1	L9	L8	L7	L6	L5	L4	L3	L2	L1	н	D	W
43-3/8"	2-5/8"	7/16"	29-1/16"	3-5/16"	2-9/16"	24-3/16"	2-9/16	5-3/8"	5-1/2"	3-1/8"	2-15/16"	7-1/4"	66-1/8"	29-15/16"	48-13/16"