Job Name/Location:

Date:
For:
■ File
■ Resubmit

PO No.:
■ Approval
■ Other

Architect:
GC:

Engr:
Mech:

Rep:

(Project Manager)

**© LG**AMMEN V B

## ARUN072CTE4

Multi V™ IV Heat Pump 575V 6.0 Ton Outdoor Unit

# 5.0 Ton Outdoor Unit

#### **Performance:**

(Company)

Cooling Mode:

N	ominal Capacity (Btu/h)	72,000
Po	ower Input¹ (kW)	4.37

#### Heating Mode:

Nominal Capacity (Btu/h)	81,000
Power Input¹ (kW)	5.02

Nominal Capacity is outside the scope of AHRI Standard 1230 and based on the following conditions: Indoor: 80°F DB / 67°F WB Indoor: 70°F DB

 Indoor:
 80°F DB / 67°F WB
 Indoor:
 70°F DB

 Outdoor
 95°F DB
 Outdoor
 47°F DB / 43°F WB

#### **Electrical:**

Power Supply (V/Hz/Ø)	575/60/3
MOP (A)	20
MCA (A)	13.6
Rated Amps (A)	11.3
Compressor A (A)	9.2
Compressor B (A)	-
Fan (A)	2.1

#### Piping:

Refrigerant Charge (lbs)	16.9
Liquid Line (in, OD)	3/8
Vapor Line (in, OD)	3/4

#### **Standard Features:**

- •HiPOR (high pressure oil return)
- •Smart Oil Control
- •Split Coil Defrost
- Night Quiet Operation
- Fault Detection and Diagnosis

#### **Optional Accessories:**

Air Guide - PRAGX2S0

### **Operating Range:**

Tag #:

Cooling (°F WB)	14-122
Heating (°F DB)	-13 - 61

#### **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Number of Indoor Units <sup>2</sup>	13
Sound Pressure <sup>3</sup> dB(A)	58.5
Net Unit Weight (lbs)	430
Shipping Weight (lbs)	452
Communication Cable <sup>4</sup> (No x AWG)	2 x 18
Heat Exchanger Coating	GoldFin™

#### Compressor:

Туре	HSS DC Scroll
Quantity	1
Oil/Type	PVE/FVC68D

#### Fan:

Туре	Propeller
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (CFM)	7,400

#### Notes:

- 1.For AHRI ratings, refer to the AHRI website http://www.ahridirectory.org(will be registered). 2.The combination ratio must be between 50 130%.
- 3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.
- 4.All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code.
- 5.Nominal data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination ratio between 95-105%.
- 6.The voltage tolerance is ± 10%
- 7.Power wiring cable size must comply with the applicable local and national code.








# ARUN072CTE4 Multi V™ IV Heat Pump 575V 6.0 Ton Outdoor Unit



Tag #:		
Date:		
PO No.:	 	



= Center of Gravity	tolerance of $\pm$ 0.25 in.	<ul> <li>All dimensions have a</li> </ul>
ξŢ		ave a

Note			
- All dir	Z	~	×
Note - All dimensions have	29-5/8"	13-1/2"	17-5/8"

Center of Gravity

M4	МЗ	M2	M1	L11	L10	L9	L8	L7	16	L5	L4	L3	L2	L1	Н	D	W
31-3/16"	2-5/8"	7/16"	29-1/16"	3-5/16"	2-9/16"	24-3/16"	2-9/16"	2-9/16"	22-7/16"	5-3/8"	5-1/2"	3-1/8"	2-15/16"	7-1/4"	66-1/8"	29-15/16"	36-1/4"