Job Name/Location: Tag #:

Date:	For: File Resubmit
PO No.:	Approval Other
Architect:	GC:
Engr:	Mech:
Rep:	
(Company)	(Project Manager)



## ARUB096CTE4

Multi V™ IV Heat Recovery 575V 8.0 Ton Outdoor Unit

#### Performance:

Cooling Mode:

Nominal Capacity (Btu/h)	96,000
Power Input <sup>1</sup> (kW)	5.76

#### Heating Mode:

Nominal Capacity (Btu/h)	108,000
Power Input¹ (kW)	6.76

Nominal Capacity is outside the scope of AHRI Standard 1230 and based on the following conditions:

Indoor: 80°F DB / 67°F WB Indoor: 70°F DB Outdoor 95°F DB Outdoor 47°F DB / 43°F WB

#### **Electrical:**

Liectifical.	
Power Supply (V/Hz/Ø)	575/60/3
MOP (A)	25
MCA (A)	17.5
Rated Amps (A)	14.5
Compressor A (A)	11.9
Compressor B (A)	-
Fan (A)	2.6

### Piping:

23.6
3/8
3/4
7/8

#### **Standard Features:**

- •HiPOR (high pressure oil return)
- •Smart Oil Control
- Split Coil Defrost
- Night Quiet Operation
- Fault Detection and Diagnosis

#### **Optional Accessories:**

Air Guide - PRAGX3S0 (2 required)

### **Operating Range:**

Cooling (°F DB)	14-122
Heating (°F WB)	-13 - 61

#### **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Number of Indoor Units <sup>2</sup>	16
Sound Pressure <sup>3</sup> dB(A)	59.0
Net Unit Weight (lbs)	540
Shipping Weight (lbs)	573
Communication Cable <sup>4</sup> (No. x AWG)	2 x 18
Heat Exchanger Coating	GoldFin™

#### Compressor:

Compressor Type	HSS DC Scroll
Compressor Quantity	1
Oil/Type	PVE/FVC68D

#### Fan:

Type Quantity	Propeller 2
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (CFM)	9,850

- 1.For AHRI ratings, refer to the AHRI website http://www.ahridirectory.org.(will be registered) 2. The combination ratio must be between 50 - 130%.
- 3.Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.

  4.All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code.
- 5.Nominal data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a  $\boldsymbol{0}$  ft level difference between outdoor and indoor units. All capacities are net with a
- combination ratio between 95-105%. 6.The voltage tolerance is ± 10%.
- 7. Power wiring cable size must comply with the applicable local and national code.






# ARUB096CTE4

Multi V™ IV Heat Recovery 575V 8.0 Ton Outdoor Unit



Tag #:		
Dato:		

PO No.:



V	フ

= Center of Gravity

Note - All dimensions have	Note - All o
29-5/8"	Z
13-1/2"	Υ
17-5/8"	X

Side View

Center of Gravity

M4	M3	M2	M1	L9	L8	L7	L6	L5	L4	L3	L2	L1	н	D	W
43-3/8"	2-5/8"	7/16"	29-1/16"	3-5/16"	2-9/16"	24-3/16"	2-9/16	5-3/8"	5-1/2"	3-1/8"	2-15/16"	7-1/4"	66-1/8"	29-15/16"	48-13/16"