Job Name/Location:					Tag #:	
Date:		For:	File	Resubmit		
PO No.:			Approval	Other		ea
Architect:	GC:				i li	Cracke
Engr:	Mech	ı:				
Rep:	(-					
(Company)	(Project M	anager)				

LMN159HVT

Multi F Wall Mounted High Efficiency Indoor Unit 14,300 Btu/h



Performance:

Nominal Cooling Capacity (Btu/h)	14,300
Nominal Heating Capacity (Btu/h)	15,600

Cooling Nominal Test Conditions: Indoor: 80°F DB / 67°F WB Outdoor: 95°F DB / 75°F WB

Heating Nominal Test Conditions: Indoor: 70°F DB / 60°F WB Outdoor: 47°F DB / 43°F WB

Electrical:

Power Supply (V¹/Hz/Ø)	208-230/60/1
Rated Amps (A)	0.4

Piping:

Installed Liquid Pipe (in., O.D.)	ø1/4
Installed Vapor Pipe (in., O.D.)	ø3/8
Liquid Connection (in., O.D.)	ø1/4
Vapor Connection (in., O.D.)	ø3/8
Drain (in., O.D. / I.D.)	27/32,5/8
Temperature Sensor	Thermistor

Controls Features:

- 4-Way auto swing24-Hour on/off timerAuto operation
- Auto restartChaos wind
- Inverter (variable speed fan)
- Jet cool/Jet heat3M Micro Dust Filter

- Self-cleaning indoor coil
 Sleep mode
 Condensate sensor connection
 Built-in Wi-Fi via Smart ThinQ app

Included Accessories:

Wireless Remote Controller — AKB74955602

Optional Accessories:

☐ MultiSITE™ CRC1 - PREMTBVC0 ☐ MultiSITE CRC1+ - PREMTBVC1 ☐ Dry Contact - PDRYCB320 ☐ RS3 Controller - PREMTB100

Entering Mixed Air:

Coc	oling (°F DB)	57 ~ 77
Hea	ating (°F WB)	59 ~ 81

Unit Data:

Refrigerant Type	R410A
Refrigerant Control	EEV
Sound Pressure (H/M/L) (±3 dB[A]) ²	42 / 38 / 32
Primary Filter	Washable Pre-filter
Secondard Filter	3M Micro Dust
Net Weight (lbs.)	18.3
Shipping Weight (lbs.)	23.4
'' '	

Fan:

Туре	Cross Flow
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow H/M/L (CFM)	314 / 268 / 184

Notes:

- NOTES:

 1. Acceptable operating voltage: 187V-253V.
 2. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.
 3. See Engineering Manual for sensible and latent capacities.
 4. All communication / connection (power) cable from the outdoor unit to the indoor unit is field supplied and must be a minimum of four-conductor, 18 AWG, stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoor unit only), and must comply with applicable local and national codes.
 5. Power wiring cable size must comply with applicable local and national code.
 6. The indoor unit comes with a dry helium charge.
 7. Corresponding refrigerant piping length is in accordance with standard length of each outdoor unit and the level difference is 0 ft. All capacities are net with a combination ratio between 95 105%.
 8. Must follow installation in instructions in the applicable LG installation manual.

- 8. Must follow installation instructions in the applicable LG installation manual.







Job I	Name/	Location:
-------	-------	-----------

LMN159HVT

Multi F Wall Mounted High Efficiency Indoor Unit 14,300 Btu/h



Tag No.: ______

Date: _____
PO No.: _____

