



MULTI F

MULTI F MAX

PERFORMANCE DATA MANUAL

Multi-Zone Heat Pump Systems 1.5 to 5 Tons



Dual and Tri-Zone
Multi F



Quad-Zone
Multi F



Eight-Zone
Multi F MAX

PROPRIETARY DATA NOTICE

This document, as well as all reports, illustrations, data, information, and other materials are the property of LG Electronics U.S.A., Inc., and are disclosed by LG Electronics U.S.A., Inc. only in confidence.

This document is for design purposes only.

For more technical materials such as submittals, catalogs, installation, owner's, and service manuals, visit www.lghvac.com.

Cooling Capacity Data	4-260
Multi F LMU18CHV.....	5-13
Multi F LMU24CHV.....	14-43
Multi F LMU30CHV.....	44-106
Multi F LMU36CHV.....	107-211
Multi F MAX LMU480HV	212-228
Multi F MAX LMU540HV	227-243
Multi F MAX LMU600HV	244-260
Heating Capacity Data.....	261-431
Multi F LMU18CHV.....	262-267
Multi F LMU24CHV.....	268-287
Multi F LMU30CHV.....	288-329
Multi F LMU36CHV.....	330-399
Multi F MAX LMU480HV	400-409
Multi F MAX LMU540HV	410-420
Multi F MAX LMU600HV	421-431

COOLING CAPACITY DATA

Multi F LMU18CHV on page 5

Multi F LMU24CHV on page 14

Multi F LMU30CHV on page 44

Multi F LMU36CHV on page 107

Multi F MAX LMU480HV on page 212

Multi F MAX LMU540HV on page 227

Multi F MAX LMU600HV on page 244

Table 1: LMU18CHV Cooling Capacity Table — Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	13.76	0.70	14.62	0.72	15.47	0.75	16.09	0.76	17.18	0.77	18.04	0.79
		0	13.76	0.71	14.61	0.73	15.47	0.76	16.08	0.77	17.17	0.78	18.03	0.80
		5	13.75	0.72	14.60	0.74	15.45	0.77	16.07	0.78	17.16	0.79	18.01	0.81
		10	13.73	0.73	14.59	0.75	15.44	0.78	16.06	0.79	17.15	0.81	18.00	0.82
		14	13.72	0.74	14.58	0.77	15.43	0.79	16.04	0.80	17.13	0.82	17.99	0.83
		20	13.71	0.75	14.57	0.78	15.42	0.80	16.03	0.81	17.12	0.83	17.97	0.85
		25	13.70	0.76	14.55	0.79	15.41	0.82	16.02	0.83	17.11	0.84	17.96	0.86
		30	13.69	0.77	14.54	0.80	15.39	0.83	16.01	0.84	17.09	0.85	17.94	0.87
		35	13.68	0.78	14.53	0.81	15.38	0.84	16.00	0.85	17.08	0.86	17.93	0.88
		40	13.67	0.79	14.52	0.82	15.37	0.85	15.98	0.86	17.07	0.88	17.92	0.89
		45	13.66	0.80	14.51	0.83	15.36	0.86	15.97	0.87	17.06	0.89	17.90	0.91
		50	13.65	0.81	14.50	0.84	15.35	0.87	15.96	0.88	17.04	0.90	17.89	0.92
		55	13.64	0.82	14.49	0.85	15.33	0.88	15.95	0.89	17.03	0.91	17.88	0.93
		60	13.63	0.83	14.48	0.86	15.32	0.90	15.93	0.91	17.02	0.92	17.86	0.94
		65	13.62	0.84	14.47	0.88	15.31	0.91	15.92	0.92	17.00	0.93	17.85	0.95
		70	13.61	0.86	14.45	0.89	15.30	0.92	15.91	0.93	16.99	0.95	17.83	0.97
		75	13.28	0.90	14.12	0.93	14.97	0.97	15.58	0.98	16.65	1.00	17.50	1.02
		80	12.95	0.95	13.80	0.98	14.64	1.02	15.24	1.03	16.32	1.05	17.16	1.07
		85	12.63	0.99	13.47	1.03	14.31	1.07	14.91	1.08	15.99	1.10	16.82	1.12
		90	12.30	1.04	13.14	1.08	13.98	1.12	14.58	1.13	15.65	1.15	16.49	1.17
		95	11.95	1.09	12.79	1.13	13.62	1.17	14.00	1.18	15.28	1.20	16.12	1.23
		100	11.66	1.13	12.49	1.17	13.33	1.22	13.82	1.23	14.99	1.25	15.82	1.28
		105	11.37	1.18	12.20	1.22	13.04	1.27	13.64	1.28	14.70	1.30	15.53	1.33
		110	11.08	1.22	11.91	1.27	12.74	1.32	13.35	1.33	14.41	1.36	15.24	1.38
		115	10.79	1.27	11.62	1.32	12.45	1.36	13.06	1.38	14.12	1.41	14.95	1.43
		118	10.61	1.30	11.45	1.35	12.28	1.39	12.88	1.41	13.94	1.44	14.78	1.47
		122	10.56	1.33	11.39	1.38	12.22	1.43	12.82	1.45	13.89	1.48	14.72	1.51
	7 + 9	-4	15.73	0.73	16.71	0.76	17.68	0.79	18.39	0.80	19.64	0.81	20.61	0.83
		0	15.72	0.74	16.70	0.77	17.67	0.80	18.38	0.81	19.63	0.82	20.60	0.84
		5	15.71	0.75	16.68	0.78	17.66	0.81	18.36	0.82	19.61	0.83	20.59	0.85
		10	15.70	0.76	16.67	0.79	17.65	0.82	18.35	0.83	19.60	0.85	20.57	0.86
		14	15.68	0.78	16.66	0.80	17.63	0.83	18.34	0.84	19.58	0.86	20.56	0.88
		20	15.67	0.79	16.65	0.82	17.62	0.85	18.32	0.86	19.57	0.87	20.54	0.89
		25	15.66	0.80	16.63	0.83	17.61	0.86	18.31	0.87	19.55	0.88	20.52	0.90
		30	15.65	0.81	16.62	0.84	17.59	0.87	18.29	0.88	19.54	0.90	20.51	0.91
		35	15.64	0.82	16.61	0.85	17.58	0.88	18.28	0.89	19.52	0.91	20.49	0.93
		40	15.62	0.83	16.60	0.86	17.57	0.89	18.27	0.90	19.51	0.92	20.48	0.94
		45	15.61	0.84	16.58	0.87	17.55	0.91	18.25	0.92	19.49	0.93	20.46	0.95
		50	15.60	0.85	16.57	0.89	17.54	0.92	18.24	0.93	19.48	0.95	20.45	0.96
		55	15.59	0.87	16.56	0.90	17.53	0.93	18.22	0.94	19.46	0.96	20.43	0.98
		60	15.58	0.88	16.54	0.91	17.51	0.94	18.21	0.95	19.45	0.97	20.41	0.99
		65	15.57	0.89	16.53	0.92	17.50	0.95	18.20	0.96	19.43	0.98	20.40	1.00
		70	15.55	0.90	16.52	0.93	17.49	0.97	18.18	0.98	19.42	0.99	20.38	1.01
		75	15.18	0.95	16.14	0.98	17.11	1.02	17.80	1.03	19.03	1.05	20.00	1.07
		80	14.80	1.00	15.77	1.03	16.73	1.07	17.42	1.08	18.65	1.10	19.61	1.12
		85	14.43	1.04	15.39	1.08	16.35	1.12	17.04	1.13	18.27	1.16	19.23	1.18
		90	14.06	1.09	15.02	1.13	15.98	1.17	16.67	1.19	17.89	1.21	18.84	1.23
		95	13.66	1.14	14.61	1.18	15.56	1.23	16.00	1.24	17.47	1.26	18.42	1.29
		100	13.33	1.19	14.28	1.23	15.23	1.28	15.79	1.29	17.13	1.32	18.09	1.34
		105	12.99	1.24	13.95	1.28	14.90	1.33	15.59	1.35	16.80	1.37	17.75	1.40
		110	12.66	1.29	13.61	1.33	14.57	1.38	15.25	1.40	16.47	1.42	17.42	1.45
		115	12.33	1.33	13.28	1.38	14.23	1.43	14.92	1.45	16.14	1.48	17.09	1.51
		118	12.13	1.36	13.08	1.41	14.03	1.47	14.72	1.48	15.94	1.51	16.89	1.54
		122	12.06	1.40	13.02	1.45	13.97	1.51	14.65	1.52	15.87	1.55	16.82	1.58

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU18CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 2: LMU18CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 9	-4	16.71	0.78	17.75	0.80	18.79	0.83	19.54	0.84	20.87	0.86	21.90	0.88
		0	16.70	0.78	17.74	0.81	18.78	0.84	19.53	0.85	20.85	0.87	21.89	0.88
		5	16.69	0.80	17.73	0.83	18.76	0.86	19.51	0.87	20.84	0.88	21.87	0.90
		10	16.68	0.81	17.71	0.84	18.75	0.87	19.50	0.88	20.82	0.89	21.86	0.91
		14	16.67	0.82	17.70	0.85	18.74	0.88	19.48	0.89	20.80	0.91	21.84	0.93
		20	16.65	0.83	17.69	0.86	18.72	0.89	19.47	0.90	20.79	0.92	21.82	0.94
		25	16.64	0.84	17.67	0.87	18.71	0.91	19.45	0.92	20.77	0.93	21.81	0.95
		30	16.63	0.86	17.66	0.89	18.69	0.92	19.44	0.93	20.76	0.95	21.79	0.97
		35	16.61	0.87	17.65	0.90	18.68	0.93	19.42	0.94	20.74	0.96	21.77	0.98
		40	16.60	0.88	17.63	0.91	18.66	0.94	19.41	0.95	20.73	0.97	21.76	0.99
		45	16.59	0.89	17.62	0.92	18.65	0.96	19.39	0.97	20.71	0.99	21.74	1.01
		50	16.58	0.90	17.61	0.94	18.63	0.97	19.38	0.98	20.69	1.00	21.72	1.02
		55	16.56	0.91	17.59	0.95	18.62	0.98	19.36	0.99	20.68	1.01	21.71	1.03
		60	16.55	0.93	17.58	0.96	18.61	0.99	19.35	1.01	20.66	1.02	21.69	1.05
		65	16.54	0.94	17.57	0.97	18.59	1.01	19.33	1.02	20.65	1.04	21.67	1.06
		70	16.53	0.95	17.55	0.98	18.58	1.02	19.32	1.03	20.63	1.05	21.66	1.07
		75	16.13	1.00	17.15	1.04	18.18	1.07	18.91	1.09	20.22	1.11	21.25	1.13
		80	15.73	1.05	16.75	1.09	17.77	1.13	18.51	1.14	19.81	1.16	20.84	1.19
		85	15.34	1.10	16.35	1.14	17.37	1.19	18.11	1.20	19.41	1.22	20.43	1.25
		90	14.94	1.15	15.96	1.20	16.97	1.24	17.71	1.25	19.01	1.28	20.02	1.30
		95	14.51	1.21	15.52	1.25	16.54	1.30	17.00	1.31	18.56	1.33	19.57	1.36
		100	14.16	1.26	15.17	1.30	16.18	1.35	16.78	1.37	18.20	1.39	19.22	1.42
		105	13.81	1.31	14.82	1.36	15.83	1.41	16.56	1.42	17.85	1.45	18.86	1.48
		110	13.45	1.36	14.46	1.41	15.48	1.46	16.21	1.48	17.50	1.50	18.51	1.53
		115	13.10	1.41	14.11	1.46	15.12	1.52	15.85	1.53	17.14	1.56	18.16	1.59
		118	12.89	1.44	13.90	1.49	14.91	1.55	15.64	1.57	16.93	1.60	17.94	1.63
		122	12.82	1.48	13.83	1.54	14.84	1.59	15.57	1.61	16.86	1.64	17.87	1.67
	7 + 12	-4	16.71	0.78	17.75	0.80	18.79	0.83	19.54	0.84	20.87	0.86	21.90	0.88
		0	16.70	0.78	17.74	0.81	18.78	0.84	19.53	0.85	20.85	0.87	21.89	0.88
		5	16.69	0.80	17.73	0.83	18.76	0.86	19.51	0.87	20.84	0.88	21.87	0.90
		10	16.68	0.81	17.71	0.84	18.75	0.87	19.50	0.88	20.82	0.89	21.86	0.91
		14	16.67	0.82	17.70	0.85	18.74	0.88	19.48	0.89	20.80	0.91	21.84	0.93
		20	16.65	0.83	17.69	0.86	18.72	0.89	19.47	0.90	20.79	0.92	21.82	0.94
		25	16.64	0.84	17.67	0.87	18.71	0.91	19.45	0.92	20.77	0.93	21.81	0.95
		30	16.63	0.86	17.66	0.89	18.69	0.92	19.44	0.93	20.76	0.95	21.79	0.97
		35	16.61	0.87	17.65	0.90	18.68	0.93	19.42	0.94	20.74	0.96	21.77	0.98
		40	16.60	0.88	17.63	0.91	18.66	0.94	19.41	0.95	20.73	0.97	21.76	0.99
		45	16.59	0.89	17.62	0.92	18.65	0.96	19.39	0.97	20.71	0.99	21.74	1.01
		50	16.58	0.90	17.61	0.94	18.63	0.97	19.38	0.98	20.69	1.00	21.72	1.02
		55	16.56	0.91	17.59	0.95	18.62	0.98	19.36	0.99	20.68	1.01	21.71	1.03
		60	16.55	0.93	17.58	0.96	18.61	0.99	19.35	1.01	20.66	1.02	21.69	1.05
		65	16.54	0.94	17.57	0.97	18.59	1.01	19.33	1.02	20.65	1.04	21.67	1.06
		70	16.53	0.95	17.55	0.98	18.58	1.02	19.32	1.03	20.63	1.05	21.66	1.07
		75	16.13	1.00	17.15	1.04	18.18	1.07	18.91	1.09	20.22	1.11	21.25	1.13
		80	15.73	1.05	16.75	1.09	17.77	1.13	18.51	1.14	19.81	1.16	20.84	1.19
		85	15.34	1.10	16.35	1.14	17.37	1.19	18.11	1.20	19.41	1.22	20.43	1.25
		90	14.94	1.15	15.96	1.20	16.97	1.24	17.71	1.25	19.01	1.28	20.02	1.30
		95	14.51	1.21	15.52	1.25	16.54	1.30	17.00	1.31	18.56	1.33	19.57	1.36
		100	14.16	1.26	15.17	1.30	16.18	1.35	16.78	1.37	18.20	1.39	19.22	1.42
		105	13.81	1.31	14.82	1.36	15.83	1.41	16.56	1.42	17.85	1.45	18.86	1.48
		110	13.45	1.36	14.46	1.41	15.48	1.46	16.21	1.48	17.50	1.50	18.51	1.53
		115	13.10	1.41	14.11	1.46	15.12	1.52	15.85	1.53	17.14	1.56	18.16	1.59
		118	12.89	1.44	13.90	1.49	14.91	1.55	15.64	1.57	16.93	1.60	17.94	1.63
		122	12.82	1.48	13.83	1.54	14.84	1.59	15.57	1.61	16.86	1.64	17.87	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 3: LMU18CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 12	-4	16.71	0.78	17.75	0.80	18.79	0.83	19.54	0.84	20.87	0.86	21.90	0.88
		0	16.70	0.78	17.74	0.81	18.78	0.84	19.53	0.85	20.85	0.87	21.89	0.88
		5	16.69	0.80	17.73	0.83	18.76	0.86	19.51	0.87	20.84	0.88	21.87	0.90
		10	16.68	0.81	17.71	0.84	18.75	0.87	19.50	0.88	20.82	0.89	21.86	0.91
		14	16.67	0.82	17.70	0.85	18.74	0.88	19.48	0.89	20.80	0.91	21.84	0.93
		20	16.65	0.83	17.69	0.86	18.72	0.89	19.47	0.90	20.79	0.92	21.82	0.94
		25	16.64	0.84	17.67	0.87	18.71	0.91	19.45	0.92	20.77	0.93	21.81	0.95
		30	16.63	0.86	17.66	0.89	18.69	0.92	19.44	0.93	20.76	0.95	21.79	0.97
		35	16.61	0.87	17.65	0.90	18.68	0.93	19.42	0.94	20.74	0.96	21.77	0.98
		40	16.60	0.88	17.63	0.91	18.66	0.94	19.41	0.95	20.73	0.97	21.76	0.99
		45	16.59	0.89	17.62	0.92	18.65	0.96	19.39	0.97	20.71	0.99	21.74	1.01
		50	16.58	0.90	17.61	0.94	18.63	0.97	19.38	0.98	20.69	1.00	21.72	1.02
		55	16.56	0.91	17.59	0.95	18.62	0.98	19.36	0.99	20.68	1.01	21.71	1.03
		60	16.55	0.93	17.58	0.96	18.61	0.99	19.35	1.01	20.66	1.02	21.69	1.05
		65	16.54	0.94	17.57	0.97	18.59	1.01	19.33	1.02	20.65	1.04	21.67	1.06
		70	16.53	0.95	17.55	0.98	18.58	1.02	19.32	1.03	20.63	1.05	21.66	1.07
		75	16.13	1.00	17.15	1.04	18.18	1.07	18.91	1.09	20.22	1.11	21.25	1.13
		80	15.73	1.05	16.75	1.09	17.77	1.13	18.51	1.14	19.81	1.16	20.84	1.19
		85	15.34	1.10	16.35	1.14	17.37	1.19	18.11	1.20	19.41	1.22	20.43	1.25
		90	14.94	1.15	15.96	1.20	16.97	1.24	17.71	1.25	19.01	1.28	20.02	1.30
		95	14.51	1.21	15.52	1.25	16.54	1.30	17.00	1.31	18.56	1.33	19.57	1.36
		100	14.16	1.26	15.17	1.30	16.18	1.35	16.78	1.37	18.20	1.39	19.22	1.42
		105	13.81	1.31	14.82	1.36	15.83	1.41	16.56	1.42	17.85	1.45	18.86	1.48
		110	13.45	1.36	14.46	1.41	15.48	1.46	16.21	1.48	17.50	1.50	18.51	1.53
		115	13.10	1.41	14.11	1.46	15.12	1.52	15.85	1.53	17.14	1.56	18.16	1.59
		118	12.89	1.44	13.90	1.49	14.91	1.55	15.64	1.57	16.93	1.60	17.94	1.63
		122	12.82	1.48	13.83	1.54	14.84	1.59	15.57	1.61	16.86	1.64	17.87	1.67
	7 + 15	-4	16.71	0.78	17.75	0.80	18.79	0.83	19.54	0.84	20.87	0.86	21.90	0.88
		0	16.70	0.78	17.74	0.81	18.78	0.84	19.53	0.85	20.85	0.87	21.89	0.88
		5	16.69	0.80	17.73	0.83	18.76	0.86	19.51	0.87	20.84	0.88	21.87	0.90
		10	16.68	0.81	17.71	0.84	18.75	0.87	19.50	0.88	20.82	0.89	21.86	0.91
		14	16.67	0.82	17.70	0.85	18.74	0.88	19.48	0.89	20.80	0.91	21.84	0.93
		20	16.65	0.83	17.69	0.86	18.72	0.89	19.47	0.90	20.79	0.92	21.82	0.94
		25	16.64	0.84	17.67	0.87	18.71	0.91	19.45	0.92	20.77	0.93	21.81	0.95
		30	16.63	0.86	17.66	0.89	18.69	0.92	19.44	0.93	20.76	0.95	21.79	0.97
		35	16.61	0.87	17.65	0.90	18.68	0.93	19.42	0.94	20.74	0.96	21.77	0.98
		40	16.60	0.88	17.63	0.91	18.66	0.94	19.41	0.95	20.73	0.97	21.76	0.99
		45	16.59	0.89	17.62	0.92	18.65	0.96	19.39	0.97	20.71	0.99	21.74	1.01
		50	16.58	0.90	17.61	0.94	18.63	0.97	19.38	0.98	20.69	1.00	21.72	1.02
		55	16.56	0.91	17.59	0.95	18.62	0.98	19.36	0.99	20.68	1.01	21.71	1.03
		60	16.55	0.93	17.58	0.96	18.61	0.99	19.35	1.01	20.66	1.02	21.69	1.05
		65	16.54	0.94	17.57	0.97	18.59	1.01	19.33	1.02	20.65	1.04	21.67	1.06
		70	16.53	0.95	17.55	0.98	18.58	1.02	19.32	1.03	20.63	1.05	21.66	1.07
		75	16.13	1.00	17.15	1.04	18.18	1.07	18.91	1.09	20.22	1.11	21.25	1.13
		80	15.73	1.05	16.75	1.09	17.77	1.13	18.51	1.14	19.81	1.16	20.84	1.19
		85	15.34	1.10	16.35	1.14	17.37	1.19	18.11	1.20	19.41	1.22	20.43	1.25
		90	14.94	1.15	15.96	1.20	16.97	1.24	17.71	1.25	19.01	1.28	20.02	1.30
		95	14.51	1.21	15.52	1.25	16.54	1.30	17.00	1.31	18.56	1.33	19.57	1.36
		100	14.16	1.26	15.17	1.30	16.18	1.35	16.78	1.37	18.20	1.39	19.22	1.42
		105	13.81	1.31	14.82	1.36	15.83	1.41	16.56	1.42	17.85	1.45	18.86	1.48
		110	13.45	1.36	14.46	1.41	15.48	1.46	16.21	1.48	17.50	1.50	18.51	1.53
		115	13.10	1.41	14.11	1.46	15.12	1.52	15.85	1.53	17.14	1.56	18.16	1.59
		118	12.89	1.44	13.90	1.49	14.91	1.55	15.64	1.57	16.93	1.60	17.94	1.63
		122	12.82	1.48	13.83	1.54	14.84	1.59	15.57	1.61	16.86	1.64	17.87	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU18CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 4: LMU18CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	16.71	0.78	17.75	0.80	18.79	0.83	19.54	0.84	20.87	0.86	21.90	0.88
		0	16.70	0.78	17.74	0.81	18.78	0.84	19.53	0.85	20.85	0.87	21.89	0.88
		5	16.69	0.80	17.73	0.83	18.76	0.86	19.51	0.87	20.84	0.88	21.87	0.90
		10	16.68	0.81	17.71	0.84	18.75	0.87	19.50	0.88	20.82	0.89	21.86	0.91
		14	16.67	0.82	17.70	0.85	18.74	0.88	19.48	0.89	20.80	0.91	21.84	0.93
		20	16.65	0.83	17.69	0.86	18.72	0.89	19.47	0.90	20.79	0.92	21.82	0.94
		25	16.64	0.84	17.67	0.87	18.71	0.91	19.45	0.92	20.77	0.93	21.81	0.95
		30	16.63	0.86	17.66	0.89	18.69	0.92	19.44	0.93	20.76	0.95	21.79	0.97
		35	16.61	0.87	17.65	0.90	18.68	0.93	19.42	0.94	20.74	0.96	21.77	0.98
		40	16.60	0.88	17.63	0.91	18.66	0.94	19.41	0.95	20.73	0.97	21.76	0.99
		45	16.59	0.89	17.62	0.92	18.65	0.96	19.39	0.97	20.71	0.99	21.74	1.01
		50	16.58	0.90	17.61	0.94	18.63	0.97	19.38	0.98	20.69	1.00	21.72	1.02
		55	16.56	0.91	17.59	0.95	18.62	0.98	19.36	0.99	20.68	1.01	21.71	1.03
		60	16.55	0.93	17.58	0.96	18.61	0.99	19.35	1.01	20.66	1.02	21.69	1.05
		65	16.54	0.94	17.57	0.97	18.59	1.01	19.33	1.02	20.65	1.04	21.67	1.06
		70	16.53	0.95	17.55	0.98	18.58	1.02	19.32	1.03	20.63	1.05	21.66	1.07
		75	16.13	1.00	17.15	1.04	18.18	1.07	18.91	1.09	20.22	1.11	21.25	1.13
		80	15.73	1.05	16.75	1.09	17.77	1.13	18.51	1.14	19.81	1.16	20.84	1.19
		85	15.34	1.10	16.35	1.14	17.37	1.19	18.11	1.20	19.41	1.22	20.43	1.25
		90	14.94	1.15	15.96	1.20	16.97	1.24	17.71	1.25	19.01	1.28	20.02	1.30
		95	14.51	1.21	15.52	1.25	16.54	1.30	17.00	1.31	18.56	1.33	19.57	1.36
		100	14.16	1.26	15.17	1.30	16.18	1.35	16.78	1.37	18.20	1.39	19.22	1.42
		105	13.81	1.31	14.82	1.36	15.83	1.41	16.56	1.42	17.85	1.45	18.86	1.48
		110	13.45	1.36	14.46	1.41	15.48	1.46	16.21	1.48	17.50	1.50	18.51	1.53
		115	13.10	1.41	14.11	1.46	15.12	1.52	15.85	1.53	17.14	1.56	18.16	1.59
		118	12.89	1.44	13.90	1.49	14.91	1.55	15.64	1.57	16.93	1.60	17.94	1.63
		122	12.82	1.48	13.83	1.54	14.84	1.59	15.57	1.61	16.86	1.64	17.87	1.67
	12 + 12	-4	16.71	0.78	17.75	0.80	18.79	0.83	19.54	0.84	20.87	0.86	21.90	0.88
		0	16.70	0.78	17.74	0.81	18.78	0.84	19.53	0.85	20.85	0.87	21.89	0.88
		5	16.69	0.80	17.73	0.83	18.76	0.86	19.51	0.87	20.84	0.88	21.87	0.90
		10	16.68	0.81	17.71	0.84	18.75	0.87	19.50	0.88	20.82	0.89	21.86	0.91
		14	16.67	0.82	17.70	0.85	18.74	0.88	19.48	0.89	20.80	0.91	21.84	0.93
		20	16.65	0.83	17.69	0.86	18.72	0.89	19.47	0.90	20.79	0.92	21.82	0.94
		25	16.64	0.84	17.67	0.87	18.71	0.91	19.45	0.92	20.77	0.93	21.81	0.95
		30	16.63	0.86	17.66	0.89	18.69	0.92	19.44	0.93	20.76	0.95	21.79	0.97
		35	16.61	0.87	17.65	0.90	18.68	0.93	19.42	0.94	20.74	0.96	21.77	0.98
		40	16.60	0.88	17.63	0.91	18.66	0.94	19.41	0.95	20.73	0.97	21.76	0.99
		45	16.59	0.89	17.62	0.92	18.65	0.96	19.39	0.97	20.71	0.99	21.74	1.01
		50	16.58	0.90	17.61	0.94	18.63	0.97	19.38	0.98	20.69	1.00	21.72	1.02
		55	16.56	0.91	17.59	0.95	18.62	0.98	19.36	0.99	20.68	1.01	21.71	1.03
		60	16.55	0.93	17.58	0.96	18.61	0.99	19.35	1.01	20.66	1.02	21.69	1.05
		65	16.54	0.94	17.57	0.97	18.59	1.01	19.33	1.02	20.65	1.04	21.67	1.06
		70	16.53	0.95	17.55	0.98	18.58	1.02	19.32	1.03	20.63	1.05	21.66	1.07
		75	16.13	1.00	17.15	1.04	18.18	1.07	18.91	1.09	20.22	1.11	21.25	1.13
		80	15.73	1.05	16.75	1.09	17.77	1.13	18.51	1.14	19.81	1.16	20.84	1.19
		85	15.34	1.10	16.35	1.14	17.37	1.19	18.11	1.20	19.41	1.22	20.43	1.25
		90	14.94	1.15	15.96	1.20	16.97	1.24	17.71	1.25	19.01	1.28	20.02	1.30
		95	14.51	1.21	15.52	1.25	16.54	1.30	17.00	1.31	18.56	1.33	19.57	1.36
		100	14.16	1.26	15.17	1.30	16.18	1.35	16.78	1.37	18.20	1.39	19.22	1.42
		105	13.81	1.31	14.82	1.36	15.83	1.41	16.56	1.42	17.85	1.45	18.86	1.48
		110	13.45	1.36	14.46	1.41	15.48	1.46	16.21	1.48	17.50	1.50	18.51	1.53
		115	13.10	1.41	14.11	1.46	15.12	1.52	15.85	1.53	17.14	1.56	18.16	1.59
		118	12.89	1.44	13.90	1.49	14.91	1.55	15.64	1.57	16.93	1.60	17.94	1.63
		122	12.82	1.48	13.83	1.54	14.84	1.59	15.57	1.61	16.86	1.64	17.87	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 5: LMU18CHV Cooling Capacity Table — Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 9	-4	13.76	0.77	14.62	0.80	15.47	0.83	16.09	0.84	17.18	0.86	18.04	0.87
		0	13.76	0.78	14.61	0.81	15.47	0.84	16.08	0.85	17.17	0.87	18.03	0.88
		5	13.75	0.80	14.60	0.82	15.45	0.85	16.07	0.86	17.16	0.88	18.01	0.90
		10	13.73	0.81	14.59	0.84	15.44	0.87	16.06	0.88	17.15	0.89	18.00	0.91
		14	13.72	0.82	14.58	0.85	15.43	0.88	16.04	0.89	17.13	0.91	17.99	0.92
		20	13.71	0.83	14.57	0.86	15.42	0.89	16.03	0.90	17.12	0.92	17.97	0.94
		25	13.70	0.84	14.55	0.87	15.41	0.90	16.02	0.92	17.11	0.93	17.96	0.95
		30	13.69	0.85	14.54	0.89	15.39	0.92	16.01	0.93	17.09	0.95	17.94	0.96
		35	13.68	0.87	14.53	0.90	15.38	0.93	16.00	0.94	17.08	0.96	17.93	0.98
		40	13.67	0.88	14.52	0.91	15.37	0.94	15.98	0.95	17.07	0.97	17.92	0.99
		45	13.66	0.89	14.51	0.92	15.36	0.96	15.97	0.97	17.06	0.98	17.90	1.00
		50	13.65	0.90	14.50	0.93	15.35	0.97	15.96	0.98	17.04	1.00	17.89	1.02
		55	13.64	0.91	14.49	0.95	15.33	0.98	15.95	0.99	17.03	1.01	17.88	1.03
		60	13.63	0.92	14.48	0.96	15.32	0.99	15.93	1.00	17.02	1.02	17.86	1.04
		65	13.62	0.94	14.47	0.97	15.31	1.01	15.92	1.02	17.00	1.04	17.85	1.06
		70	13.61	0.95	14.45	0.98	15.30	1.02	15.91	1.03	16.99	1.05	17.83	1.07
		75	13.28	1.00	14.12	1.04	14.97	1.07	15.58	1.09	16.65	1.11	17.50	1.13
		80	12.95	1.05	13.80	1.09	14.64	1.13	15.24	1.14	16.32	1.16	17.16	1.19
		85	12.63	1.10	13.47	1.14	14.31	1.18	14.91	1.20	15.99	1.22	16.82	1.24
		90	12.30	1.15	13.14	1.19	13.98	1.24	14.58	1.25	15.65	1.28	16.49	1.30
		95	11.95	1.20	12.79	1.25	13.62	1.29	14.00	1.31	15.28	1.33	16.12	1.36
		100	11.66	1.25	12.49	1.30	13.33	1.35	13.82	1.36	14.99	1.39	15.82	1.42
		105	11.37	1.31	12.20	1.35	13.04	1.40	13.64	1.42	14.70	1.45	15.53	1.47
		110	11.08	1.36	11.91	1.41	12.74	1.46	13.35	1.47	14.41	1.50	15.24	1.53
		115	10.79	1.41	11.62	1.46	12.45	1.51	13.06	1.53	14.12	1.56	14.95	1.59
		118	10.61	1.44	11.45	1.49	12.28	1.55	12.88	1.56	13.94	1.59	14.78	1.62
		122	10.56	1.48	11.39	1.53	12.22	1.59	12.82	1.61	13.89	1.64	14.72	1.67
	9 + 12	-4	13.76	0.77	14.62	0.80	15.47	0.83	16.09	0.84	17.18	0.86	18.04	0.87
		0	13.76	0.78	14.61	0.81	15.47	0.84	16.08	0.85	17.17	0.87	18.03	0.88
		5	13.75	0.80	14.60	0.82	15.45	0.85	16.07	0.86	17.16	0.88	18.01	0.90
		10	13.73	0.81	14.59	0.84	15.44	0.87	16.06	0.88	17.15	0.89	18.00	0.91
		14	13.72	0.82	14.58	0.85	15.43	0.88	16.04	0.89	17.13	0.91	17.99	0.92
		20	13.71	0.83	14.57	0.86	15.42	0.89	16.03	0.90	17.12	0.92	17.97	0.94
		25	13.70	0.84	14.55	0.87	15.41	0.90	16.02	0.92	17.11	0.93	17.96	0.95
		30	13.69	0.85	14.54	0.89	15.39	0.92	16.01	0.93	17.09	0.95	17.94	0.96
		35	13.68	0.87	14.53	0.90	15.38	0.93	16.00	0.94	17.08	0.96	17.93	0.98
		40	13.67	0.88	14.52	0.91	15.37	0.94	15.98	0.95	17.07	0.97	17.92	0.99
		45	13.66	0.89	14.51	0.92	15.36	0.96	15.97	0.97	17.06	0.98	17.90	1.00
		50	13.65	0.90	14.50	0.93	15.35	0.97	15.96	0.98	17.04	1.00	17.89	1.02
		55	13.64	0.91	14.49	0.95	15.33	0.98	15.95	0.99	17.03	1.01	17.88	1.03
		60	13.63	0.92	14.48	0.96	15.32	0.99	15.93	1.00	17.02	1.02	17.86	1.04
		65	13.62	0.94	14.47	0.97	15.31	1.01	15.92	1.02	17.00	1.04	17.85	1.06
		70	13.61	0.95	14.45	0.98	15.30	1.02	15.91	1.03	16.99	1.05	17.83	1.07
		75	13.28	1.00	14.12	1.04	14.97	1.07	15.58	1.09	16.65	1.11	17.50	1.13
		80	12.95	1.05	13.80	1.09	14.64	1.13	15.24	1.14	16.32	1.16	17.16	1.19
		85	12.63	1.10	13.47	1.14	14.31	1.18	14.91	1.20	15.99	1.22	16.82	1.24
		90	12.30	1.15	13.14	1.19	13.98	1.24	14.58	1.25	15.65	1.28	16.49	1.30
		95	11.95	1.20	12.79	1.25	13.62	1.29	14.00	1.31	15.28	1.33	16.12	1.36
		100	11.66	1.25	12.49	1.30	13.33	1.35	13.82	1.36	14.99	1.39	15.82	1.42
		105	11.37	1.31	12.20	1.35	13.04	1.40	13.64	1.42	14.70	1.45	15.53	1.47
		110	11.08	1.36	11.91	1.41	12.74	1.46	13.35	1.47	14.41	1.50	15.24	1.53
		115	10.79	1.41	11.62	1.46	12.45	1.51	13.06	1.53	14.12	1.56	14.95	1.59
		118	10.61	1.44	11.45	1.49	12.28	1.55	12.88	1.56	13.94	1.59	14.78	1.62
		122	10.56	1.48	11.39	1.53	12.22	1.59	12.82	1.61	13.89	1.64	14.72	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 6: LMU18CHV Cooling Capacity Table — Ducted (continued) and Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 12	-4	13.76	0.77	14.62	0.80	15.47	0.83	16.09	0.84	17.18	0.86	18.04	0.87
		0	13.76	0.78	14.61	0.81	15.47	0.84	16.08	0.85	17.17	0.87	18.03	0.88
		5	13.75	0.80	14.60	0.82	15.45	0.85	16.07	0.86	17.16	0.88	18.01	0.90
		10	13.73	0.81	14.59	0.84	15.44	0.87	16.06	0.88	17.15	0.89	18.00	0.91
		14	13.72	0.82	14.58	0.85	15.43	0.88	16.04	0.89	17.13	0.91	17.99	0.92
		20	13.71	0.83	14.57	0.86	15.42	0.89	16.03	0.90	17.12	0.92	17.97	0.94
		25	13.70	0.84	14.55	0.87	15.41	0.90	16.02	0.92	17.11	0.93	17.96	0.95
		30	13.69	0.85	14.54	0.89	15.39	0.92	16.01	0.93	17.09	0.95	17.94	0.96
		35	13.68	0.87	14.53	0.90	15.38	0.93	16.00	0.94	17.08	0.96	17.93	0.98
		40	13.67	0.88	14.52	0.91	15.37	0.94	15.98	0.95	17.07	0.97	17.92	0.99
		45	13.66	0.89	14.51	0.92	15.36	0.96	15.97	0.97	17.06	0.98	17.90	1.00
		50	13.65	0.90	14.50	0.93	15.35	0.97	15.96	0.98	17.04	1.00	17.89	1.02
		55	13.64	0.91	14.49	0.95	15.33	0.98	15.95	0.99	17.03	1.01	17.88	1.03
		60	13.63	0.92	14.48	0.96	15.32	0.99	15.93	1.00	17.02	1.02	17.86	1.04
		65	13.62	0.94	14.47	0.97	15.31	1.01	15.92	1.02	17.00	1.04	17.85	1.06
		70	13.61	0.95	14.45	0.98	15.30	1.02	15.91	1.03	16.99	1.05	17.83	1.07
		75	13.28	1.00	14.12	1.04	14.97	1.07	15.58	1.09	16.65	1.11	17.50	1.13
		80	12.95	1.05	13.80	1.09	14.64	1.13	15.24	1.14	16.32	1.16	17.16	1.19
		85	12.63	1.10	13.47	1.14	14.31	1.18	14.91	1.20	15.99	1.22	16.82	1.24
		90	12.30	1.15	13.14	1.19	13.98	1.24	14.58	1.25	15.65	1.28	16.49	1.30
		95	11.95	1.20	12.79	1.25	13.62	1.29	14.00	1.31	15.28	1.33	16.12	1.36
		100	11.66	1.25	12.49	1.30	13.33	1.35	13.82	1.36	14.99	1.39	15.82	1.42
		105	11.37	1.31	12.20	1.35	13.04	1.40	13.64	1.42	14.70	1.45	15.53	1.47
		110	11.08	1.36	11.91	1.41	12.74	1.46	13.35	1.47	14.41	1.50	15.24	1.53
		115	10.79	1.41	11.62	1.46	12.45	1.51	13.06	1.53	14.12	1.56	14.95	1.59
		118	10.61	1.44	11.45	1.49	12.28	1.55	12.88	1.56	13.94	1.59	14.78	1.62
Two (2) Mixed Indoor Units	7 + 9	122	10.56	1.48	11.39	1.53	12.22	1.59	12.82	1.61	13.89	1.64	14.72	1.67
		-4	14.34	0.73	15.23	0.76	16.12	0.79	16.77	0.80	17.90	0.81	18.80	0.83
		0	14.33	0.74	15.22	0.77	16.11	0.80	16.76	0.81	17.90	0.82	18.79	0.84
		5	14.32	0.75	15.21	0.78	16.10	0.81	16.74	0.82	17.88	0.83	18.77	0.85
		10	14.31	0.76	15.20	0.79	16.09	0.82	16.73	0.83	17.87	0.85	18.76	0.86
		14	14.30	0.78	15.19	0.80	16.08	0.83	16.72	0.84	17.85	0.86	18.74	0.88
		20	14.29	0.79	15.18	0.82	16.06	0.85	16.71	0.85	17.84	0.87	18.73	0.89
		25	14.28	0.80	15.17	0.83	16.05	0.86	16.69	0.87	17.83	0.88	18.71	0.90
		30	14.27	0.81	15.15	0.84	16.04	0.87	16.68	0.88	17.81	0.90	18.70	0.91
		35	14.26	0.82	15.14	0.85	16.03	0.88	16.67	0.89	17.80	0.91	18.68	0.93
		40	14.25	0.83	15.13	0.86	16.02	0.89	16.65	0.90	17.79	0.92	18.67	0.94
		45	14.24	0.84	15.12	0.87	16.00	0.90	16.64	0.92	17.77	0.93	18.66	0.95
		50	14.22	0.85	15.11	0.88	15.99	0.92	16.63	0.93	17.76	0.94	18.64	0.96
		55	14.21	0.86	15.10	0.90	15.98	0.93	16.62	0.94	17.74	0.96	18.63	0.98
		60	14.20	0.88	15.08	0.91	15.97	0.94	16.60	0.95	17.73	0.97	18.61	0.99
		65	14.19	0.89	15.07	0.92	15.95	0.95	16.59	0.96	17.72	0.98	18.60	1.00
		70	14.18	0.90	15.06	0.93	15.94	0.96	16.58	0.98	17.70	0.99	18.58	1.01
		75	13.84	0.95	14.72	0.98	15.60	1.02	16.23	1.03	17.35	1.05	18.23	1.07
		80	13.50	0.99	14.37	1.03	15.25	1.07	15.88	1.08	17.00	1.10	17.88	1.12
		85	13.16	1.04	14.03	1.08	14.91	1.12	15.54	1.13	16.66	1.15	17.53	1.18
		90	12.82	1.09	13.69	1.13	14.57	1.17	15.20	1.19	16.31	1.21	17.18	1.23
		95	12.45	1.14	13.32	1.18	14.19	1.22	14.59	1.24	15.93	1.26	16.79	1.29
		100	12.15	1.19	13.02	1.23	13.89	1.28	14.40	1.29	15.62	1.32	16.49	1.34
		105	11.85	1.24	12.72	1.28	13.58	1.33	14.21	1.34	15.32	1.37	16.19	1.40
		110	11.54	1.29	12.41	1.33	13.28	1.38	13.91	1.40	15.02	1.42	15.88	1.45
		115	11.24	1.33	12.11	1.38	12.98	1.43	13.60	1.45	14.71	1.48	15.58	1.51
		118	11.06	1.36	11.93	1.41	12.80	1.46	13.42	1.48	14.53	1.51	15.40	1.54
		122	11.00	1.40	11.87	1.45	12.73	1.51	13.36	1.52	14.47	1.55	15.34	1.58

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 7: LMU18CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 9	-4	15.24	0.77	16.19	0.80	17.13	0.83	17.81	0.84	19.02	0.86	19.97	0.87
		0	15.23	0.78	16.18	0.81	17.12	0.84	17.81	0.85	19.01	0.87	19.96	0.88
		5	15.22	0.80	16.16	0.82	17.11	0.85	17.79	0.86	19.00	0.88	19.94	0.90
		10	15.21	0.81	16.15	0.84	17.09	0.87	17.78	0.88	18.98	0.89	19.93	0.91
		14	15.19	0.82	16.14	0.85	17.08	0.88	17.76	0.89	18.97	0.91	19.91	0.93
		20	15.18	0.83	16.13	0.86	17.07	0.89	17.75	0.90	18.95	0.92	19.90	0.94
		25	15.17	0.84	16.11	0.87	17.06	0.91	17.74	0.92	18.94	0.93	19.88	0.95
		30	15.16	0.85	16.10	0.89	17.04	0.92	17.72	0.93	18.93	0.95	19.87	0.97
		35	15.15	0.87	16.09	0.90	17.03	0.93	17.71	0.94	18.91	0.96	19.85	0.98
		40	15.14	0.88	16.08	0.91	17.02	0.94	17.70	0.95	18.90	0.97	19.84	0.99
		45	15.13	0.89	16.06	0.92	17.00	0.96	17.68	0.97	18.88	0.99	19.82	1.00
		50	15.11	0.90	16.05	0.93	16.99	0.97	17.67	0.98	18.87	1.00	19.81	1.02
		55	15.10	0.91	16.04	0.95	16.98	0.98	17.66	0.99	18.85	1.01	19.79	1.03
		60	15.09	0.93	16.03	0.96	16.96	0.99	17.64	1.01	18.84	1.02	19.78	1.04
		65	15.08	0.94	16.02	0.97	16.95	1.01	17.63	1.02	18.82	1.04	19.76	1.06
		70	15.07	0.95	16.00	0.98	16.94	1.02	17.61	1.03	18.81	1.05	19.75	1.07
		75	14.70	1.00	15.64	1.04	16.57	1.07	17.25	1.09	18.44	1.11	19.37	1.13
		80	14.34	1.05	15.27	1.09	16.20	1.13	16.88	1.14	18.07	1.16	19.00	1.19
		85	13.98	1.10	14.91	1.14	15.84	1.18	16.51	1.20	17.70	1.22	18.63	1.24
		90	13.62	1.15	14.55	1.20	15.48	1.24	16.15	1.25	17.33	1.28	18.26	1.30
		95	13.23	1.20	14.16	1.25	15.08	1.29	15.50	1.31	16.92	1.33	17.84	1.36
		100	12.91	1.26	13.83	1.30	14.75	1.35	15.30	1.36	16.60	1.39	17.52	1.42
		105	12.59	1.31	13.51	1.35	14.43	1.40	15.10	1.42	16.28	1.45	17.20	1.48
		110	12.27	1.36	13.19	1.41	14.11	1.46	14.78	1.48	15.95	1.50	16.88	1.53
		115	11.94	1.41	12.87	1.46	13.79	1.51	14.45	1.53	15.63	1.56	16.55	1.59
		118	11.75	1.44	12.67	1.49	13.59	1.55	14.26	1.56	15.44	1.59	16.36	1.63
		122	11.69	1.48	12.61	1.53	13.53	1.59	14.20	1.61	15.37	1.64	16.30	1.67
	7 + 12	-4	15.24	0.77	16.19	0.80	17.13	0.83	17.81	0.84	19.02	0.86	19.97	0.87
		0	15.23	0.78	16.18	0.81	17.12	0.84	17.81	0.85	19.01	0.87	19.96	0.88
		5	15.22	0.80	16.16	0.82	17.11	0.85	17.79	0.86	19.00	0.88	19.94	0.90
		10	15.21	0.81	16.15	0.84	17.09	0.87	17.78	0.88	18.98	0.89	19.93	0.91
		14	15.19	0.82	16.14	0.85	17.08	0.88	17.76	0.89	18.97	0.91	19.91	0.93
		20	15.18	0.83	16.13	0.86	17.07	0.89	17.75	0.90	18.95	0.92	19.90	0.94
		25	15.17	0.84	16.11	0.87	17.06	0.91	17.74	0.92	18.94	0.93	19.88	0.95
		30	15.16	0.85	16.10	0.89	17.04	0.92	17.72	0.93	18.93	0.95	19.87	0.97
		35	15.15	0.87	16.09	0.90	17.03	0.93	17.71	0.94	18.91	0.96	19.85	0.98
		40	15.14	0.88	16.08	0.91	17.02	0.94	17.70	0.95	18.90	0.97	19.84	0.99
		45	15.13	0.89	16.06	0.92	17.00	0.96	17.68	0.97	18.88	0.99	19.82	1.00
		50	15.11	0.90	16.05	0.93	16.99	0.97	17.67	0.98	18.87	1.00	19.81	1.02
		55	15.10	0.91	16.04	0.95	16.98	0.98	17.66	0.99	18.85	1.01	19.79	1.03
		60	15.09	0.93	16.03	0.96	16.96	0.99	17.64	1.01	18.84	1.02	19.78	1.04
		65	15.08	0.94	16.02	0.97	16.95	1.01	17.63	1.02	18.82	1.04	19.76	1.06
70		15.07	0.95	16.00	0.98	16.94	1.02	17.61	1.03	18.81	1.05	19.75	1.07	
75		14.70	1.00	15.64	1.04	16.57	1.07	17.25	1.09	18.44	1.11	19.37	1.13	
80		14.34	1.05	15.27	1.09	16.20	1.13	16.88	1.14	18.07	1.16	19.00	1.19	
85		13.98	1.10	14.91	1.14	15.84	1.18	16.51	1.20	17.70	1.22	18.63	1.24	
90		13.62	1.15	14.55	1.20	15.48	1.24	16.15	1.25	17.33	1.28	18.26	1.30	
95		13.23	1.20	14.16	1.25	15.08	1.29	15.50	1.31	16.92	1.33	17.84	1.36	
100		12.91	1.26	13.83	1.30	14.75	1.35	15.30	1.36	16.60	1.39	17.52	1.42	
105		12.59	1.31	13.51	1.35	14.43	1.40	15.10	1.42	16.28	1.45	17.20	1.48	
110		12.27	1.36	13.19	1.41	14.11	1.46	14.78	1.48	15.95	1.50	16.88	1.53	
115		11.94	1.41	12.87	1.46	13.79	1.51	14.45	1.53	15.63	1.56	16.55	1.59	
118	11.75	1.44	12.67	1.49	13.59	1.55	14.26	1.56	15.44	1.59	16.36	1.63		
122	11.69	1.48	12.61	1.53	13.53	1.59	14.20	1.61	15.37	1.64	16.30	1.67		

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU18CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 8: LMU18CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 12	-4	15.24	0.77	16.19	0.80	17.13	0.83	17.81	0.84	19.02	0.86	19.97	0.87
		0	15.23	0.78	16.18	0.81	17.12	0.84	17.81	0.85	19.01	0.87	19.96	0.88
		5	15.22	0.80	16.16	0.82	17.11	0.85	17.79	0.86	19.00	0.88	19.94	0.90
		10	15.21	0.81	16.15	0.84	17.09	0.87	17.78	0.88	18.98	0.89	19.93	0.91
		14	15.19	0.82	16.14	0.85	17.08	0.88	17.76	0.89	18.97	0.91	19.91	0.93
		20	15.18	0.83	16.13	0.86	17.07	0.89	17.75	0.90	18.95	0.92	19.90	0.94
		25	15.17	0.84	16.11	0.87	17.06	0.91	17.74	0.92	18.94	0.93	19.88	0.95
		30	15.16	0.85	16.10	0.89	17.04	0.92	17.72	0.93	18.93	0.95	19.87	0.97
		35	15.15	0.87	16.09	0.90	17.03	0.93	17.71	0.94	18.91	0.96	19.85	0.98
		40	15.14	0.88	16.08	0.91	17.02	0.94	17.70	0.95	18.90	0.97	19.84	0.99
		45	15.13	0.89	16.06	0.92	17.00	0.96	17.68	0.97	18.88	0.99	19.82	1.00
		50	15.11	0.90	16.05	0.93	16.99	0.97	17.67	0.98	18.87	1.00	19.81	1.02
		55	15.10	0.91	16.04	0.95	16.98	0.98	17.66	0.99	18.85	1.01	19.79	1.03
		60	15.09	0.93	16.03	0.96	16.96	0.99	17.64	1.01	18.84	1.02	19.78	1.04
		65	15.08	0.94	16.02	0.97	16.95	1.01	17.63	1.02	18.82	1.04	19.76	1.06
		70	15.07	0.95	16.00	0.98	16.94	1.02	17.61	1.03	18.81	1.05	19.75	1.07
		75	14.70	1.00	15.64	1.04	16.57	1.07	17.25	1.09	18.44	1.11	19.37	1.13
		80	14.34	1.05	15.27	1.09	16.20	1.13	16.88	1.14	18.07	1.16	19.00	1.19
		85	13.98	1.10	14.91	1.14	15.84	1.18	16.51	1.20	17.70	1.22	18.63	1.24
		90	13.62	1.15	14.55	1.20	15.48	1.24	16.15	1.25	17.33	1.28	18.26	1.30
		95	13.23	1.20	14.16	1.25	15.08	1.29	15.50	1.31	16.92	1.33	17.84	1.36
		100	12.91	1.26	13.83	1.30	14.75	1.35	15.30	1.36	16.60	1.39	17.52	1.42
		105	12.59	1.31	13.51	1.35	14.43	1.40	15.10	1.42	16.28	1.45	17.20	1.48
		110	12.27	1.36	13.19	1.41	14.11	1.46	14.78	1.48	15.95	1.50	16.88	1.53
		115	11.94	1.41	12.87	1.46	13.79	1.51	14.45	1.53	15.63	1.56	16.55	1.59
		118	11.75	1.44	12.67	1.49	13.59	1.55	14.26	1.56	15.44	1.59	16.36	1.63
		122	11.69	1.48	12.61	1.53	13.53	1.59	14.20	1.61	15.37	1.64	16.30	1.67
	9 + 15	-4	15.24	0.77	16.19	0.80	17.13	0.83	17.81	0.84	19.02	0.86	19.97	0.87
		0	15.23	0.78	16.18	0.81	17.12	0.84	17.81	0.85	19.01	0.87	19.96	0.88
		5	15.22	0.80	16.16	0.82	17.11	0.85	17.79	0.86	19.00	0.88	19.94	0.90
		10	15.21	0.81	16.15	0.84	17.09	0.87	17.78	0.88	18.98	0.89	19.93	0.91
		14	15.19	0.82	16.14	0.85	17.08	0.88	17.76	0.89	18.97	0.91	19.91	0.93
		20	15.18	0.83	16.13	0.86	17.07	0.89	17.75	0.90	18.95	0.92	19.90	0.94
		25	15.17	0.84	16.11	0.87	17.06	0.91	17.74	0.92	18.94	0.93	19.88	0.95
		30	15.16	0.85	16.10	0.89	17.04	0.92	17.72	0.93	18.93	0.95	19.87	0.97
		35	15.15	0.87	16.09	0.90	17.03	0.93	17.71	0.94	18.91	0.96	19.85	0.98
		40	15.14	0.88	16.08	0.91	17.02	0.94	17.70	0.95	18.90	0.97	19.84	0.99
		45	15.13	0.89	16.06	0.92	17.00	0.96	17.68	0.97	18.88	0.99	19.82	1.00
		50	15.11	0.90	16.05	0.93	16.99	0.97	17.67	0.98	18.87	1.00	19.81	1.02
		55	15.10	0.91	16.04	0.95	16.98	0.98	17.66	0.99	18.85	1.01	19.79	1.03
		60	15.09	0.93	16.03	0.96	16.96	0.99	17.64	1.01	18.84	1.02	19.78	1.04
		65	15.08	0.94	16.02	0.97	16.95	1.01	17.63	1.02	18.82	1.04	19.76	1.06
		70	15.07	0.95	16.00	0.98	16.94	1.02	17.61	1.03	18.81	1.05	19.75	1.07
		75	14.70	1.00	15.64	1.04	16.57	1.07	17.25	1.09	18.44	1.11	19.37	1.13
		80	14.34	1.05	15.27	1.09	16.20	1.13	16.88	1.14	18.07	1.16	19.00	1.19
		85	13.98	1.10	14.91	1.14	15.84	1.18	16.51	1.20	17.70	1.22	18.63	1.24
		90	13.62	1.15	14.55	1.20	15.48	1.24	16.15	1.25	17.33	1.28	18.26	1.30
		95	13.23	1.20	14.16	1.25	15.08	1.29	15.50	1.31	16.92	1.33	17.84	1.36
		100	12.91	1.26	13.83	1.30	14.75	1.35	15.30	1.36	16.60	1.39	17.52	1.42
		105	12.59	1.31	13.51	1.35	14.43	1.40	15.10	1.42	16.28	1.45	17.20	1.48
		110	12.27	1.36	13.19	1.41	14.11	1.46	14.78	1.48	15.95	1.50	16.88	1.53
		115	11.94	1.41	12.87	1.46	13.79	1.51	14.45	1.53	15.63	1.56	16.55	1.59
		118	11.75	1.44	12.67	1.49	13.59	1.55	14.26	1.56	15.44	1.59	16.36	1.63
		122	11.69	1.48	12.61	1.53	13.53	1.59	14.20	1.61	15.37	1.64	16.30	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 9: LMU18CHV Cooling Capacity Table — Mixed Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 12	-4	15.24	0.77	16.19	0.80	17.13	0.83	17.81	0.84	19.02	0.86	19.97	0.87
		0	15.23	0.78	16.18	0.81	17.12	0.84	17.81	0.85	19.01	0.87	19.96	0.88
		5	15.22	0.80	16.16	0.82	17.11	0.85	17.79	0.86	19.00	0.88	19.94	0.90
		10	15.21	0.81	16.15	0.84	17.09	0.87	17.78	0.88	18.98	0.89	19.93	0.91
		14	15.19	0.82	16.14	0.85	17.08	0.88	17.76	0.89	18.97	0.91	19.91	0.93
		20	15.18	0.83	16.13	0.86	17.07	0.89	17.75	0.90	18.95	0.92	19.90	0.94
		25	15.17	0.84	16.11	0.87	17.06	0.91	17.74	0.92	18.94	0.93	19.88	0.95
		30	15.16	0.85	16.10	0.89	17.04	0.92	17.72	0.93	18.93	0.95	19.87	0.97
		35	15.15	0.87	16.09	0.90	17.03	0.93	17.71	0.94	18.91	0.96	19.85	0.98
		40	15.14	0.88	16.08	0.91	17.02	0.94	17.70	0.95	18.90	0.97	19.84	0.99
		45	15.13	0.89	16.06	0.92	17.00	0.96	17.68	0.97	18.88	0.99	19.82	1.00
		50	15.11	0.90	16.05	0.93	16.99	0.97	17.67	0.98	18.87	1.00	19.81	1.02
		55	15.10	0.91	16.04	0.95	16.98	0.98	17.66	0.99	18.85	1.01	19.79	1.03
		60	15.09	0.93	16.03	0.96	16.96	0.99	17.64	1.01	18.84	1.02	19.78	1.04
		65	15.08	0.94	16.02	0.97	16.95	1.01	17.63	1.02	18.82	1.04	19.76	1.06
		70	15.07	0.95	16.00	0.98	16.94	1.02	17.61	1.03	18.81	1.05	19.75	1.07
		75	14.70	1.00	15.64	1.04	16.57	1.07	17.25	1.09	18.44	1.11	19.37	1.13
		80	14.34	1.05	15.27	1.09	16.20	1.13	16.88	1.14	18.07	1.16	19.00	1.19
		85	13.98	1.10	14.91	1.14	15.84	1.18	16.51	1.20	17.70	1.22	18.63	1.24
		90	13.62	1.15	14.55	1.20	15.48	1.24	16.15	1.25	17.33	1.28	18.26	1.30
		95	13.23	1.20	14.16	1.25	15.08	1.29	15.50	1.31	16.92	1.33	17.84	1.36
		100	12.91	1.26	13.83	1.30	14.75	1.35	15.30	1.36	16.60	1.39	17.52	1.42
		105	12.59	1.31	13.51	1.35	14.43	1.40	15.10	1.42	16.28	1.45	17.20	1.48
		110	12.27	1.36	13.19	1.41	14.11	1.46	14.78	1.48	15.95	1.50	16.88	1.53
		115	11.94	1.41	12.87	1.46	13.79	1.51	14.45	1.53	15.63	1.56	16.55	1.59
		118	11.75	1.44	12.67	1.49	13.59	1.55	14.26	1.56	15.44	1.59	16.36	1.63
		122	11.69	1.48	12.61	1.53	13.53	1.59	14.20	1.61	15.37	1.64	16.30	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 10: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	13.76	0.67	14.62	0.70	15.47	0.72	16.09	0.73	17.18	0.75	18.04	0.76
		0	13.76	0.68	14.61	0.71	15.47	0.73	16.08	0.74	17.17	0.75	18.03	0.77
		5	13.75	0.69	14.60	0.72	15.45	0.74	16.07	0.75	17.16	0.77	18.01	0.78
		10	13.73	0.70	14.59	0.73	15.44	0.76	16.06	0.76	17.15	0.78	18.00	0.79
		14	13.72	0.71	14.58	0.74	15.43	0.77	16.04	0.78	17.13	0.79	17.99	0.81
		20	13.71	0.72	14.57	0.75	15.42	0.78	16.03	0.79	17.12	0.80	17.97	0.82
		25	13.70	0.73	14.55	0.76	15.41	0.79	16.02	0.80	17.11	0.81	17.96	0.83
		30	13.69	0.74	14.54	0.77	15.39	0.80	16.01	0.81	17.09	0.82	17.94	0.84
		35	13.68	0.75	14.53	0.78	15.38	0.81	16.00	0.82	17.08	0.84	17.93	0.85
		40	13.67	0.76	14.52	0.79	15.37	0.82	15.98	0.83	17.07	0.85	17.92	0.86
		45	13.66	0.77	14.51	0.80	15.36	0.83	15.97	0.84	17.06	0.86	17.90	0.88
		50	13.65	0.79	14.50	0.81	15.35	0.84	15.96	0.85	17.04	0.87	17.89	0.89
		55	13.64	0.80	14.49	0.82	15.33	0.85	15.95	0.86	17.03	0.88	17.88	0.90
		60	13.63	0.81	14.48	0.84	15.32	0.87	15.93	0.88	17.02	0.89	17.86	0.91
		65	13.62	0.82	14.47	0.85	15.31	0.88	15.92	0.89	17.00	0.90	17.85	0.92
		70	13.61	0.83	14.45	0.86	15.30	0.89	15.91	0.90	16.99	0.91	17.83	0.93
		75	13.28	0.87	14.12	0.90	14.97	0.94	15.58	0.95	16.65	0.96	17.50	0.98
		80	12.95	0.92	13.80	0.95	14.64	0.98	15.24	0.99	16.32	1.01	17.16	1.03
		85	12.63	0.96	13.47	0.99	14.31	1.03	14.91	1.04	15.99	1.06	16.82	1.08
		90	12.30	1.00	13.14	1.04	13.98	1.08	14.58	1.09	15.65	1.11	16.49	1.13
		95	11.95	1.05	12.79	1.09	13.62	1.13	14.00	1.14	15.28	1.16	16.12	1.18
		100	11.66	1.09	12.49	1.13	13.33	1.17	13.82	1.19	14.99	1.21	15.82	1.24
		105	11.37	1.14	12.20	1.18	13.04	1.22	13.64	1.24	14.70	1.26	15.53	1.29
		110	11.08	1.18	11.91	1.23	12.74	1.27	13.35	1.29	14.41	1.31	15.24	1.34
		115	10.79	1.23	11.62	1.27	12.45	1.32	13.06	1.33	14.12	1.36	14.95	1.39
		118	10.61	1.25	11.45	1.30	12.28	1.35	12.88	1.36	13.94	1.39	14.78	1.42
		122	10.56	1.29	11.39	1.34	12.22	1.39	12.82	1.40	13.89	1.43	14.72	1.46
	7 + 9	-4	15.73	0.76	16.71	0.79	17.68	0.82	18.39	0.83	19.64	0.84	20.61	0.86
		0	15.72	0.77	16.70	0.80	17.67	0.83	18.38	0.84	19.63	0.85	20.60	0.87
		5	15.71	0.78	16.68	0.81	17.66	0.84	18.36	0.85	19.61	0.87	20.59	0.89
		10	15.70	0.80	16.67	0.82	17.65	0.85	18.35	0.86	19.60	0.88	20.57	0.90
		14	15.68	0.81	16.66	0.84	17.63	0.87	18.34	0.88	19.58	0.89	20.56	0.91
		20	15.67	0.82	16.65	0.85	17.62	0.88	18.32	0.89	19.57	0.91	20.54	0.92
		25	15.66	0.83	16.63	0.86	17.61	0.89	18.31	0.90	19.55	0.92	20.52	0.94
		30	15.65	0.84	16.62	0.87	17.59	0.90	18.29	0.92	19.54	0.93	20.51	0.95
		35	15.64	0.85	16.61	0.88	17.58	0.92	18.28	0.93	19.52	0.95	20.49	0.96
		40	15.62	0.87	16.60	0.90	17.57	0.93	18.27	0.94	19.51	0.96	20.48	0.98
		45	15.61	0.88	16.58	0.91	17.55	0.94	18.25	0.95	19.49	0.97	20.46	0.99
		50	15.60	0.89	16.57	0.92	17.54	0.95	18.24	0.97	19.48	0.98	20.45	1.00
		55	15.59	0.90	16.56	0.93	17.53	0.97	18.22	0.98	19.46	1.00	20.43	1.02
		60	15.58	0.91	16.54	0.94	17.51	0.98	18.21	0.99	19.45	1.01	20.41	1.03
		65	15.57	0.92	16.53	0.96	17.50	0.99	18.20	1.00	19.43	1.02	20.40	1.04
		70	15.55	0.93	16.52	0.97	17.49	1.00	18.18	1.02	19.42	1.03	20.38	1.06
		75	15.18	0.99	16.14	1.02	17.11	1.06	17.80	1.07	19.03	1.09	20.00	1.11
		80	14.80	1.04	15.77	1.07	16.73	1.11	17.42	1.13	18.65	1.15	19.61	1.17
		85	14.43	1.09	15.39	1.13	16.35	1.17	17.04	1.18	18.27	1.20	19.23	1.23
		90	14.06	1.14	15.02	1.18	15.98	1.22	16.67	1.24	17.89	1.26	18.84	1.28
		95	13.66	1.19	14.61	1.23	15.56	1.28	16.00	1.29	17.47	1.31	18.42	1.34
		100	13.33	1.24	14.28	1.28	15.23	1.33	15.79	1.34	17.13	1.37	18.09	1.40
		105	12.99	1.29	13.95	1.33	14.90	1.38	15.59	1.40	16.80	1.43	17.75	1.45
		110	12.66	1.34	13.61	1.39	14.57	1.44	15.25	1.45	16.47	1.48	17.42	1.51
		115	12.33	1.39	13.28	1.44	14.23	1.49	14.92	1.51	16.14	1.54	17.09	1.57
		118	12.13	1.42	13.08	1.47	14.03	1.52	14.72	1.54	15.94	1.57	16.89	1.60
		122	12.06	1.46	13.02	1.51	13.97	1.57	14.65	1.59	15.87	1.62	16.82	1.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 11: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 9	-4	17.70	0.85	18.80	0.88	19.89	0.92	20.69	0.93	22.09	0.94	23.19	0.96
		0	17.69	0.86	18.79	0.89	19.88	0.93	20.68	0.94	22.08	0.95	23.18	0.97
		5	17.67	0.88	18.77	0.91	19.87	0.94	20.66	0.95	22.06	0.97	23.16	0.99
		10	17.66	0.89	18.76	0.92	19.85	0.95	20.64	0.97	22.05	0.98	23.14	1.00
		14	17.65	0.90	18.74	0.93	19.84	0.97	20.63	0.98	22.03	1.00	23.12	1.02
		20	17.63	0.91	18.73	0.95	19.82	0.98	20.61	0.99	22.01	1.01	23.11	1.03
		25	17.62	0.93	18.71	0.96	19.81	1.00	20.60	1.01	22.00	1.03	23.09	1.05
		30	17.60	0.94	18.70	0.97	19.79	1.01	20.58	1.02	21.98	1.04	23.07	1.06
		35	17.59	0.95	18.68	0.99	19.78	1.02	20.57	1.04	21.96	1.05	23.05	1.08
		40	17.58	0.97	18.67	1.00	19.76	1.04	20.55	1.05	21.94	1.07	23.04	1.09
		45	17.56	0.98	18.66	1.01	19.75	1.05	20.53	1.06	21.93	1.08	23.02	1.11
		50	17.55	0.99	18.64	1.03	19.73	1.07	20.52	1.08	21.91	1.10	23.00	1.12
		55	17.54	1.00	18.63	1.04	19.72	1.08	20.50	1.09	21.89	1.11	22.98	1.13
		60	17.52	1.02	18.61	1.05	19.70	1.09	20.49	1.11	21.88	1.13	22.97	1.15
		65	17.51	1.03	18.60	1.07	19.69	1.11	20.47	1.12	21.86	1.14	22.95	1.16
		70	17.50	1.04	18.58	1.08	19.67	1.12	20.46	1.13	21.84	1.16	22.93	1.18
		75	17.08	1.10	18.16	1.14	19.24	1.18	20.03	1.20	21.41	1.22	22.50	1.24
		80	16.66	1.16	17.74	1.20	18.82	1.24	19.60	1.26	20.98	1.28	22.06	1.31
		85	16.24	1.21	17.32	1.26	18.40	1.30	19.17	1.32	20.55	1.34	21.63	1.37
		90	15.82	1.27	16.90	1.32	17.97	1.36	18.75	1.38	20.12	1.40	21.20	1.43
		95	15.37	1.33	16.44	1.37	17.51	1.42	18.00	1.44	19.65	1.47	20.72	1.50
		100	14.99	1.38	16.06	1.43	17.13	1.48	17.77	1.50	19.28	1.53	20.35	1.56
		105	14.62	1.44	15.69	1.49	16.76	1.54	17.53	1.56	18.90	1.59	19.97	1.62
		110	14.24	1.49	15.32	1.55	16.39	1.61	17.16	1.62	18.53	1.65	19.60	1.69
		115	13.87	1.55	14.94	1.61	16.01	1.67	16.79	1.68	18.15	1.72	19.22	1.75
		118	13.65	1.58	14.72	1.64	15.79	1.70	16.56	1.72	17.93	1.75	19.00	1.79
		122	13.57	1.63	14.64	1.69	15.71	1.75	16.49	1.77	17.85	1.80	18.92	1.84
	7 + 12	-4	18.68	0.89	19.84	0.93	21.00	0.96	21.84	0.97	23.32	0.99	24.48	1.01
		0	18.67	0.90	19.83	0.94	20.99	0.97	21.83	0.98	23.31	1.00	24.47	1.02
		5	18.65	0.92	19.81	0.95	20.97	0.99	21.81	1.00	23.29	1.02	24.45	1.04
		10	18.64	0.93	19.80	0.97	20.96	1.00	21.79	1.01	23.27	1.03	24.43	1.05
		14	18.63	0.94	19.78	0.98	20.94	1.02	21.77	1.03	23.25	1.05	24.41	1.07
		20	18.61	0.96	19.77	0.99	20.92	1.03	21.76	1.04	23.23	1.06	24.39	1.08
		25	18.60	0.97	19.75	1.01	20.91	1.04	21.74	1.06	23.22	1.08	24.37	1.10
		30	18.58	0.99	19.74	1.02	20.89	1.06	21.72	1.07	23.20	1.09	24.35	1.11
		35	18.57	1.00	19.72	1.04	20.88	1.07	21.71	1.09	23.18	1.11	24.33	1.13
		40	18.55	1.01	19.71	1.05	20.86	1.09	21.69	1.10	23.16	1.12	24.32	1.14
		45	18.54	1.03	19.69	1.06	20.84	1.10	21.67	1.12	23.15	1.14	24.30	1.16
		50	18.53	1.04	19.68	1.08	20.83	1.12	21.66	1.13	23.13	1.15	24.28	1.17
		55	18.51	1.05	19.66	1.09	20.81	1.13	21.64	1.14	23.11	1.17	24.26	1.19
		60	18.50	1.07	19.65	1.11	20.80	1.15	21.63	1.16	23.09	1.18	24.24	1.21
		65	18.48	1.08	19.63	1.12	20.78	1.16	21.61	1.17	23.08	1.20	24.22	1.22
		70	18.47	1.09	19.62	1.13	20.76	1.18	21.59	1.19	23.06	1.21	24.20	1.24
		75	18.02	1.15	19.17	1.20	20.31	1.24	21.14	1.25	22.60	1.28	23.75	1.30
		80	17.58	1.21	18.72	1.26	19.86	1.30	20.69	1.32	22.15	1.34	23.29	1.37
		85	17.14	1.27	18.28	1.32	19.42	1.37	20.24	1.38	21.69	1.41	22.83	1.44
		90	16.70	1.33	17.84	1.38	18.97	1.43	19.79	1.45	21.24	1.47	22.38	1.50
		95	16.22	1.39	17.35	1.44	18.48	1.49	19.00	1.51	20.74	1.54	21.87	1.57
		100	15.83	1.45	16.96	1.50	18.09	1.56	18.75	1.57	20.35	1.60	21.48	1.64
		105	15.43	1.51	16.56	1.56	17.69	1.62	18.51	1.64	19.95	1.67	21.08	1.70
		110	15.04	1.57	16.17	1.62	17.30	1.68	18.11	1.70	19.56	1.73	20.69	1.77
		115	14.64	1.63	15.77	1.68	16.90	1.75	17.72	1.77	19.16	1.80	20.29	1.84
		118	14.40	1.66	15.53	1.72	16.66	1.78	17.48	1.81	18.92	1.84	20.05	1.88
		122	14.33	1.71	15.46	1.77	16.59	1.84	17.40	1.86	18.85	1.89	19.98	1.93

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 12: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 12	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02
	7 + 15	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 13: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02
	12 + 12	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 14: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 18	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02
	9 + 18	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 15: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	12 + 15	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02
	12 + 18	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 16: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 15	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02
	7 + 24	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 17: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 24	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02
	15 + 18	-4	19.66	0.93	20.88	0.97	22.11	1.00	22.99	1.02	24.55	1.03	25.77	1.06
		0	19.65	0.95	20.87	0.98	22.09	1.02	22.97	1.03	24.53	1.05	25.75	1.07
		5	19.64	0.96	20.86	1.00	22.07	1.03	22.96	1.04	24.51	1.06	25.73	1.08
		10	19.62	0.97	20.84	1.01	22.06	1.05	22.94	1.06	24.50	1.08	25.71	1.10
		14	19.61	0.99	20.82	1.02	22.04	1.06	22.92	1.07	24.48	1.09	25.69	1.12
		20	19.59	1.00	20.81	1.04	22.02	1.08	22.90	1.09	24.46	1.11	25.67	1.13
		25	19.58	1.02	20.79	1.05	22.01	1.09	22.89	1.11	24.44	1.13	25.65	1.15
		30	19.56	1.03	20.78	1.07	21.99	1.11	22.87	1.12	24.42	1.14	25.64	1.16
		35	19.55	1.05	20.76	1.08	21.97	1.12	22.85	1.14	24.40	1.16	25.62	1.18
		40	19.53	1.06	20.74	1.10	21.96	1.14	22.83	1.15	24.38	1.17	25.60	1.20
		45	19.52	1.07	20.73	1.11	21.94	1.15	22.82	1.17	24.36	1.19	25.58	1.21
		50	19.50	1.09	20.71	1.13	21.92	1.17	22.80	1.18	24.35	1.20	25.56	1.23
		55	19.49	1.10	20.70	1.14	21.91	1.18	22.78	1.20	24.33	1.22	25.54	1.25
		60	19.47	1.12	20.68	1.16	21.89	1.20	22.76	1.21	24.31	1.24	25.52	1.26
		65	19.46	1.13	20.66	1.17	21.87	1.21	22.75	1.23	24.29	1.25	25.50	1.28
		70	19.44	1.15	20.65	1.19	21.86	1.23	22.73	1.24	24.27	1.27	25.48	1.29
		75	18.97	1.21	20.18	1.25	21.38	1.30	22.25	1.31	23.79	1.34	25.00	1.36
		80	18.51	1.27	19.71	1.31	20.91	1.36	21.78	1.38	23.31	1.40	24.51	1.43
		85	18.04	1.33	19.24	1.38	20.44	1.43	21.30	1.45	22.84	1.47	24.03	1.50
		90	17.58	1.39	18.77	1.44	19.97	1.50	20.83	1.51	22.36	1.54	23.56	1.57
		95	17.08	1.45	18.26	1.51	19.45	1.56	20.00	1.58	21.83	1.61	23.02	1.64
		100	16.66	1.52	17.85	1.57	19.04	1.63	19.74	1.65	21.42	1.68	22.61	1.71
		105	16.24	1.58	17.43	1.64	18.62	1.69	19.48	1.71	21.00	1.75	22.19	1.78
		110	15.83	1.64	17.02	1.70	18.21	1.76	19.07	1.78	20.59	1.81	21.78	1.85
		115	15.41	1.70	16.60	1.76	17.79	1.83	18.65	1.85	20.17	1.88	21.36	1.92
		118	15.16	1.74	16.35	1.80	17.54	1.87	18.40	1.89	19.92	1.92	21.11	1.96
		122	15.08	1.79	16.27	1.85	17.46	1.92	18.32	1.94	19.84	1.98	21.03	2.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 18: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 7	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
	7 + 7 + 9	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 19: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 9	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
	7 + 7 + 12	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 20: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 9	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
	7 + 9 + 12	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 21: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 15	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
	9 + 9 + 12	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 22: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 15	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
	7 + 12 + 12	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 23: LMU24CHV Cooling Capacity Table — Non-Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 18	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
	9 + 9 + 15	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 24: LMU24CHV Cooling Capacity Table — Non-Ducted (continued) and Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 12 + 12	-4	19.66	0.88	20.88	0.91	22.11	0.94	22.99	0.95	24.55	0.97	25.77	0.99
		0	19.65	0.89	20.87	0.92	22.09	0.95	22.97	0.96	24.53	0.98	25.75	1.00
		5	19.64	0.90	20.86	0.93	22.07	0.97	22.96	0.98	24.51	1.00	25.73	1.02
		10	19.62	0.91	20.84	0.95	22.06	0.98	22.94	0.99	24.50	1.01	25.71	1.03
		14	19.61	0.93	20.82	0.96	22.04	1.00	22.92	1.01	24.48	1.03	25.69	1.05
		20	19.59	0.94	20.81	0.97	22.02	1.01	22.90	1.02	24.46	1.04	25.67	1.06
		25	19.58	0.95	20.79	0.99	22.01	1.02	22.89	1.04	24.44	1.06	25.65	1.08
		30	19.56	0.97	20.78	1.00	21.99	1.04	22.87	1.05	24.42	1.07	25.64	1.09
		35	19.55	0.98	20.76	1.02	21.97	1.05	22.85	1.07	24.40	1.09	25.62	1.11
		40	19.53	0.99	20.74	1.03	21.96	1.07	22.83	1.08	24.38	1.10	25.60	1.12
		45	19.52	1.01	20.73	1.04	21.94	1.08	22.82	1.09	24.36	1.11	25.58	1.14
		50	19.50	1.02	20.71	1.06	21.92	1.10	22.80	1.11	24.35	1.13	25.56	1.15
		55	19.49	1.03	20.70	1.07	21.91	1.11	22.78	1.12	24.33	1.14	25.54	1.17
		60	19.47	1.05	20.68	1.08	21.89	1.12	22.76	1.14	24.31	1.16	25.52	1.18
		65	19.46	1.06	20.66	1.10	21.87	1.14	22.75	1.15	24.29	1.17	25.50	1.20
		70	19.44	1.07	20.65	1.11	21.86	1.15	22.73	1.17	24.27	1.19	25.48	1.21
		75	18.97	1.13	20.18	1.17	21.38	1.22	22.25	1.23	23.79	1.25	25.00	1.28
		80	18.51	1.19	19.71	1.23	20.91	1.28	21.78	1.29	23.31	1.32	24.51	1.34
		85	18.04	1.25	19.24	1.29	20.44	1.34	21.30	1.36	22.84	1.38	24.03	1.41
		90	17.58	1.30	18.77	1.35	19.97	1.40	20.83	1.42	22.36	1.44	23.56	1.47
		95	17.08	1.36	18.26	1.41	19.45	1.46	20.00	1.48	21.83	1.51	23.02	1.54
		100	16.66	1.42	17.85	1.47	19.04	1.53	19.74	1.54	21.42	1.57	22.61	1.60
		105	16.24	1.48	17.43	1.53	18.62	1.59	19.48	1.61	21.00	1.64	22.19	1.67
		110	15.83	1.54	17.02	1.59	18.21	1.65	19.07	1.67	20.59	1.70	21.78	1.74
		115	15.41	1.59	16.60	1.65	17.79	1.71	18.65	1.73	20.17	1.77	21.36	1.80
		118	15.16	1.63	16.35	1.69	17.54	1.75	18.40	1.77	19.92	1.80	21.11	1.84
		122	15.08	1.68	16.27	1.74	17.46	1.80	18.32	1.82	19.84	1.85	21.03	1.89
Two (2) Ducted Indoor Units	9 + 9	-4	15.75	0.89	16.73	0.92	17.71	0.96	18.41	0.97	19.66	0.99	20.64	1.01
		0	15.74	0.90	16.72	0.93	17.70	0.97	18.40	0.98	19.65	1.00	20.63	1.02
		5	15.73	0.91	16.71	0.95	17.68	0.98	18.39	0.99	19.64	1.01	20.61	1.03
		10	15.72	0.93	16.69	0.96	17.67	1.00	18.37	1.01	19.62	1.03	20.60	1.05
		14	15.70	0.94	16.68	0.98	17.65	1.01	18.36	1.02	19.61	1.04	20.58	1.06
		20	15.69	0.96	16.67	0.99	17.64	1.03	18.35	1.04	19.59	1.06	20.57	1.08
		25	15.68	0.97	16.65	1.00	17.63	1.04	18.33	1.05	19.58	1.07	20.55	1.09
		30	15.67	0.98	16.64	1.02	17.61	1.06	18.32	1.07	19.56	1.09	20.53	1.11
		35	15.66	1.00	16.63	1.03	17.60	1.07	18.30	1.08	19.55	1.10	20.52	1.12
		40	15.64	1.01	16.62	1.05	17.59	1.08	18.29	1.10	19.53	1.12	20.50	1.14
		45	15.63	1.02	16.60	1.06	17.57	1.10	18.28	1.11	19.52	1.13	20.49	1.16
		50	15.62	1.04	16.59	1.07	17.56	1.11	18.26	1.13	19.50	1.15	20.47	1.17
		55	15.61	1.05	16.58	1.09	17.55	1.13	18.25	1.14	19.49	1.16	20.46	1.19
		60	15.60	1.06	16.57	1.10	17.53	1.14	18.23	1.16	19.47	1.18	20.44	1.20
		65	15.58	1.08	16.55	1.12	17.52	1.16	18.22	1.17	19.46	1.19	20.42	1.22
		70	15.57	1.09	16.54	1.13	17.51	1.17	18.21	1.19	19.44	1.21	20.41	1.23
		75	15.20	1.15	16.16	1.19	17.13	1.24	17.82	1.25	19.06	1.27	20.02	1.30
		80	14.82	1.21	15.79	1.25	16.75	1.30	17.44	1.31	18.67	1.34	19.63	1.36
		85	14.45	1.27	15.41	1.31	16.37	1.36	17.06	1.38	18.29	1.40	19.25	1.43
		90	14.08	1.33	15.04	1.37	16.00	1.42	16.69	1.44	17.91	1.47	18.87	1.50
		95	13.68	1.39	14.63	1.44	15.58	1.49	16.02	1.51	17.49	1.53	18.44	1.56
		100	13.34	1.44	14.30	1.50	15.25	1.55	15.81	1.57	17.16	1.60	18.11	1.63
		105	13.01	1.50	13.96	1.56	14.92	1.61	15.60	1.63	16.82	1.66	17.78	1.70
		110	12.68	1.56	13.63	1.62	14.58	1.68	15.27	1.70	16.49	1.73	17.44	1.76
		115	12.34	1.62	13.30	1.68	14.25	1.74	14.94	1.76	16.16	1.79	17.11	1.83
		118	12.15	1.66	13.10	1.72	14.05	1.78	14.74	1.80	15.96	1.83	16.91	1.87
		122	12.08	1.70	13.03	1.76	13.98	1.83	14.67	1.85	15.89	1.89	16.84	1.92

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 25: LMU24CHV Cooling Capacity Table — Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 12	-4	17.50	0.98	18.59	1.01	19.67	1.05	20.46	1.06	21.85	1.08	22.93	1.10
		0	17.49	0.99	18.58	1.02	19.66	1.06	20.45	1.07	21.84	1.09	22.92	1.12
		5	17.48	1.00	18.56	1.04	19.65	1.08	20.43	1.09	21.82	1.11	22.90	1.13
		10	17.46	1.02	18.55	1.06	19.63	1.09	20.41	1.11	21.80	1.13	22.89	1.15
		14	17.45	1.03	18.53	1.07	19.62	1.11	20.40	1.12	21.78	1.14	22.87	1.17
		20	17.44	1.05	18.52	1.09	19.60	1.13	20.38	1.14	21.77	1.16	22.85	1.18
		25	17.42	1.06	18.50	1.10	19.59	1.14	20.37	1.16	21.75	1.18	22.83	1.20
		30	17.41	1.08	18.49	1.12	19.57	1.16	20.35	1.17	21.73	1.19	22.82	1.22
		35	17.40	1.09	18.48	1.13	19.56	1.17	20.34	1.19	21.72	1.21	22.80	1.23
		40	17.38	1.11	18.46	1.15	19.54	1.19	20.32	1.20	21.70	1.23	22.78	1.25
		45	17.37	1.12	18.45	1.16	19.53	1.21	20.31	1.22	21.68	1.24	22.76	1.27
		50	17.36	1.14	18.43	1.18	19.51	1.22	20.29	1.24	21.67	1.26	22.75	1.28
		55	17.34	1.15	18.42	1.19	19.50	1.24	20.27	1.25	21.65	1.28	22.73	1.30
		60	17.33	1.17	18.41	1.21	19.48	1.25	20.26	1.27	21.63	1.29	22.71	1.32
		65	17.32	1.18	18.39	1.23	19.47	1.27	20.24	1.28	21.62	1.31	22.69	1.33
		70	17.30	1.20	18.38	1.24	19.45	1.29	20.23	1.30	21.60	1.32	22.68	1.35
		75	16.89	1.26	17.96	1.31	19.03	1.36	19.80	1.37	21.17	1.40	22.25	1.42
		80	16.47	1.33	17.54	1.37	18.61	1.42	19.38	1.44	20.75	1.47	21.82	1.50
		85	16.06	1.39	17.12	1.44	18.19	1.49	18.96	1.51	20.32	1.54	21.39	1.57
		90	15.64	1.46	16.71	1.51	17.77	1.56	18.54	1.58	19.90	1.61	20.96	1.64
		95	15.20	1.52	16.26	1.58	17.31	1.63	17.80	1.65	19.43	1.68	20.49	1.72
		100	14.83	1.58	15.89	1.64	16.94	1.70	17.57	1.72	19.06	1.75	20.12	1.79
		105	14.46	1.65	15.52	1.71	16.57	1.77	17.34	1.79	18.69	1.83	19.75	1.86
		110	14.09	1.71	15.15	1.78	16.20	1.84	16.97	1.86	18.32	1.90	19.38	1.94
		115	13.72	1.78	14.78	1.84	15.83	1.91	16.60	1.93	17.95	1.97	19.01	2.01
		118	13.49	1.82	14.55	1.88	15.61	1.95	16.38	1.97	17.73	2.01	18.79	2.05
		122	13.42	1.87	14.48	1.94	15.54	2.01	16.30	2.03	17.66	2.07	18.71	2.11
	12 + 12	-4	17.50	0.98	18.59	1.01	19.67	1.05	20.46	1.06	21.85	1.08	22.93	1.10
		0	17.49	0.99	18.58	1.02	19.66	1.06	20.45	1.07	21.84	1.09	22.92	1.12
		5	17.48	1.00	18.56	1.04	19.65	1.08	20.43	1.09	21.82	1.11	22.90	1.13
		10	17.46	1.02	18.55	1.06	19.63	1.09	20.41	1.11	21.80	1.13	22.89	1.15
		14	17.45	1.03	18.53	1.07	19.62	1.11	20.40	1.12	21.78	1.14	22.87	1.17
		20	17.44	1.05	18.52	1.09	19.60	1.13	20.38	1.14	21.77	1.16	22.85	1.18
		25	17.42	1.06	18.50	1.10	19.59	1.14	20.37	1.16	21.75	1.18	22.83	1.20
		30	17.41	1.08	18.49	1.12	19.57	1.16	20.35	1.17	21.73	1.19	22.82	1.22
		35	17.40	1.09	18.48	1.13	19.56	1.17	20.34	1.19	21.72	1.21	22.80	1.23
		40	17.38	1.11	18.46	1.15	19.54	1.19	20.32	1.20	21.70	1.23	22.78	1.25
		45	17.37	1.12	18.45	1.16	19.53	1.21	20.31	1.22	21.68	1.24	22.76	1.27
		50	17.36	1.14	18.43	1.18	19.51	1.22	20.29	1.24	21.67	1.26	22.75	1.28
		55	17.34	1.15	18.42	1.19	19.50	1.24	20.27	1.25	21.65	1.28	22.73	1.30
		60	17.33	1.17	18.41	1.21	19.48	1.25	20.26	1.27	21.63	1.29	22.71	1.32
		65	17.32	1.18	18.39	1.23	19.47	1.27	20.24	1.28	21.62	1.31	22.69	1.33
		70	17.30	1.20	18.38	1.24	19.45	1.29	20.23	1.30	21.60	1.32	22.68	1.35
		75	16.89	1.26	17.96	1.31	19.03	1.36	19.80	1.37	21.17	1.40	22.25	1.42
		80	16.47	1.33	17.54	1.37	18.61	1.42	19.38	1.44	20.75	1.47	21.82	1.50
		85	16.06	1.39	17.12	1.44	18.19	1.49	18.96	1.51	20.32	1.54	21.39	1.57
		90	15.64	1.46	16.71	1.51	17.77	1.56	18.54	1.58	19.90	1.61	20.96	1.64
		95	15.20	1.52	16.26	1.58	17.31	1.63	17.80	1.65	19.43	1.68	20.49	1.72
		100	14.83	1.58	15.89	1.64	16.94	1.70	17.57	1.72	19.06	1.75	20.12	1.79
		105	14.46	1.65	15.52	1.71	16.57	1.77	17.34	1.79	18.69	1.83	19.75	1.86
		110	14.09	1.71	15.15	1.78	16.20	1.84	16.97	1.86	18.32	1.90	19.38	1.94
		115	13.72	1.78	14.78	1.84	15.83	1.91	16.60	1.93	17.95	1.97	19.01	2.01
		118	13.49	1.82	14.55	1.88	15.61	1.95	16.38	1.97	17.73	2.01	18.79	2.05
		122	13.42	1.87	14.48	1.94	15.54	2.01	16.30	2.03	17.66	2.07	18.71	2.11

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 26: LMU24CHV Cooling Capacity Table — Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 18	-4	17.50	0.98	18.59	1.01	19.67	1.05	20.46	1.06	21.85	1.08	22.93	1.10
		0	17.49	0.99	18.58	1.02	19.66	1.06	20.45	1.07	21.84	1.09	22.92	1.12
		5	17.48	1.00	18.56	1.04	19.65	1.08	20.43	1.09	21.82	1.11	22.90	1.13
		10	17.46	1.02	18.55	1.06	19.63	1.09	20.41	1.11	21.80	1.13	22.89	1.15
		14	17.45	1.03	18.53	1.07	19.62	1.11	20.40	1.12	21.78	1.14	22.87	1.17
		20	17.44	1.05	18.52	1.09	19.60	1.13	20.38	1.14	21.77	1.16	22.85	1.18
		25	17.42	1.06	18.50	1.10	19.59	1.14	20.37	1.16	21.75	1.18	22.83	1.20
		30	17.41	1.08	18.49	1.12	19.57	1.16	20.35	1.17	21.73	1.19	22.82	1.22
		35	17.40	1.09	18.48	1.13	19.56	1.17	20.34	1.19	21.72	1.21	22.80	1.23
		40	17.38	1.11	18.46	1.15	19.54	1.19	20.32	1.20	21.70	1.23	22.78	1.25
		45	17.37	1.12	18.45	1.16	19.53	1.21	20.31	1.22	21.68	1.24	22.76	1.27
		50	17.36	1.14	18.43	1.18	19.51	1.22	20.29	1.24	21.67	1.26	22.75	1.28
		55	17.34	1.15	18.42	1.19	19.50	1.24	20.27	1.25	21.65	1.28	22.73	1.30
		60	17.33	1.17	18.41	1.21	19.48	1.25	20.26	1.27	21.63	1.29	22.71	1.32
		65	17.32	1.18	18.39	1.23	19.47	1.27	20.24	1.28	21.62	1.31	22.69	1.33
		70	17.30	1.20	18.38	1.24	19.45	1.29	20.23	1.30	21.60	1.32	22.68	1.35
		75	16.89	1.26	17.96	1.31	19.03	1.36	19.80	1.37	21.17	1.40	22.25	1.42
		80	16.47	1.33	17.54	1.37	18.61	1.42	19.38	1.44	20.75	1.47	21.82	1.50
		85	16.06	1.39	17.12	1.44	18.19	1.49	18.96	1.51	20.32	1.54	21.39	1.57
		90	15.64	1.46	16.71	1.51	17.77	1.56	18.54	1.58	19.90	1.61	20.96	1.64
		95	15.20	1.52	16.26	1.58	17.31	1.63	17.80	1.65	19.43	1.68	20.49	1.72
		100	14.83	1.58	15.89	1.64	16.94	1.70	17.57	1.72	19.06	1.75	20.12	1.79
		105	14.46	1.65	15.52	1.71	16.57	1.77	17.34	1.79	18.69	1.83	19.75	1.86
		110	14.09	1.71	15.15	1.78	16.20	1.84	16.97	1.86	18.32	1.90	19.38	1.94
		115	13.72	1.78	14.78	1.84	15.83	1.91	16.60	1.93	17.95	1.97	19.01	2.01
		118	13.49	1.82	14.55	1.88	15.61	1.95	16.38	1.97	17.73	2.01	18.79	2.05
		122	13.42	1.87	14.48	1.94	15.54	2.01	16.30	2.03	17.66	2.07	18.71	2.11
	12 + 18	-4	17.50	0.92	18.59	0.95	19.67	0.98	20.46	1.00	21.85	1.01	22.93	1.03
		0	17.49	0.93	18.58	0.96	19.66	0.99	20.45	1.01	21.84	1.03	22.92	1.05
		5	17.48	0.94	18.56	0.98	19.65	1.01	20.43	1.02	21.82	1.04	22.90	1.06
		10	17.46	0.95	18.55	0.99	19.63	1.03	20.41	1.04	21.80	1.06	22.89	1.08
		14	17.45	1.03	18.53	1.07	19.62	1.11	20.40	1.12	21.78	1.14	22.87	1.17
		20	17.44	1.05	18.52	1.09	19.60	1.13	20.38	1.14	21.77	1.16	22.85	1.18
		25	17.42	1.06	18.50	1.10	19.59	1.14	20.37	1.16	21.75	1.18	22.83	1.20
		30	17.41	1.08	18.49	1.12	19.57	1.16	20.35	1.17	21.73	1.19	22.82	1.22
		35	17.40	1.09	18.48	1.13	19.56	1.17	20.34	1.19	21.72	1.21	22.80	1.23
		40	17.38	1.11	18.46	1.15	19.54	1.19	20.32	1.20	21.70	1.23	22.78	1.25
		45	17.37	1.12	18.45	1.16	19.53	1.21	20.31	1.22	21.68	1.24	22.76	1.27
		50	17.36	1.14	18.43	1.18	19.51	1.22	20.29	1.24	21.67	1.26	22.75	1.28
		55	17.34	1.15	18.42	1.19	19.50	1.24	20.27	1.25	21.65	1.28	22.73	1.30
		60	17.33	1.17	18.41	1.21	19.48	1.25	20.26	1.27	21.63	1.29	22.71	1.32
		65	17.32	1.18	18.39	1.23	19.47	1.27	20.24	1.28	21.62	1.31	22.69	1.33
		70	17.30	1.20	18.38	1.24	19.45	1.29	20.23	1.30	21.60	1.32	22.68	1.35
		75	16.89	1.26	17.96	1.31	19.03	1.36	19.80	1.37	21.17	1.40	22.25	1.42
		80	16.47	1.33	17.54	1.37	18.61	1.42	19.38	1.44	20.75	1.47	21.82	1.50
		85	16.06	1.39	17.12	1.44	18.19	1.49	18.96	1.51	20.32	1.54	21.39	1.57
		90	15.64	1.46	16.71	1.51	17.77	1.56	18.54	1.58	19.90	1.61	20.96	1.64
		95	15.20	1.52	16.26	1.58	17.31	1.63	17.80	1.65	19.43	1.68	20.49	1.72
		100	14.83	1.58	15.89	1.64	16.94	1.70	17.57	1.72	19.06	1.75	20.12	1.79
		105	14.46	1.65	15.52	1.71	16.57	1.77	17.34	1.79	18.69	1.83	19.75	1.86
		110	14.09	1.71	15.15	1.78	16.20	1.84	16.97	1.86	18.32	1.90	19.38	1.94
		115	13.72	1.78	14.78	1.84	15.83	1.91	16.60	1.93	17.95	1.97	19.01	2.01
		118	13.49	1.82	14.55	1.88	15.61	1.95	16.38	1.97	17.73	2.01	18.79	2.05
		122	13.42	1.87	14.48	1.94	15.54	2.01	16.30	2.03	17.66	2.07	18.71	2.11

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 27: LMU24CHV Cooling Capacity Table — Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 9 + 9	-4	17.50	0.92	18.59	0.95	19.67	0.98	20.46	1.00	21.85	1.01	22.93	1.03
		0	17.49	0.93	18.58	0.96	19.66	0.99	20.45	1.01	21.84	1.03	22.92	1.05
		5	17.48	0.94	18.56	0.98	19.65	1.01	20.43	1.02	21.82	1.04	22.90	1.06
		10	17.46	0.95	18.55	0.99	19.63	1.03	20.41	1.04	21.80	1.06	22.89	1.08
		14	17.45	0.97	18.53	1.00	19.62	1.04	20.40	1.05	21.78	1.07	22.87	1.09
		20	17.44	0.98	18.52	1.02	19.60	1.06	20.38	1.07	21.77	1.09	22.85	1.11
		25	17.42	1.00	18.50	1.03	19.59	1.07	20.37	1.08	21.75	1.10	22.83	1.13
		30	17.41	1.01	18.49	1.05	19.57	1.09	20.35	1.10	21.73	1.12	22.82	1.14
		35	17.40	1.02	18.48	1.06	19.56	1.10	20.34	1.11	21.72	1.13	22.80	1.16
		40	17.38	1.04	18.46	1.08	19.54	1.12	20.32	1.13	21.70	1.15	22.78	1.17
		45	17.37	1.05	18.45	1.09	19.53	1.13	20.31	1.14	21.68	1.16	22.76	1.19
		50	17.36	1.07	18.43	1.11	19.51	1.15	20.29	1.16	21.67	1.18	22.75	1.20
		55	17.34	1.08	18.42	1.12	19.50	1.16	20.27	1.17	21.65	1.20	22.73	1.22
		60	17.33	1.09	18.41	1.13	19.48	1.18	20.26	1.19	21.63	1.21	22.71	1.24
		65	17.32	1.11	18.39	1.15	19.47	1.19	20.24	1.20	21.62	1.23	22.69	1.25
		70	17.30	1.12	18.38	1.16	19.45	1.21	20.23	1.22	21.60	1.24	22.68	1.27
		75	16.89	1.18	17.96	1.23	19.03	1.27	19.80	1.28	21.17	1.31	22.25	1.34
		80	16.47	1.24	17.54	1.29	18.61	1.34	19.38	1.35	20.75	1.38	21.82	1.40
		85	16.06	1.30	17.12	1.35	18.19	1.40	18.96	1.42	20.32	1.44	21.39	1.47
		90	15.64	1.36	16.71	1.41	17.77	1.47	18.54	1.48	19.90	1.51	20.96	1.54
		95	15.20	1.42	16.26	1.48	17.31	1.53	17.80	1.55	19.43	1.58	20.49	1.61
		100	14.83	1.48	15.89	1.54	16.94	1.60	17.57	1.61	19.06	1.64	20.12	1.68
		105	14.46	1.55	15.52	1.60	16.57	1.66	17.34	1.68	18.69	1.71	19.75	1.75
		110	14.09	1.61	15.15	1.66	16.20	1.73	16.97	1.75	18.32	1.78	19.38	1.81
		115	13.72	1.67	14.78	1.73	15.83	1.79	16.60	1.81	17.95	1.85	19.01	1.88
		118	13.49	1.70	14.55	1.77	15.61	1.83	16.38	1.85	17.73	1.89	18.79	1.92
		122	13.42	1.75	14.48	1.82	15.54	1.88	16.30	1.90	17.66	1.94	18.71	1.98
	9 + 9 + 12	-4	17.50	0.92	18.59	0.95	19.67	0.98	20.46	1.00	21.85	1.01	22.93	1.03
		0	17.49	0.93	18.58	0.96	19.66	0.99	20.45	1.01	21.84	1.03	22.92	1.05
		5	17.48	0.94	18.56	0.98	19.65	1.01	20.43	1.02	21.82	1.04	22.90	1.06
		10	17.46	0.95	18.55	0.99	19.63	1.03	20.41	1.04	21.80	1.06	22.89	1.08
		14	17.45	0.97	18.53	1.00	19.62	1.04	20.40	1.05	21.78	1.07	22.87	1.09
		20	17.44	0.98	18.52	1.02	19.60	1.06	20.38	1.07	21.77	1.09	22.85	1.11
		25	17.42	1.00	18.50	1.03	19.59	1.07	20.37	1.08	21.75	1.10	22.83	1.13
		30	17.41	1.01	18.49	1.05	19.57	1.09	20.35	1.10	21.73	1.12	22.82	1.14
		35	17.40	1.02	18.48	1.06	19.56	1.10	20.34	1.11	21.72	1.13	22.80	1.16
		40	17.38	1.04	18.46	1.08	19.54	1.12	20.32	1.13	21.70	1.15	22.78	1.17
		45	17.37	1.05	18.45	1.09	19.53	1.13	20.31	1.14	21.68	1.16	22.76	1.19
		50	17.36	1.07	18.43	1.11	19.51	1.15	20.29	1.16	21.67	1.18	22.75	1.20
		55	17.34	1.08	18.42	1.12	19.50	1.16	20.27	1.17	21.65	1.20	22.73	1.22
		60	17.33	1.09	18.41	1.13	19.48	1.18	20.26	1.19	21.63	1.21	22.71	1.24
		65	17.32	1.11	18.39	1.15	19.47	1.19	20.24	1.20	21.62	1.23	22.69	1.25
		70	17.30	1.12	18.38	1.16	19.45	1.21	20.23	1.22	21.60	1.24	22.68	1.27
		75	16.89	1.18	17.96	1.23	19.03	1.27	19.80	1.28	21.17	1.31	22.25	1.34
		80	16.47	1.24	17.54	1.29	18.61	1.34	19.38	1.35	20.75	1.38	21.82	1.40
		85	16.06	1.30	17.12	1.35	18.19	1.40	18.96	1.42	20.32	1.44	21.39	1.47
		90	15.64	1.36	16.71	1.41	17.77	1.47	18.54	1.48	19.90	1.51	20.96	1.54
		95	15.20	1.42	16.26	1.48	17.31	1.53	17.80	1.55	19.43	1.58	20.49	1.61
		100	14.83	1.48	15.89	1.54	16.94	1.60	17.57	1.61	19.06	1.64	20.12	1.68
		105	14.46	1.55	15.52	1.60	16.57	1.66	17.34	1.68	18.69	1.71	19.75	1.75
		110	14.09	1.61	15.15	1.66	16.20	1.73	16.97	1.75	18.32	1.78	19.38	1.81
		115	13.72	1.67	14.78	1.73	15.83	1.79	16.60	1.81	17.95	1.85	19.01	1.88
		118	13.49	1.70	14.55	1.77	15.61	1.83	16.38	1.85	17.73	1.89	18.79	1.92
		122	13.42	1.75	14.48	1.82	15.54	1.88	16.30	1.90	17.66	1.94	18.71	1.98

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 28: LMU24CHV Cooling Capacity Table — Ducted (continued) and Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 12 + 12	-4	17.50	0.92	18.59	0.95	19.67	0.98	20.46	1.00	21.85	1.01	22.93	1.03
		0	17.49	0.93	18.58	0.96	19.66	0.99	20.45	1.01	21.84	1.03	22.92	1.05
		5	17.48	0.94	18.56	0.98	19.65	1.01	20.43	1.02	21.82	1.04	22.90	1.06
		10	17.46	0.95	18.55	0.99	19.63	1.03	20.41	1.04	21.80	1.06	22.89	1.08
		14	17.45	0.97	18.53	1.00	19.62	1.04	20.40	1.05	21.78	1.07	22.87	1.09
		20	17.44	0.98	18.52	1.02	19.60	1.06	20.38	1.07	21.77	1.09	22.85	1.11
		25	17.42	1.00	18.50	1.03	19.59	1.07	20.37	1.08	21.75	1.10	22.83	1.13
		30	17.41	1.01	18.49	1.05	19.57	1.09	20.35	1.10	21.73	1.12	22.82	1.14
		35	17.40	1.02	18.48	1.06	19.56	1.10	20.34	1.11	21.72	1.13	22.80	1.16
		40	17.38	1.04	18.46	1.08	19.54	1.12	20.32	1.13	21.70	1.15	22.78	1.17
		45	17.37	1.05	18.45	1.09	19.53	1.13	20.31	1.14	21.68	1.16	22.76	1.19
		50	17.36	1.07	18.43	1.11	19.51	1.15	20.29	1.16	21.67	1.18	22.75	1.20
		55	17.34	1.08	18.42	1.12	19.50	1.16	20.27	1.17	21.65	1.20	22.73	1.22
		60	17.33	1.09	18.41	1.13	19.48	1.18	20.26	1.19	21.63	1.21	22.71	1.24
		65	17.32	1.11	18.39	1.15	19.47	1.19	20.24	1.20	21.62	1.23	22.69	1.25
		70	17.30	1.12	18.38	1.16	19.45	1.21	20.23	1.22	21.60	1.24	22.68	1.27
		75	16.89	1.18	17.96	1.23	19.03	1.27	19.80	1.28	21.17	1.31	22.25	1.34
		80	16.47	1.24	17.54	1.29	18.61	1.34	19.38	1.35	20.75	1.38	21.82	1.40
		85	16.06	1.30	17.12	1.35	18.19	1.40	18.96	1.42	20.32	1.44	21.39	1.47
		90	15.64	1.36	16.71	1.41	17.77	1.47	18.54	1.48	19.90	1.51	20.96	1.54
		95	15.20	1.42	16.26	1.48	17.31	1.53	17.80	1.55	19.43	1.58	20.49	1.61
		100	14.83	1.48	15.89	1.54	16.94	1.60	17.57	1.61	19.06	1.64	20.12	1.68
		105	14.46	1.55	15.52	1.60	16.57	1.66	17.34	1.68	18.69	1.71	19.75	1.75
		110	14.09	1.61	15.15	1.66	16.20	1.73	16.97	1.75	18.32	1.78	19.38	1.81
		115	13.72	1.67	14.78	1.73	15.83	1.79	16.60	1.81	17.95	1.85	19.01	1.88
		118	13.49	1.70	14.55	1.77	15.61	1.83	16.38	1.85	17.73	1.89	18.79	1.92
		122	13.42	1.75	14.48	1.82	15.54	1.88	16.30	1.90	17.66	1.94	18.71	1.98
Two (2) Mixed Indoor Units	7 + 9	-4	14.87	0.78	15.79	0.81	16.71	0.84	17.38	0.85	18.56	0.86	19.48	0.88
		0	14.86	0.79	15.78	0.82	16.70	0.85	17.37	0.86	18.55	0.87	19.47	0.89
		5	14.84	0.80	15.77	0.83	16.69	0.86	17.35	0.87	18.53	0.89	19.45	0.91
		10	14.83	0.81	15.75	0.84	16.68	0.87	17.34	0.88	18.52	0.90	19.44	0.92
		14	14.82	0.83	15.74	0.86	16.66	0.89	17.33	0.90	18.50	0.91	19.42	0.93
		20	14.81	0.84	15.73	0.87	16.65	0.90	17.31	0.91	18.49	0.93	19.41	0.95
		25	14.80	0.85	15.72	0.88	16.64	0.91	17.30	0.92	18.48	0.94	19.40	0.96
		30	14.79	0.86	15.71	0.89	16.63	0.93	17.29	0.94	18.46	0.95	19.38	0.97
		35	14.78	0.87	15.69	0.90	16.61	0.94	17.28	0.95	18.45	0.97	19.37	0.99
		40	14.77	0.88	15.68	0.92	16.60	0.95	17.26	0.96	18.43	0.98	19.35	1.00
		45	14.75	0.90	15.67	0.93	16.59	0.96	17.25	0.97	18.42	0.99	19.34	1.01
		50	14.74	0.91	15.66	0.94	16.57	0.98	17.24	0.99	18.41	1.01	19.32	1.03
		55	14.73	0.92	15.65	0.95	16.56	0.99	17.22	1.00	18.39	1.02	19.31	1.04
		60	14.72	0.93	15.63	0.97	16.55	1.00	17.21	1.01	18.38	1.03	19.29	1.05
		65	14.71	0.94	15.62	0.98	16.54	1.01	17.20	1.03	18.36	1.05	19.28	1.07
		70	14.70	0.96	15.61	0.99	16.52	1.03	17.18	1.04	18.35	1.06	19.26	1.08
		75	14.34	1.01	15.25	1.04	16.17	1.08	16.82	1.09	17.99	1.12	18.90	1.14
		80	13.99	1.06	14.90	1.10	15.81	1.14	16.46	1.15	17.62	1.17	18.53	1.20
		85	13.64	1.11	14.55	1.15	15.45	1.19	16.11	1.21	17.26	1.23	18.17	1.25
		90	13.29	1.16	14.19	1.20	15.10	1.25	15.75	1.26	16.90	1.29	17.81	1.31
		95	12.91	1.21	13.81	1.26	14.71	1.30	15.12	1.32	16.51	1.34	17.41	1.37
		100	12.59	1.27	13.49	1.31	14.39	1.36	14.92	1.38	16.19	1.40	17.09	1.43
		105	12.28	1.32	13.18	1.37	14.08	1.41	14.73	1.43	15.88	1.46	16.78	1.49
		110	11.97	1.37	12.87	1.42	13.76	1.47	14.41	1.49	15.56	1.52	16.46	1.55
		115	11.65	1.42	12.55	1.47	13.45	1.53	14.10	1.54	15.25	1.57	16.15	1.60
		118	11.46	1.45	12.36	1.50	13.26	1.56	13.91	1.58	15.06	1.61	15.96	1.64
		122	11.40	1.49	12.30	1.55	13.20	1.60	13.85	1.62	15.00	1.65	15.90	1.69

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 29: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 9	-4	16.72	0.87	17.76	0.90	18.80	0.94	19.55	0.95	20.88	0.96	21.92	0.98
		0	16.71	0.88	17.75	0.91	18.79	0.95	19.54	0.96	20.87	0.98	21.90	0.99
		5	16.70	0.90	17.74	0.93	18.77	0.96	19.52	0.97	20.85	0.99	21.89	1.01
		10	16.69	0.91	17.72	0.94	18.76	0.98	19.51	0.99	20.83	1.01	21.87	1.03
		14	16.67	0.92	17.71	0.96	18.75	0.99	19.49	1.00	20.82	1.02	21.85	1.04
		20	16.66	0.93	17.70	0.97	18.73	1.00	19.48	1.02	20.80	1.03	21.84	1.06
		25	16.65	0.95	17.68	0.98	18.72	1.02	19.46	1.03	20.79	1.05	21.82	1.07
		30	16.64	0.96	17.67	1.00	18.70	1.03	19.45	1.04	20.77	1.06	21.80	1.09
		35	16.62	0.97	17.66	1.01	18.69	1.05	19.43	1.06	20.75	1.08	21.79	1.10
		40	16.61	0.99	17.64	1.02	18.67	1.06	19.42	1.07	20.74	1.09	21.77	1.12
		45	16.60	1.00	17.63	1.04	18.66	1.08	19.40	1.09	20.72	1.11	21.75	1.13
		50	16.59	1.01	17.62	1.05	18.65	1.09	19.39	1.10	20.71	1.12	21.74	1.15
		55	16.57	1.03	17.60	1.06	18.63	1.10	19.37	1.12	20.69	1.14	21.72	1.16
		60	16.56	1.04	17.59	1.08	18.62	1.12	19.36	1.13	20.67	1.15	21.70	1.18
		65	16.55	1.05	17.58	1.09	18.60	1.13	19.35	1.15	20.66	1.17	21.69	1.19
		70	16.53	1.07	17.56	1.11	18.59	1.15	19.33	1.16	20.64	1.18	21.67	1.21
		75	16.14	1.12	17.16	1.17	18.19	1.21	18.93	1.22	20.23	1.25	21.26	1.27
		80	15.74	1.18	16.76	1.23	17.78	1.27	18.52	1.28	19.83	1.31	20.85	1.34
		85	15.34	1.24	16.36	1.29	17.38	1.33	18.12	1.35	19.42	1.37	20.44	1.40
		90	14.95	1.30	15.97	1.34	16.98	1.39	17.72	1.41	19.02	1.44	20.03	1.47
		95	14.52	1.36	15.53	1.40	16.55	1.46	17.01	1.47	18.57	1.50	19.58	1.53
		100	14.17	1.41	15.18	1.46	16.19	1.52	16.79	1.54	18.22	1.56	19.23	1.60
		105	13.82	1.47	14.83	1.52	15.84	1.58	16.57	1.60	17.86	1.63	18.87	1.66
		110	13.46	1.53	14.47	1.58	15.48	1.64	16.22	1.66	17.51	1.69	18.52	1.73
		115	13.11	1.59	14.12	1.64	15.13	1.70	15.86	1.72	17.15	1.76	18.17	1.79
		118	12.90	1.62	13.91	1.68	14.92	1.74	15.65	1.76	16.94	1.79	17.95	1.83
		122	12.82	1.67	13.84	1.73	14.85	1.79	15.58	1.81	16.87	1.84	17.88	1.88
	7 + 12	-4	17.65	0.91	18.75	0.95	19.84	0.98	20.64	0.99	22.04	1.01	23.13	1.03
		0	17.64	0.92	18.74	0.96	19.83	0.99	20.63	1.00	22.03	1.02	23.12	1.04
		5	17.63	0.94	18.72	0.97	19.82	1.01	20.61	1.02	22.01	1.04	23.10	1.06
		10	17.61	0.95	18.71	0.99	19.80	1.02	20.59	1.03	21.99	1.05	23.08	1.08
		14	17.60	0.97	18.69	1.00	19.79	1.04	20.58	1.05	21.97	1.07	23.07	1.09
		20	17.59	0.98	18.68	1.02	19.77	1.05	20.56	1.07	21.96	1.09	23.05	1.11
		25	17.57	0.99	18.67	1.03	19.76	1.07	20.55	1.08	21.94	1.10	23.03	1.12
		30	17.56	1.01	18.65	1.04	19.74	1.08	20.53	1.10	21.92	1.12	23.01	1.14
		35	17.55	1.02	18.64	1.06	19.73	1.10	20.51	1.11	21.91	1.13	23.00	1.15
		40	17.53	1.04	18.62	1.07	19.71	1.11	20.50	1.13	21.89	1.15	22.98	1.17
		45	17.52	1.05	18.61	1.09	19.70	1.13	20.48	1.14	21.87	1.16	22.96	1.19
		50	17.51	1.06	18.59	1.10	19.68	1.14	20.47	1.16	21.86	1.18	22.94	1.20
		55	17.49	1.08	18.58	1.12	19.67	1.16	20.45	1.17	21.84	1.19	22.93	1.22
		60	17.48	1.09	18.57	1.13	19.65	1.17	20.44	1.19	21.82	1.21	22.91	1.23
		65	17.47	1.11	18.55	1.15	19.64	1.19	20.42	1.20	21.81	1.22	22.89	1.25
		70	17.45	1.12	18.54	1.16	19.62	1.20	20.40	1.22	21.79	1.24	22.87	1.26
		75	17.03	1.18	18.11	1.22	19.20	1.27	19.98	1.28	21.36	1.31	22.44	1.33
		80	16.61	1.24	17.69	1.29	18.77	1.33	19.55	1.35	20.93	1.37	22.01	1.40
		85	16.20	1.30	17.27	1.35	18.35	1.40	19.13	1.41	20.50	1.44	21.58	1.47
		90	15.78	1.36	16.85	1.41	17.93	1.46	18.70	1.48	20.07	1.51	21.15	1.54
		95	15.33	1.42	16.40	1.47	17.47	1.53	17.96	1.54	19.60	1.57	20.67	1.60
		100	14.96	1.48	16.02	1.54	17.09	1.59	17.72	1.61	19.23	1.64	20.30	1.67
		105	14.58	1.54	15.65	1.60	16.72	1.66	17.49	1.68	18.85	1.71	19.92	1.74
		110	14.21	1.60	15.28	1.66	16.35	1.72	17.12	1.74	18.48	1.77	19.55	1.81
		115	13.84	1.66	14.90	1.72	15.97	1.79	16.74	1.81	18.11	1.84	19.18	1.88
		118	13.61	1.70	14.68	1.76	15.75	1.82	16.52	1.85	17.88	1.88	18.95	1.92
		122	13.54	1.75	14.61	1.81	15.67	1.88	16.44	1.90	17.81	1.93	18.88	1.97

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 30: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 12	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06
	9 + 15	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 31: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 12	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06
	7 + 18	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 32: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 18	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06
	12 + 15	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 33: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 18	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06
	15 + 18	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 34: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 24*	-4	18.58	0.96	19.74	0.99	20.89	1.03	21.72	1.04	23.20	1.06	24.35	1.08
		0	18.57	0.97	19.72	1.00	20.88	1.04	21.71	1.05	23.18	1.07	24.34	1.09
		5	18.56	0.98	19.71	1.02	20.86	1.06	21.69	1.07	23.17	1.09	24.32	1.11
		10	18.54	1.00	19.69	1.03	20.84	1.07	21.68	1.08	23.15	1.10	24.30	1.13
		14	18.53	1.01	19.68	1.05	20.83	1.09	21.66	1.10	23.13	1.12	24.28	1.14
		20	18.51	1.03	19.66	1.06	20.81	1.10	21.64	1.11	23.11	1.14	24.26	1.16
		25	18.50	1.04	19.65	1.08	20.80	1.12	21.63	1.13	23.09	1.15	24.24	1.17
		30	18.49	1.05	19.63	1.09	20.78	1.13	21.61	1.15	23.08	1.17	24.23	1.19
		35	18.47	1.07	19.62	1.11	20.77	1.15	21.59	1.16	23.06	1.18	24.21	1.21
		40	18.46	1.08	19.60	1.12	20.75	1.16	21.58	1.18	23.04	1.20	24.19	1.22
		45	18.44	1.10	19.59	1.14	20.73	1.18	21.56	1.19	23.02	1.22	24.17	1.24
		50	18.43	1.11	19.57	1.15	20.72	1.20	21.54	1.21	23.01	1.23	24.15	1.26
		55	18.41	1.13	19.56	1.17	20.70	1.21	21.53	1.23	22.99	1.25	24.13	1.27
		60	18.40	1.14	19.54	1.18	20.69	1.23	21.51	1.24	22.97	1.26	24.11	1.29
		65	18.39	1.16	19.53	1.20	20.67	1.24	21.49	1.26	22.95	1.28	24.10	1.31
		70	18.37	1.17	19.51	1.21	20.65	1.26	21.48	1.27	22.94	1.30	24.08	1.32
		75	17.93	1.23	19.07	1.28	20.21	1.33	21.03	1.34	22.48	1.37	23.62	1.39
		80	17.49	1.30	18.62	1.34	19.76	1.39	20.58	1.41	22.03	1.44	23.16	1.47
		85	17.05	1.36	18.18	1.41	19.31	1.46	20.13	1.48	21.58	1.51	22.71	1.54
		90	16.61	1.42	17.74	1.48	18.87	1.53	19.69	1.55	21.13	1.58	22.26	1.61
		95	16.14	1.49	17.26	1.54	18.38	1.60	18.90	1.62	20.63	1.65	21.76	1.68
		100	15.74	1.55	16.87	1.61	17.99	1.67	18.66	1.68	20.24	1.72	21.36	1.75
		105	15.35	1.61	16.47	1.67	17.60	1.73	18.41	1.75	19.85	1.79	20.97	1.82
		110	14.96	1.68	16.08	1.74	17.21	1.80	18.02	1.82	19.45	1.86	20.58	1.89
		115	14.56	1.74	15.69	1.80	16.81	1.87	17.62	1.89	19.06	1.93	20.18	1.96
		118	14.33	1.78	15.45	1.84	16.58	1.91	17.39	1.93	18.83	1.97	19.95	2.01
		122	14.25	1.83	15.37	1.89	16.50	1.96	17.31	1.99	18.75	2.02	19.87	2.06
Three (3) Mixed Indoor Units	7 + 7 + 9	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

*The indoor unit must be non-ducted type.

Table 35: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 9	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94
	7 + 7 + 12	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 36: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 9	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94
	7 + 9 + 12	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 37: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 12	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94
	7 + 9 + 15	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU24CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 38: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 12	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94
	7 + 7 + 18	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 39: LMU24CHV Cooling Capacity Table — Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 15	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94
	9 + 12 + 12	-4	18.58	0.90	19.74	0.93	20.89	0.96	21.72	0.97	23.20	0.99	24.35	1.01
		0	18.57	0.91	19.72	0.94	20.88	0.97	21.71	0.98	23.18	1.00	24.34	1.02
		5	18.56	0.92	19.71	0.95	20.86	0.99	21.69	1.00	23.17	1.02	24.32	1.04
		10	18.54	0.93	19.69	0.97	20.84	1.00	21.68	1.02	23.15	1.03	24.30	1.06
		14	18.53	0.95	19.68	0.98	20.83	1.02	21.66	1.03	23.13	1.05	24.28	1.07
		20	18.51	0.96	19.66	1.00	20.81	1.03	21.64	1.04	23.11	1.06	24.26	1.09
		25	18.50	0.98	19.65	1.01	20.80	1.05	21.63	1.06	23.09	1.08	24.24	1.10
		30	18.49	0.99	19.63	1.02	20.78	1.06	21.61	1.07	23.08	1.09	24.23	1.12
		35	18.47	1.00	19.62	1.04	20.77	1.08	21.59	1.09	23.06	1.11	24.21	1.13
		40	18.46	1.02	19.60	1.05	20.75	1.09	21.58	1.10	23.04	1.12	24.19	1.15
		45	18.44	1.03	19.59	1.07	20.73	1.11	21.56	1.12	23.02	1.14	24.17	1.16
		50	18.43	1.04	19.57	1.08	20.72	1.12	21.54	1.13	23.01	1.15	24.15	1.18
		55	18.41	1.06	19.56	1.10	20.70	1.14	21.53	1.15	22.99	1.17	24.13	1.19
		60	18.40	1.07	19.54	1.11	20.69	1.15	21.51	1.16	22.97	1.18	24.11	1.21
		65	18.39	1.08	19.53	1.12	20.67	1.16	21.49	1.18	22.95	1.20	24.10	1.22
		70	18.37	1.10	19.51	1.14	20.65	1.18	21.48	1.19	22.94	1.22	24.08	1.24
		75	17.93	1.16	19.07	1.20	20.21	1.24	21.03	1.26	22.48	1.28	23.62	1.31
		80	17.49	1.22	18.62	1.26	19.76	1.31	20.58	1.32	22.03	1.35	23.16	1.37
		85	17.05	1.28	18.18	1.32	19.31	1.37	20.13	1.39	21.58	1.41	22.71	1.44
		90	16.61	1.33	17.74	1.38	18.87	1.43	19.69	1.45	21.13	1.48	22.26	1.51
		95	16.14	1.39	17.26	1.44	18.38	1.50	18.90	1.51	20.63	1.54	21.76	1.57
		100	15.74	1.45	16.87	1.51	17.99	1.56	18.66	1.58	20.24	1.61	21.36	1.64
		105	15.35	1.51	16.47	1.57	17.60	1.62	18.41	1.64	19.85	1.67	20.97	1.71
		110	14.96	1.57	16.08	1.63	17.21	1.69	18.02	1.71	19.45	1.74	20.58	1.77
		115	14.56	1.63	15.69	1.69	16.81	1.75	17.62	1.77	19.06	1.81	20.18	1.84
		118	14.33	1.67	15.45	1.73	16.58	1.79	17.39	1.81	18.83	1.84	19.95	1.88
		122	14.25	1.71	15.37	1.78	16.50	1.84	17.31	1.86	18.75	1.90	19.87	1.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 40: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	13.76	0.79	14.62	0.82	15.47	0.85	16.09	0.86	17.18	0.88	18.04	0.89
		0	13.76	0.80	14.61	0.83	15.47	0.86	16.08	0.87	17.17	0.89	18.03	0.90
		5	13.75	0.81	14.60	0.84	15.45	0.87	16.07	0.88	17.16	0.90	18.01	0.92
		10	13.73	0.82	14.59	0.85	15.44	0.89	16.06	0.90	17.15	0.91	18.00	0.93
		14	13.72	0.84	14.58	0.87	15.43	0.90	16.04	0.91	17.13	0.93	17.99	0.94
		20	13.71	0.85	14.57	0.88	15.42	0.91	16.03	0.92	17.12	0.94	17.97	0.96
		25	13.70	0.86	14.55	0.89	15.41	0.92	16.02	0.94	17.11	0.95	17.96	0.97
		30	13.69	0.87	14.54	0.90	15.39	0.94	16.01	0.95	17.09	0.97	17.94	0.99
		35	13.68	0.88	14.53	0.92	15.38	0.95	16.00	0.96	17.08	0.98	17.93	1.00
		40	13.67	0.90	14.52	0.93	15.37	0.96	15.98	0.97	17.07	0.99	17.92	1.01
		45	13.66	0.91	14.51	0.94	15.36	0.98	15.97	0.99	17.06	1.01	17.90	1.03
		50	13.65	0.92	14.50	0.95	15.35	0.99	15.96	1.00	17.04	1.02	17.89	1.04
		55	13.64	0.93	14.49	0.97	15.33	1.00	15.95	1.01	17.03	1.03	17.88	1.05
		60	13.63	0.94	14.48	0.98	15.32	1.02	15.93	1.03	17.02	1.05	17.86	1.07
		65	13.62	0.96	14.47	0.99	15.31	1.03	15.92	1.04	17.00	1.06	17.85	1.08
		70	13.61	0.97	14.45	1.00	15.30	1.04	15.91	1.05	16.99	1.07	17.83	1.09
		75	13.28	1.02	14.12	1.06	14.97	1.10	15.58	1.11	16.65	1.13	17.50	1.15
		80	12.95	1.07	13.80	1.11	14.64	1.15	15.24	1.17	16.32	1.19	17.16	1.21
		85	12.63	1.13	13.47	1.17	14.31	1.21	14.91	1.22	15.99	1.25	16.82	1.27
		90	12.30	1.18	13.14	1.22	13.98	1.27	14.58	1.28	15.65	1.30	16.49	1.33
		95	11.95	1.23	12.79	1.28	13.62	1.32	14.00	1.34	15.28	1.36	16.12	1.39
		100	11.66	1.28	12.49	1.33	13.33	1.38	13.82	1.39	14.99	1.42	15.82	1.45
		105	11.37	1.33	12.20	1.38	13.04	1.43	13.64	1.45	14.70	1.48	15.53	1.51
		110	11.08	1.39	11.91	1.44	12.74	1.49	13.35	1.51	14.41	1.54	15.24	1.57
		115	10.79	1.44	11.62	1.49	12.45	1.55	13.06	1.56	14.12	1.59	14.95	1.63
		118	10.61	1.47	11.45	1.52	12.28	1.58	12.88	1.60	13.94	1.63	14.78	1.66
		122	10.56	1.51	11.39	1.57	12.22	1.62	12.82	1.64	13.89	1.67	14.72	1.71
	7 + 9	-4	15.73	0.89	16.71	0.92	17.68	0.96	18.39	0.97	19.64	0.99	20.61	1.00
		0	15.72	0.90	16.70	0.93	17.67	0.97	18.38	0.98	19.63	1.00	20.60	1.02
		5	15.71	0.91	16.68	0.95	17.66	0.98	18.36	0.99	19.61	1.01	20.59	1.03
		10	15.70	0.93	16.67	0.96	17.65	1.00	18.35	1.01	19.60	1.03	20.57	1.05
		14	15.68	0.94	16.66	0.98	17.63	1.01	18.34	1.02	19.58	1.04	20.56	1.06
		20	15.67	0.95	16.65	0.99	17.62	1.03	18.32	1.04	19.57	1.06	20.54	1.08
		25	15.66	0.97	16.63	1.00	17.61	1.04	18.31	1.05	19.55	1.07	20.52	1.09
		30	15.65	0.98	16.62	1.02	17.59	1.05	18.29	1.07	19.54	1.09	20.51	1.11
		35	15.64	1.00	16.61	1.03	17.58	1.07	18.28	1.08	19.52	1.10	20.49	1.12
		40	15.62	1.01	16.60	1.05	17.57	1.08	18.27	1.10	19.51	1.12	20.48	1.14
		45	15.61	1.02	16.58	1.06	17.55	1.10	18.25	1.11	19.49	1.13	20.46	1.15
		50	15.60	1.04	16.57	1.07	17.54	1.11	18.24	1.13	19.48	1.15	20.45	1.17
		55	15.59	1.05	16.56	1.09	17.53	1.13	18.22	1.14	19.46	1.16	20.43	1.19
		60	15.58	1.06	16.54	1.10	17.51	1.14	18.21	1.16	19.45	1.18	20.41	1.20
		65	15.57	1.08	16.53	1.12	17.50	1.16	18.20	1.17	19.43	1.19	20.40	1.22
		70	15.55	1.09	16.52	1.13	17.49	1.17	18.18	1.18	19.42	1.21	20.38	1.23
		75	15.18	1.15	16.14	1.19	17.11	1.23	17.80	1.25	19.03	1.27	20.00	1.30
		80	14.80	1.21	15.77	1.25	16.73	1.30	17.42	1.31	18.65	1.34	19.61	1.36
		85	14.43	1.27	15.39	1.31	16.35	1.36	17.04	1.38	18.27	1.40	19.23	1.43
		90	14.06	1.33	15.02	1.37	15.98	1.42	16.67	1.44	17.89	1.47	18.84	1.50
		95	13.66	1.38	14.61	1.43	15.56	1.49	16.00	1.50	17.47	1.53	18.42	1.56
		100	13.33	1.44	14.28	1.50	15.23	1.55	15.79	1.57	17.13	1.60	18.09	1.63
		105	12.99	1.50	13.95	1.56	14.90	1.61	15.59	1.63	16.80	1.66	17.75	1.70
		110	12.66	1.56	13.61	1.62	14.57	1.68	15.25	1.70	16.47	1.73	17.42	1.76
		115	12.33	1.62	13.28	1.68	14.23	1.74	14.92	1.76	16.14	1.79	17.09	1.83
		118	12.13	1.65	13.08	1.71	14.03	1.78	14.72	1.80	15.94	1.83	16.89	1.87
		122	12.06	1.70	13.02	1.76	13.97	1.83	14.65	1.85	15.87	1.88	16.82	1.92

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 41: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 9	-4	17.70	1.00	18.80	1.04	19.89	1.07	20.69	1.09	22.09	1.11	23.19	1.13
		0	17.69	1.01	18.79	1.05	19.88	1.09	20.68	1.10	22.08	1.12	23.18	1.14
		5	17.67	1.03	18.77	1.07	19.87	1.10	20.66	1.12	22.06	1.14	23.16	1.16
		10	17.66	1.04	18.76	1.08	19.85	1.12	20.64	1.13	22.05	1.15	23.14	1.18
		14	17.65	1.06	18.74	1.10	19.84	1.14	20.63	1.15	22.03	1.17	23.12	1.19
		20	17.63	1.07	18.73	1.11	19.82	1.15	20.61	1.17	22.01	1.19	23.11	1.21
		25	17.62	1.09	18.71	1.13	19.81	1.17	20.60	1.18	22.00	1.21	23.09	1.23
		30	17.60	1.10	18.70	1.14	19.79	1.19	20.58	1.20	21.98	1.22	23.07	1.25
		35	17.59	1.12	18.68	1.16	19.78	1.20	20.57	1.22	21.96	1.24	23.05	1.26
		40	17.58	1.13	18.67	1.18	19.76	1.22	20.55	1.23	21.94	1.26	23.04	1.28
		45	17.56	1.15	18.66	1.19	19.75	1.23	20.53	1.25	21.93	1.27	23.02	1.30
		50	17.55	1.16	18.64	1.21	19.73	1.25	20.52	1.27	21.91	1.29	23.00	1.32
		55	17.54	1.18	18.63	1.22	19.72	1.27	20.50	1.28	21.89	1.31	22.98	1.33
		60	17.52	1.19	18.61	1.24	19.70	1.28	20.49	1.30	21.88	1.32	22.97	1.35
		65	17.51	1.21	18.60	1.25	19.69	1.30	20.47	1.32	21.86	1.34	22.95	1.37
		70	17.50	1.23	18.58	1.27	19.67	1.32	20.46	1.33	21.84	1.36	22.93	1.38
		75	17.08	1.29	18.16	1.34	19.24	1.39	20.03	1.40	21.41	1.43	22.50	1.46
		80	16.66	1.36	17.74	1.41	18.82	1.46	19.60	1.48	20.98	1.50	22.06	1.53
		85	16.24	1.42	17.32	1.48	18.40	1.53	19.17	1.55	20.55	1.58	21.63	1.61
		90	15.82	1.49	16.90	1.54	17.97	1.60	18.75	1.62	20.12	1.65	21.20	1.68
		95	15.37	1.56	16.44	1.61	17.51	1.67	18.00	1.69	19.65	1.72	20.72	1.76
		100	14.99	1.62	16.06	1.68	17.13	1.74	17.77	1.76	19.28	1.80	20.35	1.83
		105	14.62	1.69	15.69	1.75	16.76	1.81	17.53	1.83	18.90	1.87	19.97	1.91
		110	14.24	1.75	15.32	1.82	16.39	1.88	17.16	1.91	18.53	1.94	19.60	1.98
		115	13.87	1.82	14.94	1.89	16.01	1.96	16.79	1.98	18.15	2.02	19.22	2.06
		118	13.65	1.86	14.72	1.93	15.79	2.00	16.56	2.02	17.93	2.06	19.00	2.10
		122	13.57	1.91	14.64	1.98	15.71	2.05	16.49	2.08	17.85	2.12	18.92	2.16
	7 + 12	-4	18.68	1.05	19.84	1.09	21.00	1.12	21.84	1.14	23.32	1.16	24.48	1.18
		0	18.67	1.06	19.83	1.10	20.99	1.14	21.83	1.15	23.31	1.17	24.47	1.20
		5	18.65	1.08	19.81	1.11	20.97	1.16	21.81	1.17	23.29	1.19	24.45	1.21
		10	18.64	1.09	19.80	1.13	20.96	1.17	21.79	1.19	23.27	1.21	24.43	1.23
		14	18.63	1.11	19.78	1.15	20.94	1.19	21.77	1.20	23.25	1.23	24.41	1.25
		20	18.61	1.12	19.77	1.16	20.92	1.21	21.76	1.22	23.23	1.24	24.39	1.27
		25	18.60	1.14	19.75	1.18	20.91	1.22	21.74	1.24	23.22	1.26	24.37	1.29
		30	18.58	1.15	19.74	1.20	20.89	1.24	21.72	1.26	23.20	1.28	24.35	1.30
		35	18.57	1.17	19.72	1.21	20.88	1.26	21.71	1.27	23.18	1.30	24.33	1.32
		40	18.55	1.19	19.71	1.23	20.86	1.28	21.69	1.29	23.16	1.31	24.32	1.34
		45	18.54	1.20	19.69	1.25	20.84	1.29	21.67	1.31	23.15	1.33	24.30	1.36
		50	18.53	1.22	19.68	1.26	20.83	1.31	21.66	1.32	23.13	1.35	24.28	1.38
		55	18.51	1.23	19.66	1.28	20.81	1.33	21.64	1.34	23.11	1.37	24.26	1.39
		60	18.50	1.25	19.65	1.30	20.80	1.34	21.63	1.36	23.09	1.38	24.24	1.41
		65	18.48	1.27	19.63	1.31	20.78	1.36	21.61	1.38	23.08	1.40	24.22	1.43
		70	18.47	1.28	19.62	1.33	20.76	1.38	21.59	1.39	23.06	1.42	24.20	1.45
		75	18.02	1.35	19.17	1.40	20.31	1.45	21.14	1.47	22.60	1.50	23.75	1.53
		80	17.58	1.42	18.72	1.47	19.86	1.53	20.69	1.54	22.15	1.57	23.29	1.60
		85	17.14	1.49	18.28	1.54	19.42	1.60	20.24	1.62	21.69	1.65	22.83	1.68
		90	16.70	1.56	17.84	1.62	18.97	1.67	19.79	1.69	21.24	1.73	22.38	1.76
		95	16.22	1.63	17.35	1.69	18.48	1.75	19.00	1.77	20.74	1.80	21.87	1.84
		100	15.83	1.70	16.96	1.76	18.09	1.82	18.75	1.84	20.35	1.88	21.48	1.92
		105	15.43	1.77	16.56	1.83	17.69	1.90	18.51	1.92	19.95	1.96	21.08	2.00
		110	15.04	1.84	16.17	1.90	17.30	1.97	18.11	1.99	19.56	2.03	20.69	2.07
		115	14.64	1.90	15.77	1.97	16.90	2.05	17.72	2.07	19.16	2.11	20.29	2.15
		118	14.40	1.95	15.53	2.02	16.66	2.09	17.48	2.12	18.92	2.15	20.05	2.20
		122	14.33	2.00	15.46	2.07	16.59	2.15	17.40	2.18	18.85	2.22	19.98	2.26

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 42: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 12	-4	20.65	1.15	21.93	1.19	23.21	1.23	24.14	1.25	25.77	1.27	27.06	1.29
		0	20.63	1.16	21.92	1.20	23.20	1.24	24.12	1.26	25.76	1.28	27.04	1.31
		5	20.62	1.18	21.90	1.22	23.18	1.26	24.10	1.28	25.74	1.30	27.02	1.33
		10	20.60	1.19	21.88	1.24	23.16	1.28	24.08	1.30	25.72	1.32	27.00	1.35
		14	20.59	1.21	21.86	1.26	23.14	1.30	24.07	1.32	25.70	1.34	26.98	1.37
		20	20.57	1.23	21.85	1.27	23.13	1.32	24.05	1.34	25.68	1.36	26.96	1.39
		25	20.55	1.25	21.83	1.29	23.11	1.34	24.03	1.35	25.66	1.38	26.94	1.41
		30	20.54	1.26	21.81	1.31	23.09	1.36	24.01	1.37	25.64	1.40	26.92	1.43
		35	20.52	1.28	21.80	1.33	23.07	1.38	23.99	1.39	25.62	1.42	26.90	1.45
		40	20.51	1.30	21.78	1.35	23.05	1.40	23.97	1.41	25.60	1.44	26.88	1.47
		45	20.49	1.32	21.76	1.36	23.04	1.41	23.96	1.43	25.58	1.46	26.86	1.49
		50	20.48	1.33	21.75	1.38	23.02	1.43	23.94	1.45	25.56	1.48	26.83	1.51
		55	20.46	1.35	21.73	1.40	23.00	1.45	23.92	1.47	25.54	1.50	26.81	1.53
		60	20.44	1.37	21.71	1.42	22.98	1.47	23.90	1.49	25.52	1.52	26.79	1.55
		65	20.43	1.39	21.70	1.44	22.97	1.49	23.88	1.51	25.50	1.53	26.77	1.57
		70	20.41	1.40	21.68	1.45	22.95	1.51	23.86	1.53	25.48	1.55	26.75	1.58
		75	19.92	1.48	21.19	1.53	22.45	1.59	23.36	1.61	24.98	1.64	26.25	1.67
		80	19.43	1.55	20.69	1.61	21.95	1.67	22.87	1.69	24.48	1.72	25.74	1.76
		85	18.94	1.63	20.20	1.69	21.46	1.75	22.37	1.77	23.98	1.81	25.24	1.84
		90	18.46	1.71	19.71	1.77	20.97	1.83	21.87	1.85	23.48	1.89	24.73	1.93
		95	17.93	1.78	19.18	1.85	20.43	1.91	21.00	1.94	22.93	1.97	24.17	2.01
		100	17.49	1.86	18.74	1.93	19.99	2.00	20.73	2.02	22.49	2.06	23.74	2.10
		105	17.06	1.93	18.30	2.00	19.55	2.08	20.46	2.10	22.05	2.14	23.30	2.18
		110	16.62	2.01	17.87	2.08	19.12	2.16	20.02	2.18	21.62	2.22	22.86	2.27
		115	16.18	2.08	17.43	2.16	18.68	2.24	19.58	2.27	21.18	2.31	22.43	2.35
		118	15.92	2.13	17.17	2.21	18.42	2.29	19.32	2.31	20.92	2.36	22.17	2.41
		122	15.83	2.19	17.08	2.27	18.33	2.35	19.23	2.38	20.83	2.43	22.08	2.47
	7 + 15	-4	21.63	1.19	22.97	1.23	24.32	1.27	25.29	1.29	27.00	1.31	28.35	1.34
		0	21.62	1.20	22.96	1.24	24.30	1.29	25.27	1.30	26.99	1.33	28.33	1.35
		5	21.60	1.22	22.94	1.26	24.28	1.31	25.25	1.32	26.97	1.35	28.31	1.38
		10	21.58	1.24	22.92	1.28	24.26	1.33	25.23	1.34	26.94	1.37	28.29	1.40
		14	21.57	1.25	22.91	1.30	24.25	1.35	25.21	1.36	26.92	1.39	28.26	1.42
		20	21.55	1.27	22.89	1.32	24.23	1.37	25.19	1.38	26.90	1.41	28.24	1.44
		25	21.53	1.29	22.87	1.34	24.21	1.39	25.17	1.40	26.88	1.43	28.22	1.46
		30	21.52	1.31	22.85	1.36	24.19	1.41	25.15	1.42	26.86	1.45	28.20	1.48
		35	21.50	1.33	22.84	1.38	24.17	1.43	25.14	1.44	26.84	1.47	28.18	1.50
		40	21.48	1.35	22.82	1.39	24.15	1.45	25.12	1.46	26.82	1.49	28.16	1.52
		45	21.47	1.36	22.80	1.41	24.13	1.46	25.10	1.48	26.80	1.51	28.13	1.54
		50	21.45	1.38	22.78	1.43	24.12	1.48	25.08	1.50	26.78	1.53	28.11	1.56
		55	21.43	1.40	22.77	1.45	24.10	1.50	25.06	1.52	26.76	1.55	28.09	1.58
		60	21.42	1.42	22.75	1.47	24.08	1.52	25.04	1.54	26.74	1.57	28.07	1.60
		65	21.40	1.44	22.73	1.49	24.06	1.54	25.02	1.56	26.72	1.59	28.05	1.62
		70	21.39	1.45	22.71	1.51	24.04	1.56	25.00	1.58	26.70	1.61	28.03	1.64
		75	20.87	1.53	22.20	1.59	23.52	1.65	24.48	1.66	26.17	1.70	27.50	1.73
		80	20.36	1.61	21.68	1.67	23.00	1.73	23.95	1.75	25.64	1.78	26.96	1.82
		85	19.85	1.69	21.16	1.75	22.48	1.81	23.44	1.83	25.12	1.87	26.44	1.91
		90	19.34	1.77	20.65	1.83	21.97	1.90	22.92	1.92	24.60	1.96	25.91	2.00
		95	18.78	1.85	20.09	1.91	21.40	1.98	22.00	2.01	24.02	2.04	25.33	2.08
		100	18.33	1.92	19.63	1.99	20.94	2.07	21.71	2.09	23.56	2.13	24.87	2.17
		105	17.87	2.00	19.18	2.08	20.48	2.15	21.43	2.18	23.10	2.22	24.41	2.26
		110	17.41	2.08	18.72	2.16	20.03	2.24	20.97	2.26	22.64	2.30	23.95	2.35
		115	16.95	2.16	18.26	2.24	19.57	2.32	20.52	2.35	22.19	2.39	23.50	2.44
		118	16.68	2.21	17.99	2.29	19.30	2.37	20.24	2.40	21.91	2.44	23.22	2.49
		122	16.59	2.27	17.90	2.35	19.20	2.44	20.15	2.47	21.82	2.51	23.13	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 43: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	23.60	1.27	25.06	1.31	26.53	1.36	27.58	1.38	29.46	1.40	30.92	1.43
		0	23.58	1.28	25.05	1.33	26.51	1.38	27.57	1.39	29.44	1.42	30.91	1.45
		5	23.56	1.30	25.03	1.35	26.49	1.40	27.55	1.42	29.42	1.44	30.88	1.47
		10	23.55	1.32	25.01	1.37	26.47	1.42	27.53	1.44	29.39	1.46	30.86	1.49
		14	23.53	1.34	24.99	1.39	26.45	1.44	27.50	1.46	29.37	1.48	30.83	1.51
		20	23.51	1.36	24.97	1.41	26.43	1.46	27.48	1.48	29.35	1.51	30.81	1.54
		25	23.49	1.38	24.95	1.43	26.41	1.48	27.46	1.50	29.33	1.53	30.79	1.56
		30	23.47	1.40	24.93	1.45	26.39	1.50	27.44	1.52	29.30	1.55	30.76	1.58
		35	23.46	1.42	24.91	1.47	26.37	1.52	27.42	1.54	29.28	1.57	30.74	1.60
		40	23.44	1.44	24.89	1.49	26.35	1.54	27.40	1.56	29.26	1.59	30.72	1.62
		45	23.42	1.46	24.87	1.51	26.33	1.56	27.38	1.58	29.24	1.61	30.69	1.65
		50	23.40	1.48	24.85	1.53	26.31	1.59	27.36	1.60	29.21	1.63	30.67	1.67
		55	23.38	1.50	24.84	1.55	26.29	1.61	27.34	1.62	29.19	1.66	30.64	1.69
		60	23.37	1.51	24.82	1.57	26.27	1.63	27.32	1.65	29.17	1.68	30.62	1.71
		65	23.35	1.53	24.80	1.59	26.25	1.65	27.29	1.67	29.15	1.70	30.60	1.73
		70	23.33	1.55	24.78	1.61	26.23	1.67	27.27	1.69	29.13	1.72	30.57	1.75
		75	22.77	1.64	24.21	1.70	25.66	1.76	26.70	1.78	28.55	1.81	29.99	1.85
		80	22.21	1.72	23.65	1.78	25.09	1.85	26.13	1.87	27.97	1.90	29.42	1.94
		85	21.65	1.80	23.09	1.87	24.53	1.94	25.57	1.96	27.40	2.00	28.84	2.04
		90	21.09	1.89	22.53	1.96	23.96	2.03	25.00	2.05	26.83	2.09	28.27	2.13
		95	20.49	1.97	21.92	2.04	23.35	2.12	24.00	2.14	26.20	2.18	27.63	2.23
		100	19.99	2.06	21.42	2.13	22.85	2.21	23.69	2.23	25.70	2.28	27.13	2.32
		105	19.49	2.14	20.92	2.22	22.35	2.30	23.38	2.32	25.20	2.37	26.63	2.42
		110	18.99	2.22	20.42	2.30	21.85	2.39	22.88	2.42	24.70	2.46	26.13	2.51
		115	18.49	2.31	19.92	2.39	21.35	2.48	22.38	2.51	24.20	2.55	25.63	2.61
		118	18.19	2.36	19.62	2.44	21.05	2.53	22.08	2.56	23.90	2.61	25.33	2.66
		122	18.10	2.42	19.52	2.51	20.95	2.60	21.98	2.63	23.81	2.68	25.23	2.74
	12 + 12	-4	23.60	1.27	25.06	1.31	26.53	1.36	27.58	1.38	29.46	1.40	30.92	1.43
		0	23.58	1.28	25.05	1.33	26.51	1.38	27.57	1.39	29.44	1.42	30.91	1.45
		5	23.56	1.30	25.03	1.35	26.49	1.40	27.55	1.42	29.42	1.44	30.88	1.47
		10	23.55	1.32	25.01	1.37	26.47	1.42	27.53	1.44	29.39	1.46	30.86	1.49
		14	23.53	1.34	24.99	1.39	26.45	1.44	27.50	1.46	29.37	1.48	30.83	1.51
		20	23.51	1.36	24.97	1.41	26.43	1.46	27.48	1.48	29.35	1.51	30.81	1.54
		25	23.49	1.38	24.95	1.43	26.41	1.48	27.46	1.50	29.33	1.53	30.79	1.56
		30	23.47	1.40	24.93	1.45	26.39	1.50	27.44	1.52	29.30	1.55	30.76	1.58
		35	23.46	1.42	24.91	1.47	26.37	1.52	27.42	1.54	29.28	1.57	30.74	1.60
		40	23.44	1.44	24.89	1.49	26.35	1.54	27.40	1.56	29.26	1.59	30.72	1.62
		45	23.42	1.46	24.87	1.51	26.33	1.56	27.38	1.58	29.24	1.61	30.69	1.65
		50	23.40	1.48	24.85	1.53	26.31	1.59	27.36	1.60	29.21	1.63	30.67	1.67
		55	23.38	1.50	24.84	1.55	26.29	1.61	27.34	1.62	29.19	1.66	30.64	1.69
		60	23.37	1.51	24.82	1.57	26.27	1.63	27.32	1.65	29.17	1.68	30.62	1.71
		65	23.35	1.53	24.80	1.59	26.25	1.65	27.29	1.67	29.15	1.70	30.60	1.73
		70	23.33	1.55	24.78	1.61	26.23	1.67	27.27	1.69	29.13	1.72	30.57	1.75
		75	22.77	1.64	24.21	1.70	25.66	1.76	26.70	1.78	28.55	1.81	29.99	1.85
		80	22.21	1.72	23.65	1.78	25.09	1.85	26.13	1.87	27.97	1.90	29.42	1.94
		85	21.65	1.80	23.09	1.87	24.53	1.94	25.57	1.96	27.40	2.00	28.84	2.04
		90	21.09	1.89	22.53	1.96	23.96	2.03	25.00	2.05	26.83	2.09	28.27	2.13
		95	20.49	1.97	21.92	2.04	23.35	2.12	24.00	2.14	26.20	2.18	27.63	2.23
		100	19.99	2.06	21.42	2.13	22.85	2.21	23.69	2.23	25.70	2.28	27.13	2.32
		105	19.49	2.14	20.92	2.22	22.35	2.30	23.38	2.32	25.20	2.37	26.63	2.42
		110	18.99	2.22	20.42	2.30	21.85	2.39	22.88	2.42	24.70	2.46	26.13	2.51
		115	18.49	2.31	19.92	2.39	21.35	2.48	22.38	2.51	24.20	2.55	25.63	2.61
		118	18.19	2.36	19.62	2.44	21.05	2.53	22.08	2.56	23.90	2.61	25.33	2.66
		122	18.10	2.42	19.52	2.51	20.95	2.60	21.98	2.63	23.81	2.68	25.23	2.74

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 44: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 18	-4	24.58	1.31	26.10	1.36	27.63	1.41	28.73	1.43	30.68	1.46	32.21	1.48
		0	24.57	1.33	26.09	1.38	27.62	1.43	28.72	1.44	30.67	1.47	32.19	1.50
		5	24.54	1.35	26.07	1.40	27.59	1.45	28.69	1.47	30.64	1.49	32.17	1.52
		10	24.53	1.37	26.05	1.42	27.57	1.47	28.67	1.49	30.62	1.52	32.14	1.55
		14	24.51	1.39	26.03	1.44	27.55	1.49	28.65	1.51	30.60	1.54	32.12	1.57
		20	24.49	1.41	26.01	1.46	27.53	1.52	28.63	1.53	30.57	1.56	32.09	1.59
		25	24.47	1.43	25.99	1.48	27.51	1.54	28.61	1.55	30.55	1.58	32.07	1.62
		30	24.45	1.45	25.97	1.50	27.49	1.56	28.59	1.58	30.53	1.61	32.04	1.64
		35	24.43	1.47	25.95	1.52	27.47	1.58	28.56	1.60	30.50	1.63	32.02	1.66
		40	24.41	1.49	25.93	1.54	27.45	1.60	28.54	1.62	30.48	1.65	32.00	1.68
		45	24.40	1.51	25.91	1.57	27.43	1.62	28.52	1.64	30.46	1.67	31.97	1.71
		50	24.38	1.53	25.89	1.59	27.40	1.64	28.50	1.66	30.43	1.69	31.95	1.73
		55	24.36	1.55	25.87	1.61	27.38	1.67	28.48	1.68	30.41	1.72	31.92	1.75
		60	24.34	1.57	25.85	1.63	27.36	1.69	28.45	1.71	30.39	1.74	31.90	1.77
		65	24.32	1.59	25.83	1.65	27.34	1.71	28.43	1.73	30.36	1.76	31.87	1.80
		70	24.30	1.61	25.81	1.67	27.32	1.73	28.41	1.75	30.34	1.78	31.85	1.82
		75	23.72	1.70	25.22	1.76	26.73	1.82	27.82	1.84	29.74	1.88	31.24	1.92
		80	23.13	1.78	24.63	1.85	26.14	1.92	27.22	1.94	29.14	1.97	30.64	2.01
		85	22.55	1.87	24.05	1.94	25.55	2.01	26.63	2.03	28.54	2.07	30.04	2.11
		90	21.97	1.96	23.47	2.03	24.96	2.10	26.04	2.13	27.95	2.17	29.44	2.21
		95	21.34	2.04	22.83	2.12	24.32	2.20	25.00	2.22	27.29	2.26	28.78	2.31
		100	20.82	2.13	22.31	2.21	23.80	2.29	24.68	2.32	26.77	2.36	28.26	2.41
		105	20.30	2.22	21.79	2.30	23.28	2.38	24.35	2.41	26.25	2.46	27.74	2.50
		110	19.78	2.30	21.27	2.39	22.76	2.48	23.83	2.50	25.73	2.55	27.22	2.60
		115	19.26	2.39	20.75	2.48	22.24	2.57	23.31	2.60	25.21	2.65	26.70	2.70
		118	18.95	2.44	20.44	2.53	21.93	2.63	23.00	2.66	24.90	2.71	26.39	2.76
		122	18.85	2.51	20.34	2.61	21.82	2.70	22.90	2.73	24.80	2.78	26.28	2.84
	9 + 18	-4	26.54	1.41	28.19	1.46	29.84	1.51	31.03	1.53	33.14	1.56	34.79	1.59
		0	26.53	1.42	28.18	1.47	29.83	1.53	31.02	1.55	33.12	1.58	34.77	1.61
		5	26.51	1.45	28.15	1.50	29.80	1.55	30.99	1.57	33.09	1.60	34.74	1.63
		10	26.49	1.47	28.13	1.52	29.78	1.58	30.97	1.59	33.07	1.62	34.71	1.66
		14	26.47	1.49	28.11	1.54	29.76	1.60	30.94	1.62	33.04	1.65	34.69	1.68
		20	26.45	1.51	28.09	1.57	29.73	1.62	30.92	1.64	33.02	1.67	34.66	1.71
		25	26.43	1.53	28.07	1.59	29.71	1.65	30.90	1.66	32.99	1.70	34.63	1.73
		30	26.41	1.55	28.05	1.61	29.69	1.67	30.87	1.69	32.97	1.72	34.61	1.75
		35	26.39	1.57	28.03	1.63	29.66	1.69	30.85	1.71	32.94	1.74	34.58	1.78
		40	26.37	1.60	28.00	1.65	29.64	1.71	30.82	1.73	32.92	1.77	34.55	1.80
		45	26.35	1.62	27.98	1.68	29.62	1.74	30.80	1.76	32.89	1.79	34.53	1.83
		50	26.33	1.64	27.96	1.70	29.60	1.76	30.78	1.78	32.87	1.81	34.50	1.85
		55	26.31	1.66	27.94	1.72	29.57	1.78	30.75	1.80	32.84	1.84	34.48	1.87
		60	26.29	1.68	27.92	1.74	29.55	1.81	30.73	1.83	32.82	1.86	34.45	1.90
		65	26.27	1.70	27.90	1.76	29.53	1.83	30.71	1.85	32.79	1.88	34.42	1.92
		70	26.25	1.72	27.88	1.79	29.51	1.85	30.68	1.87	32.77	1.91	34.40	1.95
		75	25.61	1.82	27.24	1.88	28.87	1.95	30.04	1.97	32.12	2.01	33.74	2.05
		80	24.98	1.91	26.60	1.98	28.23	2.05	29.40	2.08	31.47	2.11	33.09	2.16
		85	24.36	2.00	25.97	2.08	27.59	2.15	28.76	2.18	30.83	2.22	32.45	2.26
		90	23.73	2.10	25.34	2.17	26.96	2.25	28.12	2.28	30.19	2.32	31.80	2.37
		95	23.05	2.19	24.66	2.27	26.26	2.35	27.00	2.38	29.48	2.42	31.08	2.47
		100	22.49	2.28	24.10	2.37	25.70	2.45	26.65	2.48	28.91	2.53	30.52	2.58
		105	21.93	2.37	23.53	2.46	25.14	2.55	26.30	2.58	28.35	2.63	29.96	2.68
		110	21.37	2.47	22.97	2.56	24.58	2.65	25.74	2.68	27.79	2.73	29.40	2.79
		115	20.81	2.56	22.41	2.65	24.02	2.75	25.18	2.78	27.23	2.84	28.84	2.89
		118	20.47	2.62	22.08	2.71	23.68	2.81	24.84	2.84	26.89	2.90	28.50	2.96
		122	20.36	2.69	21.96	2.79	23.57	2.89	24.73	2.92	26.78	2.98	28.39	3.04

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 45: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	12 + 15	-4	26.54	1.41	28.19	1.46	29.84	1.51	31.03	1.53	33.14	1.56	34.79	1.59
		0	26.53	1.42	28.18	1.47	29.83	1.53	31.02	1.55	33.12	1.58	34.77	1.61
		5	26.51	1.45	28.15	1.50	29.80	1.55	30.99	1.57	33.09	1.60	34.74	1.63
		10	26.49	1.47	28.13	1.52	29.78	1.58	30.97	1.59	33.07	1.62	34.71	1.66
		14	26.47	1.49	28.11	1.54	29.76	1.60	30.94	1.62	33.04	1.65	34.69	1.68
		20	26.45	1.51	28.09	1.57	29.73	1.62	30.92	1.64	33.02	1.67	34.66	1.71
		25	26.43	1.53	28.07	1.59	29.71	1.65	30.90	1.66	32.99	1.70	34.63	1.73
		30	26.41	1.55	28.05	1.61	29.69	1.67	30.87	1.69	32.97	1.72	34.61	1.75
		35	26.39	1.57	28.03	1.63	29.66	1.69	30.85	1.71	32.94	1.74	34.58	1.78
		40	26.37	1.60	28.00	1.65	29.64	1.71	30.82	1.73	32.92	1.77	34.55	1.80
		45	26.35	1.62	27.98	1.68	29.62	1.74	30.80	1.76	32.89	1.79	34.53	1.83
		50	26.33	1.64	27.96	1.70	29.60	1.76	30.78	1.78	32.87	1.81	34.50	1.85
		55	26.31	1.66	27.94	1.72	29.57	1.78	30.75	1.80	32.84	1.84	34.48	1.87
		60	26.29	1.68	27.92	1.74	29.55	1.81	30.73	1.83	32.82	1.86	34.45	1.90
		65	26.27	1.70	27.90	1.76	29.53	1.83	30.71	1.85	32.79	1.88	34.42	1.92
		70	26.25	1.72	27.88	1.79	29.51	1.85	30.68	1.87	32.77	1.91	34.40	1.95
		75	25.61	1.82	27.24	1.88	28.87	1.95	30.04	1.97	32.12	2.01	33.74	2.05
		80	24.98	1.91	26.60	1.98	28.23	2.05	29.40	2.08	31.47	2.11	33.09	2.16
		85	24.36	2.00	25.97	2.08	27.59	2.15	28.76	2.18	30.83	2.22	32.45	2.26
		90	23.73	2.10	25.34	2.17	26.96	2.25	28.12	2.28	30.19	2.32	31.80	2.37
		95	23.05	2.19	24.66	2.27	26.26	2.35	27.00	2.38	29.48	2.42	31.08	2.47
		100	22.49	2.28	24.10	2.37	25.70	2.45	26.65	2.48	28.91	2.53	30.52	2.58
		105	21.93	2.37	23.53	2.46	25.14	2.55	26.30	2.58	28.35	2.63	29.96	2.68
		110	21.37	2.47	22.97	2.56	24.58	2.65	25.74	2.68	27.79	2.73	29.40	2.79
		115	20.81	2.56	22.41	2.65	24.02	2.75	25.18	2.78	27.23	2.84	28.84	2.89
		118	20.47	2.62	22.08	2.71	23.68	2.81	24.84	2.84	26.89	2.90	28.50	2.96
		122	20.36	2.69	21.96	2.79	23.57	2.89	24.73	2.92	26.78	2.98	28.39	3.04
	12 + 18	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 46: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 15	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30
	7 + 24	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 47: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 24	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30
	15 + 18	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 48: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	18 + 18	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30
	12 + 24	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
		105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 49: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 24	-4	29.49	1.53	31.33	1.59	33.16	1.64	34.48	1.66	36.82	1.69	38.65	1.73
		0	29.48	1.55	31.31	1.60	33.14	1.66	34.46	1.68	36.80	1.71	38.63	1.75
		5	29.45	1.57	31.28	1.63	33.11	1.69	34.43	1.71	36.77	1.74	38.60	1.77
		10	29.43	1.59	31.26	1.65	33.09	1.71	34.41	1.73	36.74	1.77	38.57	1.80
		14	29.41	1.62	31.24	1.68	33.06	1.74	34.38	1.76	36.71	1.79	38.54	1.83
		20	29.39	1.64	31.21	1.70	33.04	1.76	34.35	1.78	36.69	1.82	38.51	1.85
		25	29.36	1.66	31.19	1.73	33.01	1.79	34.33	1.81	36.66	1.84	38.48	1.88
		30	29.34	1.69	31.16	1.75	32.99	1.81	34.30	1.83	36.63	1.87	38.45	1.91
		35	29.32	1.71	31.14	1.77	32.96	1.84	34.28	1.86	36.60	1.89	38.42	1.93
		40	29.30	1.73	31.12	1.80	32.94	1.86	34.25	1.88	36.57	1.92	38.39	1.96
		45	29.27	1.76	31.09	1.82	32.91	1.89	34.22	1.91	36.55	1.95	38.36	1.98
		50	29.25	1.78	31.07	1.85	32.89	1.91	34.20	1.93	36.52	1.97	38.34	2.01
		55	29.23	1.80	31.04	1.87	32.86	1.94	34.17	1.96	36.49	2.00	38.31	2.04
		60	29.21	1.83	31.02	1.89	32.83	1.96	34.14	1.99	36.46	2.02	38.28	2.06
		65	29.18	1.85	31.00	1.92	32.81	1.99	34.12	2.01	36.43	2.05	38.25	2.09
		70	29.16	1.87	30.97	1.94	32.78	2.01	34.09	2.04	36.41	2.07	38.22	2.12
		75	28.46	1.97	30.27	2.05	32.07	2.12	33.38	2.15	35.69	2.19	37.49	2.23
		80	27.76	2.08	29.56	2.15	31.36	2.23	32.66	2.26	34.97	2.30	36.77	2.34
		85	27.06	2.18	28.86	2.26	30.66	2.34	31.96	2.37	34.25	2.41	36.05	2.46
		90	26.37	2.28	28.16	2.36	29.95	2.45	31.25	2.48	33.54	2.52	35.33	2.57
		95	25.61	2.38	27.40	2.47	29.18	2.56	30.00	2.59	32.75	2.63	34.53	2.69
		100	24.99	2.48	26.77	2.57	28.56	2.66	29.61	2.70	32.13	2.75	33.91	2.80
Three (3) Non-Ducted Indoor Units	7 + 7 + 7	105	24.37	2.58	26.15	2.68	27.93	2.77	29.22	2.80	31.50	2.86	33.29	2.91
		110	23.74	2.68	25.53	2.78	27.31	2.88	28.60	2.91	30.88	2.97	32.66	3.03
		115	23.12	2.78	24.90	2.88	26.69	2.99	27.98	3.02	30.26	3.08	32.04	3.14
		118	22.74	2.84	24.53	2.95	26.31	3.06	27.60	3.09	29.88	3.15	31.67	3.21
		122	22.62	2.92	24.40	3.03	26.19	3.14	27.48	3.18	29.76	3.24	31.54	3.30
		-4	20.65	1.11	21.93	1.15	23.21	1.19	24.14	1.21	25.77	1.23	27.06	1.25
		0	20.63	1.12	21.92	1.16	23.20	1.21	24.12	1.22	25.76	1.24	27.04	1.27
		5	20.62	1.14	21.90	1.18	23.18	1.23	24.10	1.24	25.74	1.26	27.02	1.29
		10	20.60	1.16	21.88	1.20	23.16	1.24	24.08	1.26	25.72	1.28	27.00	1.31
		14	20.59	1.17	21.86	1.22	23.14	1.26	24.07	1.28	25.70	1.30	26.98	1.33
		20	20.57	1.19	21.85	1.24	23.13	1.28	24.05	1.30	25.68	1.32	26.96	1.35
		25	20.55	1.21	21.83	1.25	23.11	1.30	24.03	1.31	25.66	1.34	26.94	1.37
		30	20.54	1.23	21.81	1.27	23.09	1.32	24.01	1.33	25.64	1.36	26.92	1.38
		35	20.52	1.24	21.80	1.29	23.07	1.33	23.99	1.35	25.62	1.38	26.90	1.40
		40	20.51	1.26	21.78	1.31	23.05	1.35	23.97	1.37	25.60	1.39	26.88	1.42
		45	20.49	1.28	21.76	1.32	23.04	1.37	23.96	1.39	25.58	1.41	26.86	1.44
		50	20.48	1.29	21.75	1.34	23.02	1.39	23.94	1.41	25.56	1.43	26.83	1.46
		55	20.46	1.31	21.73	1.36	23.00	1.41	23.92	1.42	25.54	1.45	26.81	1.48
		60	20.44	1.33	21.71	1.38	22.98	1.43	23.90	1.44	25.52	1.47	26.79	1.50
		65	20.43	1.34	21.70	1.39	22.97	1.44	23.88	1.46	25.50	1.49	26.77	1.52
		70	20.41	1.36	21.68	1.41	22.95	1.46	23.86	1.48	25.48	1.51	26.75	1.54
		75	19.92	1.43	21.19	1.49	22.45	1.54	23.36	1.56	24.98	1.59	26.25	1.62
		80	19.43	1.51	20.69	1.56	21.95	1.62	22.87	1.64	24.48	1.67	25.74	1.70
		85	18.94	1.58	20.20	1.64	21.46	1.70	22.37	1.72	23.98	1.75	25.24	1.79
		90	18.46	1.65	19.71	1.71	20.97	1.78	21.87	1.80	23.48	1.83	24.73	1.87
		95	17.93	1.73	19.18	1.79	20.43	1.86	21.00	1.88	22.93	1.91	24.17	1.95
		100	17.49	1.80	18.74	1.87	19.99	1.93	20.73	1.96	22.49	1.99	23.74	2.03
		105	17.06	1.87	18.30	1.94	19.55	2.01	20.46	2.04	22.05	2.08	23.30	2.12
		110	16.62	1.95	17.87	2.02	19.12	2.09	20.02	2.12	21.62	2.16	22.86	2.20
		115	16.18	2.02	17.43	2.10	18.68	2.17	19.58	2.20	21.18	2.24	22.43	2.28
		118	15.92	2.07	17.17	2.14	18.42	2.22	19.32	2.24	20.92	2.29	22.17	2.33
		122	15.83	2.12	17.08	2.20	18.33	2.28	19.23	2.31	20.83	2.35	22.08	2.40

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 50: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 9	-4	22.61	1.20	24.02	1.24	25.42	1.29	26.44	1.30	28.23	1.33	29.63	1.35
		0	22.60	1.21	24.00	1.26	25.41	1.30	26.42	1.32	28.21	1.34	29.62	1.37
		5	22.58	1.23	23.98	1.28	25.39	1.32	26.40	1.34	28.19	1.36	29.59	1.39
		10	22.56	1.25	23.97	1.29	25.37	1.34	26.38	1.36	28.17	1.38	29.57	1.41
		14	22.55	1.27	23.95	1.31	25.35	1.36	26.36	1.38	28.15	1.40	29.55	1.43
		20	22.53	1.29	23.93	1.33	25.33	1.38	26.34	1.40	28.13	1.42	29.53	1.45
		25	22.51	1.30	23.91	1.35	25.31	1.40	26.32	1.42	28.10	1.44	29.50	1.47
		30	22.50	1.32	23.89	1.37	25.29	1.42	26.30	1.44	28.08	1.46	29.48	1.49
		35	22.48	1.34	23.87	1.39	25.27	1.44	26.28	1.46	28.06	1.48	29.46	1.51
		40	22.46	1.36	23.86	1.41	25.25	1.46	26.26	1.48	28.04	1.50	29.44	1.53
		45	22.44	1.38	23.84	1.43	25.23	1.48	26.24	1.50	28.02	1.52	29.41	1.55
		50	22.43	1.39	23.82	1.45	25.21	1.50	26.22	1.52	28.00	1.54	29.39	1.58
		55	22.41	1.41	23.80	1.46	25.19	1.52	26.20	1.54	27.98	1.56	29.37	1.60
		60	22.39	1.43	23.78	1.48	25.17	1.54	26.18	1.56	27.95	1.58	29.35	1.62
		65	22.37	1.45	23.76	1.50	25.15	1.56	26.16	1.57	27.93	1.60	29.32	1.64
		70	22.36	1.47	23.75	1.52	25.13	1.58	26.14	1.59	27.91	1.62	29.30	1.66
		75	21.82	1.55	23.20	1.60	24.59	1.66	25.59	1.68	27.36	1.71	28.75	1.75
		80	21.28	1.63	22.66	1.69	24.04	1.75	25.04	1.77	26.81	1.80	28.19	1.84
		85	20.75	1.70	22.13	1.77	23.50	1.83	24.50	1.85	26.26	1.89	27.64	1.93
		90	20.22	1.78	21.59	1.85	22.96	1.92	23.96	1.94	25.71	1.98	27.09	2.01
		95	19.64	1.86	21.00	1.93	22.37	2.00	23.00	2.02	25.11	2.06	26.48	2.10
		100	19.16	1.94	20.53	2.01	21.89	2.09	22.70	2.11	24.63	2.15	26.00	2.19
		105	18.68	2.02	20.05	2.10	21.42	2.17	22.40	2.20	24.15	2.24	25.52	2.28
		110	18.20	2.10	19.57	2.18	20.94	2.26	21.93	2.28	23.67	2.33	25.04	2.37
		115	17.72	2.18	19.09	2.26	20.46	2.34	21.45	2.37	23.20	2.41	24.56	2.46
		118	17.44	2.23	18.80	2.31	20.17	2.39	21.16	2.42	22.91	2.47	24.28	2.52
		122	17.34	2.29	18.71	2.37	20.08	2.46	21.07	2.49	22.81	2.54	24.18	2.59
	7 + 9 + 9	-4	24.58	1.29	26.10	1.34	27.63	1.39	28.73	1.40	30.68	1.43	32.21	1.46
		0	24.57	1.31	26.09	1.35	27.62	1.40	28.72	1.42	30.67	1.44	32.19	1.47
		5	24.54	1.33	26.07	1.37	27.59	1.43	28.69	1.44	30.64	1.47	32.17	1.50
		10	24.53	1.35	26.05	1.40	27.57	1.45	28.67	1.46	30.62	1.49	32.14	1.52
		14	24.51	1.37	26.03	1.42	27.55	1.47	28.65	1.48	30.60	1.51	32.12	1.54
		20	24.49	1.39	26.01	1.44	27.53	1.49	28.63	1.51	30.57	1.53	32.09	1.56
		25	24.47	1.40	25.99	1.46	27.51	1.51	28.61	1.53	30.55	1.56	32.07	1.59
		30	24.45	1.42	25.97	1.48	27.49	1.53	28.59	1.55	30.53	1.58	32.04	1.61
		35	24.43	1.44	25.95	1.50	27.47	1.55	28.56	1.57	30.50	1.60	32.02	1.63
		40	24.41	1.46	25.93	1.52	27.45	1.57	28.54	1.59	30.48	1.62	32.00	1.65
		45	24.40	1.48	25.91	1.54	27.43	1.59	28.52	1.61	30.46	1.64	31.97	1.68
		50	24.38	1.50	25.89	1.56	27.40	1.61	28.50	1.63	30.43	1.66	31.95	1.70
		55	24.36	1.52	25.87	1.58	27.38	1.64	28.48	1.65	30.41	1.69	31.92	1.72
		60	24.34	1.54	25.85	1.60	27.36	1.66	28.45	1.68	30.39	1.71	31.90	1.74
		65	24.32	1.56	25.83	1.62	27.34	1.68	28.43	1.70	30.36	1.73	31.87	1.76
		70	24.30	1.58	25.81	1.64	27.32	1.70	28.41	1.72	30.34	1.75	31.85	1.79
		75	23.72	1.67	25.22	1.73	26.73	1.79	27.82	1.81	29.74	1.85	31.24	1.88
		80	23.13	1.75	24.63	1.82	26.14	1.88	27.22	1.90	29.14	1.94	30.64	1.98
		85	22.55	1.84	24.05	1.90	25.55	1.97	26.63	2.00	28.54	2.03	30.04	2.08
		90	21.97	1.92	23.47	1.99	24.96	2.07	26.04	2.09	27.95	2.13	29.44	2.17
		95	21.34	2.01	22.83	2.08	24.32	2.16	25.00	2.18	27.29	2.22	28.78	2.27
		100	20.82	2.09	22.31	2.17	23.80	2.25	24.68	2.27	26.77	2.32	28.26	2.36
		105	20.30	2.18	21.79	2.26	23.28	2.34	24.35	2.37	26.25	2.41	27.74	2.46
		110	19.78	2.26	21.27	2.35	22.76	2.43	23.83	2.46	25.73	2.51	27.22	2.56
		115	19.26	2.35	20.75	2.44	22.24	2.52	23.31	2.55	25.21	2.60	26.70	2.65
		118	18.95	2.40	20.44	2.49	21.93	2.58	23.00	2.61	24.90	2.66	26.39	2.71
		122	18.85	2.47	20.34	2.56	21.82	2.65	22.90	2.68	24.80	2.73	26.28	2.79

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 51: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 12	-4	25.56	1.31	27.15	1.36	28.74	1.41	29.88	1.43	31.91	1.46	33.50	1.48
		0	25.55	1.33	27.13	1.38	28.72	1.43	29.87	1.44	31.89	1.47	33.48	1.50
		5	25.53	1.35	27.11	1.40	28.70	1.45	29.84	1.47	31.87	1.49	33.45	1.52
		10	25.51	1.37	27.09	1.42	28.68	1.47	29.82	1.49	31.84	1.52	33.43	1.55
		14	25.49	1.39	27.07	1.44	28.65	1.49	29.80	1.51	31.82	1.54	33.40	1.57
		20	25.47	1.41	27.05	1.46	28.63	1.52	29.77	1.53	31.80	1.56	33.38	1.59
		25	25.45	1.43	27.03	1.48	28.61	1.54	29.75	1.55	31.77	1.58	33.35	1.62
		30	25.43	1.45	27.01	1.50	28.59	1.56	29.73	1.58	31.75	1.61	33.33	1.64
		35	25.41	1.47	26.99	1.52	28.57	1.58	29.71	1.60	31.72	1.63	33.30	1.66
		40	25.39	1.49	26.97	1.54	28.54	1.60	29.68	1.62	31.70	1.65	33.27	1.68
		45	25.37	1.51	26.95	1.57	28.52	1.62	29.66	1.64	31.67	1.67	33.25	1.71
		50	25.35	1.53	26.93	1.59	28.50	1.64	29.64	1.66	31.65	1.69	33.22	1.73
		55	25.33	1.55	26.91	1.61	28.48	1.67	29.61	1.68	31.63	1.72	33.20	1.75
		60	25.31	1.57	26.88	1.63	28.46	1.69	29.59	1.71	31.60	1.74	33.17	1.77
		65	25.29	1.59	26.86	1.65	28.43	1.71	29.57	1.73	31.58	1.76	33.15	1.80
		70	25.27	1.61	26.84	1.67	28.41	1.73	29.55	1.75	31.55	1.78	33.12	1.82
		75	24.67	1.70	26.23	1.76	27.80	1.82	28.93	1.84	30.93	1.88	32.49	1.92
		80	24.06	1.78	25.62	1.85	27.18	1.92	28.31	1.94	30.31	1.97	31.87	2.01
		85	23.45	1.87	25.01	1.94	26.57	2.01	27.70	2.03	29.69	2.07	31.24	2.11
		90	22.85	1.96	24.41	2.03	25.96	2.10	27.08	2.13	29.07	2.17	30.62	2.21
		95	22.20	2.04	23.74	2.12	25.29	2.20	26.00	2.22	28.38	2.26	29.93	2.31
		100	21.66	2.13	23.20	2.21	24.75	2.29	25.66	2.32	27.84	2.36	29.39	2.41
		105	21.12	2.22	22.66	2.30	24.21	2.38	25.33	2.41	27.30	2.46	28.85	2.50
		110	20.58	2.30	22.12	2.39	23.67	2.48	24.79	2.50	26.76	2.55	28.31	2.60
		115	20.04	2.39	21.58	2.48	23.13	2.57	24.25	2.60	26.22	2.65	27.77	2.70
		118	19.71	2.44	21.26	2.53	22.80	2.63	23.92	2.66	25.90	2.71	27.44	2.76
		122	19.60	2.51	21.15	2.61	22.70	2.70	23.81	2.73	25.79	2.78	27.34	2.84
	9 + 9 + 9	-4	26.54	1.34	28.19	1.39	29.84	1.44	31.03	1.45	33.14	1.48	34.79	1.51
		0	26.53	1.35	28.18	1.40	29.83	1.45	31.02	1.47	33.12	1.50	34.77	1.53
		5	26.51	1.37	28.15	1.42	29.80	1.48	30.99	1.49	33.09	1.52	34.74	1.55
		10	26.49	1.39	28.13	1.45	29.78	1.50	30.97	1.52	33.07	1.54	34.71	1.57
		14	26.47	1.41	28.11	1.47	29.76	1.52	30.94	1.54	33.04	1.57	34.69	1.60
		20	26.45	1.44	28.09	1.49	29.73	1.54	30.92	1.56	33.02	1.59	34.66	1.62
		25	26.43	1.46	28.07	1.51	29.71	1.56	30.90	1.58	32.99	1.61	34.63	1.64
		30	26.41	1.48	28.05	1.53	29.69	1.59	30.87	1.60	32.97	1.63	34.61	1.67
		35	26.39	1.50	28.03	1.55	29.66	1.61	30.85	1.63	32.94	1.66	34.58	1.69
		40	26.37	1.52	28.00	1.57	29.64	1.63	30.82	1.65	32.92	1.68	34.55	1.71
		45	26.35	1.54	27.98	1.59	29.62	1.65	30.80	1.67	32.89	1.70	34.53	1.74
		50	26.33	1.56	27.96	1.61	29.60	1.67	30.78	1.69	32.87	1.72	34.50	1.76
		55	26.31	1.58	27.94	1.64	29.57	1.69	30.75	1.71	32.84	1.75	34.48	1.78
		60	26.29	1.60	27.92	1.66	29.55	1.72	30.73	1.74	32.82	1.77	34.45	1.80
		65	26.27	1.62	27.90	1.68	29.53	1.74	30.71	1.76	32.79	1.79	34.42	1.83
		70	26.25	1.64	27.88	1.70	29.51	1.76	30.68	1.78	32.77	1.81	34.40	1.85
		75	25.61	1.73	27.24	1.79	28.87	1.86	30.04	1.88	32.12	1.91	33.74	1.95
		80	24.98	1.82	26.60	1.88	28.23	1.95	29.40	1.97	31.47	2.01	33.09	2.05
		85	24.36	1.90	25.97	1.97	27.59	2.05	28.76	2.07	30.83	2.11	32.45	2.15
		90	23.73	1.99	25.34	2.06	26.96	2.14	28.12	2.16	30.19	2.21	31.80	2.25
		95	23.05	2.08	24.66	2.16	26.26	2.24	27.00	2.26	29.48	2.30	31.08	2.35
		100	22.49	2.17	24.10	2.25	25.70	2.33	26.65	2.36	28.91	2.40	30.52	2.45
		105	21.93	2.26	23.53	2.34	25.14	2.43	26.30	2.45	28.35	2.50	29.96	2.55
		110	21.37	2.35	22.97	2.43	24.58	2.52	25.74	2.55	27.79	2.60	29.40	2.65
		115	20.81	2.43	22.41	2.52	24.02	2.61	25.18	2.65	27.23	2.69	28.84	2.75
		118	20.47	2.49	22.08	2.58	23.68	2.67	24.84	2.70	26.89	2.75	28.50	2.81
		122	20.36	2.56	21.96	2.65	23.57	2.75	24.73	2.78	26.78	2.83	28.39	2.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 52: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 12	-4	27.53	1.37	29.24	1.42	30.95	1.47	32.18	1.49	34.37	1.51	36.08	1.54
		0	27.51	1.38	29.22	1.43	30.93	1.48	32.16	1.50	34.35	1.53	36.06	1.56
		5	27.49	1.40	29.20	1.46	30.90	1.51	32.14	1.53	34.32	1.55	36.03	1.59
		10	27.47	1.42	29.18	1.48	30.88	1.53	32.11	1.55	34.29	1.58	36.00	1.61
		14	27.45	1.45	29.15	1.50	30.86	1.55	32.09	1.57	34.27	1.60	35.97	1.63
		20	27.43	1.47	29.13	1.52	30.83	1.58	32.06	1.59	34.24	1.62	35.94	1.66
		25	27.41	1.49	29.11	1.54	30.81	1.60	32.04	1.62	34.21	1.65	35.92	1.68
		30	27.39	1.51	29.09	1.56	30.79	1.62	32.02	1.64	34.19	1.67	35.89	1.70
		35	27.36	1.53	29.06	1.58	30.76	1.64	31.99	1.66	34.16	1.69	35.86	1.73
		40	27.34	1.55	29.04	1.61	30.74	1.66	31.97	1.68	34.14	1.72	35.83	1.75
		45	27.32	1.57	29.02	1.63	30.72	1.69	31.94	1.71	34.11	1.74	35.81	1.77
		50	27.30	1.59	29.00	1.65	30.69	1.71	31.92	1.73	34.08	1.76	35.78	1.80
		55	27.28	1.61	28.98	1.67	30.67	1.73	31.89	1.75	34.06	1.78	35.75	1.82
		60	27.26	1.63	28.95	1.69	30.65	1.75	31.87	1.77	34.03	1.81	35.72	1.84
		65	27.24	1.65	28.93	1.71	30.62	1.78	31.84	1.80	34.01	1.83	35.70	1.87
		70	27.22	1.67	28.91	1.74	30.60	1.80	31.82	1.82	33.98	1.85	35.67	1.89
		75	26.56	1.76	28.25	1.83	29.94	1.90	31.15	1.92	33.31	1.95	34.99	1.99
		80	25.91	1.85	27.59	1.92	29.27	1.99	30.49	2.02	32.64	2.05	34.32	2.09
		85	25.26	1.95	26.94	2.02	28.61	2.09	29.83	2.11	31.97	2.15	33.65	2.20
		90	24.61	2.04	26.28	2.11	27.96	2.19	29.17	2.21	31.30	2.25	32.98	2.30
		95	23.91	2.13	25.57	2.20	27.24	2.28	28.00	2.31	30.57	2.35	32.23	2.40
		100	23.32	2.22	24.99	2.30	26.65	2.38	27.64	2.41	29.98	2.45	31.65	2.50
		105	22.74	2.31	24.41	2.39	26.07	2.48	27.27	2.51	29.40	2.55	31.07	2.60
		110	22.16	2.40	23.82	2.48	25.49	2.57	26.69	2.60	28.82	2.65	30.49	2.71
		115	21.58	2.49	23.24	2.58	24.91	2.67	26.11	2.70	28.24	2.75	29.90	2.81
		118	21.23	2.54	22.89	2.63	24.56	2.73	25.76	2.76	27.89	2.81	29.55	2.87
		122	21.11	2.61	22.78	2.71	24.44	2.81	25.64	2.84	27.77	2.89	29.44	2.95
	7 + 7 + 15	-4	28.51	1.40	30.28	1.45	32.05	1.50	33.33	1.52	35.59	1.55	37.36	1.58
		0	28.50	1.41	30.27	1.46	32.03	1.52	33.31	1.53	35.57	1.56	37.34	1.59
		5	28.47	1.43	30.24	1.49	32.01	1.54	33.29	1.56	35.54	1.59	37.31	1.62
		10	28.45	1.46	30.22	1.51	31.98	1.56	33.26	1.58	35.52	1.61	37.28	1.64
		14	28.43	1.48	30.19	1.53	31.96	1.59	33.23	1.60	35.49	1.63	37.26	1.67
		20	28.41	1.50	30.17	1.55	31.94	1.61	33.21	1.63	35.46	1.66	37.23	1.69
		25	28.39	1.52	30.15	1.57	31.91	1.63	33.18	1.65	35.44	1.68	37.20	1.72
		30	28.36	1.54	30.13	1.60	31.89	1.65	33.16	1.67	35.41	1.70	37.17	1.74
		35	28.34	1.56	30.10	1.62	31.86	1.68	33.13	1.70	35.38	1.73	37.14	1.76
		40	28.32	1.58	30.08	1.64	31.84	1.70	33.11	1.72	35.36	1.75	37.11	1.79
		45	28.30	1.60	30.06	1.66	31.81	1.72	33.08	1.74	35.33	1.78	37.09	1.81
		50	28.28	1.62	30.03	1.68	31.79	1.75	33.06	1.77	35.30	1.80	37.06	1.84
		55	28.26	1.65	30.01	1.71	31.76	1.77	33.03	1.79	35.27	1.82	37.03	1.86
		60	28.23	1.67	29.99	1.73	31.74	1.79	33.01	1.81	35.25	1.85	37.00	1.88
		65	28.21	1.69	29.96	1.75	31.72	1.81	32.98	1.83	35.22	1.87	36.97	1.91
		70	28.19	1.71	29.94	1.77	31.69	1.84	32.96	1.86	35.19	1.89	36.94	1.93
		75	27.51	1.80	29.26	1.87	31.00	1.94	32.27	1.96	34.50	1.99	36.24	2.04
		80	26.83	1.89	28.58	1.96	30.32	2.03	31.58	2.06	33.80	2.10	35.54	2.14
		85	26.16	1.99	27.90	2.06	29.64	2.13	30.89	2.16	33.11	2.20	34.85	2.24
		90	25.49	2.08	27.22	2.15	28.96	2.23	30.21	2.26	32.42	2.30	34.16	2.35
		95	24.76	2.17	26.48	2.25	28.21	2.33	29.00	2.36	31.66	2.40	33.38	2.45
		100	24.16	2.26	25.88	2.35	27.61	2.43	28.62	2.46	31.06	2.51	32.78	2.56
		105	23.55	2.36	25.28	2.44	27.00	2.53	28.25	2.56	30.45	2.61	32.18	2.66
		110	22.95	2.45	24.68	2.54	26.40	2.63	27.65	2.66	29.85	2.71	31.57	2.76
		115	22.35	2.54	24.07	2.63	25.80	2.73	27.04	2.76	29.25	2.81	30.97	2.87
		118	21.99	2.60	23.71	2.69	25.44	2.79	26.68	2.82	28.88	2.87	30.61	2.93
		122	21.86	2.67	23.59	2.77	25.31	2.87	26.56	2.90	28.76	2.95	30.49	3.01

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 53: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 12	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	7 + 9 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 54: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 12 + 12	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	7 + 7 + 18	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 55: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	9 + 12 + 12	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 56: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 18	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	7 + 12 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 57: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 18	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	9 + 12 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 58: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 12 + 12	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	7 + 12 + 18	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 59: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 15 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	7 + 7 + 24	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 60: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 12 + 18	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	9 + 15 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 61: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 12 + 15	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
	7 + 9 + 24	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 62: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 15 + 18	-4	29.49	1.43	31.33	1.48	33.16	1.54	34.48	1.55	36.82	1.58	38.65	1.62
		0	29.48	1.45	31.31	1.50	33.14	1.55	34.46	1.57	36.80	1.60	38.63	1.63
		5	29.45	1.47	31.28	1.52	33.11	1.58	34.43	1.60	36.77	1.63	38.60	1.66
		10	29.43	1.49	31.26	1.55	33.09	1.60	34.41	1.62	36.74	1.65	38.57	1.68
		14	29.41	1.51	31.24	1.57	33.06	1.63	34.38	1.64	36.71	1.68	38.54	1.71
		20	29.39	1.54	31.21	1.59	33.04	1.65	34.35	1.67	36.69	1.70	38.51	1.73
		25	29.36	1.56	31.19	1.61	33.01	1.67	34.33	1.69	36.66	1.72	38.48	1.76
		30	29.34	1.58	31.16	1.64	32.99	1.70	34.30	1.72	36.63	1.75	38.45	1.78
		35	29.32	1.60	31.14	1.66	32.96	1.72	34.28	1.74	36.60	1.77	38.42	1.81
		40	29.30	1.62	31.12	1.68	32.94	1.74	34.25	1.76	36.57	1.80	38.39	1.83
		45	29.27	1.64	31.09	1.70	32.91	1.77	34.22	1.79	36.55	1.82	38.36	1.86
		50	29.25	1.67	31.07	1.73	32.89	1.79	34.20	1.81	36.52	1.84	38.34	1.88
		55	29.23	1.69	31.04	1.75	32.86	1.81	34.17	1.83	36.49	1.87	38.31	1.91
		60	29.21	1.71	31.02	1.77	32.83	1.84	34.14	1.86	36.46	1.89	38.28	1.93
		65	29.18	1.73	31.00	1.79	32.81	1.86	34.12	1.88	36.43	1.92	38.25	1.95
		70	29.16	1.75	30.97	1.82	32.78	1.88	34.09	1.90	36.41	1.94	38.22	1.98
		75	28.46	1.85	30.27	1.91	32.07	1.98	33.38	2.01	35.69	2.04	37.49	2.09
		80	27.76	1.94	29.56	2.01	31.36	2.09	32.66	2.11	34.97	2.15	36.77	2.19
		85	27.06	2.04	28.86	2.11	30.66	2.19	31.96	2.21	34.25	2.25	36.05	2.30
		90	26.37	2.13	28.16	2.21	29.95	2.29	31.25	2.32	33.54	2.36	35.33	2.41
		95	25.61	2.23	27.40	2.31	29.18	2.39	30.00	2.42	32.75	2.46	34.53	2.51
		100	24.99	2.32	26.77	2.40	28.56	2.49	29.61	2.52	32.13	2.57	33.91	2.62
		105	24.37	2.41	26.15	2.50	27.93	2.59	29.22	2.62	31.50	2.67	33.29	2.73
		110	23.74	2.51	25.53	2.60	27.31	2.70	28.60	2.73	30.88	2.78	32.66	2.83
		115	23.12	2.60	24.90	2.70	26.69	2.80	27.98	2.83	30.26	2.88	32.04	2.94
		118	22.74	2.66	24.53	2.76	26.31	2.86	27.60	2.89	29.88	2.94	31.67	3.00
		122	22.62	2.74	24.40	2.84	26.19	2.94	27.48	2.97	29.76	3.03	31.54	3.09
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 7	-4	27.53	1.28	29.24	1.33	30.95	1.37	32.18	1.39	34.37	1.42	36.08	1.44
		0	27.51	1.29	29.22	1.34	30.93	1.39	32.16	1.41	34.35	1.43	36.06	1.46
		5	27.49	1.31	29.20	1.36	30.90	1.41	32.14	1.43	34.32	1.46	36.03	1.48
		10	27.47	1.33	29.18	1.38	30.88	1.43	32.11	1.45	34.29	1.48	36.00	1.51
		14	27.45	1.35	29.15	1.40	30.86	1.45	32.09	1.47	34.27	1.50	35.97	1.53
		20	27.43	1.37	29.13	1.42	30.83	1.47	32.06	1.49	34.24	1.52	35.94	1.55
		25	27.41	1.39	29.11	1.44	30.81	1.50	32.04	1.51	34.21	1.54	35.92	1.57
		30	27.39	1.41	29.09	1.46	30.79	1.52	32.02	1.53	34.19	1.56	35.89	1.59
		35	27.36	1.43	29.06	1.48	30.76	1.54	31.99	1.56	34.16	1.58	35.86	1.62
		40	27.34	1.45	29.04	1.50	30.74	1.56	31.97	1.58	34.14	1.61	35.83	1.64
		45	27.32	1.47	29.02	1.52	30.72	1.58	31.94	1.60	34.11	1.63	35.81	1.66
		50	27.30	1.49	29.00	1.54	30.69	1.60	31.92	1.62	34.08	1.65	35.78	1.68
		55	27.28	1.51	28.98	1.56	30.67	1.62	31.89	1.64	34.06	1.67	35.75	1.70
		60	27.26	1.53	28.95	1.58	30.65	1.64	31.87	1.66	34.03	1.69	35.72	1.73
		65	27.24	1.55	28.93	1.60	30.62	1.66	31.84	1.68	34.01	1.71	35.70	1.75
		70	27.22	1.57	28.91	1.62	30.60	1.68	31.82	1.70	33.98	1.74	35.67	1.77
		75	26.56	1.65	28.25	1.71	29.94	1.77	31.15	1.80	33.31	1.83	34.99	1.87
		80	25.91	1.74	27.59	1.80	29.27	1.87	30.49	1.89	32.64	1.92	34.32	1.96
		85	25.26	1.82	26.94	1.89	28.61	1.96	29.83	1.98	31.97	2.02	33.65	2.06
		90	24.61	1.91	26.28	1.97	27.96	2.05	29.17	2.07	31.30	2.11	32.98	2.15
		95	23.91	1.99	25.57	2.06	27.24	2.14	28.00	2.16	30.57	2.20	32.23	2.25
		100	23.32	2.07	24.99	2.15	26.65	2.23	27.64	2.25	29.98	2.30	31.65	2.34
		105	22.74	2.16	24.41	2.24	26.07	2.32	27.27	2.35	29.40	2.39	31.07	2.44
		110	22.16	2.24	23.82	2.33	25.49	2.41	26.69	2.44	28.82	2.48	30.49	2.53
		115	21.58	2.33	23.24	2.41	24.91	2.50	26.11	2.53	28.24	2.58	29.90	2.63
		118	21.23	2.38	22.89	2.47	24.56	2.56	25.76	2.59	27.89	2.63	29.55	2.69
		122	21.11	2.45	22.78	2.54	24.44	2.63	25.64	2.66	27.77	2.71	29.44	2.76

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 63: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 9	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	7 + 7 + 9 + 9	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 64: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 12	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	7 + 9 + 9 + 9	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 65: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 9 + 12	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	7 + 7 + 7 + 15	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 66: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 9 + 9	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	7 + 9 + 9 + 12	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 67: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 9 + 15	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	7 + 7 + 12 + 12	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 68: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 18	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	9 + 9 + 9 + 12	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 69: LMU30CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 9 + 15	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95
	7 + 9 + 12 + 12	-4	29.49	1.37	31.33	1.42	33.16	1.47	34.48	1.49	36.82	1.51	38.65	1.54
		0	29.48	1.38	31.31	1.43	33.14	1.48	34.46	1.50	36.80	1.53	38.63	1.56
		5	29.45	1.40	31.28	1.46	33.11	1.51	34.43	1.53	36.77	1.55	38.60	1.59
		10	29.43	1.42	31.26	1.48	33.09	1.53	34.41	1.55	36.74	1.58	38.57	1.61
		14	29.41	1.45	31.24	1.50	33.06	1.55	34.38	1.57	36.71	1.60	38.54	1.63
		20	29.39	1.47	31.21	1.52	33.04	1.58	34.35	1.59	36.69	1.62	38.51	1.66
		25	29.36	1.49	31.19	1.54	33.01	1.60	34.33	1.62	36.66	1.65	38.48	1.68
		30	29.34	1.51	31.16	1.56	32.99	1.62	34.30	1.64	36.63	1.67	38.45	1.70
		35	29.32	1.53	31.14	1.58	32.96	1.64	34.28	1.66	36.60	1.69	38.42	1.73
		40	29.30	1.55	31.12	1.61	32.94	1.66	34.25	1.68	36.57	1.72	38.39	1.75
		45	29.27	1.57	31.09	1.63	32.91	1.69	34.22	1.71	36.55	1.74	38.36	1.77
		50	29.25	1.59	31.07	1.65	32.89	1.71	34.20	1.73	36.52	1.76	38.34	1.80
		55	29.23	1.61	31.04	1.67	32.86	1.73	34.17	1.75	36.49	1.78	38.31	1.82
		60	29.21	1.63	31.02	1.69	32.83	1.75	34.14	1.77	36.46	1.81	38.28	1.84
		65	29.18	1.65	31.00	1.71	32.81	1.78	34.12	1.80	36.43	1.83	38.25	1.87
		70	29.16	1.67	30.97	1.74	32.78	1.80	34.09	1.82	36.41	1.85	38.22	1.89
		75	28.46	1.76	30.27	1.83	32.07	1.90	33.38	1.92	35.69	1.95	37.49	1.99
		80	27.76	1.85	29.56	1.92	31.36	1.99	32.66	2.02	34.97	2.05	36.77	2.09
		85	27.06	1.95	28.86	2.02	30.66	2.09	31.96	2.11	34.25	2.15	36.05	2.20
		90	26.37	2.04	28.16	2.11	29.95	2.19	31.25	2.21	33.54	2.25	35.33	2.30
		95	25.61	2.13	27.40	2.20	29.18	2.28	30.00	2.31	32.75	2.35	34.53	2.40
		100	24.99	2.22	26.77	2.30	28.56	2.38	29.61	2.41	32.13	2.45	33.91	2.50
		105	24.37	2.31	26.15	2.39	27.93	2.48	29.22	2.51	31.50	2.55	33.29	2.60
		110	23.74	2.40	25.53	2.48	27.31	2.57	28.60	2.60	30.88	2.65	32.66	2.71
		115	23.12	2.49	24.90	2.58	26.69	2.67	27.98	2.70	30.26	2.75	32.04	2.81
		118	22.74	2.54	24.53	2.63	26.31	2.73	27.60	2.76	29.88	2.81	31.67	2.87
		122	22.62	2.61	24.40	2.71	26.19	2.81	27.48	2.84	29.76	2.89	31.54	2.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 70: LMU30CHV Cooling Capacity Table —Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 9	-4	15.36	1.08	16.31	1.12	17.26	1.16	17.95	1.17	19.17	1.19	20.13	1.22
		0	15.35	1.09	16.30	1.13	17.25	1.17	17.94	1.18	19.16	1.21	20.11	1.23
		5	15.34	1.11	16.29	1.15	17.24	1.19	17.93	1.20	19.15	1.22	20.10	1.25
		10	15.32	1.12	16.28	1.16	17.23	1.21	17.91	1.22	19.13	1.24	20.08	1.27
		14	15.31	1.14	16.26	1.18	17.21	1.22	17.90	1.24	19.12	1.26	20.07	1.29
		20	15.30	1.16	16.25	1.20	17.20	1.24	17.89	1.26	19.10	1.28	20.05	1.30
		25	15.29	1.17	16.24	1.21	17.19	1.26	17.87	1.27	19.09	1.30	20.04	1.32
		30	15.28	1.19	16.23	1.23	17.17	1.28	17.86	1.29	19.07	1.32	20.02	1.34
		35	15.27	1.20	16.21	1.25	17.16	1.29	17.85	1.31	19.06	1.33	20.01	1.36
		40	15.25	1.22	16.20	1.27	17.15	1.31	17.83	1.33	19.04	1.35	19.99	1.38
		45	15.24	1.24	16.19	1.28	17.14	1.33	17.82	1.34	19.03	1.37	19.98	1.40
		50	15.23	1.25	16.18	1.30	17.12	1.35	17.81	1.36	19.01	1.39	19.96	1.42
		55	15.22	1.27	16.16	1.32	17.11	1.36	17.79	1.38	19.00	1.41	19.94	1.43
		60	15.21	1.29	16.15	1.33	17.10	1.38	17.78	1.40	18.98	1.42	19.93	1.45
		65	15.20	1.30	16.14	1.35	17.08	1.40	17.76	1.42	18.97	1.44	19.91	1.47
		70	15.18	1.32	16.13	1.37	17.07	1.42	17.75	1.43	18.96	1.46	19.90	1.49
		75	14.82	1.39	15.76	1.44	16.70	1.49	17.38	1.51	18.58	1.54	19.52	1.57
		80	14.45	1.46	15.39	1.51	16.33	1.57	17.01	1.59	18.21	1.62	19.14	1.65
		85	14.09	1.53	15.03	1.59	15.96	1.65	16.64	1.67	17.83	1.70	18.77	1.73
		90	13.73	1.60	14.66	1.66	15.60	1.72	16.27	1.74	17.46	1.78	18.40	1.81
		95	13.34	1.67	14.26	1.74	15.19	1.80	15.62	1.82	17.05	1.85	17.98	1.89
		100	13.01	1.75	13.94	1.81	14.87	1.88	15.42	1.90	16.73	1.93	17.66	1.97
		105	12.69	1.82	13.62	1.88	14.54	1.95	15.22	1.97	16.40	2.01	17.33	2.05
		110	12.36	1.89	13.29	1.96	14.22	2.03	14.89	2.05	16.08	2.09	17.01	2.13
		115	12.04	1.96	12.97	2.03	13.89	2.11	14.57	2.13	15.75	2.17	16.68	2.21
		118	11.84	2.00	12.77	2.08	13.70	2.15	14.37	2.18	15.56	2.22	16.49	2.26
		122	11.78	2.06	12.71	2.13	13.63	2.21	14.31	2.24	15.49	2.28	16.42	2.33
	9 + 12	-4	17.91	1.24	19.03	1.28	20.14	1.33	20.94	1.34	22.36	1.37	23.48	1.40
		0	17.90	1.25	19.01	1.30	20.13	1.34	20.93	1.36	22.35	1.38	23.46	1.41
		5	17.89	1.27	19.00	1.32	20.11	1.36	20.91	1.38	22.33	1.41	23.44	1.43
		10	17.87	1.29	18.98	1.34	20.09	1.38	20.90	1.40	22.32	1.43	23.43	1.46
		14	17.86	1.31	18.97	1.36	20.08	1.41	20.88	1.42	22.30	1.45	23.41	1.48
		20	17.85	1.33	18.96	1.38	20.06	1.43	20.86	1.44	22.28	1.47	23.39	1.50
		25	17.83	1.35	18.94	1.39	20.05	1.45	20.85	1.46	22.26	1.49	23.37	1.52
		30	17.82	1.36	18.93	1.41	20.03	1.47	20.83	1.48	22.25	1.51	23.35	1.54
		35	17.81	1.38	18.91	1.43	20.02	1.49	20.82	1.50	22.23	1.53	23.34	1.56
		40	17.79	1.40	18.90	1.45	20.00	1.51	20.80	1.52	22.21	1.55	23.32	1.58
		45	17.78	1.42	18.88	1.47	19.99	1.53	20.79	1.54	22.20	1.57	23.30	1.60
		50	17.77	1.44	18.87	1.49	19.97	1.55	20.77	1.56	22.18	1.59	23.28	1.63
		55	17.75	1.46	18.85	1.51	19.96	1.57	20.75	1.58	22.16	1.61	23.26	1.65
		60	17.74	1.48	18.84	1.53	19.94	1.59	20.74	1.61	22.14	1.64	23.25	1.67
		65	17.72	1.50	18.83	1.55	19.93	1.61	20.72	1.63	22.13	1.66	23.23	1.69
		70	17.71	1.51	18.81	1.57	19.91	1.63	20.71	1.65	22.11	1.68	23.21	1.71
		75	17.28	1.60	18.38	1.65	19.48	1.72	20.27	1.73	21.67	1.77	22.77	1.80
		80	16.86	1.68	17.95	1.74	19.05	1.80	19.84	1.82	21.24	1.86	22.33	1.90
		85	16.44	1.76	17.53	1.82	18.62	1.89	19.41	1.91	20.80	1.95	21.90	1.99
		90	16.01	1.84	17.10	1.91	18.19	1.98	18.98	2.00	20.37	2.04	21.46	2.08
		95	15.56	1.92	16.64	1.99	17.72	2.07	18.22	2.09	19.89	2.13	20.97	2.17
		100	15.18	2.00	16.26	2.08	17.34	2.15	17.98	2.18	19.51	2.22	20.60	2.26
		105	14.80	2.09	15.88	2.16	16.97	2.24	17.75	2.27	19.13	2.31	20.22	2.36
		110	14.42	2.17	15.50	2.25	16.59	2.33	17.37	2.36	18.75	2.40	19.84	2.45
		115	14.04	2.25	15.12	2.33	16.21	2.42	16.99	2.45	18.38	2.49	19.46	2.54
		118	13.81	2.30	14.90	2.38	15.98	2.47	16.76	2.50	18.15	2.55	19.23	2.60
		122	13.74	2.36	14.82	2.45	15.90	2.54	16.69	2.57	18.07	2.62	19.16	2.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 71: LMU30CHV Cooling Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 12	-4	20.47	1.37	21.74	1.42	23.01	1.47	23.93	1.49	25.55	1.51	26.83	1.54
		0	20.46	1.38	21.73	1.43	23.00	1.48	23.92	1.50	25.54	1.53	26.81	1.56
		5	20.44	1.40	21.71	1.46	22.98	1.51	23.90	1.53	25.52	1.55	26.79	1.59
		10	20.43	1.42	21.69	1.48	22.96	1.53	23.88	1.55	25.50	1.58	26.77	1.61
		14	20.41	1.45	21.68	1.50	22.94	1.55	23.86	1.57	25.48	1.60	26.75	1.63
		20	20.39	1.47	21.66	1.52	22.93	1.58	23.84	1.59	25.46	1.62	26.73	1.66
		25	20.38	1.49	21.64	1.54	22.91	1.60	23.82	1.62	25.44	1.65	26.71	1.68
		30	20.36	1.51	21.63	1.56	22.89	1.62	23.81	1.64	25.42	1.67	26.69	1.70
		35	20.35	1.53	21.61	1.58	22.87	1.64	23.79	1.66	25.40	1.69	26.67	1.73
		40	20.33	1.55	21.59	1.61	22.86	1.66	23.77	1.68	25.38	1.72	26.65	1.75
		45	20.32	1.57	21.58	1.63	22.84	1.69	23.75	1.71	25.36	1.74	26.63	1.77
		50	20.30	1.59	21.56	1.65	22.82	1.71	23.73	1.73	25.34	1.76	26.60	1.80
		55	20.29	1.61	21.55	1.67	22.80	1.73	23.71	1.75	25.32	1.78	26.58	1.82
		60	20.27	1.63	21.53	1.69	22.79	1.75	23.70	1.77	25.31	1.81	26.56	1.84
		65	20.25	1.65	21.51	1.71	22.77	1.78	23.68	1.80	25.29	1.83	26.54	1.87
		70	20.24	1.67	21.50	1.74	22.75	1.80	23.66	1.82	25.27	1.85	26.52	1.89
		75	19.75	1.76	21.01	1.83	22.26	1.90	23.16	1.92	24.77	1.95	26.02	1.99
		80	19.26	1.85	20.52	1.92	21.77	1.99	22.67	2.02	24.27	2.05	25.52	2.09
		85	18.78	1.95	20.03	2.02	21.28	2.09	22.18	2.11	23.77	2.15	25.02	2.20
		90	18.30	2.04	19.54	2.11	20.79	2.19	21.69	2.21	23.28	2.25	24.52	2.30
		95	17.78	2.13	19.01	2.20	20.25	2.28	20.82	2.31	22.73	2.35	23.97	2.40
		100	17.34	2.22	18.58	2.30	19.82	2.38	20.55	2.41	22.30	2.45	23.53	2.50
		105	16.91	2.31	18.15	2.39	19.39	2.48	20.28	2.51	21.86	2.55	23.10	2.60
		110	16.48	2.40	17.71	2.48	18.95	2.57	19.85	2.60	21.43	2.65	22.67	2.71
		115	16.04	2.49	17.28	2.58	18.52	2.67	19.41	2.70	21.00	2.75	22.24	2.81
		118	15.78	2.54	17.02	2.63	18.26	2.73	19.16	2.76	20.74	2.81	21.98	2.87
		122	15.70	2.61	16.94	2.71	18.17	2.81	19.07	2.84	20.65	2.89	21.89	2.95
	9 + 18	-4	23.03	1.52	24.47	1.58	25.90	1.63	26.93	1.65	28.76	1.68	30.19	1.72
		0	23.02	1.54	24.45	1.59	25.88	1.65	26.91	1.67	28.74	1.70	30.17	1.74
		5	23.00	1.56	24.43	1.62	25.86	1.68	26.89	1.70	28.72	1.73	30.15	1.76
		10	22.99	1.59	24.41	1.64	25.84	1.70	26.87	1.72	28.70	1.75	30.12	1.79
		14	22.97	1.61	24.39	1.67	25.82	1.73	26.85	1.75	28.67	1.78	30.10	1.82
		20	22.95	1.63	24.38	1.69	25.80	1.75	26.83	1.77	28.65	1.81	30.08	1.84
		25	22.93	1.65	24.36	1.71	25.78	1.78	26.81	1.80	28.63	1.83	30.05	1.87
		30	22.92	1.68	24.34	1.74	25.76	1.80	26.79	1.82	28.61	1.86	30.03	1.89
		35	22.90	1.70	24.32	1.76	25.74	1.83	26.77	1.85	28.59	1.88	30.01	1.92
		40	22.88	1.72	24.30	1.79	25.72	1.85	26.75	1.87	28.56	1.91	29.99	1.95
		45	22.86	1.75	24.28	1.81	25.70	1.88	26.73	1.90	28.54	1.93	29.96	1.97
		50	22.85	1.77	24.26	1.83	25.68	1.90	26.71	1.92	28.52	1.96	29.94	2.00
		55	22.83	1.79	24.25	1.86	25.66	1.93	26.69	1.95	28.50	1.99	29.92	2.03
		60	22.81	1.82	24.23	1.88	25.64	1.95	26.67	1.97	28.48	2.01	29.89	2.05
		65	22.79	1.84	24.21	1.91	25.62	1.98	26.65	2.00	28.46	2.04	29.87	2.08
		70	22.78	1.86	24.19	1.93	25.60	2.00	26.63	2.02	28.43	2.06	29.85	2.10
		75	22.23	1.96	23.64	2.03	25.05	2.11	26.07	2.13	27.87	2.17	29.28	2.22
		80	21.68	2.06	23.09	2.14	24.49	2.22	25.51	2.24	27.31	2.28	28.72	2.33
		85	21.14	2.16	22.54	2.24	23.94	2.32	24.96	2.35	26.75	2.40	28.16	2.44
		90	20.59	2.26	21.99	2.35	23.39	2.43	24.41	2.46	26.20	2.51	27.60	2.56
		95	20.00	2.36	21.40	2.45	22.79	2.54	23.43	2.57	25.58	2.62	26.97	2.67
		100	19.52	2.47	20.91	2.56	22.30	2.65	23.13	2.68	25.09	2.73	26.48	2.78
		105	19.03	2.57	20.42	2.66	21.82	2.76	22.82	2.79	24.60	2.84	26.00	2.90
		110	18.54	2.67	19.94	2.76	21.33	2.86	22.34	2.90	24.12	2.95	25.51	3.01
		115	18.06	2.77	19.45	2.87	20.84	2.97	21.85	3.01	23.63	3.06	25.02	3.12
		118	17.76	2.83	19.16	2.93	20.55	3.04	21.56	3.07	23.34	3.13	24.73	3.19
		122	17.67	2.91	19.06	3.01	20.45	3.12	21.46	3.16	23.24	3.22	24.63	3.28

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 72: LMU30CHV Cooling Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 18	-4	25.59	1.65	27.18	1.71	28.77	1.77	29.92	1.79	31.95	1.83	33.54	1.86
		0	25.58	1.67	27.17	1.73	28.75	1.79	29.90	1.81	31.93	1.85	33.52	1.88
		5	25.56	1.70	27.14	1.76	28.73	1.82	29.88	1.84	31.90	1.88	33.49	1.92
		10	25.54	1.72	27.12	1.78	28.71	1.85	29.85	1.87	31.88	1.91	33.47	1.94
		14	25.52	1.75	27.10	1.81	28.69	1.88	29.83	1.90	31.86	1.93	33.44	1.97
		20	25.50	1.77	27.08	1.84	28.66	1.90	29.81	1.92	31.83	1.96	33.42	2.00
		25	25.48	1.80	27.06	1.86	28.64	1.93	29.79	1.95	31.81	1.99	33.39	2.03
		30	25.46	1.82	27.04	1.89	28.62	1.96	29.76	1.98	31.78	2.02	33.36	2.06
		35	25.44	1.85	27.02	1.91	28.60	1.98	29.74	2.01	31.76	2.04	33.34	2.09
		40	25.42	1.87	27.00	1.94	28.58	2.01	29.72	2.03	31.73	2.07	33.31	2.11
		45	25.40	1.90	26.98	1.97	28.56	2.04	29.69	2.06	31.71	2.10	33.29	2.14
		50	25.38	1.92	26.96	1.99	28.53	2.06	29.67	2.09	31.69	2.13	33.26	2.17
		55	25.36	1.95	26.94	2.02	28.51	2.09	29.65	2.12	31.66	2.16	33.24	2.20
		60	25.34	1.97	26.92	2.04	28.49	2.12	29.63	2.14	31.64	2.18	33.21	2.23
		65	25.32	2.00	26.90	2.07	28.47	2.15	29.60	2.17	31.61	2.21	33.19	2.26
		70	25.30	2.02	26.87	2.10	28.45	2.17	29.58	2.20	31.59	2.24	33.16	2.28
		75	24.69	2.13	26.26	2.21	27.83	2.29	28.96	2.32	30.96	2.36	32.53	2.41
		80	24.09	2.24	25.65	2.32	27.21	2.41	28.34	2.43	30.34	2.48	31.90	2.53
		85	23.48	2.35	25.04	2.43	26.60	2.52	27.73	2.55	29.72	2.60	31.28	2.65
		90	22.88	2.46	24.43	2.55	25.99	2.64	27.11	2.67	29.10	2.72	30.66	2.78
		95	22.22	2.57	23.77	2.66	25.32	2.76	26.03	2.79	28.42	2.84	29.96	2.90
		100	21.68	2.68	23.23	2.77	24.78	2.88	25.69	2.91	27.87	2.96	29.42	3.02
		105	21.14	2.79	22.69	2.89	24.24	2.99	25.36	3.03	27.33	3.08	28.88	3.15
		110	20.60	2.89	22.15	3.00	23.70	3.11	24.81	3.15	26.79	3.20	28.34	3.27
		115	20.06	3.00	21.61	3.11	23.16	3.23	24.27	3.26	26.25	3.33	27.80	3.39
		118	19.73	3.07	21.28	3.18	22.83	3.30	23.95	3.34	25.93	3.40	27.47	3.47
		122	19.63	3.16	21.17	3.27	22.72	3.39	23.84	3.43	25.82	3.49	27.37	3.56
	18 + 18	-4	26.94	1.65	28.61	1.71	30.28	1.77	31.49	1.79	33.63	1.83	35.30	1.86
		0	26.92	1.67	28.60	1.73	30.27	1.79	31.47	1.81	33.61	1.85	35.28	1.88
		5	26.90	1.70	28.57	1.76	30.24	1.82	31.45	1.84	33.58	1.88	35.25	1.92
		10	26.88	1.72	28.55	1.78	30.22	1.85	31.43	1.87	33.56	1.91	35.23	1.94
		14	26.86	1.75	28.53	1.81	30.20	1.88	31.40	1.90	33.53	1.93	35.20	1.97
		20	26.84	1.77	28.51	1.84	30.17	1.90	31.38	1.92	33.51	1.96	35.17	2.00
		25	26.82	1.80	28.48	1.86	30.15	1.93	31.35	1.95	33.48	1.99	35.15	2.03
		30	26.80	1.82	28.46	1.89	30.13	1.96	31.33	1.98	33.46	2.02	35.12	2.06
		35	26.78	1.85	28.44	1.91	30.10	1.98	31.31	2.01	33.43	2.04	35.09	2.09
		40	26.76	1.87	28.42	1.94	30.08	2.01	31.28	2.03	33.40	2.07	35.07	2.11
		45	26.74	1.90	28.40	1.97	30.06	2.04	31.26	2.06	33.38	2.10	35.04	2.14
		50	26.72	1.92	28.38	1.99	30.04	2.06	31.23	2.09	33.35	2.13	35.01	2.17
		55	26.70	1.95	28.35	2.02	30.01	2.09	31.21	2.12	33.33	2.16	34.99	2.20
		60	26.68	1.97	28.33	2.04	29.99	2.12	31.19	2.14	33.30	2.18	34.96	2.23
		65	26.66	2.00	28.31	2.07	29.97	2.15	31.16	2.17	33.28	2.21	34.93	2.26
		70	26.63	2.02	28.29	2.10	29.94	2.17	31.14	2.20	33.25	2.24	34.91	2.28
		75	25.99	2.13	27.64	2.21	29.29	2.29	30.49	2.32	32.59	2.36	34.24	2.41
		80	25.35	2.24	27.00	2.32	28.64	2.41	29.83	2.43	31.94	2.48	33.58	2.53
		85	24.72	2.35	26.36	2.43	28.00	2.52	29.19	2.55	31.29	2.60	32.93	2.65
		90	24.08	2.46	25.72	2.55	27.36	2.64	28.54	2.67	30.63	2.72	32.27	2.78
		95	23.39	2.57	25.02	2.66	26.65	2.76	27.40	2.79	29.91	2.84	31.54	2.90
		100	22.82	2.68	24.45	2.77	26.08	2.88	27.05	2.91	29.34	2.96	30.97	3.02
		105	22.25	2.79	23.88	2.89	25.51	2.99	26.69	3.03	28.77	3.08	30.40	3.15
		110	21.68	2.89	23.31	3.00	24.94	3.11	26.12	3.15	28.20	3.20	29.83	3.27
		115	21.11	3.00	22.74	3.11	24.37	3.23	25.55	3.26	27.63	3.33	29.26	3.39
		118	20.77	3.07	22.40	3.18	24.03	3.30	25.21	3.34	27.29	3.40	28.92	3.47
		122	20.66	3.16	22.29	3.27	23.92	3.39	25.09	3.43	27.18	3.49	28.81	3.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 73: LMU30CHV Cooling Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 9 + 9	-4	23.03	1.44	24.47	1.50	25.90	1.55	26.93	1.57	28.76	1.60	30.19	1.63
		0	23.02	1.46	24.45	1.51	25.88	1.57	26.91	1.59	28.74	1.62	30.17	1.65
		5	23.00	1.48	24.43	1.54	25.86	1.59	26.89	1.61	28.72	1.64	30.15	1.67
		10	22.99	1.51	24.41	1.56	25.84	1.62	26.87	1.64	28.70	1.67	30.12	1.70
		14	22.97	1.53	24.39	1.58	25.82	1.64	26.85	1.66	28.67	1.69	30.10	1.72
		20	22.95	1.55	24.38	1.61	25.80	1.66	26.83	1.68	28.65	1.71	30.08	1.75
		25	22.93	1.57	24.36	1.63	25.78	1.69	26.81	1.71	28.63	1.74	30.05	1.77
		30	22.92	1.59	24.34	1.65	25.76	1.71	26.79	1.73	28.61	1.76	30.03	1.80
		35	22.90	1.61	24.32	1.67	25.74	1.73	26.77	1.75	28.59	1.79	30.01	1.82
		40	22.88	1.64	24.30	1.70	25.72	1.76	26.75	1.78	28.56	1.81	29.99	1.85
		45	22.86	1.66	24.28	1.72	25.70	1.78	26.73	1.80	28.54	1.84	29.96	1.87
		50	22.85	1.68	24.26	1.74	25.68	1.81	26.71	1.83	28.52	1.86	29.94	1.90
		55	22.83	1.70	24.25	1.76	25.66	1.83	26.69	1.85	28.50	1.88	29.92	1.92
		60	22.81	1.72	24.23	1.79	25.64	1.85	26.67	1.87	28.48	1.91	29.89	1.95
		65	22.79	1.75	24.21	1.81	25.62	1.88	26.65	1.90	28.46	1.93	29.87	1.97
		70	22.78	1.77	24.19	1.83	25.60	1.90	26.63	1.92	28.43	1.96	29.85	2.00
		75	22.23	1.86	23.64	1.93	25.05	2.00	26.07	2.03	27.87	2.06	29.28	2.10
		80	21.68	1.96	23.09	2.03	24.49	2.10	25.51	2.13	27.31	2.17	28.72	2.21
		85	21.14	2.05	22.54	2.13	23.94	2.21	24.96	2.23	26.75	2.27	28.16	2.32
		90	20.59	2.15	21.99	2.23	23.39	2.31	24.41	2.34	26.20	2.38	27.60	2.43
		95	20.00	2.25	21.40	2.33	22.79	2.41	23.83	2.44	25.58	2.49	26.97	2.54
		100	19.52	2.34	20.91	2.43	22.30	2.51	23.33	2.54	25.09	2.59	26.48	2.64
		105	19.03	2.44	20.42	2.53	21.82	2.62	22.82	2.65	24.60	2.70	26.00	2.75
		110	18.54	2.53	19.94	2.62	21.33	2.72	22.34	2.75	24.12	2.80	25.51	2.86
		115	18.06	2.63	19.45	2.72	20.84	2.82	21.85	2.85	23.63	2.91	25.02	2.97
		118	17.76	2.68	19.16	2.78	20.55	2.88	21.56	2.92	23.34	2.97	24.73	3.03
		122	17.67	2.76	19.06	2.86	20.45	2.97	21.46	3.00	23.24	3.06	24.63	3.12
	9 + 9 + 12	-4	25.59	1.54	27.18	1.60	28.77	1.66	29.92	1.68	31.95	1.71	33.54	1.74
		0	25.58	1.56	27.17	1.62	28.75	1.68	29.90	1.70	31.93	1.73	33.52	1.76
		5	25.56	1.59	27.14	1.64	28.73	1.70	29.88	1.72	31.90	1.76	33.49	1.79
		10	25.54	1.61	27.12	1.67	28.71	1.73	29.85	1.75	31.88	1.78	33.47	1.82
		14	25.52	1.63	27.10	1.69	28.69	1.75	29.83	1.77	31.86	1.81	33.44	1.84
		20	25.50	1.66	27.08	1.72	28.66	1.78	29.81	1.80	31.83	1.83	33.42	1.87
		25	25.48	1.68	27.06	1.74	28.64	1.81	29.79	1.83	31.81	1.86	33.39	1.90
		30	25.46	1.70	27.04	1.77	28.62	1.83	29.76	1.85	31.78	1.89	33.36	1.92
		35	25.44	1.73	27.02	1.79	28.60	1.86	29.74	1.88	31.76	1.91	33.34	1.95
		40	25.42	1.75	27.00	1.81	28.58	1.88	29.72	1.90	31.73	1.94	33.31	1.98
		45	25.40	1.77	26.98	1.84	28.56	1.91	29.69	1.93	31.71	1.96	33.29	2.00
		50	25.38	1.80	26.96	1.86	28.53	1.93	29.67	1.95	31.69	1.99	33.26	2.03
		55	25.36	1.82	26.94	1.89	28.51	1.96	29.65	1.98	31.66	2.02	33.24	2.06
		60	25.34	1.84	26.92	1.91	28.49	1.98	29.63	2.00	31.64	2.04	33.21	2.08
		65	25.32	1.87	26.90	1.94	28.47	2.01	29.60	2.03	31.61	2.07	33.19	2.11
		70	25.30	1.89	26.87	1.96	28.45	2.03	29.58	2.06	31.59	2.09	33.16	2.14
		75	24.69	1.99	26.26	2.07	27.83	2.14	28.96	2.17	30.96	2.21	32.53	2.25
		80	24.09	2.10	25.65	2.17	27.21	2.25	28.34	2.28	30.34	2.32	31.90	2.37
		85	23.48	2.20	25.04	2.28	26.60	2.36	27.73	2.39	29.72	2.43	31.28	2.48
		90	22.88	2.30	24.43	2.38	25.99	2.47	27.11	2.50	29.10	2.55	30.66	2.60
		95	22.22	2.40	23.77	2.49	25.32	2.58	26.03	2.61	28.42	2.66	29.96	2.71
		100	21.68	2.50	23.23	2.60	24.78	2.69	25.69	2.72	27.87	2.77	29.42	2.83
		105	21.14	2.61	22.69	2.70	24.24	2.80	25.36	2.83	27.33	2.88	28.88	2.94
		110	20.60	2.71	22.15	2.81	23.70	2.91	24.81	2.94	26.79	3.00	28.34	3.06
		115	20.06	2.81	21.61	2.91	23.16	3.02	24.27	3.05	26.25	3.11	27.80	3.17
		118	19.73	2.87	21.28	2.98	22.83	3.08	23.95	3.12	25.93	3.18	27.47	3.24
		122	19.63	2.95	21.17	3.06	22.72	3.17	23.84	3.21	25.82	3.27	27.37	3.33

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 74: LMU30CHV Cooling Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 12 + 12	-4	26.94	1.54	28.61	1.60	30.28	1.66	31.49	1.68	33.63	1.71	35.30	1.74
		0	26.92	1.56	28.60	1.62	30.27	1.68	31.47	1.70	33.61	1.73	35.28	1.76
		5	26.90	1.59	28.57	1.64	30.24	1.70	31.45	1.72	33.58	1.76	35.25	1.79
		10	26.88	1.61	28.55	1.67	30.22	1.73	31.43	1.75	33.56	1.78	35.23	1.82
		14	26.86	1.63	28.53	1.69	30.20	1.75	31.40	1.77	33.53	1.81	35.20	1.84
		20	26.84	1.66	28.51	1.72	30.17	1.78	31.38	1.80	33.51	1.83	35.17	1.87
		25	26.82	1.68	28.48	1.74	30.15	1.81	31.35	1.83	33.48	1.86	35.15	1.90
		30	26.80	1.70	28.46	1.77	30.13	1.83	31.33	1.85	33.46	1.89	35.12	1.92
		35	26.78	1.73	28.44	1.79	30.10	1.86	31.31	1.88	33.43	1.91	35.09	1.95
		40	26.76	1.75	28.42	1.81	30.08	1.88	31.28	1.90	33.40	1.94	35.07	1.98
		45	26.74	1.77	28.40	1.84	30.06	1.91	31.26	1.93	33.38	1.96	35.04	2.00
		50	26.72	1.80	28.38	1.86	30.04	1.93	31.23	1.95	33.35	1.99	35.01	2.03
		55	26.70	1.82	28.35	1.89	30.01	1.96	31.21	1.98	33.33	2.02	34.99	2.06
		60	26.68	1.84	28.33	1.91	29.99	1.98	31.19	2.00	33.30	2.04	34.96	2.08
		65	26.66	1.87	28.31	1.94	29.97	2.01	31.16	2.03	33.28	2.07	34.93	2.11
		70	26.63	1.89	28.29	1.96	29.94	2.03	31.14	2.06	33.25	2.09	34.91	2.14
		75	25.99	1.99	27.64	2.07	29.29	2.14	30.49	2.17	32.59	2.21	34.24	2.25
		80	25.35	2.10	27.00	2.17	28.64	2.25	29.83	2.28	31.94	2.32	33.58	2.37
		85	24.72	2.20	26.36	2.28	28.00	2.36	29.19	2.39	31.29	2.43	32.93	2.48
		90	24.08	2.30	25.72	2.38	27.36	2.47	28.54	2.50	30.63	2.55	32.27	2.60
		95	23.39	2.40	25.02	2.49	26.65	2.58	27.40	2.61	29.91	2.66	31.54	2.71
		100	22.82	2.50	24.45	2.60	26.08	2.69	27.05	2.72	29.34	2.77	30.97	2.83
		105	22.25	2.61	23.88	2.70	25.51	2.80	26.69	2.83	28.77	2.88	30.40	2.94
		110	21.68	2.71	23.31	2.81	24.94	2.91	26.12	2.94	28.20	3.00	29.83	3.06
		115	21.11	2.81	22.74	2.91	24.37	3.02	25.55	3.05	27.63	3.11	29.26	3.17
		118	20.77	2.87	22.40	2.98	24.03	3.08	25.21	3.12	27.29	3.18	28.92	3.24
		122	20.66	2.95	22.29	3.06	23.92	3.17	25.09	3.21	27.18	3.27	28.81	3.33
	9 + 9 + 18	-4	26.94	1.54	28.61	1.60	30.28	1.66	31.49	1.68	33.63	1.71	35.30	1.74
		0	26.92	1.56	28.60	1.62	30.27	1.68	31.47	1.70	33.61	1.73	35.28	1.76
		5	26.90	1.59	28.57	1.64	30.24	1.70	31.45	1.72	33.58	1.76	35.25	1.79
		10	26.88	1.61	28.55	1.67	30.22	1.73	31.43	1.75	33.56	1.78	35.23	1.82
		14	26.86	1.63	28.53	1.69	30.20	1.75	31.40	1.77	33.53	1.81	35.20	1.84
		20	26.84	1.66	28.51	1.72	30.17	1.78	31.38	1.80	33.51	1.83	35.17	1.87
		25	26.82	1.68	28.48	1.74	30.15	1.81	31.35	1.83	33.48	1.86	35.15	1.90
		30	26.80	1.70	28.46	1.77	30.13	1.83	31.33	1.85	33.46	1.89	35.12	1.92
		35	26.78	1.73	28.44	1.79	30.10	1.86	31.31	1.88	33.43	1.91	35.09	1.95
		40	26.76	1.75	28.42	1.81	30.08	1.88	31.28	1.90	33.40	1.94	35.07	1.98
		45	26.74	1.77	28.40	1.84	30.06	1.91	31.26	1.93	33.38	1.96	35.04	2.00
		50	26.72	1.80	28.38	1.86	30.04	1.93	31.23	1.95	33.35	1.99	35.01	2.03
		55	26.70	1.82	28.35	1.89	30.01	1.96	31.21	1.98	33.33	2.02	34.99	2.06
		60	26.68	1.84	28.33	1.91	29.99	1.98	31.19	2.00	33.30	2.04	34.96	2.08
		65	26.66	1.87	28.31	1.94	29.97	2.01	31.16	2.03	33.28	2.07	34.93	2.11
		70	26.63	1.89	28.29	1.96	29.94	2.03	31.14	2.06	33.25	2.09	34.91	2.14
		75	25.99	1.99	27.64	2.07	29.29	2.14	30.49	2.17	32.59	2.21	34.24	2.25
		80	25.35	2.10	27.00	2.17	28.64	2.25	29.83	2.28	31.94	2.32	33.58	2.37
		85	24.72	2.20	26.36	2.28	28.00	2.36	29.19	2.39	31.29	2.43	32.93	2.48
		90	24.08	2.30	25.72	2.38	27.36	2.47	28.54	2.50	30.63	2.55	32.27	2.60
		95	23.39	2.40	25.02	2.49	26.65	2.58	27.40	2.61	29.91	2.66	31.54	2.71
		100	22.82	2.50	24.45	2.60	26.08	2.69	27.05	2.72	29.34	2.77	30.97	2.83
		105	22.25	2.61	23.88	2.70	25.51	2.80	26.69	2.83	28.77	2.88	30.40	2.94
		110	21.68	2.71	23.31	2.81	24.94	2.91	26.12	2.94	28.20	3.00	29.83	3.06
		115	21.11	2.81	22.74	2.91	24.37	3.02	25.55	3.05	27.63	3.11	29.26	3.17
		118	20.77	2.87	22.40	2.98	24.03	3.08	25.21	3.12	27.29	3.18	28.92	3.24
		122	20.66	2.95	22.29	3.06	23.92	3.17	25.09	3.21	27.18	3.27	28.81	3.33

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 75: LMU30CHV Cooling Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	12 + 12 + 12	-4	26.94	1.54	28.61	1.60	30.28	1.66	31.49	1.68	33.63	1.71	35.30	1.74
		0	26.92	1.56	28.60	1.62	30.27	1.68	31.47	1.70	33.61	1.73	35.28	1.76
		5	26.90	1.59	28.57	1.64	30.24	1.70	31.45	1.72	33.58	1.76	35.25	1.79
		10	26.88	1.61	28.55	1.67	30.22	1.73	31.43	1.75	33.56	1.78	35.23	1.82
		14	26.86	1.63	28.53	1.69	30.20	1.75	31.40	1.77	33.53	1.81	35.20	1.84
		20	26.84	1.66	28.51	1.72	30.17	1.78	31.38	1.80	33.51	1.83	35.17	1.87
		25	26.82	1.68	28.48	1.74	30.15	1.81	31.35	1.83	33.48	1.86	35.15	1.90
		30	26.80	1.70	28.46	1.77	30.13	1.83	31.33	1.85	33.46	1.89	35.12	1.92
		35	26.78	1.73	28.44	1.79	30.10	1.86	31.31	1.88	33.43	1.91	35.09	1.95
		40	26.76	1.75	28.42	1.81	30.08	1.88	31.28	1.90	33.40	1.94	35.07	1.98
		45	26.74	1.77	28.40	1.84	30.06	1.91	31.26	1.93	33.38	1.96	35.04	2.00
		50	26.72	1.80	28.38	1.86	30.04	1.93	31.23	1.95	33.35	1.99	35.01	2.03
		55	26.70	1.82	28.35	1.89	30.01	1.96	31.21	1.98	33.33	2.02	34.99	2.06
		60	26.68	1.84	28.33	1.91	29.99	1.98	31.19	2.00	33.30	2.04	34.96	2.08
		65	26.66	1.87	28.31	1.94	29.97	2.01	31.16	2.03	33.28	2.07	34.93	2.11
		70	26.63	1.89	28.29	1.96	29.94	2.03	31.14	2.06	33.25	2.09	34.91	2.14
		75	25.99	1.99	27.64	2.07	29.29	2.14	30.49	2.17	32.59	2.21	34.24	2.25
		80	25.35	2.10	27.00	2.17	28.64	2.25	29.83	2.28	31.94	2.32	33.58	2.37
		85	24.72	2.20	26.36	2.28	28.00	2.36	29.19	2.39	31.29	2.43	32.93	2.48
		90	24.08	2.30	25.72	2.38	27.36	2.47	28.54	2.50	30.63	2.55	32.27	2.60
		95	23.39	2.40	25.02	2.49	26.65	2.58	27.40	2.61	29.91	2.66	31.54	2.71
		100	22.82	2.50	24.45	2.60	26.08	2.69	27.05	2.72	29.34	2.77	30.97	2.83
		105	22.25	2.61	23.88	2.70	25.51	2.80	26.69	2.83	28.77	2.88	30.40	2.94
		110	21.68	2.71	23.31	2.81	24.94	2.91	26.12	2.94	28.20	3.00	29.83	3.06
		115	21.11	2.81	22.74	2.91	24.37	3.02	25.55	3.05	27.63	3.11	29.26	3.17
		118	20.77	2.87	22.40	2.98	24.03	3.08	25.21	3.12	27.29	3.18	28.92	3.24
		122	20.66	2.95	22.29	3.06	23.92	3.17	25.09	3.21	27.18	3.27	28.81	3.33
	9 + 12 + 18	-4	26.94	1.54	28.61	1.60	30.28	1.66	31.49	1.68	33.63	1.71	35.30	1.74
		0	26.92	1.56	28.60	1.62	30.27	1.68	31.47	1.70	33.61	1.73	35.28	1.76
		5	26.90	1.59	28.57	1.64	30.24	1.70	31.45	1.72	33.58	1.76	35.25	1.79
		10	26.88	1.61	28.55	1.67	30.22	1.73	31.43	1.75	33.56	1.78	35.23	1.82
		14	26.86	1.63	28.53	1.69	30.20	1.75	31.40	1.77	33.53	1.81	35.20	1.84
		20	26.84	1.66	28.51	1.72	30.17	1.78	31.38	1.80	33.51	1.83	35.17	1.87
		25	26.82	1.68	28.48	1.74	30.15	1.81	31.35	1.83	33.48	1.86	35.15	1.90
		30	26.80	1.70	28.46	1.77	30.13	1.83	31.33	1.85	33.46	1.89	35.12	1.92
		35	26.78	1.73	28.44	1.79	30.10	1.86	31.31	1.88	33.43	1.91	35.09	1.95
		40	26.76	1.75	28.42	1.81	30.08	1.88	31.28	1.90	33.40	1.94	35.07	1.98
		45	26.74	1.77	28.40	1.84	30.06	1.91	31.26	1.93	33.38	1.96	35.04	2.00
		50	26.72	1.80	28.38	1.86	30.04	1.93	31.23	1.95	33.35	1.99	35.01	2.03
		55	26.70	1.82	28.35	1.89	30.01	1.96	31.21	1.98	33.33	2.02	34.99	2.06
		60	26.68	1.84	28.33	1.91	29.99	1.98	31.19	2.00	33.30	2.04	34.96	2.08
		65	26.66	1.87	28.31	1.94	29.97	2.01	31.16	2.03	33.28	2.07	34.93	2.11
		70	26.63	1.89	28.29	1.96	29.94	2.03	31.14	2.06	33.25	2.09	34.91	2.14
		75	25.99	1.99	27.64	2.07	29.29	2.14	30.49	2.17	32.59	2.21	34.24	2.25
		80	25.35	2.10	27.00	2.17	28.64	2.25	29.83	2.28	31.94	2.32	33.58	2.37
		85	24.72	2.20	26.36	2.28	28.00	2.36	29.19	2.39	31.29	2.43	32.93	2.48
		90	24.08	2.30	25.72	2.38	27.36	2.47	28.54	2.50	30.63	2.55	32.27	2.60
		95	23.39	2.40	25.02	2.49	26.65	2.58	27.40	2.61	29.91	2.66	31.54	2.71
		100	22.82	2.50	24.45	2.60	26.08	2.69	27.05	2.72	29.34	2.77	30.97	2.83
		105	22.25	2.61	23.88	2.70	25.51	2.80	26.69	2.83	28.77	2.88	30.40	2.94
		110	21.68	2.71	23.31	2.81	24.94	2.91	26.12	2.94	28.20	3.00	29.83	3.06
		115	21.11	2.81	22.74	2.91	24.37	3.02	25.55	3.05	27.63	3.11	29.26	3.17
		118	20.77	2.87	22.40	2.98	24.03	3.08	25.21	3.12	27.29	3.18	28.92	3.24
		122	20.66	2.95	22.29	3.06	23.92	3.17	25.09	3.21	27.18	3.27	28.81	3.33

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 76: LMU30CHV Cooling Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 9 + 9	-4	26.94	1.47	28.61	1.53	30.28	1.58	31.49	1.60	33.63	1.63	35.30	1.66
		0	26.92	1.49	28.60	1.54	30.27	1.60	31.47	1.62	33.61	1.65	35.28	1.68
		5	26.90	1.51	28.57	1.57	30.24	1.63	31.45	1.64	33.58	1.68	35.25	1.71
		10	26.88	1.54	28.55	1.59	30.22	1.65	31.43	1.67	33.56	1.70	35.23	1.73
		14	26.86	1.56	28.53	1.62	30.20	1.67	31.40	1.69	33.53	1.73	35.20	1.76
		20	26.84	1.58	28.51	1.64	30.17	1.70	31.38	1.72	33.51	1.75	35.17	1.79
		25	26.82	1.60	28.48	1.66	30.15	1.72	31.35	1.74	33.48	1.77	35.15	1.81
		30	26.80	1.63	28.46	1.68	30.13	1.75	31.33	1.77	33.46	1.80	35.12	1.84
		35	26.78	1.65	28.44	1.71	30.10	1.77	31.31	1.79	33.43	1.82	35.09	1.86
		40	26.76	1.67	28.42	1.73	30.08	1.79	31.28	1.82	33.40	1.85	35.07	1.89
		45	26.74	1.69	28.40	1.75	30.06	1.82	31.26	1.84	33.38	1.87	35.04	1.91
		50	26.72	1.71	28.38	1.78	30.04	1.84	31.23	1.86	33.35	1.90	35.01	1.94
		55	26.70	1.74	28.35	1.80	30.01	1.87	31.21	1.89	33.33	1.92	34.99	1.96
		60	26.68	1.76	28.33	1.82	29.99	1.89	31.19	1.91	33.30	1.95	34.96	1.99
		65	26.66	1.78	28.31	1.85	29.97	1.91	31.16	1.94	33.28	1.97	34.93	2.01
		70	26.63	1.80	28.29	1.87	29.94	1.94	31.14	1.96	33.25	2.00	34.91	2.04
		75	25.99	1.90	27.64	1.97	29.29	2.04	30.49	2.07	32.59	2.11	34.24	2.15
		80	25.35	2.00	27.00	2.07	28.64	2.15	29.83	2.17	31.94	2.21	33.58	2.26
		85	24.72	2.10	26.36	2.17	28.00	2.25	29.19	2.28	31.29	2.32	32.93	2.37
		90	24.08	2.19	25.72	2.27	27.36	2.36	28.54	2.38	30.63	2.43	32.27	2.48
		95	23.39	2.29	25.02	2.37	26.65	2.46	27.40	2.49	29.91	2.54	31.54	2.59
		100	22.82	2.39	24.45	2.48	26.08	2.57	27.05	2.60	29.34	2.64	30.97	2.70
		105	22.25	2.49	23.88	2.58	25.51	2.67	26.69	2.70	28.77	2.75	30.40	2.81
		110	21.68	2.58	23.31	2.68	24.94	2.78	26.12	2.81	28.20	2.86	29.83	2.92
		115	21.11	2.68	22.74	2.78	24.37	2.88	25.55	2.91	27.63	2.97	29.26	3.03
		118	20.77	2.74	22.40	2.84	24.03	2.94	25.21	2.98	27.29	3.03	28.92	3.09
		122	20.66	2.82	22.29	2.92	23.92	3.03	25.09	3.06	27.18	3.12	28.81	3.18
	9 + 9 + 9 + 12	-4	26.94	1.47	28.61	1.53	30.28	1.58	31.49	1.60	33.63	1.63	35.30	1.66
		0	26.92	1.49	28.60	1.54	30.27	1.60	31.47	1.62	33.61	1.65	35.28	1.68
		5	26.90	1.51	28.57	1.57	30.24	1.63	31.45	1.64	33.58	1.68	35.25	1.71
		10	26.88	1.54	28.55	1.59	30.22	1.65	31.43	1.67	33.56	1.70	35.23	1.73
		14	26.86	1.56	28.53	1.62	30.20	1.67	31.40	1.69	33.53	1.73	35.20	1.76
		20	26.84	1.58	28.51	1.64	30.17	1.70	31.38	1.72	33.51	1.75	35.17	1.79
		25	26.82	1.60	28.48	1.66	30.15	1.72	31.35	1.74	33.48	1.77	35.15	1.81
		30	26.80	1.63	28.46	1.68	30.13	1.75	31.33	1.77	33.46	1.80	35.12	1.84
		35	26.78	1.65	28.44	1.71	30.10	1.77	31.31	1.79	33.43	1.82	35.09	1.86
		40	26.76	1.67	28.42	1.73	30.08	1.79	31.28	1.82	33.40	1.85	35.07	1.89
		45	26.74	1.69	28.40	1.75	30.06	1.82	31.26	1.84	33.38	1.87	35.04	1.91
		50	26.72	1.71	28.38	1.78	30.04	1.84	31.23	1.86	33.35	1.90	35.01	1.94
		55	26.70	1.74	28.35	1.80	30.01	1.87	31.21	1.89	33.33	1.92	34.99	1.96
		60	26.68	1.76	28.33	1.82	29.99	1.89	31.19	1.91	33.30	1.95	34.96	1.99
		65	26.66	1.78	28.31	1.85	29.97	1.91	31.16	1.94	33.28	1.97	34.93	2.01
		70	26.63	1.80	28.29	1.87	29.94	1.94	31.14	1.96	33.25	2.00	34.91	2.04
		75	25.99	1.90	27.64	1.97	29.29	2.04	30.49	2.07	32.59	2.11	34.24	2.15
		80	25.35	2.00	27.00	2.07	28.64	2.15	29.83	2.17	31.94	2.21	33.58	2.26
		85	24.72	2.10	26.36	2.17	28.00	2.25	29.19	2.28	31.29	2.32	32.93	2.37
		90	24.08	2.19	25.72	2.27	27.36	2.36	28.54	2.38	30.63	2.43	32.27	2.48
		95	23.39	2.29	25.02	2.37	26.65	2.46	27.40	2.49	29.91	2.54	31.54	2.59
		100	22.82	2.39	24.45	2.48	26.08	2.57	27.05	2.60	29.34	2.64	30.97	2.70
		105	22.25	2.49	23.88	2.58	25.51	2.67	26.69	2.70	28.77	2.75	30.40	2.81
		110	21.68	2.58	23.31	2.68	24.94	2.78	26.12	2.81	28.20	2.86	29.83	2.92
		115	21.11	2.68	22.74	2.78	24.37	2.88	25.55	2.91	27.63	2.97	29.26	3.03
		118	20.77	2.74	22.40	2.84	24.03	2.94	25.21	2.98	27.29	3.03	28.92	3.09
		122	20.66	2.82	22.29	2.92	23.92	3.03	25.09	3.06	27.18	3.12	28.81	3.18

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 77: LMU30CHV Cooling Capacity Table —Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 9	-4	14.69	0.92	15.60	0.96	16.51	0.99	17.17	1.00	18.34	1.02	19.25	1.04
		0	14.68	0.93	15.59	0.97	16.50	1.00	17.16	1.01	18.33	1.03	19.24	1.05
		5	14.67	0.95	15.58	0.98	16.49	1.02	17.15	1.03	18.31	1.05	19.22	1.07
		10	14.66	0.96	15.57	1.00	16.48	1.03	17.13	1.05	18.30	1.07	19.21	1.09
		14	14.65	0.98	15.56	1.01	16.46	1.05	17.12	1.06	18.28	1.08	19.19	1.10
		20	14.63	0.99	15.54	1.03	16.45	1.06	17.11	1.08	18.27	1.10	19.18	1.12
		25	14.62	1.00	15.53	1.04	16.44	1.08	17.10	1.09	18.26	1.11	19.16	1.13
		30	14.61	1.02	15.52	1.06	16.43	1.09	17.08	1.11	18.24	1.13	19.15	1.15
		35	14.60	1.03	15.51	1.07	16.41	1.11	17.07	1.12	18.23	1.14	19.13	1.17
		40	14.59	1.05	15.50	1.08	16.40	1.12	17.06	1.14	18.21	1.16	19.12	1.18
		45	14.58	1.06	15.48	1.10	16.39	1.14	17.04	1.15	18.20	1.17	19.11	1.20
		50	14.57	1.07	15.47	1.11	16.38	1.15	17.03	1.17	18.19	1.19	19.09	1.21
		55	14.56	1.09	15.46	1.13	16.36	1.17	17.02	1.18	18.17	1.21	19.08	1.23
		60	14.55	1.10	15.45	1.14	16.35	1.18	17.00	1.20	18.16	1.22	19.06	1.25
		65	14.53	1.12	15.44	1.16	16.34	1.20	16.99	1.21	18.14	1.24	19.05	1.26
		70	14.52	1.13	15.42	1.17	16.33	1.21	16.98	1.23	18.13	1.25	19.03	1.28
		75	14.17	1.19	15.07	1.24	15.97	1.28	16.62	1.29	17.77	1.32	18.67	1.35
		80	13.82	1.25	14.72	1.30	15.62	1.35	16.27	1.36	17.41	1.39	18.31	1.41
		85	13.48	1.31	14.37	1.36	15.27	1.41	15.91	1.43	17.06	1.45	17.95	1.48
		90	13.13	1.37	14.02	1.42	14.92	1.48	15.56	1.49	16.70	1.52	17.60	1.55
		95	12.76	1.44	13.64	1.49	14.53	1.54	14.94	1.56	16.31	1.59	17.20	1.62
		100	12.44	1.50	13.33	1.55	14.22	1.61	14.75	1.63	16.00	1.66	16.89	1.69
		105	12.13	1.56	13.02	1.61	13.91	1.67	14.55	1.69	15.69	1.72	16.58	1.76
		110	11.82	1.62	12.71	1.68	13.60	1.74	14.24	1.76	15.38	1.79	16.27	1.83
		115	11.51	1.68	12.40	1.74	13.29	1.80	13.93	1.83	15.07	1.86	15.96	1.90
		118	11.33	1.72	12.21	1.78	13.10	1.84	13.75	1.86	14.88	1.90	15.77	1.94
		122	11.26	1.76	12.15	1.83	13.04	1.90	13.68	1.92	14.82	1.95	15.71	1.99
	9 + 9	-4	16.53	1.04	17.55	1.08	18.58	1.12	19.32	1.13	20.63	1.15	21.66	1.18
		0	16.52	1.05	17.54	1.09	18.57	1.13	19.31	1.14	20.62	1.17	21.65	1.19
		5	16.50	1.07	17.53	1.11	18.55	1.15	19.29	1.16	20.60	1.18	21.63	1.21
		10	16.49	1.09	17.52	1.13	18.54	1.17	19.28	1.18	20.59	1.20	21.61	1.23
		14	16.48	1.10	17.50	1.14	18.53	1.18	19.26	1.20	20.57	1.22	21.60	1.24
		20	16.47	1.12	17.49	1.16	18.51	1.20	19.25	1.21	20.56	1.24	21.58	1.26
		25	16.45	1.13	17.48	1.17	18.50	1.22	19.24	1.23	20.54	1.25	21.56	1.28
		30	16.44	1.15	17.46	1.19	18.48	1.23	19.22	1.25	20.53	1.27	21.55	1.30
		35	16.43	1.16	17.45	1.21	18.47	1.25	19.21	1.27	20.51	1.29	21.53	1.32
		40	16.42	1.18	17.44	1.22	18.45	1.27	19.19	1.28	20.49	1.31	21.51	1.33
		45	16.40	1.20	17.42	1.24	18.44	1.29	19.18	1.30	20.48	1.32	21.50	1.35
		50	16.39	1.21	17.41	1.26	18.43	1.30	19.16	1.32	20.46	1.34	21.48	1.37
		55	16.38	1.23	17.40	1.27	18.41	1.32	19.15	1.33	20.45	1.36	21.46	1.39
		60	16.37	1.24	17.38	1.29	18.40	1.34	19.13	1.35	20.43	1.38	21.45	1.40
		65	16.35	1.26	17.37	1.31	18.38	1.35	19.12	1.37	20.42	1.39	21.43	1.42
		70	16.34	1.28	17.36	1.32	18.37	1.37	19.10	1.39	20.40	1.41	21.41	1.44
		75	15.95	1.34	16.96	1.39	17.97	1.44	18.70	1.46	20.00	1.49	21.01	1.52
		80	15.55	1.41	16.56	1.46	17.57	1.52	18.30	1.54	19.59	1.56	20.60	1.60
		85	15.16	1.48	16.17	1.54	17.18	1.59	17.91	1.61	19.19	1.64	20.20	1.67
		90	14.77	1.55	15.78	1.61	16.78	1.67	17.51	1.69	18.79	1.72	19.80	1.75
		95	14.35	1.62	15.35	1.68	16.35	1.74	16.81	1.76	18.35	1.79	19.35	1.83
		100	14.00	1.69	15.00	1.75	16.00	1.81	16.59	1.83	18.00	1.87	19.00	1.91
		105	13.65	1.76	14.65	1.82	15.65	1.89	16.37	1.91	17.65	1.95	18.65	1.98
		110	13.30	1.83	14.30	1.89	15.30	1.96	16.02	1.98	17.30	2.02	18.30	2.06
		115	12.95	1.89	13.95	1.96	14.95	2.04	15.68	2.06	16.95	2.10	17.95	2.14
		118	12.74	1.94	13.74	2.01	14.74	2.08	15.47	2.10	16.74	2.14	17.74	2.19
		122	12.67	1.99	13.67	2.06	14.67	2.14	15.40	2.16	16.67	2.20	17.67	2.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 78: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 12	-4	17.44	1.09	18.52	1.13	19.61	1.17	20.39	1.18	21.77	1.21	22.86	1.23
		0	17.43	1.10	18.51	1.14	19.60	1.18	20.38	1.20	21.76	1.22	22.84	1.24
		5	17.42	1.12	18.50	1.16	19.58	1.20	20.36	1.22	21.74	1.24	22.83	1.26
		10	17.40	1.13	18.48	1.18	19.57	1.22	20.35	1.23	21.73	1.26	22.81	1.28
		14	17.39	1.15	18.47	1.19	19.55	1.24	20.33	1.25	21.71	1.27	22.79	1.30
		20	17.38	1.17	18.46	1.21	19.54	1.25	20.32	1.27	21.69	1.29	22.77	1.32
		25	17.36	1.18	18.44	1.23	19.52	1.27	20.30	1.29	21.68	1.31	22.76	1.34
		30	17.35	1.20	18.43	1.24	19.51	1.29	20.28	1.31	21.66	1.33	22.74	1.36
		35	17.34	1.22	18.41	1.26	19.49	1.31	20.27	1.32	21.64	1.35	22.72	1.38
		40	17.32	1.23	18.40	1.28	19.48	1.33	20.25	1.34	21.63	1.37	22.70	1.39
		45	17.31	1.25	18.39	1.30	19.46	1.34	20.24	1.36	21.61	1.38	22.69	1.41
		50	17.30	1.27	18.37	1.31	19.45	1.36	20.22	1.38	21.59	1.40	22.67	1.43
		55	17.28	1.28	18.36	1.33	19.43	1.38	20.21	1.40	21.58	1.42	22.65	1.45
		60	17.27	1.30	18.34	1.35	19.42	1.40	20.19	1.41	21.56	1.44	22.63	1.47
		65	17.26	1.32	18.33	1.36	19.40	1.41	20.18	1.43	21.54	1.46	22.62	1.49
		70	17.24	1.33	18.32	1.38	19.39	1.43	20.16	1.45	21.53	1.48	22.60	1.51
		75	16.83	1.41	17.90	1.46	18.97	1.51	19.74	1.53	21.10	1.56	22.17	1.59
		80	16.41	1.48	17.48	1.53	18.55	1.59	19.32	1.61	20.68	1.64	21.74	1.67
		85	16.00	1.55	17.07	1.61	18.13	1.66	18.90	1.68	20.26	1.72	21.32	1.75
		90	15.59	1.62	16.65	1.68	17.71	1.74	18.48	1.76	19.83	1.79	20.89	1.83
		95	15.15	1.69	16.20	1.75	17.26	1.82	17.74	1.84	19.37	1.87	20.42	1.91
		100	14.78	1.77	15.83	1.83	16.89	1.90	17.51	1.92	19.00	1.95	20.05	1.99
		105	14.41	1.84	15.46	1.90	16.52	1.97	17.28	2.00	18.63	2.03	19.68	2.07
		110	14.04	1.91	15.09	1.98	16.15	2.05	16.91	2.07	18.26	2.11	19.31	2.16
		115	13.67	1.98	14.73	2.05	15.78	2.13	16.54	2.15	17.89	2.19	18.95	2.24
		118	13.45	2.02	14.50	2.10	15.56	2.17	16.32	2.20	17.67	2.24	18.72	2.29
		122	13.38	2.08	14.43	2.16	15.49	2.24	16.25	2.26	17.60	2.30	18.65	2.35
	9 + 12	-4	19.28	1.19	20.48	1.23	21.67	1.28	22.54	1.29	24.07	1.32	25.27	1.34
		0	19.27	1.20	20.47	1.25	21.66	1.29	22.53	1.31	24.06	1.33	25.25	1.36
		5	19.25	1.22	20.45	1.27	21.64	1.31	22.51	1.33	24.04	1.35	25.23	1.38
		10	19.24	1.24	20.43	1.29	21.63	1.33	22.49	1.35	24.02	1.37	25.21	1.40
		14	19.22	1.26	20.42	1.30	21.61	1.35	22.47	1.37	24.00	1.39	25.19	1.42
		20	19.21	1.28	20.40	1.32	21.59	1.37	22.46	1.39	23.98	1.41	25.17	1.44
		25	19.19	1.29	20.39	1.34	21.58	1.39	22.44	1.41	23.96	1.43	25.15	1.46
		30	19.18	1.31	20.37	1.36	21.56	1.41	22.42	1.43	23.94	1.45	25.14	1.48
		35	19.16	1.33	20.36	1.38	21.55	1.43	22.41	1.45	23.93	1.47	25.12	1.50
		40	19.15	1.35	20.34	1.40	21.53	1.45	22.39	1.47	23.91	1.49	25.10	1.52
		45	19.14	1.37	20.32	1.42	21.51	1.47	22.37	1.48	23.89	1.51	25.08	1.54
		50	19.12	1.38	20.31	1.43	21.50	1.49	22.35	1.50	23.87	1.53	25.06	1.56
		55	19.11	1.40	20.29	1.45	21.48	1.51	22.34	1.52	23.85	1.55	25.04	1.58
		60	19.09	1.42	20.28	1.47	21.46	1.53	22.32	1.54	23.83	1.57	25.02	1.60
		65	19.08	1.44	20.26	1.49	21.45	1.55	22.30	1.56	23.82	1.59	25.00	1.62
		70	19.06	1.46	20.25	1.51	21.43	1.56	22.29	1.58	23.80	1.61	24.98	1.65
		75	18.60	1.54	19.78	1.59	20.97	1.65	21.82	1.67	23.33	1.70	24.51	1.73
		80	18.14	1.61	19.32	1.67	20.50	1.73	21.35	1.75	22.86	1.79	24.04	1.82
		85	17.69	1.69	18.87	1.75	20.04	1.82	20.89	1.84	22.39	1.87	23.57	1.91
		90	17.24	1.77	18.41	1.84	19.58	1.90	20.43	1.92	21.92	1.96	23.10	2.00
		95	16.74	1.85	17.91	1.92	19.07	1.99	19.61	2.01	21.41	2.05	22.57	2.09
		100	16.33	1.93	17.50	2.00	18.67	2.07	19.36	2.10	21.00	2.13	22.17	2.18
		105	15.93	2.01	17.09	2.08	18.26	2.16	19.10	2.18	20.59	2.22	21.76	2.27
		110	15.52	2.09	16.69	2.16	17.85	2.24	18.69	2.27	20.18	2.31	21.35	2.36
		115	15.11	2.16	16.28	2.24	17.44	2.32	18.29	2.35	19.78	2.40	20.94	2.44
		118	14.87	2.21	16.03	2.29	17.20	2.38	18.04	2.40	19.53	2.45	20.70	2.50
		122	14.79	2.27	15.95	2.36	17.12	2.44	17.96	2.47	19.45	2.52	20.62	2.57

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 79: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 15	-4	22.03	1.32	23.40	1.37	24.77	1.42	25.76	1.43	27.51	1.46	28.87	1.49
		0	22.02	1.33	23.39	1.38	24.76	1.43	25.74	1.45	27.49	1.48	28.86	1.51
		5	22.00	1.36	23.37	1.40	24.73	1.46	25.72	1.47	27.47	1.50	28.83	1.53
		10	21.99	1.38	23.35	1.43	24.72	1.48	25.70	1.49	27.45	1.52	28.81	1.55
		14	21.97	1.40	23.33	1.45	24.70	1.50	25.68	1.52	27.43	1.54	28.79	1.58
		20	21.95	1.42	23.32	1.47	24.68	1.52	25.66	1.54	27.40	1.57	28.77	1.60
		25	21.93	1.44	23.30	1.49	24.66	1.54	25.64	1.56	27.38	1.59	28.75	1.62
		30	21.92	1.46	23.28	1.51	24.64	1.56	25.62	1.58	27.36	1.61	28.72	1.64
		35	21.90	1.48	23.26	1.53	24.62	1.59	25.60	1.60	27.34	1.63	28.70	1.67
		40	21.88	1.50	23.24	1.55	24.60	1.61	25.58	1.63	27.32	1.66	28.68	1.69
		45	21.87	1.52	23.23	1.57	24.58	1.63	25.56	1.65	27.30	1.68	28.66	1.71
		50	21.85	1.54	23.21	1.59	24.57	1.65	25.55	1.67	27.28	1.70	28.64	1.73
		55	21.83	1.56	23.19	1.61	24.55	1.67	25.53	1.69	27.26	1.72	28.61	1.76
		60	21.82	1.58	23.17	1.63	24.53	1.69	25.51	1.71	27.24	1.74	28.59	1.78
		65	21.80	1.60	23.15	1.65	24.51	1.71	25.49	1.73	27.22	1.77	28.57	1.80
		70	21.78	1.62	23.14	1.68	24.49	1.74	25.47	1.76	27.20	1.79	28.55	1.83
		75	21.26	1.70	22.61	1.77	23.96	1.83	24.93	1.85	26.66	1.89	28.01	1.92
		80	20.74	1.79	22.08	1.86	23.43	1.92	24.40	1.95	26.12	1.98	27.47	2.02
		85	20.22	1.88	21.56	1.95	22.90	2.02	23.87	2.04	25.59	2.08	26.93	2.12
		90	19.70	1.96	21.04	2.04	22.38	2.11	23.34	2.14	25.05	2.18	26.39	2.22
		95	19.13	2.05	20.47	2.13	21.80	2.20	22.41	2.23	24.46	2.27	25.80	2.32
		100	18.67	2.14	20.00	2.22	21.33	2.30	22.12	2.32	24.00	2.37	25.33	2.42
		105	18.20	2.23	19.53	2.31	20.87	2.39	21.83	2.42	23.53	2.46	24.87	2.51
		110	17.73	2.31	19.07	2.40	20.40	2.49	21.36	2.51	23.07	2.56	24.40	2.61
		115	17.27	2.40	18.60	2.49	19.93	2.58	20.90	2.61	22.60	2.66	23.93	2.71
		118	16.99	2.45	18.32	2.54	19.66	2.64	20.62	2.67	22.32	2.72	23.65	2.77
		122	16.90	2.52	18.23	2.61	19.56	2.71	20.52	2.74	22.23	2.79	23.56	2.85
	12 + 12	-4	22.03	1.32	23.40	1.37	24.77	1.42	25.76	1.43	27.51	1.46	28.87	1.49
		0	22.02	1.33	23.39	1.38	24.76	1.43	25.74	1.45	27.49	1.48	28.86	1.51
		5	22.00	1.36	23.37	1.40	24.73	1.46	25.72	1.47	27.47	1.50	28.83	1.53
		10	21.99	1.38	23.35	1.43	24.72	1.48	25.70	1.49	27.45	1.52	28.81	1.55
		14	21.97	1.40	23.33	1.45	24.70	1.50	25.68	1.52	27.43	1.54	28.79	1.58
		20	21.95	1.42	23.32	1.47	24.68	1.52	25.66	1.54	27.40	1.57	28.77	1.60
		25	21.93	1.44	23.30	1.49	24.66	1.54	25.64	1.56	27.38	1.59	28.75	1.62
		30	21.92	1.46	23.28	1.51	24.64	1.56	25.62	1.58	27.36	1.61	28.72	1.64
		35	21.90	1.48	23.26	1.53	24.62	1.59	25.60	1.60	27.34	1.63	28.70	1.67
		40	21.88	1.50	23.24	1.55	24.60	1.61	25.58	1.63	27.32	1.66	28.68	1.69
		45	21.87	1.52	23.23	1.57	24.58	1.63	25.56	1.65	27.30	1.68	28.66	1.71
		50	21.85	1.54	23.21	1.59	24.57	1.65	25.55	1.67	27.28	1.70	28.64	1.73
		55	21.83	1.56	23.19	1.61	24.55	1.67	25.53	1.69	27.26	1.72	28.61	1.76
		60	21.82	1.58	23.17	1.63	24.53	1.69	25.51	1.71	27.24	1.74	28.59	1.78
		65	21.80	1.60	23.15	1.65	24.51	1.71	25.49	1.73	27.22	1.77	28.57	1.80
		70	21.78	1.62	23.14	1.68	24.49	1.74	25.47	1.76	27.20	1.79	28.55	1.83
		75	21.26	1.70	22.61	1.77	23.96	1.83	24.93	1.85	26.66	1.89	28.01	1.92
		80	20.74	1.79	22.08	1.86	23.43	1.92	24.40	1.95	26.12	1.98	27.47	2.02
		85	20.22	1.88	21.56	1.95	22.90	2.02	23.87	2.04	25.59	2.08	26.93	2.12
		90	19.70	1.96	21.04	2.04	22.38	2.11	23.34	2.14	25.05	2.18	26.39	2.22
		95	19.13	2.05	20.47	2.13	21.80	2.20	22.41	2.23	24.46	2.27	25.80	2.32
		100	18.67	2.14	20.00	2.22	21.33	2.30	22.12	2.32	24.00	2.37	25.33	2.42
		105	18.20	2.23	19.53	2.31	20.87	2.39	21.83	2.42	23.53	2.46	24.87	2.51
		110	17.73	2.31	19.07	2.40	20.40	2.49	21.36	2.51	23.07	2.56	24.40	2.61
		115	17.27	2.40	18.60	2.49	19.93	2.58	20.90	2.61	22.60	2.66	23.93	2.71
		118	16.99	2.45	18.32	2.54	19.66	2.64	20.62	2.67	22.32	2.72	23.65	2.77
		122	16.90	2.52	18.23	2.61	19.56	2.71	20.52	2.74	22.23	2.79	23.56	2.85

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 80: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 18	-4	22.96	1.37	24.38	1.42	25.81	1.47	26.84	1.49	28.66	1.51	30.08	1.54
		0	22.94	1.38	24.37	1.43	25.79	1.48	26.82	1.50	28.64	1.53	30.07	1.56
		5	22.92	1.40	24.35	1.46	25.77	1.51	26.80	1.53	28.62	1.55	30.04	1.59
		10	22.91	1.42	24.33	1.48	25.75	1.53	26.78	1.55	28.60	1.58	30.02	1.61
		14	22.89	1.45	24.31	1.50	25.73	1.55	26.76	1.57	28.58	1.60	30.00	1.63
		20	22.87	1.47	24.29	1.52	25.71	1.58	26.74	1.59	28.55	1.62	29.97	1.66
		25	22.86	1.49	24.27	1.54	25.69	1.60	26.72	1.62	28.53	1.65	29.95	1.68
		30	22.84	1.51	24.26	1.56	25.67	1.62	26.70	1.64	28.51	1.67	29.93	1.70
		35	22.82	1.53	24.24	1.58	25.65	1.64	26.68	1.66	28.49	1.69	29.91	1.73
		40	22.80	1.55	24.22	1.61	25.63	1.66	26.66	1.68	28.47	1.72	29.88	1.75
		45	22.79	1.57	24.20	1.63	25.62	1.69	26.64	1.71	28.45	1.74	29.86	1.77
		50	22.77	1.59	24.18	1.65	25.60	1.71	26.62	1.73	28.42	1.76	29.84	1.80
		55	22.75	1.61	24.16	1.67	25.58	1.73	26.60	1.75	28.40	1.78	29.81	1.82
		60	22.73	1.63	24.14	1.69	25.56	1.75	26.58	1.77	28.38	1.81	29.79	1.84
		65	22.72	1.65	24.13	1.71	25.54	1.78	26.56	1.80	28.36	1.83	29.77	1.87
		70	22.70	1.67	24.11	1.74	25.52	1.80	26.54	1.82	28.34	1.85	29.75	1.89
		75	22.15	1.76	23.56	1.83	24.96	1.90	25.98	1.92	27.78	1.95	29.18	1.99
		80	21.61	1.85	23.01	1.92	24.41	1.99	25.42	2.02	27.22	2.05	28.62	2.09
		85	21.06	1.95	22.46	2.02	23.86	2.09	24.87	2.11	26.66	2.15	28.06	2.20
		90	20.52	2.04	21.92	2.11	23.31	2.19	24.32	2.21	26.11	2.25	27.50	2.30
		95	19.94	2.13	21.32	2.20	22.71	2.28	23.35	2.31	25.49	2.35	26.88	2.40
		100	19.45	2.22	20.84	2.30	22.23	2.38	23.05	2.41	25.00	2.45	26.39	2.50
		105	18.96	2.31	20.35	2.39	21.74	2.48	22.74	2.51	24.52	2.55	25.91	2.60
		110	18.48	2.40	19.87	2.48	21.26	2.57	22.26	2.60	24.03	2.65	25.42	2.71
		115	17.99	2.49	19.38	2.58	20.77	2.67	21.77	2.70	23.55	2.75	24.94	2.81
		118	17.70	2.54	19.09	2.63	20.48	2.73	21.48	2.76	23.26	2.81	24.65	2.87
		122	17.61	2.61	18.99	2.71	20.38	2.81	21.39	2.84	23.16	2.89	24.55	2.95
	9 + 18	-4	24.78	1.46	26.32	1.51	27.86	1.57	28.98	1.59	30.94	1.62	32.48	1.65
		0	24.77	1.48	26.31	1.53	27.85	1.59	28.96	1.61	30.93	1.64	32.46	1.67
		5	24.75	1.50	26.29	1.56	27.83	1.61	28.94	1.63	30.90	1.66	32.44	1.70
		10	24.73	1.52	26.27	1.58	27.80	1.64	28.91	1.66	30.88	1.69	32.41	1.72
		14	24.71	1.55	26.25	1.60	27.78	1.66	28.89	1.68	30.85	1.71	32.39	1.75
		20	24.69	1.57	26.23	1.63	27.76	1.68	28.87	1.70	30.83	1.74	32.36	1.77
		25	24.68	1.59	26.21	1.65	27.74	1.71	28.85	1.73	30.81	1.76	32.34	1.80
		30	24.66	1.61	26.19	1.67	27.72	1.73	28.83	1.75	30.78	1.79	32.31	1.82
		35	24.64	1.63	26.17	1.69	27.70	1.76	28.80	1.78	30.76	1.81	32.29	1.85
		40	24.62	1.66	26.15	1.72	27.68	1.78	28.78	1.80	30.73	1.83	32.26	1.87
		45	24.60	1.68	26.13	1.74	27.66	1.80	28.76	1.82	30.71	1.86	32.24	1.90
		50	24.58	1.70	26.11	1.76	27.63	1.83	28.74	1.85	30.69	1.88	32.21	1.92
		55	24.56	1.72	26.09	1.79	27.61	1.85	28.72	1.87	30.66	1.91	32.19	1.95
		60	24.54	1.75	26.07	1.81	27.59	1.88	28.69	1.90	30.64	1.93	32.17	1.97
		65	24.52	1.77	26.05	1.83	27.57	1.90	28.67	1.92	30.62	1.96	32.14	2.00
		70	24.51	1.79	26.03	1.86	27.55	1.92	28.65	1.95	30.59	1.98	32.12	2.02
		75	23.92	1.89	25.43	1.96	26.95	2.03	28.05	2.05	29.99	2.09	31.51	2.13
		80	23.33	1.98	24.84	2.06	26.36	2.13	27.45	2.16	29.38	2.20	30.90	2.24
		85	22.74	2.08	24.25	2.16	25.76	2.23	26.85	2.26	28.78	2.30	30.30	2.35
		90	22.16	2.18	23.66	2.26	25.17	2.34	26.26	2.37	28.19	2.41	29.69	2.46
		95	21.52	2.27	23.02	2.36	24.52	2.44	25.21	2.47	27.52	2.52	29.02	2.57
		100	21.00	2.37	22.50	2.46	24.00	2.55	24.88	2.57	27.00	2.62	28.50	2.68
		105	20.47	2.47	21.97	2.56	23.47	2.65	24.56	2.68	26.47	2.73	27.97	2.78
		110	19.95	2.56	21.45	2.66	22.95	2.75	24.03	2.78	25.95	2.84	27.45	2.89
		115	19.43	2.66	20.93	2.76	22.43	2.86	23.51	2.89	25.42	2.94	26.92	3.00
		118	19.11	2.72	20.61	2.82	22.11	2.92	23.19	2.95	25.11	3.01	26.61	3.07
		122	19.01	2.79	20.51	2.90	22.01	3.00	23.09	3.04	25.01	3.09	26.50	3.16

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 81: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 15	-4	24.78	1.46	26.32	1.51	27.86	1.57	28.98	1.59	30.94	1.62	32.48	1.65
		0	24.77	1.48	26.31	1.53	27.85	1.59	28.96	1.61	30.93	1.64	32.46	1.67
		5	24.75	1.50	26.29	1.56	27.83	1.61	28.94	1.63	30.90	1.66	32.44	1.70
		10	24.73	1.52	26.27	1.58	27.80	1.64	28.91	1.66	30.88	1.69	32.41	1.72
		14	24.71	1.55	26.25	1.60	27.78	1.66	28.89	1.68	30.85	1.71	32.39	1.75
		20	24.69	1.57	26.23	1.63	27.76	1.68	28.87	1.70	30.83	1.74	32.36	1.77
		25	24.68	1.59	26.21	1.65	27.74	1.71	28.85	1.73	30.81	1.76	32.34	1.80
		30	24.66	1.61	26.19	1.67	27.72	1.73	28.83	1.75	30.78	1.79	32.31	1.82
		35	24.64	1.63	26.17	1.69	27.70	1.76	28.80	1.78	30.76	1.81	32.29	1.85
		40	24.62	1.66	26.15	1.72	27.68	1.78	28.78	1.80	30.73	1.83	32.26	1.87
		45	24.60	1.68	26.13	1.74	27.66	1.80	28.76	1.82	30.71	1.86	32.24	1.90
		50	24.58	1.70	26.11	1.76	27.63	1.83	28.74	1.85	30.69	1.88	32.21	1.92
		55	24.56	1.72	26.09	1.79	27.61	1.85	28.72	1.87	30.66	1.91	32.19	1.95
		60	24.54	1.75	26.07	1.81	27.59	1.88	28.69	1.90	30.64	1.93	32.17	1.97
		65	24.52	1.77	26.05	1.83	27.57	1.90	28.67	1.92	30.62	1.96	32.14	2.00
		70	24.51	1.79	26.03	1.86	27.55	1.92	28.65	1.95	30.59	1.98	32.12	2.02
		75	23.92	1.89	25.43	1.96	26.95	2.03	28.05	2.05	29.99	2.09	31.51	2.13
		80	23.33	1.98	24.84	2.06	26.36	2.13	27.45	2.16	29.38	2.20	30.90	2.24
		85	22.74	2.08	24.25	2.16	25.76	2.23	26.85	2.26	28.78	2.30	30.30	2.35
		90	22.16	2.18	23.66	2.26	25.17	2.34	26.26	2.37	28.19	2.41	29.69	2.46
		95	21.52	2.27	23.02	2.36	24.52	2.44	25.21	2.47	27.52	2.52	29.02	2.57
		100	21.00	2.37	22.50	2.46	24.00	2.55	24.88	2.57	27.00	2.62	28.50	2.68
		105	20.47	2.47	21.97	2.56	23.47	2.65	24.56	2.68	26.47	2.73	27.97	2.78
		110	19.95	2.56	21.45	2.66	22.95	2.75	24.03	2.78	25.95	2.84	27.45	2.89
		115	19.43	2.66	20.93	2.76	22.43	2.86	23.51	2.89	25.42	2.94	26.92	3.00
		118	19.11	2.72	20.61	2.82	22.11	2.92	23.19	2.95	25.11	3.01	26.61	3.07
		122	19.01	2.79	20.51	2.90	22.01	3.00	23.09	3.04	25.01	3.09	26.50	3.16
	12 + 18	-4	27.55	1.59	29.26	1.65	30.97	1.71	32.20	1.73	34.39	1.76	36.10	1.80
		0	27.53	1.61	29.24	1.67	30.95	1.73	32.19	1.75	34.37	1.78	36.08	1.82
		5	27.51	1.64	29.22	1.69	30.93	1.76	32.16	1.78	34.34	1.81	36.05	1.85
		10	27.49	1.66	29.20	1.72	30.90	1.78	32.14	1.80	34.32	1.84	36.02	1.87
		14	27.47	1.68	29.17	1.74	30.88	1.81	32.11	1.83	34.29	1.86	36.00	1.90
		20	27.45	1.71	29.15	1.77	30.86	1.83	32.09	1.86	34.27	1.89	35.97	1.93
		25	27.43	1.73	29.13	1.80	30.83	1.86	32.06	1.88	34.24	1.92	35.94	1.96
		30	27.41	1.76	29.11	1.82	30.81	1.89	32.04	1.91	34.21	1.94	35.91	1.98
		35	27.38	1.78	29.08	1.85	30.79	1.91	32.01	1.93	34.19	1.97	35.89	2.01
		40	27.36	1.80	29.06	1.87	30.76	1.94	31.99	1.96	34.16	2.00	35.86	2.04
		45	27.34	1.83	29.04	1.90	30.74	1.96	31.96	1.99	34.13	2.02	35.83	2.07
		50	27.32	1.85	29.02	1.92	30.71	1.99	31.94	2.01	34.11	2.05	35.81	2.09
		55	27.30	1.88	29.00	1.95	30.69	2.02	31.92	2.04	34.08	2.08	35.78	2.12
		60	27.28	1.90	28.97	1.97	30.67	2.04	31.89	2.07	34.06	2.10	35.75	2.15
		65	27.26	1.93	28.95	2.00	30.64	2.07	31.87	2.09	34.03	2.13	35.72	2.17
		70	27.24	1.95	28.93	2.02	30.62	2.09	31.84	2.12	34.00	2.16	35.70	2.20
		75	26.58	2.05	28.27	2.13	29.96	2.21	31.18	2.23	33.33	2.27	35.02	2.32
		80	25.93	2.16	27.61	2.24	29.29	2.32	30.51	2.35	32.66	2.39	34.34	2.44
		85	25.28	2.26	26.96	2.35	28.64	2.43	29.85	2.46	31.99	2.51	33.67	2.56
		90	24.63	2.37	26.30	2.46	27.98	2.55	29.19	2.58	31.33	2.62	33.00	2.68
		95	23.92	2.48	25.59	2.57	27.26	2.66	28.02	2.69	30.59	2.74	32.26	2.80
		100	23.34	2.58	25.01	2.67	26.67	2.77	27.66	2.80	30.01	2.86	31.67	2.91
		105	22.76	2.69	24.42	2.78	26.09	2.89	27.29	2.92	29.42	2.97	31.09	3.03
		110	22.17	2.79	23.84	2.89	25.51	3.00	26.71	3.03	28.84	3.09	30.51	3.15
		115	21.59	2.90	23.26	3.00	24.93	3.11	26.13	3.15	28.26	3.21	29.92	3.27
		118	21.24	2.96	22.91	3.07	24.58	3.18	25.78	3.22	27.91	3.28	29.58	3.34
		122	21.13	3.04	22.79	3.15	24.46	3.27	25.66	3.31	27.79	3.37	29.46	3.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU30CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 82: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 24	-4	27.88	1.59	29.61	1.65	31.34	1.71	32.60	1.73	34.81	1.76	36.54	1.80
		0	27.87	1.61	29.60	1.67	31.33	1.73	32.58	1.75	34.79	1.78	36.52	1.82
		5	27.84	1.64	29.57	1.69	31.30	1.76	32.55	1.78	34.76	1.81	36.49	1.85
		10	27.82	1.66	29.55	1.72	31.28	1.78	32.53	1.80	34.73	1.84	36.46	1.87
		14	27.80	1.68	29.53	1.74	31.25	1.81	32.50	1.83	34.71	1.86	36.43	1.90
		20	27.78	1.71	29.51	1.77	31.23	1.83	32.48	1.86	34.68	1.89	36.41	1.93
		25	27.76	1.73	29.48	1.80	31.21	1.86	32.45	1.88	34.65	1.92	36.38	1.96
		30	27.74	1.76	29.46	1.82	31.18	1.89	32.43	1.91	34.63	1.94	36.35	1.98
		35	27.72	1.78	29.44	1.85	31.16	1.91	32.40	1.93	34.60	1.97	36.32	2.01
		40	27.70	1.80	29.42	1.87	31.14	1.94	32.38	1.96	34.58	2.00	36.30	2.04
		45	27.67	1.83	29.39	1.90	31.11	1.96	32.35	1.99	34.55	2.02	36.27	2.07
		50	27.65	1.85	29.37	1.92	31.09	1.99	32.33	2.01	34.52	2.05	36.24	2.09
		55	27.63	1.88	29.35	1.95	31.06	2.02	32.30	2.04	34.50	2.08	36.21	2.12
		60	27.61	1.90	29.33	1.97	31.04	2.04	32.28	2.07	34.47	2.10	36.18	2.15
		65	27.59	1.93	29.30	2.00	31.02	2.07	32.25	2.09	34.44	2.13	36.16	2.17
		70	27.57	1.95	29.28	2.02	30.99	2.09	32.23	2.12	34.42	2.16	36.13	2.20
		75	26.90	2.05	28.61	2.13	30.32	2.21	31.55	2.23	33.74	2.27	35.44	2.32
		80	26.24	2.16	27.94	2.24	29.65	2.32	30.88	2.35	33.06	2.39	34.76	2.44
		85	25.58	2.26	27.28	2.35	28.98	2.43	30.21	2.46	32.38	2.51	34.08	2.56
		90	24.93	2.37	26.62	2.46	28.32	2.55	29.54	2.58	31.71	2.62	33.40	2.68
		95	24.21	2.48	25.90	2.57	27.59	2.66	28.36	2.69	30.96	2.74	32.65	2.80
		100	23.62	2.58	25.31	2.67	27.00	2.77	27.99	2.80	30.37	2.86	32.06	2.91
		105	23.03	2.69	24.72	2.78	26.41	2.89	27.63	2.92	29.78	2.97	31.47	3.03
		110	22.44	2.79	24.13	2.89	25.82	3.00	27.04	3.03	29.19	3.09	30.88	3.15
		115	21.85	2.90	23.54	3.00	25.23	3.11	26.45	3.15	28.60	3.21	30.29	3.27
		118	21.50	2.96	23.19	3.07	24.87	3.18	26.09	3.22	28.25	3.28	29.93	3.34
		122	21.38	3.04	23.07	3.15	24.76	3.27	25.97	3.31	28.13	3.37	29.82	3.44
	9 + 24*	-4	28.22	1.59	29.97	1.65	31.72	1.71	32.99	1.73	35.23	1.76	36.98	1.80
		0	28.20	1.61	29.95	1.67	31.70	1.73	32.97	1.75	35.21	1.78	36.96	1.82
		5	28.18	1.64	29.93	1.69	31.68	1.76	32.94	1.78	35.18	1.81	36.93	1.85
		10	28.16	1.66	29.90	1.72	31.65	1.78	32.92	1.80	35.15	1.84	36.90	1.87
		14	28.13	1.68	29.88	1.74	31.63	1.81	32.89	1.83	35.12	1.86	36.87	1.90
		20	28.11	1.71	29.86	1.77	31.60	1.83	32.87	1.86	35.10	1.89	36.84	1.93
		25	28.09	1.73	29.84	1.80	31.58	1.86	32.84	1.88	35.07	1.92	36.81	1.96
		30	28.07	1.76	29.81	1.82	31.56	1.89	32.82	1.91	35.04	1.94	36.79	1.98
		35	28.05	1.78	29.79	1.85	31.53	1.91	32.79	1.93	35.02	1.97	36.76	2.01
		40	28.03	1.80	29.77	1.87	31.51	1.94	32.77	1.96	34.99	2.00	36.73	2.04
		45	28.01	1.83	29.75	1.90	31.48	1.96	32.74	1.99	34.96	2.02	36.70	2.07
		50	27.98	1.85	29.72	1.92	31.46	1.99	32.72	2.01	34.94	2.05	36.67	2.09
		55	27.96	1.88	29.70	1.95	31.44	2.02	32.69	2.04	34.91	2.08	36.65	2.12
		60	27.94	1.90	29.68	1.97	31.41	2.04	32.67	2.07	34.88	2.10	36.62	2.15
		65	27.92	1.93	29.65	2.00	31.39	2.07	32.64	2.09	34.86	2.13	36.59	2.17
		70	27.90	1.95	29.63	2.02	31.36	2.09	32.62	2.12	34.83	2.16	36.56	2.20
		75	27.23	2.05	28.96	2.13	30.68	2.21	31.93	2.23	34.14	2.27	35.87	2.32
		80	26.56	2.16	28.28	2.24	30.00	2.32	31.25	2.35	33.45	2.39	35.18	2.44
		85	25.89	2.26	27.61	2.35	29.33	2.43	30.57	2.46	32.77	2.51	34.49	2.56
		90	25.22	2.37	26.94	2.46	28.66	2.55	29.90	2.58	32.09	2.62	33.80	2.68
		95	24.50	2.48	26.21	2.57	27.92	2.66	28.70	2.69	31.33	2.74	33.04	2.80
		100	23.91	2.58	25.61	2.67	27.32	2.77	28.33	2.80	30.73	2.86	32.44	2.91
		105	23.31	2.69	25.02	2.78	26.72	2.89	27.96	2.92	30.14	2.97	31.84	3.03
		110	22.71	2.79	24.42	2.89	26.13	3.00	27.36	3.03	29.54	3.09	31.25	3.15
		115	22.12	2.90	23.82	3.00	25.53	3.11	26.76	3.15	28.94	3.21	30.65	3.27
		118	21.76	2.96	23.47	3.07	25.17	3.18	26.40	3.22	28.59	3.28	30.29	3.34
		122	21.64	3.04	23.35	3.15	25.05	3.27	26.29	3.31	28.47	3.37	30.17	3.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

*The indoor unit must be non-ducted type.

Table 83: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	15 + 18	-4	28.22	1.59	29.97	1.65	31.72	1.71	32.99	1.73	35.23	1.76	36.98	1.80
		0	28.20	1.61	29.95	1.67	31.70	1.73	32.97	1.75	35.21	1.78	36.96	1.82
		5	28.18	1.64	29.93	1.69	31.68	1.76	32.94	1.78	35.18	1.81	36.93	1.85
		10	28.16	1.66	29.90	1.72	31.65	1.78	32.92	1.80	35.15	1.84	36.90	1.87
		14	28.13	1.68	29.88	1.74	31.63	1.81	32.89	1.83	35.12	1.86	36.87	1.90
		20	28.11	1.71	29.86	1.77	31.60	1.83	32.87	1.86	35.10	1.89	36.84	1.93
		25	28.09	1.73	29.84	1.80	31.58	1.86	32.84	1.88	35.07	1.92	36.81	1.96
		30	28.07	1.76	29.81	1.82	31.56	1.89	32.82	1.91	35.04	1.94	36.79	1.98
		35	28.05	1.78	29.79	1.85	31.53	1.91	32.79	1.93	35.02	1.97	36.76	2.01
		40	28.03	1.80	29.77	1.87	31.51	1.94	32.77	1.96	34.99	2.00	36.73	2.04
		45	28.01	1.83	29.75	1.90	31.48	1.96	32.74	1.99	34.96	2.02	36.70	2.07
		50	27.98	1.85	29.72	1.92	31.46	1.99	32.72	2.01	34.94	2.05	36.67	2.09
		55	27.96	1.88	29.70	1.95	31.44	2.02	32.69	2.04	34.91	2.08	36.65	2.12
		60	27.94	1.90	29.68	1.97	31.41	2.04	32.67	2.07	34.88	2.10	36.62	2.15
		65	27.92	1.93	29.65	2.00	31.39	2.07	32.64	2.09	34.86	2.13	36.59	2.17
		70	27.90	1.95	29.63	2.02	31.36	2.09	32.62	2.12	34.83	2.16	36.56	2.20
		75	27.23	2.05	28.96	2.13	30.68	2.21	31.93	2.23	34.14	2.27	35.87	2.32
		80	26.56	2.16	28.28	2.24	30.00	2.32	31.25	2.35	33.45	2.39	35.18	2.44
		85	25.89	2.26	27.61	2.35	29.33	2.43	30.57	2.46	32.77	2.51	34.49	2.56
		90	25.22	2.37	26.94	2.46	28.66	2.55	29.90	2.58	32.09	2.62	33.80	2.68
		95	24.50	2.48	26.21	2.57	27.92	2.66	28.70	2.69	31.33	2.74	33.04	2.80
		100	23.91	2.58	25.61	2.67	27.32	2.77	28.33	2.80	30.73	2.86	32.44	2.91
		105	23.31	2.69	25.02	2.78	26.72	2.89	27.96	2.92	30.14	2.97	31.84	3.03
		110	22.71	2.79	24.42	2.89	26.13	3.00	27.36	3.03	29.54	3.09	31.25	3.15
		115	22.12	2.90	23.82	3.00	25.53	3.11	26.76	3.15	28.94	3.21	30.65	3.27
		118	21.76	2.96	23.47	3.07	25.17	3.18	26.40	3.22	28.59	3.28	30.29	3.34
		122	21.64	3.04	23.35	3.15	25.05	3.27	26.29	3.31	28.47	3.37	30.17	3.44
	18 + 18	-4	28.22	1.59	29.97	1.65	31.72	1.71	32.99	1.73	35.23	1.76	36.98	1.80
		0	28.20	1.61	29.95	1.67	31.70	1.73	32.97	1.75	35.21	1.78	36.96	1.82
		5	28.18	1.64	29.93	1.69	31.68	1.76	32.94	1.78	35.18	1.81	36.93	1.85
		10	28.16	1.66	29.90	1.72	31.65	1.78	32.92	1.80	35.15	1.84	36.90	1.87
		14	28.13	1.68	29.88	1.74	31.63	1.81	32.89	1.83	35.12	1.86	36.87	1.90
		20	28.11	1.71	29.86	1.77	31.60	1.83	32.87	1.86	35.10	1.89	36.84	1.93
		25	28.09	1.73	29.84	1.80	31.58	1.86	32.84	1.88	35.07	1.92	36.81	1.96
		30	28.07	1.76	29.81	1.82	31.56	1.89	32.82	1.91	35.04	1.94	36.79	1.98
		35	28.05	1.78	29.79	1.85	31.53	1.91	32.79	1.93	35.02	1.97	36.76	2.01
		40	28.03	1.80	29.77	1.87	31.51	1.94	32.77	1.96	34.99	2.00	36.73	2.04
		45	28.01	1.83	29.75	1.90	31.48	1.96	32.74	1.99	34.96	2.02	36.70	2.07
		50	27.98	1.85	29.72	1.92	31.46	1.99	32.72	2.01	34.94	2.05	36.67	2.09
		55	27.96	1.88	29.70	1.95	31.44	2.02	32.69	2.04	34.91	2.08	36.65	2.12
		60	27.94	1.90	29.68	1.97	31.41	2.04	32.67	2.07	34.88	2.10	36.62	2.15
		65	27.92	1.93	29.65	2.00	31.39	2.07	32.64	2.09	34.86	2.13	36.59	2.17
		70	27.90	1.95	29.63	2.02	31.36	2.09	32.62	2.12	34.83	2.16	36.56	2.20
		75	27.23	2.05	28.96	2.13	30.68	2.21	31.93	2.23	34.14	2.27	35.87	2.32
		80	26.56	2.16	28.28	2.24	30.00	2.32	31.25	2.35	33.45	2.39	35.18	2.44
		85	25.89	2.26	27.61	2.35	29.33	2.43	30.57	2.46	32.77	2.51	34.49	2.56
		90	25.22	2.37	26.94	2.46	28.66	2.55	29.90	2.58	32.09	2.62	33.80	2.68
		95	24.50	2.48	26.21	2.57	27.92	2.66	28.70	2.69	31.33	2.74	33.04	2.80
		100	23.91	2.58	25.61	2.67	27.32	2.77	28.33	2.80	30.73	2.86	32.44	2.91
		105	23.31	2.69	25.02	2.78	26.72	2.89	27.96	2.92	30.14	2.97	31.84	3.03
		110	22.71	2.79	24.42	2.89	26.13	3.00	27.36	3.03	29.54	3.09	31.25	3.15
		115	22.12	2.90	23.82	3.00	25.53	3.11	26.76	3.15	28.94	3.21	30.65	3.27
		118	21.76	2.96	23.47	3.07	25.17	3.18	26.40	3.22	28.59	3.28	30.29	3.34
		122	21.64	3.04	23.35	3.15	25.05	3.27	26.29	3.31	28.47	3.37	30.17	3.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 84: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 24*	-4	28.22	1.59	29.97	1.65	31.72	1.71	32.99	1.73	35.23	1.76	36.98	1.80
		0	28.20	1.61	29.95	1.67	31.70	1.73	32.97	1.75	35.21	1.78	36.96	1.82
		5	28.18	1.64	29.93	1.69	31.68	1.76	32.94	1.78	35.18	1.81	36.93	1.85
		10	28.16	1.66	29.90	1.72	31.65	1.78	32.92	1.80	35.15	1.84	36.90	1.87
		14	28.13	1.68	29.88	1.74	31.63	1.81	32.89	1.83	35.12	1.86	36.87	1.90
		20	28.11	1.71	29.86	1.77	31.60	1.83	32.87	1.86	35.10	1.89	36.84	1.93
		25	28.09	1.73	29.84	1.80	31.58	1.86	32.84	1.88	35.07	1.92	36.81	1.96
		30	28.07	1.76	29.81	1.82	31.56	1.89	32.82	1.91	35.04	1.94	36.79	1.98
		35	28.05	1.78	29.79	1.85	31.53	1.91	32.79	1.93	35.02	1.97	36.76	2.01
		40	28.03	1.80	29.77	1.87	31.51	1.94	32.77	1.96	34.99	2.00	36.73	2.04
		45	28.01	1.83	29.75	1.90	31.48	1.96	32.74	1.99	34.96	2.02	36.70	2.07
		50	27.98	1.85	29.72	1.92	31.46	1.99	32.72	2.01	34.94	2.05	36.67	2.09
		55	27.96	1.88	29.70	1.95	31.44	2.02	32.69	2.04	34.91	2.08	36.65	2.12
		60	27.94	1.90	29.68	1.97	31.41	2.04	32.67	2.07	34.88	2.10	36.62	2.15
		65	27.92	1.93	29.65	2.00	31.39	2.07	32.64	2.09	34.86	2.13	36.59	2.17
		70	27.90	1.95	29.63	2.02	31.36	2.09	32.62	2.12	34.83	2.16	36.56	2.20
		75	27.23	2.05	28.96	2.13	30.68	2.21	31.93	2.23	34.14	2.27	35.87	2.32
		80	26.56	2.16	28.28	2.24	30.00	2.32	31.25	2.35	33.45	2.39	35.18	2.44
		85	25.89	2.26	27.61	2.35	29.33	2.43	30.57	2.46	32.77	2.51	34.49	2.56
		90	25.22	2.37	26.94	2.46	28.66	2.55	29.90	2.58	32.09	2.62	33.80	2.68
		95	24.50	2.48	26.21	2.57	27.92	2.66	28.70	2.69	31.33	2.74	33.04	2.80
		100	23.91	2.58	25.61	2.67	27.32	2.77	28.33	2.80	30.73	2.86	32.44	2.91
		105	23.31	2.69	25.02	2.78	26.72	2.89	27.96	2.92	30.14	2.97	31.84	3.03
		110	22.71	2.79	24.42	2.89	26.13	3.00	27.36	3.03	29.54	3.09	31.25	3.15
		115	22.12	2.90	23.82	3.00	25.53	3.11	26.76	3.15	28.94	3.21	30.65	3.27
		118	21.76	2.96	23.47	3.07	25.17	3.18	26.40	3.22	28.59	3.28	30.29	3.34
		122	21.64	3.04	23.35	3.15	25.05	3.27	26.29	3.31	28.47	3.37	30.17	3.44
	15 + 24*	-4	28.22	1.59	29.97	1.65	31.72	1.71	32.99	1.73	35.23	1.76	36.98	1.80
		0	28.20	1.61	29.95	1.67	31.70	1.73	32.97	1.75	35.21	1.78	36.96	1.82
		5	28.18	1.64	29.93	1.69	31.68	1.76	32.94	1.78	35.18	1.81	36.93	1.85
		10	28.16	1.66	29.90	1.72	31.65	1.78	32.92	1.80	35.15	1.84	36.90	1.87
		14	28.13	1.68	29.88	1.74	31.63	1.81	32.89	1.83	35.12	1.86	36.87	1.90
		20	28.11	1.71	29.86	1.77	31.60	1.83	32.87	1.86	35.10	1.89	36.84	1.93
		25	28.09	1.73	29.84	1.80	31.58	1.86	32.84	1.88	35.07	1.92	36.81	1.96
		30	28.07	1.76	29.81	1.82	31.56	1.89	32.82	1.91	35.04	1.94	36.79	1.98
		35	28.05	1.78	29.79	1.85	31.53	1.91	32.79	1.93	35.02	1.97	36.76	2.01
		40	28.03	1.80	29.77	1.87	31.51	1.94	32.77	1.96	34.99	2.00	36.73	2.04
		45	28.01	1.83	29.75	1.90	31.48	1.96	32.74	1.99	34.96	2.02	36.70	2.07
		50	27.98	1.85	29.72	1.92	31.46	1.99	32.72	2.01	34.94	2.05	36.67	2.09
		55	27.96	1.88	29.70	1.95	31.44	2.02	32.69	2.04	34.91	2.08	36.65	2.12
		60	27.94	1.90	29.68	1.97	31.41	2.04	32.67	2.07	34.88	2.10	36.62	2.15
		65	27.92	1.93	29.65	2.00	31.39	2.07	32.64	2.09	34.86	2.13	36.59	2.17
		70	27.90	1.95	29.63	2.02	31.36	2.09	32.62	2.12	34.83	2.16	36.56	2.20
		75	27.23	2.05	28.96	2.13	30.68	2.21	31.93	2.23	34.14	2.27	35.87	2.32
		80	26.56	2.16	28.28	2.24	30.00	2.32	31.25	2.35	33.45	2.39	35.18	2.44
		85	25.89	2.26	27.61	2.35	29.33	2.43	30.57	2.46	32.77	2.51	34.49	2.56
		90	25.22	2.37	26.94	2.46	28.66	2.55	29.90	2.58	32.09	2.62	33.80	2.68
		95	24.50	2.48	26.21	2.57	27.92	2.66	28.70	2.69	31.33	2.74	33.04	2.80
		100	23.91	2.58	25.61	2.67	27.32	2.77	28.33	2.80	30.73	2.86	32.44	2.91
		105	23.31	2.69	25.02	2.78	26.72	2.89	27.96	2.92	30.14	2.97	31.84	3.03
		110	22.71	2.79	24.42	2.89	26.13	3.00	27.36	3.03	29.54	3.09	31.25	3.15
		115	22.12	2.90	23.82	3.00	25.53	3.11	26.76	3.15	28.94	3.21	30.65	3.27
		118	21.76	2.96	23.47	3.07	25.17	3.18	26.40	3.22	28.59	3.28	30.29	3.34
		122	21.64	3.04	23.35	3.15	25.05	3.27	26.29	3.31	28.47	3.37	30.17	3.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

*The indoor unit must be non-ducted type.

Table 85: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 9	-4	21.12	1.24	22.43	1.29	23.74	1.33	24.69	1.35	26.36	1.38	27.68	1.40
		0	21.11	1.26	22.42	1.30	23.73	1.35	24.67	1.36	26.35	1.39	27.66	1.42
		5	21.09	1.28	22.40	1.32	23.71	1.37	24.65	1.39	26.33	1.41	27.64	1.44
		10	21.07	1.30	22.38	1.34	23.69	1.39	24.64	1.41	26.31	1.43	27.62	1.46
		14	21.06	1.31	22.36	1.36	23.67	1.41	24.62	1.43	26.29	1.45	27.60	1.48
		20	21.04	1.33	22.35	1.38	23.65	1.43	24.60	1.45	26.27	1.48	27.57	1.51
		25	21.02	1.35	22.33	1.40	23.64	1.45	24.58	1.47	26.25	1.50	27.55	1.53
		30	21.01	1.37	22.31	1.42	23.62	1.47	24.56	1.49	26.23	1.52	27.53	1.55
		35	20.99	1.39	22.30	1.44	23.60	1.49	24.54	1.51	26.21	1.54	27.51	1.57
		40	20.98	1.41	22.28	1.46	23.58	1.51	24.52	1.53	26.19	1.56	27.49	1.59
		45	20.96	1.43	22.26	1.48	23.56	1.53	24.50	1.55	26.17	1.58	27.47	1.61
		50	20.94	1.45	22.25	1.50	23.55	1.55	24.49	1.57	26.15	1.60	27.45	1.63
		55	20.93	1.47	22.23	1.52	23.53	1.57	24.47	1.59	26.13	1.62	27.43	1.65
		60	20.91	1.48	22.21	1.54	23.51	1.59	24.45	1.61	26.11	1.64	27.41	1.68
		65	20.90	1.50	22.19	1.56	23.49	1.61	24.43	1.63	26.09	1.66	27.38	1.70
		70	20.88	1.52	22.18	1.58	23.47	1.64	24.41	1.65	26.07	1.68	27.36	1.72
		75	20.38	1.60	21.67	1.66	22.96	1.72	23.90	1.74	25.55	1.78	26.85	1.81
		80	19.88	1.69	21.17	1.75	22.46	1.81	23.39	1.83	25.04	1.87	26.33	1.90
		85	19.38	1.77	20.66	1.83	21.95	1.90	22.88	1.92	24.53	1.96	25.81	2.00
		90	18.88	1.85	20.16	1.92	21.45	1.99	22.37	2.01	24.02	2.05	25.30	2.09
		95	18.34	1.93	19.62	2.00	20.89	2.08	21.48	2.10	23.45	2.14	24.73	2.18
		100	17.89	2.01	19.17	2.09	20.45	2.16	21.20	2.19	23.00	2.23	24.28	2.28
		105	17.45	2.10	18.72	2.17	20.00	2.25	20.92	2.28	22.56	2.32	23.83	2.37
		110	17.00	2.18	18.28	2.26	19.55	2.34	20.48	2.37	22.11	2.41	23.39	2.46
		115	16.55	2.26	17.83	2.34	19.11	2.43	20.03	2.46	21.66	2.50	22.94	2.55
		118	16.28	2.31	17.56	2.39	18.84	2.48	19.76	2.51	21.39	2.56	22.67	2.61
		122	16.20	2.38	17.47	2.46	18.75	2.55	19.67	2.58	21.31	2.63	22.58	2.68
	7 + 9 + 9	-4	22.96	1.34	24.38	1.39	25.81	1.44	26.84	1.46	28.66	1.49	30.08	1.52
		0	22.94	1.36	24.37	1.41	25.79	1.46	26.82	1.48	28.64	1.50	30.07	1.53
		5	22.92	1.38	24.35	1.43	25.77	1.48	26.80	1.50	28.62	1.53	30.04	1.56
		10	22.91	1.40	24.33	1.45	25.75	1.50	26.78	1.52	28.60	1.55	30.02	1.58
		14	22.89	1.42	24.31	1.47	25.73	1.53	26.76	1.54	28.58	1.57	30.00	1.60
		20	22.87	1.44	24.29	1.49	25.71	1.55	26.74	1.57	28.55	1.60	29.97	1.63
		25	22.86	1.46	24.27	1.51	25.69	1.57	26.72	1.59	28.53	1.62	29.95	1.65
		30	22.84	1.48	24.26	1.54	25.67	1.59	26.70	1.61	28.51	1.64	29.93	1.67
		35	22.82	1.50	24.24	1.56	25.65	1.61	26.68	1.63	28.49	1.66	29.91	1.70
		40	22.80	1.52	24.22	1.58	25.63	1.64	26.66	1.65	28.47	1.69	29.88	1.72
		45	22.79	1.54	24.20	1.60	25.62	1.66	26.64	1.68	28.45	1.71	29.86	1.74
		50	22.77	1.56	24.18	1.62	25.60	1.68	26.62	1.70	28.42	1.73	29.84	1.77
		55	22.75	1.58	24.16	1.64	25.58	1.70	26.60	1.72	28.40	1.75	29.81	1.79
		60	22.73	1.60	24.14	1.66	25.56	1.72	26.58	1.74	28.38	1.78	29.79	1.81
		65	22.72	1.62	24.13	1.68	25.54	1.75	26.56	1.77	28.36	1.80	29.77	1.83
		70	22.70	1.65	24.11	1.71	25.52	1.77	26.54	1.79	28.34	1.82	29.75	1.86
		75	22.15	1.73	23.56	1.80	24.96	1.86	25.98	1.88	27.78	1.92	29.18	1.96
		80	21.61	1.82	23.01	1.89	24.41	1.96	25.42	1.98	27.22	2.02	28.62	2.06
		85	21.06	1.91	22.46	1.98	23.86	2.05	24.87	2.08	26.66	2.12	28.06	2.16
		90	20.52	2.00	21.92	2.07	23.31	2.15	24.32	2.17	26.11	2.21	27.50	2.26
		95	19.94	2.09	21.32	2.17	22.71	2.24	23.35	2.27	25.49	2.31	26.88	2.36
		100	19.45	2.18	20.84	2.26	22.23	2.34	23.05	2.37	25.00	2.41	26.39	2.46
		105	18.96	2.27	20.35	2.35	21.74	2.43	22.74	2.46	24.52	2.51	25.91	2.56
		110	18.48	2.36	19.87	2.44	21.26	2.53	22.26	2.56	24.03	2.61	25.42	2.66
		115	17.99	2.44	19.38	2.53	20.77	2.63	21.77	2.66	23.55	2.71	24.94	2.76
		118	17.70	2.50	19.09	2.59	20.48	2.68	21.48	2.71	23.26	2.76	24.65	2.82
		122	17.61	2.57	18.99	2.66	20.38	2.76	21.39	2.79	23.16	2.84	24.55	2.90

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 86: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 12	-4	23.87	1.37	25.35	1.42	26.84	1.47	27.91	1.49	29.80	1.51	31.28	1.54
		0	23.86	1.38	25.34	1.43	26.82	1.48	27.89	1.50	29.78	1.53	31.27	1.56
		5	23.84	1.40	25.32	1.46	26.80	1.51	27.87	1.53	29.76	1.55	31.24	1.59
		10	23.82	1.42	25.30	1.48	26.78	1.53	27.85	1.55	29.74	1.58	31.22	1.61
		14	23.80	1.45	25.28	1.50	26.76	1.55	27.83	1.57	29.71	1.60	31.19	1.63
		20	23.78	1.47	25.26	1.52	26.74	1.58	27.80	1.59	29.69	1.62	31.17	1.66
		25	23.77	1.49	25.24	1.54	26.72	1.60	27.78	1.62	29.67	1.65	31.14	1.68
		30	23.75	1.51	25.22	1.56	26.70	1.62	27.76	1.64	29.65	1.67	31.12	1.70
		35	23.73	1.53	25.20	1.58	26.68	1.64	27.74	1.66	29.62	1.69	31.10	1.73
		40	23.71	1.55	25.18	1.61	26.66	1.66	27.72	1.68	29.60	1.72	31.07	1.75
		45	23.69	1.57	25.16	1.63	26.64	1.69	27.70	1.71	29.58	1.74	31.05	1.77
		50	23.67	1.59	25.14	1.65	26.62	1.71	27.68	1.73	29.56	1.76	31.03	1.80
		55	23.66	1.61	25.13	1.67	26.59	1.73	27.66	1.75	29.53	1.78	31.00	1.82
		60	23.64	1.63	25.11	1.69	26.57	1.75	27.63	1.77	29.51	1.81	30.98	1.84
		65	23.62	1.65	25.09	1.71	26.55	1.78	27.61	1.80	29.49	1.83	30.95	1.87
		70	23.60	1.67	25.07	1.74	26.53	1.80	27.59	1.82	29.47	1.85	30.93	1.89
		75	23.03	1.76	24.50	1.83	25.96	1.90	27.01	1.92	28.88	1.95	30.34	1.99
		80	22.47	1.85	23.92	1.92	25.38	1.99	26.44	2.02	28.30	2.05	29.76	2.09
		85	21.90	1.95	23.36	2.02	24.81	2.09	25.86	2.11	27.72	2.15	29.18	2.20
		90	21.34	2.04	22.79	2.11	24.24	2.19	25.29	2.21	27.15	2.25	28.60	2.30
		95	20.73	2.13	22.17	2.20	23.62	2.28	24.28	2.31	26.51	2.35	27.95	2.40
		100	20.22	2.22	21.67	2.30	23.11	2.38	23.97	2.41	26.00	2.45	27.45	2.50
		105	19.72	2.31	21.16	2.39	22.61	2.48	23.65	2.51	25.50	2.55	26.94	2.60
		110	19.21	2.40	20.66	2.48	22.10	2.57	23.15	2.60	24.99	2.65	26.44	2.71
		115	18.71	2.49	20.15	2.58	21.60	2.67	22.64	2.70	24.49	2.75	25.93	2.81
		118	18.41	2.54	19.85	2.63	21.30	2.73	22.34	2.76	24.18	2.81	25.63	2.87
		122	18.31	2.61	19.75	2.71	21.19	2.81	22.24	2.84	24.08	2.89	25.53	2.95
	9 + 9 + 9	-4	24.78	1.39	26.32	1.44	27.86	1.49	28.98	1.51	30.94	1.54	32.48	1.57
		0	24.77	1.41	26.31	1.46	27.85	1.51	28.96	1.53	30.93	1.56	32.46	1.59
		5	24.75	1.43	26.29	1.48	27.83	1.53	28.94	1.55	30.90	1.58	32.44	1.61
		10	24.73	1.45	26.27	1.50	27.80	1.56	28.91	1.58	30.88	1.60	32.41	1.64
		14	24.71	1.47	26.25	1.52	27.78	1.58	28.89	1.60	30.85	1.63	32.39	1.66
		20	24.69	1.49	26.23	1.55	27.76	1.60	28.87	1.62	30.83	1.65	32.36	1.68
		25	24.68	1.51	26.21	1.57	27.74	1.63	28.85	1.64	30.81	1.67	32.34	1.71
		30	24.66	1.53	26.19	1.59	27.72	1.65	28.83	1.67	30.78	1.70	32.31	1.73
		35	24.64	1.56	26.17	1.61	27.70	1.67	28.80	1.69	30.76	1.72	32.29	1.76
		40	24.62	1.58	26.15	1.63	27.68	1.69	28.78	1.71	30.73	1.75	32.26	1.78
		45	24.60	1.60	26.13	1.66	27.66	1.72	28.76	1.74	30.71	1.77	32.24	1.80
		50	24.58	1.62	26.11	1.68	27.63	1.74	28.74	1.76	30.69	1.79	32.21	1.83
		55	24.56	1.64	26.09	1.70	27.61	1.76	28.72	1.78	30.66	1.82	32.19	1.85
		60	24.54	1.66	26.07	1.72	27.59	1.78	28.69	1.80	30.64	1.84	32.17	1.88
		65	24.52	1.68	26.05	1.74	27.57	1.81	28.67	1.83	30.62	1.86	32.14	1.90
		70	24.51	1.70	26.03	1.77	27.55	1.83	28.65	1.85	30.59	1.89	32.12	1.92
		75	23.92	1.79	25.43	1.86	26.95	1.93	28.05	1.95	29.99	1.99	31.51	2.03
		80	23.33	1.89	24.84	1.96	26.36	2.03	27.45	2.05	29.38	2.09	30.90	2.13
		85	22.74	1.98	24.25	2.05	25.76	2.13	26.85	2.15	28.78	2.19	30.30	2.23
		90	22.16	2.07	23.66	2.15	25.17	2.22	26.26	2.25	28.19	2.29	29.69	2.34
		95	21.52	2.16	23.02	2.24	24.52	2.32	25.21	2.35	27.52	2.39	29.02	2.44
		100	21.00	2.25	22.50	2.34	24.00	2.42	24.88	2.45	27.00	2.50	28.50	2.55
		105	20.47	2.35	21.97	2.43	23.47	2.52	24.56	2.55	26.47	2.60	27.97	2.65
		110	19.95	2.44	21.45	2.53	22.95	2.62	24.03	2.65	25.95	2.70	27.45	2.75
		115	19.43	2.53	20.93	2.62	22.43	2.72	23.51	2.75	25.42	2.80	26.92	2.86
		118	19.11	2.59	20.61	2.68	22.11	2.78	23.19	2.81	25.11	2.86	26.61	2.92
		122	19.01	2.66	20.51	2.76	22.01	2.86	23.09	2.89	25.01	2.94	26.50	3.00

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 87: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 12	-4	25.71	1.42	27.31	1.47	28.90	1.53	30.06	1.54	32.10	1.57	33.69	1.60
		0	25.70	1.44	27.29	1.49	28.89	1.54	30.04	1.56	32.08	1.59	33.67	1.62
		5	25.67	1.46	27.27	1.51	28.86	1.57	30.01	1.59	32.05	1.61	33.65	1.65
		10	25.65	1.48	27.25	1.53	28.84	1.59	29.99	1.61	32.03	1.64	33.62	1.67
		14	25.63	1.50	27.23	1.56	28.82	1.61	29.97	1.63	32.00	1.66	33.59	1.70
		20	25.62	1.52	27.21	1.58	28.80	1.64	29.95	1.66	31.98	1.69	33.57	1.72
		25	25.60	1.55	27.19	1.60	28.77	1.66	29.92	1.68	31.95	1.71	33.54	1.74
		30	25.58	1.57	27.16	1.62	28.75	1.68	29.90	1.70	31.93	1.73	33.52	1.77
		35	25.56	1.59	27.14	1.65	28.73	1.71	29.88	1.73	31.91	1.76	33.49	1.79
		40	25.54	1.61	27.12	1.67	28.71	1.73	29.85	1.75	31.88	1.78	33.47	1.82
		45	25.52	1.63	27.10	1.69	28.69	1.75	29.83	1.77	31.86	1.81	33.44	1.84
		50	25.50	1.65	27.08	1.71	28.66	1.78	29.81	1.80	31.83	1.83	33.42	1.87
		55	25.48	1.67	27.06	1.74	28.64	1.80	29.79	1.82	31.81	1.85	33.39	1.89
		60	25.46	1.70	27.04	1.76	28.62	1.82	29.76	1.84	31.78	1.88	33.36	1.92
		65	25.44	1.72	27.02	1.78	28.60	1.85	29.74	1.87	31.76	1.90	33.34	1.94
		70	25.42	1.74	27.00	1.80	28.58	1.87	29.72	1.89	31.73	1.93	33.31	1.96
		75	24.81	1.83	26.38	1.90	27.96	1.97	29.09	1.99	31.11	2.03	32.68	2.07
		80	24.20	1.93	25.77	2.00	27.34	2.07	28.47	2.09	30.48	2.13	32.05	2.18
		85	23.59	2.02	25.16	2.09	26.72	2.17	27.86	2.20	29.86	2.24	31.43	2.28
		90	22.98	2.11	24.55	2.19	26.11	2.27	27.24	2.30	29.24	2.34	30.80	2.39
		95	22.33	2.21	23.88	2.29	25.44	2.37	26.15	2.40	28.55	2.44	30.10	2.49
		100	21.78	2.30	23.34	2.39	24.89	2.47	25.81	2.50	28.00	2.55	29.56	2.60
		105	21.24	2.40	22.79	2.48	24.35	2.57	25.47	2.60	27.46	2.65	29.02	2.71
		110	20.69	2.49	22.25	2.58	23.81	2.68	24.93	2.71	26.92	2.76	28.47	2.81
		115	20.15	2.58	21.71	2.68	23.26	2.78	24.39	2.81	26.37	2.86	27.93	2.92
		118	19.82	2.64	21.38	2.74	22.94	2.84	24.06	2.87	26.05	2.92	27.60	2.98
		122	19.72	2.72	21.27	2.81	22.83	2.92	23.95	2.95	25.94	3.01	27.49	3.07
	9 + 9 + 12	-4	27.55	1.48	29.26	1.54	30.97	1.60	32.20	1.61	34.39	1.64	36.10	1.68
		0	27.53	1.50	29.24	1.56	30.95	1.61	32.19	1.63	34.37	1.66	36.08	1.70
		5	27.51	1.53	29.22	1.58	30.93	1.64	32.16	1.66	34.34	1.69	36.05	1.72
		10	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.02	1.75
		14	27.47	1.57	29.17	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		20	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		25	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		30	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.91	1.85
		35	27.38	1.66	29.08	1.72	30.79	1.78	32.01	1.81	34.19	1.84	35.89	1.88
		40	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		45	27.34	1.71	29.04	1.77	30.74	1.83	31.96	1.85	34.13	1.89	35.83	1.93
		50	27.32	1.73	29.02	1.79	30.71	1.86	31.94	1.88	34.11	1.91	35.81	1.95
		55	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.90	34.08	1.94	35.78	1.98
		60	27.28	1.77	28.97	1.84	30.67	1.91	31.89	1.93	34.06	1.96	35.75	2.00
		65	27.26	1.80	28.95	1.86	30.64	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		70	27.24	1.82	28.93	1.89	30.62	1.95	31.84	1.98	34.00	2.01	35.70	2.05
		75	26.58	1.92	28.27	1.99	29.96	2.06	31.18	2.08	33.33	2.12	35.02	2.17
		80	25.93	2.02	27.61	2.09	29.29	2.17	30.51	2.19	32.66	2.23	34.34	2.28
		85	25.28	2.11	26.96	2.19	28.64	2.27	29.85	2.30	31.99	2.34	33.67	2.39
		90	24.63	2.21	26.30	2.29	27.98	2.38	29.19	2.40	31.33	2.45	33.00	2.50
		95	23.92	2.31	25.59	2.39	27.26	2.48	28.02	2.51	30.59	2.56	32.26	2.61
		100	23.34	2.41	25.01	2.50	26.67	2.59	27.66	2.62	30.01	2.67	31.67	2.72
		105	22.76	2.51	24.42	2.60	26.09	2.69	27.29	2.72	29.42	2.77	31.09	2.83
		110	22.17	2.60	23.84	2.70	25.51	2.80	26.71	2.83	28.84	2.88	30.51	2.94
		115	21.59	2.70	23.26	2.80	24.93	2.90	26.13	2.94	28.26	2.99	29.92	3.05
		118	21.24	2.76	22.91	2.86	24.58	2.97	25.78	3.00	27.91	3.06	29.58	3.12
		122	21.13	2.84	22.79	2.94	24.46	3.05	25.66	3.09	27.79	3.14	29.46	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 88: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 15	-4	27.55	1.48	29.26	1.54	30.97	1.60	32.20	1.61	34.39	1.64	36.10	1.68
		0	27.53	1.50	29.24	1.56	30.95	1.61	32.19	1.63	34.37	1.66	36.08	1.70
		5	27.51	1.53	29.22	1.58	30.93	1.64	32.16	1.66	34.34	1.69	36.05	1.72
		10	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.02	1.75
		14	27.47	1.57	29.17	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		20	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		25	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		30	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.91	1.85
		35	27.38	1.66	29.08	1.72	30.79	1.78	32.01	1.81	34.19	1.84	35.89	1.88
		40	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		45	27.34	1.71	29.04	1.77	30.74	1.83	31.96	1.85	34.13	1.89	35.83	1.93
		50	27.32	1.73	29.02	1.79	30.71	1.86	31.94	1.88	34.11	1.91	35.81	1.95
		55	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.90	34.08	1.94	35.78	1.98
		60	27.28	1.77	28.97	1.84	30.67	1.91	31.89	1.93	34.06	1.96	35.75	2.00
		65	27.26	1.80	28.95	1.86	30.64	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		70	27.24	1.82	28.93	1.89	30.62	1.95	31.84	1.98	34.00	2.01	35.70	2.05
		75	26.58	1.92	28.27	1.99	29.96	2.06	31.18	2.08	33.33	2.12	35.02	2.17
		80	25.93	2.02	27.61	2.09	29.29	2.17	30.51	2.19	32.66	2.23	34.34	2.28
		85	25.28	2.11	26.96	2.19	28.64	2.27	29.85	2.30	31.99	2.34	33.67	2.39
		90	24.63	2.21	26.30	2.29	27.98	2.38	29.19	2.40	31.33	2.45	33.00	2.50
		95	23.92	2.31	25.59	2.39	27.26	2.48	28.02	2.51	30.59	2.56	32.26	2.61
		100	23.34	2.41	25.01	2.50	26.67	2.59	27.66	2.62	30.01	2.67	31.67	2.72
		105	22.76	2.51	24.42	2.60	26.09	2.69	27.29	2.72	29.42	2.77	31.09	2.83
		110	22.17	2.60	23.84	2.70	25.51	2.80	26.71	2.83	28.84	2.88	30.51	2.94
		115	21.59	2.70	23.26	2.80	24.93	2.90	26.13	2.94	28.26	2.99	29.92	3.05
		118	21.24	2.76	22.91	2.86	24.58	2.97	25.78	3.00	27.91	3.06	29.58	3.12
		122	21.13	2.84	22.79	2.94	24.46	3.05	25.66	3.09	27.79	3.14	29.46	3.21
	7 + 12 + 12	-4	27.88	1.48	29.61	1.54	31.34	1.60	32.60	1.61	34.81	1.64	36.54	1.68
		0	27.87	1.50	29.60	1.56	31.33	1.61	32.58	1.63	34.79	1.66	36.52	1.70
		5	27.84	1.53	29.57	1.58	31.30	1.64	32.55	1.66	34.76	1.69	36.49	1.72
		10	27.82	1.55	29.55	1.60	31.28	1.66	32.53	1.68	34.73	1.71	36.46	1.75
		14	27.80	1.57	29.53	1.63	31.25	1.69	32.50	1.71	34.71	1.74	36.43	1.77
		20	27.78	1.59	29.51	1.65	31.23	1.71	32.48	1.73	34.68	1.76	36.41	1.80
		25	27.76	1.62	29.48	1.67	31.21	1.74	32.45	1.76	34.65	1.79	36.38	1.82
		30	27.74	1.64	29.46	1.70	31.18	1.76	32.43	1.78	34.63	1.81	36.35	1.85
		35	27.72	1.66	29.44	1.72	31.16	1.78	32.40	1.81	34.60	1.84	36.32	1.88
		40	27.70	1.68	29.42	1.75	31.14	1.81	32.38	1.83	34.58	1.86	36.30	1.90
		45	27.67	1.71	29.39	1.77	31.11	1.83	32.35	1.85	34.55	1.89	36.27	1.93
		50	27.65	1.73	29.37	1.79	31.09	1.86	32.33	1.88	34.52	1.91	36.24	1.95
		55	27.63	1.75	29.35	1.82	31.06	1.88	32.30	1.90	34.50	1.94	36.21	1.98
		60	27.61	1.77	29.33	1.84	31.04	1.91	32.28	1.93	34.47	1.96	36.18	2.00
		65	27.59	1.80	29.30	1.86	31.02	1.93	32.25	1.95	34.44	1.99	36.16	2.03
		70	27.57	1.82	29.28	1.89	30.99	1.95	32.23	1.98	34.42	2.01	36.13	2.05
		75	26.90	1.92	28.61	1.99	30.32	2.06	31.55	2.08	33.74	2.12	35.44	2.17
		80	26.24	2.02	27.94	2.09	29.65	2.17	30.88	2.19	33.06	2.23	34.76	2.28
		85	25.58	2.11	27.28	2.19	28.98	2.27	30.21	2.30	32.38	2.34	34.08	2.39
		90	24.93	2.21	26.62	2.29	28.32	2.38	29.54	2.40	31.71	2.45	33.40	2.50
		95	24.21	2.31	25.90	2.39	27.59	2.48	28.36	2.51	30.96	2.56	32.65	2.61
		100	23.62	2.41	25.31	2.50	27.00	2.59	27.99	2.62	30.37	2.67	32.06	2.72
		105	23.03	2.51	24.72	2.60	26.41	2.69	27.63	2.72	29.78	2.77	31.47	2.83
		110	22.44	2.60	24.13	2.70	25.82	2.80	27.04	2.83	29.19	2.88	30.88	2.94
		115	21.85	2.70	23.54	2.80	25.23	2.90	26.45	2.94	28.60	2.99	30.29	3.05
		118	21.50	2.76	23.19	2.86	24.87	2.97	26.09	3.00	28.25	3.06	29.93	3.12
		122	21.38	2.84	23.07	2.94	24.76	3.05	25.97	3.09	28.13	3.14	29.82	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 89: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 18	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	9 + 9 + 15	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 90: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 12	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	7 + 9 + 18	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 91: LMU30CHV Cooling Capacity Table —Mixed Indoor Units., continued

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 15	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	9 + 9 + 18	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 92: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 15	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	12 + 12 + 12	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 93: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 18	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	7 + 7 + 24*	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

* The indoor unit must be non-ducted type.

Table 94: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 18	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	9 + 15 + 15	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 95: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 12 + 15	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
	7 + 9 + 24*	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

* The indoor unit must be non-ducted type.

Table 96: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 15 + 18	-4	28.22	1.48	29.97	1.54	31.72	1.60	32.99	1.61	35.23	1.64	36.98	1.68
		0	28.20	1.50	29.95	1.56	31.70	1.61	32.97	1.63	35.21	1.66	36.96	1.70
		5	28.18	1.53	29.93	1.58	31.68	1.64	32.94	1.66	35.18	1.69	36.93	1.72
		10	28.16	1.55	29.90	1.60	31.65	1.66	32.92	1.68	35.15	1.71	36.90	1.75
		14	28.13	1.57	29.88	1.63	31.63	1.69	32.89	1.71	35.12	1.74	36.87	1.77
		20	28.11	1.59	29.86	1.65	31.60	1.71	32.87	1.73	35.10	1.76	36.84	1.80
		25	28.09	1.62	29.84	1.67	31.58	1.74	32.84	1.76	35.07	1.79	36.81	1.82
		30	28.07	1.64	29.81	1.70	31.56	1.76	32.82	1.78	35.04	1.81	36.79	1.85
		35	28.05	1.66	29.79	1.72	31.53	1.78	32.79	1.81	35.02	1.84	36.76	1.88
		40	28.03	1.68	29.77	1.75	31.51	1.81	32.77	1.83	34.99	1.86	36.73	1.90
		45	28.01	1.71	29.75	1.77	31.48	1.83	32.74	1.85	34.96	1.89	36.70	1.93
		50	27.98	1.73	29.72	1.79	31.46	1.86	32.72	1.88	34.94	1.91	36.67	1.95
		55	27.96	1.75	29.70	1.82	31.44	1.88	32.69	1.90	34.91	1.94	36.65	1.98
		60	27.94	1.77	29.68	1.84	31.41	1.91	32.67	1.93	34.88	1.96	36.62	2.00
		65	27.92	1.80	29.65	1.86	31.39	1.93	32.64	1.95	34.86	1.99	36.59	2.03
		70	27.90	1.82	29.63	1.89	31.36	1.95	32.62	1.98	34.83	2.01	36.56	2.05
		75	27.23	1.92	28.96	1.99	30.68	2.06	31.93	2.08	34.14	2.12	35.87	2.17
		80	26.56	2.02	28.28	2.09	30.00	2.17	31.25	2.19	33.45	2.23	35.18	2.28
		85	25.89	2.11	27.61	2.19	29.33	2.27	30.57	2.30	32.77	2.34	34.49	2.39
		90	25.22	2.21	26.94	2.29	28.66	2.38	29.90	2.40	32.09	2.45	33.80	2.50
		95	24.50	2.31	26.21	2.39	27.92	2.48	28.70	2.51	31.33	2.56	33.04	2.61
		100	23.91	2.41	25.61	2.50	27.32	2.59	28.33	2.62	30.73	2.67	32.44	2.72
		105	23.31	2.51	25.02	2.60	26.72	2.69	27.96	2.72	30.14	2.77	31.84	2.83
		110	22.71	2.60	24.42	2.70	26.13	2.80	27.36	2.83	29.54	2.88	31.25	2.94
		115	22.12	2.70	23.82	2.80	25.53	2.90	26.76	2.94	28.94	2.99	30.65	3.05
		118	21.76	2.76	23.47	2.86	25.17	2.97	26.40	3.00	28.59	3.06	30.29	3.12
		122	21.64	2.84	23.35	2.94	25.05	3.05	26.29	3.09	28.47	3.14	30.17	3.21
Four (4) Mixed Indoor Units	7 + 7 + 7 + 9	-4	27.55	1.42	29.26	1.47	30.97	1.53	32.20	1.54	34.39	1.57	36.10	1.60
		0	27.53	1.44	29.24	1.49	30.95	1.54	32.19	1.56	34.37	1.59	36.08	1.62
		5	27.51	1.46	29.22	1.51	30.93	1.57	32.16	1.59	34.34	1.61	36.05	1.65
		10	27.49	1.48	29.20	1.53	30.90	1.59	32.14	1.61	34.32	1.64	36.02	1.67
		14	27.47	1.50	29.17	1.56	30.88	1.61	32.11	1.63	34.29	1.66	36.00	1.70
		20	27.45	1.52	29.15	1.58	30.86	1.64	32.09	1.66	34.27	1.69	35.97	1.72
		25	27.43	1.55	29.13	1.60	30.83	1.66	32.06	1.68	34.24	1.71	35.94	1.74
		30	27.41	1.57	29.11	1.62	30.81	1.68	32.04	1.70	34.21	1.73	35.91	1.77
		35	27.38	1.59	29.08	1.65	30.79	1.71	32.01	1.73	34.19	1.76	35.89	1.79
		40	27.36	1.61	29.06	1.67	30.76	1.73	31.99	1.75	34.16	1.78	35.86	1.82
		45	27.34	1.63	29.04	1.69	30.74	1.75	31.96	1.77	34.13	1.81	35.83	1.84
		50	27.32	1.65	29.02	1.71	30.71	1.78	31.94	1.80	34.11	1.83	35.81	1.87
		55	27.30	1.67	29.00	1.74	30.69	1.80	31.92	1.82	34.08	1.85	35.78	1.89
		60	27.28	1.70	28.97	1.76	30.67	1.82	31.89	1.84	34.06	1.88	35.75	1.92
		65	27.26	1.72	28.95	1.78	30.64	1.85	31.87	1.87	34.03	1.90	35.72	1.94
		70	27.24	1.74	28.93	1.80	30.62	1.87	31.84	1.89	34.00	1.93	35.70	1.96
		75	26.58	1.83	28.27	1.90	29.96	1.97	31.18	1.99	33.33	2.03	35.02	2.07
		80	25.93	1.93	27.61	2.00	29.29	2.07	30.51	2.09	32.66	2.13	34.34	2.18
		85	25.28	2.02	26.96	2.09	28.64	2.17	29.85	2.20	31.99	2.24	33.67	2.28
		90	24.63	2.11	26.30	2.19	27.98	2.27	29.19	2.30	31.33	2.34	33.00	2.39
		95	23.92	2.21	25.59	2.29	27.26	2.37	28.02	2.40	30.59	2.44	32.26	2.49
		100	23.34	2.30	25.01	2.39	26.67	2.47	27.66	2.50	30.01	2.55	31.67	2.60
		105	22.76	2.40	24.42	2.48	26.09	2.57	27.29	2.60	29.42	2.65	31.09	2.71
		110	22.17	2.49	23.84	2.58	25.51	2.68	26.71	2.71	28.84	2.76	30.51	2.81
		115	21.59	2.58	23.26	2.68	24.93	2.78	26.13	2.81	28.26	2.86	29.92	2.92
		118	21.24	2.64	22.91	2.74	24.58	2.84	25.78	2.87	27.91	2.92	29.58	2.98
		122	21.13	2.72	22.79	2.81	24.46	2.92	25.66	2.95	27.79	3.01	29.46	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 97: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 9	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07
	7 + 7 + 7 + 12	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 98: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 9	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07
	7 + 7 + 9 + 12	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 99: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 9 + 9	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07
	7 + 9 + 9 + 12	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 100: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 15	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07
	7 + 7 + 12 + 12	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 101: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 7 + 18	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07
	9 + 9 + 9 + 12	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 102: LMU30CHV Cooling Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 15	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07
	7 + 9 + 12 + 12	-4	28.22	1.42	29.97	1.47	31.72	1.53	32.99	1.54	35.23	1.57	36.98	1.60
		0	28.20	1.44	29.95	1.49	31.70	1.54	32.97	1.56	35.21	1.59	36.96	1.62
		5	28.18	1.46	29.93	1.51	31.68	1.57	32.94	1.59	35.18	1.61	36.93	1.65
		10	28.16	1.48	29.90	1.53	31.65	1.59	32.92	1.61	35.15	1.64	36.90	1.67
		14	28.13	1.50	29.88	1.56	31.63	1.61	32.89	1.63	35.12	1.66	36.87	1.70
		20	28.11	1.52	29.86	1.58	31.60	1.64	32.87	1.66	35.10	1.69	36.84	1.72
		25	28.09	1.55	29.84	1.60	31.58	1.66	32.84	1.68	35.07	1.71	36.81	1.74
		30	28.07	1.57	29.81	1.62	31.56	1.68	32.82	1.70	35.04	1.73	36.79	1.77
		35	28.05	1.59	29.79	1.65	31.53	1.71	32.79	1.73	35.02	1.76	36.76	1.79
		40	28.03	1.61	29.77	1.67	31.51	1.73	32.77	1.75	34.99	1.78	36.73	1.82
		45	28.01	1.63	29.75	1.69	31.48	1.75	32.74	1.77	34.96	1.81	36.70	1.84
		50	27.98	1.65	29.72	1.71	31.46	1.78	32.72	1.80	34.94	1.83	36.67	1.87
		55	27.96	1.67	29.70	1.74	31.44	1.80	32.69	1.82	34.91	1.85	36.65	1.89
		60	27.94	1.70	29.68	1.76	31.41	1.82	32.67	1.84	34.88	1.88	36.62	1.92
		65	27.92	1.72	29.65	1.78	31.39	1.85	32.64	1.87	34.86	1.90	36.59	1.94
		70	27.90	1.74	29.63	1.80	31.36	1.87	32.62	1.89	34.83	1.93	36.56	1.96
		75	27.23	1.83	28.96	1.90	30.68	1.97	31.93	1.99	34.14	2.03	35.87	2.07
		80	26.56	1.93	28.28	2.00	30.00	2.07	31.25	2.09	33.45	2.13	35.18	2.18
		85	25.89	2.02	27.61	2.09	29.33	2.17	30.57	2.20	32.77	2.24	34.49	2.28
		90	25.22	2.11	26.94	2.19	28.66	2.27	29.90	2.30	32.09	2.34	33.80	2.39
		95	24.50	2.21	26.21	2.29	27.92	2.37	28.70	2.40	31.33	2.44	33.04	2.49
		100	23.91	2.30	25.61	2.39	27.32	2.47	28.33	2.50	30.73	2.55	32.44	2.60
		105	23.31	2.40	25.02	2.48	26.72	2.57	27.96	2.60	30.14	2.65	31.84	2.71
		110	22.71	2.49	24.42	2.58	26.13	2.68	27.36	2.71	29.54	2.76	31.25	2.81
		115	22.12	2.58	23.82	2.68	25.53	2.78	26.76	2.81	28.94	2.86	30.65	2.92
		118	21.76	2.64	23.47	2.74	25.17	2.84	26.40	2.87	28.59	2.92	30.29	2.98
		122	21.64	2.72	23.35	2.81	25.05	2.92	26.29	2.95	28.47	3.01	30.17	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 103: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	13.76	0.80	14.62	0.83	15.47	0.86	16.09	0.87	17.18	0.89	18.04	0.91
		0	13.76	0.81	14.61	0.84	15.47	0.87	16.08	0.88	17.17	0.90	18.03	0.92
		5	13.75	0.83	14.60	0.86	15.45	0.89	16.07	0.90	17.16	0.92	18.01	0.93
		10	13.73	0.84	14.59	0.87	15.44	0.90	16.06	0.91	17.15	0.93	18.00	0.95
		14	13.72	0.85	14.58	0.88	15.43	0.91	16.04	0.92	17.13	0.94	17.99	0.96
		20	13.71	0.86	14.57	0.89	15.42	0.93	16.03	0.94	17.12	0.96	17.97	0.97
		25	13.70	0.88	14.55	0.91	15.41	0.94	16.02	0.95	17.11	0.97	17.96	0.99
		30	13.69	0.89	14.54	0.92	15.39	0.95	16.01	0.96	17.09	0.98	17.94	1.00
		35	13.68	0.90	14.53	0.93	15.38	0.97	16.00	0.98	17.08	1.00	17.93	1.02
		40	13.67	0.91	14.52	0.95	15.37	0.98	15.98	0.99	17.07	1.01	17.92	1.03
		45	13.66	0.92	14.51	0.96	15.36	0.99	15.97	1.00	17.06	1.02	17.90	1.04
		50	13.65	0.94	14.50	0.97	15.35	1.01	15.96	1.02	17.04	1.04	17.89	1.06
		55	13.64	0.95	14.49	0.98	15.33	1.02	15.95	1.03	17.03	1.05	17.88	1.07
		60	13.63	0.96	14.48	1.00	15.32	1.03	15.93	1.04	17.02	1.06	17.86	1.09
		65	13.62	0.97	14.47	1.01	15.31	1.05	15.92	1.06	17.00	1.08	17.85	1.10
		70	13.61	0.99	14.45	1.02	15.30	1.06	15.91	1.07	16.99	1.09	17.83	1.11
		75	13.28	1.04	14.12	1.08	14.97	1.12	15.58	1.13	16.65	1.15	17.50	1.17
		80	12.95	1.09	13.80	1.13	14.64	1.17	15.24	1.19	16.32	1.21	17.16	1.23
		85	12.63	1.15	13.47	1.19	14.31	1.23	14.91	1.24	15.99	1.27	16.82	1.29
		90	12.30	1.20	13.14	1.24	13.98	1.29	14.58	1.30	15.65	1.33	16.49	1.35
		95	11.95	1.25	12.79	1.30	13.62	1.34	14.00	1.36	15.28	1.39	16.12	1.41
		100	11.66	1.30	12.49	1.35	13.33	1.40	13.82	1.42	14.99	1.44	15.82	1.47
		105	11.37	1.36	12.20	1.41	13.04	1.46	13.64	1.48	14.70	1.50	15.53	1.53
		110	11.08	1.41	11.91	1.46	12.74	1.52	13.35	1.53	14.41	1.56	15.24	1.59
		115	10.79	1.46	11.62	1.52	12.45	1.57	13.06	1.59	14.12	1.62	14.95	1.65
		118	10.61	1.50	11.45	1.55	12.28	1.61	12.88	1.63	13.94	1.66	14.78	1.69
		122	10.56	1.54	11.39	1.59	12.22	1.65	12.82	1.67	13.89	1.70	14.72	1.74
	7 + 9	-4	15.73	0.91	16.71	0.94	17.68	0.97	18.39	0.98	19.64	1.00	20.61	1.02
		0	15.72	0.92	16.70	0.95	17.67	0.98	18.38	0.99	19.63	1.01	20.60	1.03
		5	15.71	0.93	16.68	0.96	17.66	1.00	18.36	1.01	19.61	1.03	20.59	1.05
		10	15.70	0.94	16.67	0.98	17.65	1.01	18.35	1.03	19.60	1.04	20.57	1.07
		14	15.68	0.96	16.66	0.99	17.63	1.03	18.34	1.04	19.58	1.06	20.56	1.08
		20	15.67	0.97	16.65	1.01	17.62	1.04	18.32	1.06	19.57	1.08	20.54	1.10
		25	15.66	0.98	16.63	1.02	17.61	1.06	18.31	1.07	19.55	1.09	20.52	1.11
		30	15.65	1.00	16.62	1.04	17.59	1.07	18.29	1.09	19.54	1.11	20.51	1.13
		35	15.64	1.01	16.61	1.05	17.58	1.09	18.28	1.10	19.52	1.12	20.49	1.14
		40	15.62	1.03	16.60	1.06	17.57	1.10	18.27	1.12	19.51	1.14	20.48	1.16
		45	15.61	1.04	16.58	1.08	17.55	1.12	18.25	1.13	19.49	1.15	20.46	1.17
		50	15.60	1.05	16.57	1.09	17.54	1.13	18.24	1.15	19.48	1.17	20.45	1.19
		55	15.59	1.07	16.56	1.11	17.53	1.15	18.22	1.16	19.46	1.18	20.43	1.21
		60	15.58	1.08	16.54	1.12	17.51	1.16	18.21	1.18	19.45	1.20	20.41	1.22
		65	15.57	1.10	16.53	1.14	17.50	1.18	18.20	1.19	19.43	1.21	20.40	1.24
		70	15.55	1.11	16.52	1.15	17.49	1.19	18.18	1.20	19.42	1.23	20.38	1.25
		75	15.18	1.17	16.14	1.21	17.11	1.26	17.80	1.27	19.03	1.29	20.00	1.32
		80	14.80	1.23	15.77	1.27	16.73	1.32	17.42	1.33	18.65	1.36	19.61	1.39
		85	14.43	1.29	15.39	1.34	16.35	1.38	17.04	1.40	18.27	1.43	19.23	1.45
		90	14.06	1.35	15.02	1.40	15.98	1.45	16.67	1.46	17.89	1.49	18.84	1.52
		95	13.66	1.41	14.61	1.46	15.56	1.51	16.00	1.53	17.47	1.56	18.42	1.59
		100	13.33	1.47	14.28	1.52	15.23	1.58	15.79	1.60	17.13	1.62	18.09	1.66
		105	12.99	1.53	13.95	1.58	14.90	1.64	15.59	1.66	16.80	1.69	17.75	1.73
		110	12.66	1.59	13.61	1.65	14.57	1.71	15.25	1.73	16.47	1.76	17.42	1.79
		115	12.33	1.65	13.28	1.71	14.23	1.77	14.92	1.79	16.14	1.82	17.09	1.86
		118	12.13	1.68	13.08	1.74	14.03	1.81	14.72	1.83	15.94	1.86	16.89	1.90
		122	12.06	1.73	13.02	1.79	13.97	1.86	14.65	1.88	15.87	1.92	16.82	1.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 104: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 9	-4	17.70	1.02	18.80	1.05	19.89	1.09	20.69	1.11	22.09	1.13	23.19	1.15
		0	17.69	1.03	18.79	1.07	19.88	1.11	20.68	1.12	22.08	1.14	23.18	1.16
		5	17.67	1.05	18.77	1.08	19.87	1.12	20.66	1.14	22.06	1.16	23.16	1.18
		10	17.66	1.06	18.76	1.10	19.85	1.14	20.64	1.15	22.05	1.17	23.14	1.20
		14	17.65	1.08	18.74	1.12	19.84	1.16	20.63	1.17	22.03	1.19	23.12	1.22
		20	17.63	1.09	18.73	1.13	19.82	1.17	20.61	1.19	22.01	1.21	23.11	1.23
		25	17.62	1.11	18.71	1.15	19.81	1.19	20.60	1.20	22.00	1.23	23.09	1.25
		30	17.60	1.12	18.70	1.16	19.79	1.21	20.58	1.22	21.98	1.24	23.07	1.27
		35	17.59	1.14	18.68	1.18	19.78	1.22	20.57	1.24	21.96	1.26	23.05	1.29
		40	17.58	1.15	18.67	1.20	19.76	1.24	20.55	1.25	21.94	1.28	23.04	1.30
		45	17.56	1.17	18.66	1.21	19.75	1.26	20.53	1.27	21.93	1.29	23.02	1.32
		50	17.55	1.18	18.64	1.23	19.73	1.27	20.52	1.29	21.91	1.31	23.00	1.34
		55	17.54	1.20	18.63	1.24	19.72	1.29	20.50	1.30	21.89	1.33	22.98	1.36
		60	17.52	1.22	18.61	1.26	19.70	1.31	20.49	1.32	21.88	1.35	22.97	1.37
		65	17.51	1.23	18.60	1.28	19.69	1.32	20.47	1.34	21.86	1.36	22.95	1.39
		70	17.50	1.25	18.58	1.29	19.67	1.34	20.46	1.35	21.84	1.38	22.93	1.41
		75	17.08	1.31	18.16	1.36	19.24	1.41	20.03	1.43	21.41	1.45	22.50	1.48
		80	16.66	1.38	17.74	1.43	18.82	1.48	19.60	1.50	20.98	1.53	22.06	1.56
		85	16.24	1.45	17.32	1.50	18.40	1.56	19.17	1.57	20.55	1.60	21.63	1.64
		90	15.82	1.52	16.90	1.57	17.97	1.63	18.75	1.65	20.12	1.68	21.20	1.71
		95	15.37	1.58	16.44	1.64	17.51	1.70	18.00	1.72	19.65	1.75	20.72	1.79
		100	14.99	1.65	16.06	1.71	17.13	1.77	17.77	1.79	19.28	1.83	20.35	1.86
		105	14.62	1.72	15.69	1.78	16.76	1.84	17.53	1.87	18.90	1.90	19.97	1.94
		110	14.24	1.78	15.32	1.85	16.39	1.92	17.16	1.94	18.53	1.98	19.60	2.02
		115	13.87	1.85	14.94	1.92	16.01	1.99	16.79	2.01	18.15	2.05	19.22	2.09
		118	13.65	1.89	14.72	1.96	15.79	2.03	16.56	2.06	17.93	2.09	19.00	2.14
		122	13.57	1.95	14.64	2.02	15.71	2.09	16.49	2.11	17.85	2.15	18.92	2.20
	7 + 12	-4	18.68	1.06	19.84	1.10	21.00	1.14	21.84	1.16	23.32	1.18	24.48	1.20
		0	18.67	1.08	19.83	1.12	20.99	1.16	21.83	1.17	23.31	1.19	24.47	1.22
		5	18.65	1.09	19.81	1.13	20.97	1.18	21.81	1.19	23.29	1.21	24.45	1.24
		10	18.64	1.11	19.80	1.15	20.96	1.19	21.79	1.21	23.27	1.23	24.43	1.25
		14	18.63	1.13	19.78	1.17	20.94	1.21	21.77	1.22	23.25	1.25	24.41	1.27
		20	18.61	1.14	19.77	1.18	20.92	1.23	21.76	1.24	23.23	1.26	24.39	1.29
		25	18.60	1.16	19.75	1.20	20.91	1.24	21.74	1.26	23.22	1.28	24.37	1.31
		30	18.58	1.17	19.74	1.22	20.89	1.26	21.72	1.28	23.20	1.30	24.35	1.33
		35	18.57	1.19	19.72	1.23	20.88	1.28	21.71	1.29	23.18	1.32	24.33	1.35
		40	18.55	1.21	19.71	1.25	20.86	1.30	21.69	1.31	23.16	1.34	24.32	1.36
		45	18.54	1.22	19.69	1.27	20.84	1.31	21.67	1.33	23.15	1.35	24.30	1.38
		50	18.53	1.24	19.68	1.28	20.83	1.33	21.66	1.35	23.13	1.37	24.28	1.40
		55	18.51	1.26	19.66	1.30	20.81	1.35	21.64	1.36	23.11	1.39	24.26	1.42
		60	18.50	1.27	19.65	1.32	20.80	1.37	21.63	1.38	23.09	1.41	24.24	1.44
		65	18.48	1.29	19.63	1.34	20.78	1.38	21.61	1.40	23.08	1.43	24.22	1.45
		70	18.47	1.30	19.62	1.35	20.76	1.40	21.59	1.42	23.06	1.44	24.20	1.47
		75	18.02	1.37	19.17	1.43	20.31	1.48	21.14	1.49	22.60	1.52	23.75	1.55
		80	17.58	1.45	18.72	1.50	19.86	1.55	20.69	1.57	22.15	1.60	23.29	1.63
		85	17.14	1.52	18.28	1.57	19.42	1.63	20.24	1.65	21.69	1.68	22.83	1.71
		90	16.70	1.59	17.84	1.64	18.97	1.70	19.79	1.72	21.24	1.76	22.38	1.79
		95	16.22	1.66	17.35	1.72	18.48	1.78	19.00	1.80	20.74	1.83	21.87	1.87
		100	15.83	1.73	16.96	1.79	18.09	1.86	18.75	1.88	20.35	1.91	21.48	1.95
		105	15.43	1.80	16.56	1.86	17.69	1.93	18.51	1.95	19.95	1.99	21.08	2.03
		110	15.04	1.87	16.17	1.94	17.30	2.01	18.11	2.03	19.56	2.07	20.69	2.11
		115	14.64	1.94	15.77	2.01	16.90	2.08	17.72	2.11	19.16	2.15	20.29	2.19
		118	14.40	1.98	15.53	2.05	16.66	2.13	17.48	2.15	18.92	2.19	20.05	2.24
		122	14.33	2.04	15.46	2.11	16.59	2.19	17.40	2.21	18.85	2.25	19.98	2.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 105: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 12	-4	20.65	1.17	21.93	1.21	23.21	1.25	24.14	1.27	25.77	1.29	27.06	1.32
		0	20.63	1.18	21.92	1.22	23.20	1.27	24.12	1.28	25.76	1.30	27.04	1.33
		5	20.62	1.20	21.90	1.24	23.18	1.29	24.10	1.30	25.74	1.33	27.02	1.35
		10	20.60	1.22	21.88	1.26	23.16	1.31	24.08	1.32	25.72	1.35	27.00	1.37
		14	20.59	1.23	21.86	1.28	23.14	1.32	24.07	1.34	25.70	1.36	26.98	1.39
		20	20.57	1.25	21.85	1.30	23.13	1.34	24.05	1.36	25.68	1.38	26.96	1.41
		25	20.55	1.27	21.83	1.31	23.11	1.36	24.03	1.38	25.66	1.40	26.94	1.43
		30	20.54	1.29	21.81	1.33	23.09	1.38	24.01	1.40	25.64	1.42	26.92	1.45
		35	20.52	1.30	21.80	1.35	23.07	1.40	23.99	1.42	25.62	1.44	26.90	1.47
		40	20.51	1.32	21.78	1.37	23.05	1.42	23.97	1.44	25.60	1.46	26.88	1.49
		45	20.49	1.34	21.76	1.39	23.04	1.44	23.96	1.46	25.58	1.48	26.86	1.51
		50	20.48	1.36	21.75	1.41	23.02	1.46	23.94	1.47	25.56	1.50	26.83	1.53
		55	20.46	1.37	21.73	1.42	23.00	1.48	23.92	1.49	25.54	1.52	26.81	1.55
		60	20.44	1.39	21.71	1.44	22.98	1.50	23.90	1.51	25.52	1.54	26.79	1.57
		65	20.43	1.41	21.70	1.46	22.97	1.51	23.88	1.53	25.50	1.56	26.77	1.59
		70	20.41	1.43	21.68	1.48	22.95	1.53	23.86	1.55	25.48	1.58	26.75	1.61
		75	19.92	1.50	21.19	1.56	22.45	1.62	23.36	1.64	24.98	1.67	26.25	1.70
		80	19.43	1.58	20.69	1.64	21.95	1.70	22.87	1.72	24.48	1.75	25.74	1.79
		85	18.94	1.66	20.20	1.72	21.46	1.78	22.37	1.80	23.98	1.84	25.24	1.87
		90	18.46	1.74	19.71	1.80	20.97	1.86	21.87	1.89	23.48	1.92	24.73	1.96
		95	17.93	1.81	19.18	1.88	20.43	1.95	21.00	1.97	22.93	2.01	24.17	2.05
		100	17.49	1.89	18.74	1.96	19.99	2.03	20.73	2.05	22.49	2.09	23.74	2.13
		105	17.06	1.97	18.30	2.04	19.55	2.11	20.46	2.14	22.05	2.18	23.30	2.22
		110	16.62	2.04	17.87	2.12	19.12	2.20	20.02	2.22	21.62	2.26	22.86	2.31
		115	16.18	2.12	17.43	2.20	18.68	2.28	19.58	2.30	21.18	2.35	22.43	2.40
		118	15.92	2.17	17.17	2.25	18.42	2.33	19.32	2.36	20.92	2.40	22.17	2.45
		122	15.83	2.23	17.08	2.31	18.33	2.39	19.23	2.42	20.83	2.47	22.08	2.52
	7 + 15	-4	21.63	1.21	22.97	1.25	24.32	1.30	25.29	1.31	27.00	1.34	28.35	1.36
		0	21.62	1.22	22.96	1.26	24.30	1.31	25.27	1.33	26.99	1.35	28.33	1.38
		5	21.60	1.24	22.94	1.29	24.28	1.33	25.25	1.35	26.97	1.37	28.31	1.40
		10	21.58	1.26	22.92	1.30	24.26	1.35	25.23	1.37	26.94	1.39	28.29	1.42
		14	21.57	1.28	22.91	1.32	24.25	1.37	25.21	1.39	26.92	1.41	28.26	1.44
		20	21.55	1.29	22.89	1.34	24.23	1.39	25.19	1.41	26.90	1.43	28.24	1.46
		25	21.53	1.31	22.87	1.36	24.21	1.41	25.17	1.43	26.88	1.45	28.22	1.48
		30	21.52	1.33	22.85	1.38	24.19	1.43	25.15	1.45	26.86	1.47	28.20	1.50
		35	21.50	1.35	22.84	1.40	24.17	1.45	25.14	1.47	26.84	1.49	28.18	1.52
		40	21.48	1.37	22.82	1.42	24.15	1.47	25.12	1.49	26.82	1.51	28.16	1.55
		45	21.47	1.39	22.80	1.44	24.13	1.49	25.10	1.51	26.80	1.54	28.13	1.57
		50	21.45	1.41	22.78	1.46	24.12	1.51	25.08	1.53	26.78	1.56	28.11	1.59
		55	21.43	1.42	22.77	1.48	24.10	1.53	25.06	1.55	26.76	1.58	28.09	1.61
		60	21.42	1.44	22.75	1.49	24.08	1.55	25.04	1.57	26.74	1.60	28.07	1.63
		65	21.40	1.46	22.73	1.51	24.06	1.57	25.02	1.59	26.72	1.62	28.05	1.65
		70	21.39	1.48	22.71	1.53	24.04	1.59	25.00	1.61	26.70	1.64	28.03	1.67
		75	20.87	1.56	22.20	1.62	23.52	1.67	24.48	1.69	26.17	1.73	27.50	1.76
		80	20.36	1.64	21.68	1.70	23.00	1.76	23.95	1.78	25.64	1.81	26.96	1.85
		85	19.85	1.72	21.16	1.78	22.48	1.85	23.44	1.87	25.12	1.90	26.44	1.94
		90	19.34	1.80	20.65	1.86	21.97	1.93	22.92	1.95	24.60	1.99	25.91	2.03
		95	18.78	1.88	20.09	1.95	21.40	2.02	22.00	2.04	24.02	2.08	25.33	2.12
		100	18.33	1.96	19.63	2.03	20.94	2.10	21.71	2.13	23.56	2.17	24.87	2.21
		105	17.87	2.04	19.18	2.11	20.48	2.19	21.43	2.21	23.10	2.25	24.41	2.30
		110	17.41	2.12	18.72	2.19	20.03	2.27	20.97	2.30	22.64	2.34	23.95	2.39
		115	16.95	2.20	18.26	2.28	19.57	2.36	20.52	2.39	22.19	2.43	23.50	2.48
		118	16.68	2.24	17.99	2.33	19.30	2.41	20.24	2.44	21.91	2.48	23.22	2.53
		122	16.59	2.31	17.90	2.39	19.20	2.48	20.15	2.51	21.82	2.56	23.13	2.61

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 106: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	23.60	1.29	25.06	1.34	26.53	1.39	27.58	1.40	29.46	1.43	30.92	1.46
		0	23.58	1.30	25.05	1.35	26.51	1.40	27.57	1.42	29.44	1.44	30.91	1.47
		5	23.56	1.33	25.03	1.37	26.49	1.42	27.55	1.44	29.42	1.47	30.88	1.50
		10	23.55	1.34	25.01	1.39	26.47	1.44	27.53	1.46	29.39	1.49	30.86	1.52
		14	23.53	1.36	24.99	1.41	26.45	1.47	27.50	1.48	29.37	1.51	30.83	1.54
		20	23.51	1.38	24.97	1.43	26.43	1.49	27.48	1.50	29.35	1.53	30.81	1.56
		25	23.49	1.40	24.95	1.45	26.41	1.51	27.46	1.53	29.33	1.55	30.79	1.58
		30	23.47	1.42	24.93	1.48	26.39	1.53	27.44	1.55	29.30	1.58	30.76	1.61
		35	23.46	1.44	24.91	1.50	26.37	1.55	27.42	1.57	29.28	1.60	30.74	1.63
		40	23.44	1.46	24.89	1.52	26.35	1.57	27.40	1.59	29.26	1.62	30.72	1.65
		45	23.42	1.48	24.87	1.54	26.33	1.59	27.38	1.61	29.24	1.64	30.69	1.67
		50	23.40	1.50	24.85	1.56	26.31	1.61	27.36	1.63	29.21	1.66	30.67	1.70
		55	23.38	1.52	24.84	1.58	26.29	1.63	27.34	1.65	29.19	1.68	30.64	1.72
		60	23.37	1.54	24.82	1.60	26.27	1.66	27.32	1.67	29.17	1.71	30.62	1.74
		65	23.35	1.56	24.80	1.62	26.25	1.68	27.29	1.70	29.15	1.73	30.60	1.76
		70	23.33	1.58	24.78	1.64	26.23	1.70	27.27	1.72	29.13	1.75	30.57	1.78
		75	22.77	1.67	24.21	1.73	25.66	1.79	26.70	1.81	28.55	1.84	29.99	1.88
		80	22.21	1.75	23.65	1.81	25.09	1.88	26.13	1.90	27.97	1.94	29.42	1.98
		85	21.65	1.84	23.09	1.90	24.53	1.97	25.57	1.99	27.40	2.03	28.84	2.07
		90	21.09	1.92	22.53	1.99	23.96	2.06	25.00	2.09	26.83	2.13	28.27	2.17
		95	20.49	2.01	21.92	2.08	23.35	2.16	24.00	2.18	26.20	2.22	27.63	2.27
		100	19.99	2.09	21.42	2.17	22.85	2.25	23.69	2.27	25.70	2.32	27.13	2.36
		105	19.49	2.18	20.92	2.26	22.35	2.34	23.38	2.37	25.20	2.41	26.63	2.46
		110	18.99	2.26	20.42	2.34	21.85	2.43	22.88	2.46	24.70	2.50	26.13	2.55
		115	18.49	2.35	19.92	2.43	21.35	2.52	22.38	2.55	24.20	2.60	25.63	2.65
		118	18.19	2.40	19.62	2.49	21.05	2.58	22.08	2.61	23.90	2.65	25.33	2.71
		122	18.10	2.47	19.52	2.56	20.95	2.65	21.98	2.68	23.81	2.73	25.23	2.79
	12 + 12	-4	23.60	1.29	25.06	1.34	26.53	1.39	27.58	1.40	29.46	1.43	30.92	1.46
		0	23.58	1.30	25.05	1.35	26.51	1.40	27.57	1.42	29.44	1.44	30.91	1.47
		5	23.56	1.33	25.03	1.37	26.49	1.42	27.55	1.44	29.42	1.47	30.88	1.50
		10	23.55	1.34	25.01	1.39	26.47	1.44	27.53	1.46	29.39	1.49	30.86	1.52
		14	23.53	1.36	24.99	1.41	26.45	1.47	27.50	1.48	29.37	1.51	30.83	1.54
		20	23.51	1.38	24.97	1.43	26.43	1.49	27.48	1.50	29.35	1.53	30.81	1.56
		25	23.49	1.40	24.95	1.45	26.41	1.51	27.46	1.53	29.33	1.55	30.79	1.58
		30	23.47	1.42	24.93	1.48	26.39	1.53	27.44	1.55	29.30	1.58	30.76	1.61
		35	23.46	1.44	24.91	1.50	26.37	1.55	27.42	1.57	29.28	1.60	30.74	1.63
		40	23.44	1.46	24.89	1.52	26.35	1.57	27.40	1.59	29.26	1.62	30.72	1.65
		45	23.42	1.48	24.87	1.54	26.33	1.59	27.38	1.61	29.24	1.64	30.69	1.67
		50	23.40	1.50	24.85	1.56	26.31	1.61	27.36	1.63	29.21	1.66	30.67	1.70
		55	23.38	1.52	24.84	1.58	26.29	1.63	27.34	1.65	29.19	1.68	30.64	1.72
		60	23.37	1.54	24.82	1.60	26.27	1.66	27.32	1.67	29.17	1.71	30.62	1.74
		65	23.35	1.56	24.80	1.62	26.25	1.68	27.29	1.70	29.15	1.73	30.60	1.76
		70	23.33	1.58	24.78	1.64	26.23	1.70	27.27	1.72	29.13	1.75	30.57	1.78
		75	22.77	1.67	24.21	1.73	25.66	1.79	26.70	1.81	28.55	1.84	29.99	1.88
		80	22.21	1.75	23.65	1.81	25.09	1.88	26.13	1.90	27.97	1.94	29.42	1.98
		85	21.65	1.84	23.09	1.90	24.53	1.97	25.57	1.99	27.40	2.03	28.84	2.07
		90	21.09	1.92	22.53	1.99	23.96	2.06	25.00	2.09	26.83	2.13	28.27	2.17
		95	20.49	2.01	21.92	2.08	23.35	2.16	24.00	2.18	26.20	2.22	27.63	2.27
		100	19.99	2.09	21.42	2.17	22.85	2.25	23.69	2.27	25.70	2.32	27.13	2.36
		105	19.49	2.18	20.92	2.26	22.35	2.34	23.38	2.37	25.20	2.41	26.63	2.46
		110	18.99	2.26	20.42	2.34	21.85	2.43	22.88	2.46	24.70	2.50	26.13	2.55
		115	18.49	2.35	19.92	2.43	21.35	2.52	22.38	2.55	24.20	2.60	25.63	2.65
		118	18.19	2.40	19.62	2.49	21.05	2.58	22.08	2.61	23.90	2.65	25.33	2.71
		122	18.10	2.47	19.52	2.56	20.95	2.65	21.98	2.68	23.81	2.73	25.23	2.79

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 107: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 18	-4	24.58	1.34	26.10	1.39	27.63	1.44	28.73	1.45	30.68	1.48	32.21	1.51
		0	24.57	1.35	26.09	1.40	27.62	1.45	28.72	1.47	30.67	1.50	32.19	1.53
		5	24.54	1.37	26.07	1.42	27.59	1.48	28.69	1.49	30.64	1.52	32.17	1.55
		10	24.53	1.39	26.05	1.44	27.57	1.50	28.67	1.51	30.62	1.54	32.14	1.57
		14	24.51	1.41	26.03	1.47	27.55	1.52	28.65	1.54	30.60	1.57	32.12	1.60
		20	24.49	1.43	26.01	1.49	27.53	1.54	28.63	1.56	30.57	1.59	32.09	1.62
		25	24.47	1.45	25.99	1.51	27.51	1.56	28.61	1.58	30.55	1.61	32.07	1.64
		30	24.45	1.48	25.97	1.53	27.49	1.58	28.59	1.60	30.53	1.63	32.04	1.67
		35	24.43	1.50	25.95	1.55	27.47	1.61	28.56	1.63	30.50	1.66	32.02	1.69
		40	24.41	1.52	25.93	1.57	27.45	1.63	28.54	1.65	30.48	1.68	32.00	1.71
		45	24.40	1.54	25.91	1.59	27.43	1.65	28.52	1.67	30.46	1.70	31.97	1.73
		50	24.38	1.56	25.89	1.61	27.40	1.67	28.50	1.69	30.43	1.72	31.95	1.76
		55	24.36	1.58	25.87	1.63	27.38	1.69	28.48	1.71	30.41	1.75	31.92	1.78
		60	24.34	1.60	25.85	1.66	27.36	1.72	28.45	1.74	30.39	1.77	31.90	1.80
		65	24.32	1.62	25.83	1.68	27.34	1.74	28.43	1.76	30.36	1.79	31.87	1.83
		70	24.30	1.64	25.81	1.70	27.32	1.76	28.41	1.78	30.34	1.81	31.85	1.85
		75	23.72	1.73	25.22	1.79	26.73	1.85	27.82	1.88	29.74	1.91	31.24	1.95
		80	23.13	1.81	24.63	1.88	26.14	1.95	27.22	1.97	29.14	2.01	30.64	2.05
		85	22.55	1.90	24.05	1.97	25.55	2.04	26.63	2.07	28.54	2.11	30.04	2.15
		90	21.97	1.99	23.47	2.06	24.96	2.14	26.04	2.16	27.95	2.20	29.44	2.25
		95	21.34	2.08	22.83	2.16	24.32	2.23	25.00	2.26	27.29	2.30	28.78	2.35
		100	20.82	2.17	22.31	2.25	23.80	2.33	24.68	2.36	26.77	2.40	28.26	2.45
		105	20.30	2.26	21.79	2.34	23.28	2.42	24.35	2.45	26.25	2.50	27.74	2.55
		110	19.78	2.34	21.27	2.43	22.76	2.52	23.83	2.55	25.73	2.60	27.22	2.65
		115	19.26	2.43	20.75	2.52	22.24	2.61	23.31	2.64	25.21	2.69	26.70	2.75
		118	18.95	2.49	20.44	2.58	21.93	2.67	23.00	2.70	24.90	2.75	26.39	2.81
		122	18.85	2.56	20.34	2.65	21.82	2.75	22.90	2.78	24.80	2.83	26.28	2.89
	9 + 18	-4	26.54	1.43	28.19	1.48	29.84	1.54	31.03	1.56	33.14	1.59	34.79	1.62
		0	26.53	1.45	28.18	1.50	29.83	1.56	31.02	1.57	33.12	1.60	34.77	1.63
		5	26.51	1.47	28.15	1.52	29.80	1.58	30.99	1.60	33.09	1.63	34.74	1.66
		10	26.49	1.49	28.13	1.55	29.78	1.60	30.97	1.62	33.07	1.65	34.71	1.69
		14	26.47	1.51	28.11	1.57	29.76	1.63	30.94	1.65	33.04	1.68	34.69	1.71
		20	26.45	1.54	28.09	1.59	29.73	1.65	30.92	1.67	33.02	1.70	34.66	1.73
		25	26.43	1.56	28.07	1.61	29.71	1.67	30.90	1.69	32.99	1.72	34.63	1.76
		30	26.41	1.58	28.05	1.64	29.69	1.70	30.87	1.72	32.97	1.75	34.61	1.78
		35	26.39	1.60	28.03	1.66	29.66	1.72	30.85	1.74	32.94	1.77	34.58	1.81
		40	26.37	1.62	28.00	1.68	29.64	1.74	30.82	1.76	32.92	1.80	34.55	1.83
		45	26.35	1.64	27.98	1.71	29.62	1.77	30.80	1.79	32.89	1.82	34.53	1.86
		50	26.33	1.67	27.96	1.73	29.60	1.79	30.78	1.81	32.87	1.85	34.50	1.88
		55	26.31	1.69	27.94	1.75	29.57	1.81	30.75	1.83	32.84	1.87	34.48	1.91
		60	26.29	1.71	27.92	1.77	29.55	1.84	30.73	1.86	32.82	1.89	34.45	1.93
		65	26.27	1.73	27.90	1.80	29.53	1.86	30.71	1.88	32.79	1.92	34.42	1.96
		70	26.25	1.75	27.88	1.82	29.51	1.88	30.68	1.91	32.77	1.94	34.40	1.98
		75	25.61	1.85	27.24	1.92	28.87	1.99	30.04	2.01	32.12	2.05	33.74	2.09
		80	24.98	1.94	26.60	2.01	28.23	2.09	29.40	2.11	31.47	2.15	33.09	2.19
		85	24.36	2.04	25.97	2.11	27.59	2.19	28.76	2.21	30.83	2.26	32.45	2.30
		90	23.73	2.13	25.34	2.21	26.96	2.29	28.12	2.32	30.19	2.36	31.80	2.41
		95	23.05	2.23	24.66	2.31	26.26	2.39	27.00	2.42	29.48	2.47	31.08	2.51
		100	22.49	2.32	24.10	2.41	25.70	2.49	26.65	2.52	28.91	2.57	30.52	2.62
		105	21.93	2.42	23.53	2.50	25.14	2.60	26.30	2.63	28.35	2.67	29.96	2.73
		110	21.37	2.51	22.97	2.60	24.58	2.70	25.74	2.73	27.79	2.78	29.40	2.84
		115	20.81	2.61	22.41	2.70	24.02	2.80	25.18	2.83	27.23	2.88	28.84	2.94
		118	20.47	2.66	22.08	2.76	23.68	2.86	24.84	2.89	26.89	2.95	28.50	3.01
		122	20.36	2.74	21.96	2.84	23.57	2.94	24.73	2.98	26.78	3.03	28.39	3.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 108: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	12 + 15	-4	26.54	1.43	28.19	1.48	29.84	1.54	31.03	1.56	33.14	1.59	34.79	1.62
		0	26.53	1.45	28.18	1.50	29.83	1.56	31.02	1.57	33.12	1.60	34.77	1.63
		5	26.51	1.47	28.15	1.52	29.80	1.58	30.99	1.60	33.09	1.63	34.74	1.66
		10	26.49	1.49	28.13	1.55	29.78	1.60	30.97	1.62	33.07	1.65	34.71	1.69
		14	26.47	1.51	28.11	1.57	29.76	1.63	30.94	1.65	33.04	1.68	34.69	1.71
		20	26.45	1.54	28.09	1.59	29.73	1.65	30.92	1.67	33.02	1.70	34.66	1.73
		25	26.43	1.56	28.07	1.61	29.71	1.67	30.90	1.69	32.99	1.72	34.63	1.76
		30	26.41	1.58	28.05	1.64	29.69	1.70	30.87	1.72	32.97	1.75	34.61	1.78
		35	26.39	1.60	28.03	1.66	29.66	1.72	30.85	1.74	32.94	1.77	34.58	1.81
		40	26.37	1.62	28.00	1.68	29.64	1.74	30.82	1.76	32.92	1.80	34.55	1.83
		45	26.35	1.64	27.98	1.71	29.62	1.77	30.80	1.79	32.89	1.82	34.53	1.86
		50	26.33	1.67	27.96	1.73	29.60	1.79	30.78	1.81	32.87	1.85	34.50	1.88
		55	26.31	1.69	27.94	1.75	29.57	1.81	30.75	1.83	32.84	1.87	34.48	1.91
		60	26.29	1.71	27.92	1.77	29.55	1.84	30.73	1.86	32.82	1.89	34.45	1.93
		65	26.27	1.73	27.90	1.80	29.53	1.86	30.71	1.88	32.79	1.92	34.42	1.96
		70	26.25	1.75	27.88	1.82	29.51	1.88	30.68	1.91	32.77	1.94	34.40	1.98
		75	25.61	1.85	27.24	1.92	28.87	1.99	30.04	2.01	32.12	2.05	33.74	2.09
		80	24.98	1.94	26.60	2.01	28.23	2.09	29.40	2.11	31.47	2.15	33.09	2.19
		85	24.36	2.04	25.97	2.11	27.59	2.19	28.76	2.21	30.83	2.26	32.45	2.30
		90	23.73	2.13	25.34	2.21	26.96	2.29	28.12	2.32	30.19	2.36	31.80	2.41
		95	23.05	2.23	24.66	2.31	26.26	2.39	27.00	2.42	29.48	2.47	31.08	2.51
		100	22.49	2.32	24.10	2.41	25.70	2.49	26.65	2.52	28.91	2.57	30.52	2.62
		105	21.93	2.42	23.53	2.50	25.14	2.60	26.30	2.63	28.35	2.67	29.96	2.73
		110	21.37	2.51	22.97	2.60	24.58	2.70	25.74	2.73	27.79	2.78	29.40	2.84
		115	20.81	2.61	22.41	2.70	24.02	2.80	25.18	2.83	27.23	2.88	28.84	2.94
		118	20.47	2.66	22.08	2.76	23.68	2.86	24.84	2.89	26.89	2.95	28.50	3.01
		122	20.36	2.74	21.96	2.84	23.57	2.94	24.73	2.98	26.78	3.03	28.39	3.09
	12 + 18	-4	29.49	1.56	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.76
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.78
		5	29.45	1.60	31.28	1.66	33.11	1.72	34.43	1.74	36.77	1.77	38.60	1.81
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.80	38.57	1.83
		14	29.41	1.65	31.24	1.71	33.06	1.77	34.38	1.79	36.71	1.82	38.54	1.86
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.85	38.51	1.89
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.72	31.16	1.78	32.99	1.84	34.30	1.87	36.63	1.90	38.45	1.94
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.93	38.42	1.97
		40	29.30	1.76	31.12	1.83	32.94	1.90	34.25	1.92	36.57	1.95	38.39	1.99
		45	29.27	1.79	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.98	38.36	2.02
		50	29.25	1.81	31.07	1.88	32.89	1.95	34.20	1.97	36.52	2.01	38.34	2.05
		55	29.23	1.84	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.86	31.02	1.93	32.83	2.00	34.14	2.02	36.46	2.06	38.28	2.10
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.05	36.43	2.08	38.25	2.13
		70	29.16	1.91	30.97	1.98	32.78	2.05	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.01	30.27	2.08	32.07	2.16	33.38	2.18	35.69	2.22	37.49	2.27
		80	27.76	2.11	29.56	2.19	31.36	2.27	32.66	2.29	34.97	2.34	36.77	2.38
		85	27.06	2.21	28.86	2.30	30.66	2.38	31.96	2.41	34.25	2.45	36.05	2.50
		90	26.37	2.32	28.16	2.40	29.95	2.49	31.25	2.52	33.54	2.57	35.33	2.62
		95	25.61	2.42	27.40	2.51	29.18	2.60	30.00	2.63	32.75	2.68	34.53	2.73
		100	24.99	2.52	26.77	2.62	28.56	2.71	29.61	2.74	32.13	2.79	33.91	2.85
		105	24.37	2.63	26.15	2.72	27.93	2.82	29.22	2.85	31.50	2.91	33.29	2.97
		110	23.74	2.73	25.53	2.83	27.31	2.93	28.60	2.97	30.88	3.02	32.66	3.08
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.08	30.26	3.13	32.04	3.20
		118	22.74	2.89	24.53	3.00	26.31	3.11	27.60	3.14	29.88	3.20	31.67	3.27
		122	22.62	2.98	24.40	3.08	26.19	3.20	27.48	3.23	29.76	3.29	31.54	3.36

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 109: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 15	-4	29.49	1.56	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.76
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.78
		5	29.45	1.60	31.28	1.66	33.11	1.72	34.43	1.74	36.77	1.77	38.60	1.81
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.80	38.57	1.83
		14	29.41	1.65	31.24	1.71	33.06	1.77	34.38	1.79	36.71	1.82	38.54	1.86
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.85	38.51	1.89
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.72	31.16	1.78	32.99	1.84	34.30	1.87	36.63	1.90	38.45	1.94
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.93	38.42	1.97
		40	29.30	1.76	31.12	1.83	32.94	1.90	34.25	1.92	36.57	1.95	38.39	1.99
		45	29.27	1.79	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.98	38.36	2.02
		50	29.25	1.81	31.07	1.88	32.89	1.95	34.20	1.97	36.52	2.01	38.34	2.05
		55	29.23	1.84	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.86	31.02	1.93	32.83	2.00	34.14	2.02	36.46	2.06	38.28	2.10
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.05	36.43	2.08	38.25	2.13
		70	29.16	1.91	30.97	1.98	32.78	2.05	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.01	30.27	2.08	32.07	2.16	33.38	2.18	35.69	2.22	37.49	2.27
		80	27.76	2.11	29.56	2.19	31.36	2.27	32.66	2.29	34.97	2.34	36.77	2.38
		85	27.06	2.21	28.86	2.30	30.66	2.38	31.96	2.41	34.25	2.45	36.05	2.50
		90	26.37	2.32	28.16	2.40	29.95	2.49	31.25	2.52	33.54	2.57	35.33	2.62
		95	25.61	2.42	27.40	2.51	29.18	2.60	30.00	2.63	32.75	2.68	34.53	2.73
		100	24.99	2.52	26.77	2.62	28.56	2.71	29.61	2.74	32.13	2.79	33.91	2.85
		105	24.37	2.63	26.15	2.72	27.93	2.82	29.22	2.85	31.50	2.91	33.29	2.97
		110	23.74	2.73	25.53	2.83	27.31	2.93	28.60	2.97	30.88	3.02	32.66	3.08
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.08	30.26	3.13	32.04	3.20
		118	22.74	2.89	24.53	3.00	26.31	3.11	27.60	3.14	29.88	3.20	31.67	3.27
		122	22.62	2.98	24.40	3.08	26.19	3.20	27.48	3.23	29.76	3.29	31.54	3.36
	7 + 24	-4	30.48	1.59	32.37	1.65	34.26	1.71	35.63	1.73	38.05	1.76	39.94	1.80
		0	30.46	1.61	32.35	1.67	34.24	1.73	35.61	1.75	38.03	1.78	39.92	1.82
		5	30.44	1.64	32.33	1.69	34.22	1.76	35.58	1.78	38.00	1.81	39.89	1.85
		10	30.41	1.66	32.30	1.72	34.19	1.78	35.55	1.80	37.97	1.84	39.86	1.87
		14	30.39	1.68	32.28	1.74	34.16	1.81	35.53	1.83	37.94	1.86	39.83	1.90
		20	30.37	1.71	32.25	1.77	34.14	1.83	35.50	1.86	37.91	1.89	39.80	1.93
		25	30.34	1.73	32.23	1.80	34.11	1.86	35.47	1.88	37.88	1.92	39.77	1.96
		30	30.32	1.76	32.20	1.82	34.09	1.89	35.45	1.91	37.85	1.94	39.73	1.98
		35	30.30	1.78	32.18	1.85	34.06	1.91	35.42	1.93	37.82	1.97	39.70	2.01
		40	30.27	1.80	32.15	1.87	34.03	1.94	35.39	1.96	37.79	2.00	39.67	2.04
		45	30.25	1.83	32.13	1.90	34.01	1.96	35.36	1.99	37.76	2.02	39.64	2.07
		50	30.23	1.85	32.10	1.92	33.98	1.99	35.34	2.01	37.74	2.05	39.61	2.09
		55	30.20	1.88	32.08	1.95	33.96	2.02	35.31	2.04	37.71	2.08	39.58	2.12
		60	30.18	1.90	32.05	1.97	33.93	2.04	35.28	2.07	37.68	2.10	39.55	2.15
		65	30.16	1.93	32.03	2.00	33.90	2.07	35.26	2.09	37.65	2.13	39.52	2.17
		70	30.13	1.95	32.01	2.02	33.88	2.09	35.23	2.12	37.62	2.16	39.49	2.20
		75	29.41	2.05	31.28	2.13	33.14	2.21	34.49	2.23	36.88	2.27	38.74	2.32
		80	28.68	2.16	30.55	2.24	32.41	2.32	33.75	2.35	36.13	2.39	38.00	2.44
		85	27.97	2.26	29.82	2.35	31.68	2.43	33.02	2.46	35.40	2.51	37.25	2.56
		90	27.25	2.37	29.10	2.46	30.95	2.55	32.29	2.58	34.66	2.62	36.51	2.68
		95	26.47	2.48	28.31	2.57	30.15	2.66	31.00	2.69	33.84	2.74	35.69	2.80
		100	25.82	2.58	27.67	2.67	29.51	2.77	30.60	2.80	33.20	2.86	35.04	2.91
		105	25.18	2.69	27.02	2.78	28.87	2.89	30.20	2.92	32.55	2.97	34.40	3.03
		110	24.53	2.79	26.38	2.89	28.22	3.00	29.55	3.03	31.91	3.09	33.75	3.15
		115	23.89	2.90	25.73	3.00	27.58	3.11	28.91	3.15	31.26	3.21	33.11	3.27
		118	23.50	2.96	25.35	3.07	27.19	3.18	28.52	3.22	30.88	3.28	32.72	3.34
		122	23.37	3.04	25.22	3.15	27.06	3.27	28.39	3.31	30.75	3.37	32.59	3.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 110: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Unit, continued

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 24	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
		105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53
	15 + 18	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
		105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 111: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	18 + 18	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
		105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53
	12 + 24	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
		105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 112: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 24	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
		105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53
	18 + 24	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
		105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 113: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	24 + 24	-4	31.46	1.63	33.41	1.69	35.37	1.75	36.78	1.77	39.28	1.81	41.23	1.84
		0	31.44	1.65	33.40	1.71	35.35	1.77	36.76	1.79	39.25	1.83	41.21	1.86
		5	31.42	1.68	33.37	1.74	35.32	1.80	36.73	1.82	39.22	1.86	41.17	1.89
		10	31.39	1.70	33.34	1.76	35.29	1.83	36.70	1.85	39.19	1.88	41.14	1.92
		14	31.37	1.73	33.32	1.79	35.27	1.86	36.67	1.88	39.16	1.91	41.11	1.95
		20	31.35	1.75	33.29	1.82	35.24	1.88	36.64	1.90	39.13	1.94	41.08	1.98
		25	31.32	1.78	33.27	1.84	35.21	1.91	36.62	1.93	39.10	1.97	41.05	2.01
		30	31.30	1.80	33.24	1.87	35.19	1.94	36.59	1.96	39.07	1.99	41.02	2.03
		35	31.27	1.83	33.22	1.89	35.16	1.96	36.56	1.98	39.04	2.02	40.99	2.06
		40	31.25	1.85	33.19	1.92	35.13	1.99	36.53	2.01	39.01	2.05	40.95	2.09
		45	31.23	1.88	33.17	1.94	35.10	2.02	36.51	2.04	38.98	2.08	40.92	2.12
		50	31.20	1.90	33.14	1.97	35.08	2.04	36.48	2.07	38.95	2.10	40.89	2.15
		55	31.18	1.93	33.11	2.00	35.05	2.07	36.45	2.09	38.92	2.13	40.86	2.17
		60	31.15	1.95	33.09	2.02	35.02	2.10	36.42	2.12	38.89	2.16	40.83	2.20
		65	31.13	1.98	33.06	2.05	35.00	2.12	36.39	2.15	38.86	2.19	40.80	2.23
		70	31.11	2.00	33.04	2.07	34.97	2.15	36.37	2.17	38.83	2.21	40.77	2.26
		75	30.36	2.11	32.28	2.19	34.21	2.26	35.60	2.29	38.07	2.33	39.99	2.38
		80	29.61	2.22	31.53	2.30	33.45	2.38	34.84	2.41	37.30	2.45	39.22	2.50
		85	28.87	2.32	30.78	2.41	32.70	2.50	34.09	2.53	36.54	2.57	38.46	2.62
		90	28.13	2.43	30.04	2.52	31.95	2.61	33.33	2.64	35.78	2.69	37.69	2.75
		95	27.32	2.54	29.22	2.63	31.13	2.73	32.00	2.76	34.93	2.81	36.84	2.87
		100	26.65	2.65	28.56	2.74	30.46	2.84	31.59	2.88	34.27	2.93	36.17	2.99
Three (3) Non-Ducted Indoor Units	7 + 7 + 7	105	25.99	2.76	27.89	2.86	29.80	2.96	31.17	2.99	33.60	3.05	35.51	3.11
		110	25.32	2.86	27.23	2.97	29.13	3.08	30.51	3.11	32.94	3.17	34.84	3.23
		115	24.66	2.97	26.56	3.08	28.47	3.19	29.84	3.23	32.27	3.29	34.18	3.36
		118	24.26	3.04	26.16	3.15	28.07	3.26	29.44	3.30	31.87	3.36	33.78	3.43
		122	24.13	3.12	26.03	3.24	27.93	3.35	29.31	3.39	31.74	3.46	33.64	3.53
		-4	20.65	1.13	21.93	1.17	23.21	1.21	24.14	1.23	25.77	1.25	27.06	1.28
		0	20.63	1.14	21.92	1.18	23.20	1.23	24.12	1.24	25.76	1.26	27.04	1.29
		5	20.62	1.16	21.90	1.20	23.18	1.25	24.10	1.26	25.74	1.29	27.02	1.31
		10	20.60	1.18	21.88	1.22	23.16	1.27	24.08	1.28	25.72	1.30	27.00	1.33
		14	20.59	1.20	21.86	1.24	23.14	1.28	24.07	1.30	25.70	1.32	26.98	1.35
		20	20.57	1.21	21.85	1.26	23.13	1.30	24.05	1.32	25.68	1.34	26.96	1.37
		25	20.55	1.23	21.83	1.27	23.11	1.32	24.03	1.34	25.66	1.36	26.94	1.39
		30	20.54	1.25	21.81	1.29	23.09	1.34	24.01	1.35	25.64	1.38	26.92	1.41
		35	20.52	1.26	21.80	1.31	23.07	1.36	23.99	1.37	25.62	1.40	26.90	1.43
		40	20.51	1.28	21.78	1.33	23.05	1.38	23.97	1.39	25.60	1.42	26.88	1.45
		45	20.49	1.30	21.76	1.35	23.04	1.39	23.96	1.41	25.58	1.44	26.86	1.47
		50	20.48	1.32	21.75	1.36	23.02	1.41	23.94	1.43	25.56	1.46	26.83	1.49
		55	20.46	1.33	21.73	1.38	23.00	1.43	23.92	1.45	25.54	1.48	26.81	1.51
		60	20.44	1.35	21.71	1.40	22.98	1.45	23.90	1.47	25.52	1.49	26.79	1.52
		65	20.43	1.37	21.70	1.42	22.97	1.47	23.88	1.49	25.50	1.51	26.77	1.54
		70	20.41	1.38	21.68	1.43	22.95	1.49	23.86	1.50	25.48	1.53	26.75	1.56
		75	19.92	1.46	21.19	1.51	22.45	1.57	23.36	1.59	24.98	1.62	26.25	1.65
		80	19.43	1.53	20.69	1.59	21.95	1.65	22.87	1.67	24.48	1.70	25.74	1.73
		85	18.94	1.61	20.20	1.67	21.46	1.73	22.37	1.75	23.98	1.78	25.24	1.82
		90	18.46	1.68	19.71	1.74	20.97	1.81	21.87	1.83	23.48	1.86	24.73	1.90
		95	17.93	1.76	19.18	1.82	20.43	1.89	21.00	1.91	22.93	1.95	24.17	1.98
		100	17.49	1.83	18.74	1.90	19.99	1.97	20.73	1.99	22.49	2.03	23.74	2.07
		105	17.06	1.91	18.30	1.98	19.55	2.05	20.46	2.07	22.05	2.11	23.30	2.15
		110	16.62	1.98	17.87	2.05	19.12	2.13	20.02	2.15	21.62	2.19	22.86	2.24
		115	16.18	2.06	17.43	2.13	18.68	2.21	19.58	2.23	21.18	2.28	22.43	2.32
		118	15.92	2.10	17.17	2.18	18.42	2.26	19.32	2.28	20.92	2.33	22.17	2.37
		122	15.83	2.16	17.08	2.24	18.33	2.32	19.23	2.35	20.83	2.39	22.08	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 114: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 9	-4	22.61	1.22	24.02	1.26	25.42	1.31	26.44	1.32	28.23	1.35	29.63	1.38
		0	22.60	1.23	24.00	1.28	25.41	1.32	26.42	1.34	28.21	1.36	29.62	1.39
		5	22.58	1.25	23.98	1.30	25.39	1.35	26.40	1.36	28.19	1.39	29.59	1.41
		10	22.56	1.27	23.97	1.32	25.37	1.37	26.38	1.38	28.17	1.41	29.57	1.43
		14	22.55	1.29	23.95	1.34	25.35	1.38	26.36	1.40	28.15	1.43	29.55	1.46
		20	22.53	1.31	23.93	1.36	25.33	1.40	26.34	1.42	28.13	1.45	29.53	1.48
		25	22.51	1.33	23.91	1.37	25.31	1.42	26.32	1.44	28.10	1.47	29.50	1.50
		30	22.50	1.34	23.89	1.39	25.29	1.44	26.30	1.46	28.08	1.49	29.48	1.52
		35	22.48	1.36	23.87	1.41	25.27	1.46	26.28	1.48	28.06	1.51	29.46	1.54
		40	22.46	1.38	23.86	1.43	25.25	1.48	26.26	1.50	28.04	1.53	29.44	1.56
		45	22.44	1.40	23.84	1.45	25.23	1.50	26.24	1.52	28.02	1.55	29.41	1.58
		50	22.43	1.42	23.82	1.47	25.21	1.52	26.22	1.54	28.00	1.57	29.39	1.60
		55	22.41	1.44	23.80	1.49	25.19	1.54	26.20	1.56	27.98	1.59	29.37	1.62
		60	22.39	1.46	23.78	1.51	25.17	1.56	26.18	1.58	27.95	1.61	29.35	1.64
		65	22.37	1.47	23.76	1.53	25.15	1.58	26.16	1.60	27.93	1.63	29.32	1.67
		70	22.36	1.49	23.75	1.55	25.13	1.60	26.14	1.62	27.91	1.65	29.30	1.69
		75	21.82	1.57	23.20	1.63	24.59	1.69	25.59	1.71	27.36	1.74	28.75	1.78
		80	21.28	1.65	22.66	1.71	24.04	1.78	25.04	1.80	26.81	1.83	28.19	1.87
		85	20.75	1.73	22.13	1.80	23.50	1.86	24.50	1.88	26.26	1.92	27.64	1.96
		90	20.22	1.82	21.59	1.88	22.96	1.95	23.96	1.97	25.71	2.01	27.09	2.05
		95	19.64	1.90	21.00	1.96	22.37	2.04	23.00	2.06	25.11	2.10	26.48	2.14
		100	19.16	1.98	20.53	2.05	21.89	2.12	22.70	2.15	24.63	2.19	26.00	2.23
		105	18.68	2.06	20.05	2.13	21.42	2.21	22.40	2.24	24.15	2.28	25.52	2.32
		110	18.20	2.14	19.57	2.22	20.94	2.30	21.93	2.32	23.67	2.37	25.04	2.41
		115	17.72	2.22	19.09	2.30	20.46	2.38	21.45	2.41	23.20	2.46	24.56	2.50
		118	17.44	2.27	18.80	2.35	20.17	2.43	21.16	2.46	22.91	2.51	24.28	2.56
		122	17.34	2.33	18.71	2.42	20.08	2.50	21.07	2.53	22.81	2.58	24.18	2.63
	7 + 9 + 9	-4	24.58	1.31	26.10	1.36	27.63	1.41	28.73	1.43	30.68	1.45	32.21	1.48
		0	24.57	1.33	26.09	1.38	27.62	1.43	28.72	1.44	30.67	1.47	32.19	1.50
		5	24.54	1.35	26.07	1.40	27.59	1.45	28.69	1.47	30.64	1.49	32.17	1.52
		10	24.53	1.37	26.05	1.42	27.57	1.47	28.67	1.49	30.62	1.52	32.14	1.55
		14	24.51	1.39	26.03	1.44	27.55	1.49	28.65	1.51	30.60	1.54	32.12	1.57
		20	24.49	1.41	26.01	1.46	27.53	1.51	28.63	1.53	30.57	1.56	32.09	1.59
		25	24.47	1.43	25.99	1.48	27.51	1.54	28.61	1.55	30.55	1.58	32.07	1.61
		30	24.45	1.45	25.97	1.50	27.49	1.56	28.59	1.57	30.53	1.60	32.04	1.64
		35	24.43	1.47	25.95	1.52	27.47	1.58	28.56	1.60	30.50	1.63	32.02	1.66
		40	24.41	1.49	25.93	1.54	27.45	1.60	28.54	1.62	30.48	1.65	32.00	1.68
		45	24.40	1.51	25.91	1.56	27.43	1.62	28.52	1.64	30.46	1.67	31.97	1.70
		50	24.38	1.53	25.89	1.58	27.40	1.64	28.50	1.66	30.43	1.69	31.95	1.73
		55	24.36	1.55	25.87	1.61	27.38	1.66	28.48	1.68	30.41	1.71	31.92	1.75
		60	24.34	1.57	25.85	1.63	27.36	1.69	28.45	1.70	30.39	1.74	31.90	1.77
		65	24.32	1.59	25.83	1.65	27.34	1.71	28.43	1.73	30.36	1.76	31.87	1.79
		70	24.30	1.61	25.81	1.67	27.32	1.73	28.41	1.75	30.34	1.78	31.85	1.82
		75	23.72	1.70	25.22	1.76	26.73	1.82	27.82	1.84	29.74	1.88	31.24	1.91
		80	23.13	1.78	24.63	1.85	26.14	1.91	27.22	1.94	29.14	1.97	30.64	2.01
		85	22.55	1.87	24.05	1.94	25.55	2.01	26.63	2.03	28.54	2.07	30.04	2.11
		90	21.97	1.96	23.47	2.03	24.96	2.10	26.04	2.13	27.95	2.17	29.44	2.21
		95	21.34	2.04	22.83	2.12	24.32	2.19	25.00	2.22	27.29	2.26	28.78	2.31
		100	20.82	2.13	22.31	2.21	23.80	2.29	24.68	2.31	26.77	2.36	28.26	2.41
		105	20.30	2.22	21.79	2.30	23.28	2.38	24.35	2.41	26.25	2.45	27.74	2.50
		110	19.78	2.30	21.27	2.39	22.76	2.47	23.83	2.50	25.73	2.55	27.22	2.60
		115	19.26	2.39	20.75	2.48	22.24	2.57	23.31	2.60	25.21	2.65	26.70	2.70
		118	18.95	2.44	20.44	2.53	21.93	2.62	23.00	2.65	24.90	2.70	26.39	2.76
		122	18.85	2.51	20.34	2.60	21.82	2.70	22.90	2.73	24.80	2.78	26.28	2.84

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 115: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 12	-4	25.56	1.34	27.15	1.39	28.74	1.44	29.88	1.45	31.91	1.48	33.50	1.51
		0	25.55	1.35	27.13	1.40	28.72	1.45	29.87	1.47	31.89	1.50	33.48	1.53
		5	25.53	1.37	27.11	1.42	28.70	1.48	29.84	1.49	31.87	1.52	33.45	1.55
		10	25.51	1.39	27.09	1.44	28.68	1.50	29.82	1.51	31.84	1.54	33.43	1.57
		14	25.49	1.41	27.07	1.47	28.65	1.52	29.80	1.54	31.82	1.57	33.40	1.60
		20	25.47	1.43	27.05	1.49	28.63	1.54	29.77	1.56	31.80	1.59	33.38	1.62
		25	25.45	1.45	27.03	1.51	28.61	1.56	29.75	1.58	31.77	1.61	33.35	1.64
		30	25.43	1.48	27.01	1.53	28.59	1.58	29.73	1.60	31.75	1.63	33.33	1.67
		35	25.41	1.50	26.99	1.55	28.57	1.61	29.71	1.63	31.72	1.66	33.30	1.69
		40	25.39	1.52	26.97	1.57	28.54	1.63	29.68	1.65	31.70	1.68	33.27	1.71
		45	25.37	1.54	26.95	1.59	28.52	1.65	29.66	1.67	31.67	1.70	33.25	1.73
		50	25.35	1.56	26.93	1.61	28.50	1.67	29.64	1.69	31.65	1.72	33.22	1.76
		55	25.33	1.58	26.91	1.63	28.48	1.69	29.61	1.71	31.63	1.75	33.20	1.78
		60	25.31	1.60	26.88	1.66	28.46	1.72	29.59	1.74	31.60	1.77	33.17	1.80
		65	25.29	1.62	26.86	1.68	28.43	1.74	29.57	1.76	31.58	1.79	33.15	1.83
		70	25.27	1.64	26.84	1.70	28.41	1.76	29.55	1.78	31.55	1.81	33.12	1.85
		75	24.67	1.73	26.23	1.79	27.80	1.85	28.93	1.88	30.93	1.91	32.49	1.95
		80	24.06	1.81	25.62	1.88	27.18	1.95	28.31	1.97	30.31	2.01	31.87	2.05
		85	23.45	1.90	25.01	1.97	26.57	2.04	27.70	2.07	29.69	2.11	31.24	2.15
		90	22.85	1.99	24.41	2.06	25.96	2.14	27.08	2.16	29.07	2.20	30.62	2.25
		95	22.20	2.08	23.74	2.16	25.29	2.23	26.00	2.26	28.38	2.30	29.93	2.35
		100	21.66	2.17	23.20	2.25	24.75	2.33	25.66	2.36	27.84	2.40	29.39	2.45
		105	21.12	2.26	22.66	2.34	24.21	2.42	25.33	2.45	27.30	2.50	28.85	2.55
		110	20.58	2.34	22.12	2.43	23.67	2.52	24.79	2.55	26.76	2.60	28.31	2.65
		115	20.04	2.43	21.58	2.52	23.13	2.61	24.25	2.64	26.22	2.69	27.77	2.75
		118	19.71	2.49	21.26	2.58	22.80	2.67	23.92	2.70	25.90	2.75	27.44	2.81
		122	19.60	2.56	21.15	2.65	22.70	2.75	23.81	2.78	25.79	2.83	27.34	2.89
	9 + 9 + 9	-4	26.54	1.36	28.19	1.41	29.84	1.46	31.03	1.48	33.14	1.51	34.79	1.54
		0	26.53	1.38	28.18	1.43	29.83	1.48	31.02	1.49	33.12	1.52	34.77	1.55
		5	26.51	1.40	28.15	1.45	29.80	1.50	30.99	1.52	33.09	1.55	34.74	1.58
		10	26.49	1.42	28.13	1.47	29.78	1.52	30.97	1.54	33.07	1.57	34.71	1.60
		14	26.47	1.44	28.11	1.49	29.76	1.55	30.94	1.56	33.04	1.59	34.69	1.63
		20	26.45	1.46	28.09	1.51	29.73	1.57	30.92	1.59	33.02	1.62	34.66	1.65
		25	26.43	1.48	28.07	1.53	29.71	1.59	30.90	1.61	32.99	1.64	34.63	1.67
		30	26.41	1.50	28.05	1.56	29.69	1.61	30.87	1.63	32.97	1.66	34.61	1.70
		35	26.39	1.52	28.03	1.58	29.66	1.64	30.85	1.65	32.94	1.69	34.58	1.72
		40	26.37	1.54	28.00	1.60	29.64	1.66	30.82	1.68	32.92	1.71	34.55	1.74
		45	26.35	1.56	27.98	1.62	29.62	1.68	30.80	1.70	32.89	1.73	34.53	1.77
		50	26.33	1.58	27.96	1.64	29.60	1.70	30.78	1.72	32.87	1.75	34.50	1.79
		55	26.31	1.60	27.94	1.66	29.57	1.72	30.75	1.74	32.84	1.78	34.48	1.81
		60	26.29	1.63	27.92	1.68	29.55	1.75	30.73	1.77	32.82	1.80	34.45	1.84
		65	26.27	1.65	27.90	1.71	29.53	1.77	30.71	1.79	32.79	1.82	34.42	1.86
		70	26.25	1.67	27.88	1.73	29.51	1.79	30.68	1.81	32.77	1.85	34.40	1.88
		75	25.61	1.76	27.24	1.82	28.87	1.89	30.04	1.91	32.12	1.94	33.74	1.98
		80	24.98	1.85	26.60	1.91	28.23	1.98	29.40	2.01	31.47	2.04	33.09	2.09
		85	24.36	1.94	25.97	2.01	27.59	2.08	28.76	2.10	30.83	2.14	32.45	2.19
		90	23.73	2.03	25.34	2.10	26.96	2.18	28.12	2.20	30.19	2.24	31.80	2.29
		95	23.05	2.12	24.66	2.19	26.26	2.27	27.00	2.30	29.48	2.34	31.08	2.39
		100	22.49	2.21	24.10	2.29	25.70	2.37	26.65	2.40	28.91	2.44	30.52	2.49
		105	21.93	2.30	23.53	2.38	25.14	2.47	26.30	2.50	28.35	2.54	29.96	2.59
		110	21.37	2.39	22.97	2.47	24.58	2.56	25.74	2.59	27.79	2.64	29.40	2.69
		115	20.81	2.48	22.41	2.57	24.02	2.66	25.18	2.69	27.23	2.74	28.84	2.80
		118	20.47	2.53	22.08	2.62	23.68	2.72	24.84	2.75	26.89	2.80	28.50	2.86
		122	20.36	2.60	21.96	2.70	23.57	2.80	24.73	2.83	26.78	2.88	28.39	2.94

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 116: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 12	-4	27.53	1.39	29.24	1.44	30.95	1.49	32.18	1.51	34.37	1.54	36.08	1.57
		0	27.51	1.41	29.22	1.46	30.93	1.51	32.16	1.53	34.35	1.56	36.06	1.59
		5	27.49	1.43	29.20	1.48	30.90	1.53	32.14	1.55	34.32	1.58	36.03	1.61
		10	27.47	1.45	29.18	1.50	30.88	1.56	32.11	1.58	34.29	1.60	36.00	1.64
		14	27.45	1.47	29.15	1.52	30.86	1.58	32.09	1.60	34.27	1.63	35.97	1.66
		20	27.43	1.49	29.13	1.55	30.83	1.60	32.06	1.62	34.24	1.65	35.94	1.68
		25	27.41	1.51	29.11	1.57	30.81	1.63	32.04	1.64	34.21	1.67	35.92	1.71
		30	27.39	1.53	29.09	1.59	30.79	1.65	32.02	1.67	34.19	1.70	35.89	1.73
		35	27.36	1.56	29.06	1.61	30.76	1.67	31.99	1.69	34.16	1.72	35.86	1.76
		40	27.34	1.58	29.04	1.63	30.74	1.69	31.97	1.71	34.14	1.75	35.83	1.78
		45	27.32	1.60	29.02	1.66	30.72	1.72	31.94	1.74	34.11	1.77	35.81	1.80
		50	27.30	1.62	29.00	1.68	30.69	1.74	31.92	1.76	34.08	1.79	35.78	1.83
		55	27.28	1.64	28.98	1.70	30.67	1.76	31.89	1.78	34.06	1.82	35.75	1.85
		60	27.26	1.66	28.95	1.72	30.65	1.78	31.87	1.80	34.03	1.84	35.72	1.88
		65	27.24	1.68	28.93	1.74	30.62	1.81	31.84	1.83	34.01	1.86	35.70	1.90
		70	27.22	1.70	28.91	1.77	30.60	1.83	31.82	1.85	33.98	1.89	35.67	1.92
		75	26.56	1.79	28.25	1.86	29.94	1.93	31.15	1.95	33.31	1.99	34.99	2.03
		80	25.91	1.89	27.59	1.96	29.27	2.03	30.49	2.05	32.64	2.09	34.32	2.13
		85	25.26	1.98	26.94	2.05	28.61	2.13	29.83	2.15	31.97	2.19	33.65	2.23
		90	24.61	2.07	26.28	2.15	27.96	2.22	29.17	2.25	31.30	2.29	32.98	2.34
		95	23.91	2.16	25.57	2.24	27.24	2.32	28.00	2.35	30.57	2.39	32.23	2.44
		100	23.32	2.25	24.99	2.34	26.65	2.42	27.64	2.45	29.98	2.50	31.65	2.55
		105	22.74	2.35	24.41	2.43	26.07	2.52	27.27	2.55	29.40	2.60	31.07	2.65
		110	22.16	2.44	23.82	2.53	25.49	2.62	26.69	2.65	28.82	2.70	30.49	2.75
		115	21.58	2.53	23.24	2.62	24.91	2.72	26.11	2.75	28.24	2.80	29.90	2.86
		118	21.23	2.59	22.89	2.68	24.56	2.78	25.76	2.81	27.89	2.86	29.55	2.92
		122	21.11	2.66	22.78	2.76	24.44	2.86	25.64	2.89	27.77	2.94	29.44	3.00
	7 + 7 + 15	-4	28.51	1.42	30.28	1.47	32.05	1.53	33.33	1.54	35.59	1.57	37.36	1.60
		0	28.50	1.44	30.27	1.49	32.03	1.54	33.31	1.56	35.57	1.59	37.34	1.62
		5	28.47	1.46	30.24	1.51	32.01	1.57	33.29	1.59	35.54	1.61	37.31	1.65
		10	28.45	1.48	30.22	1.53	31.98	1.59	33.26	1.61	35.52	1.64	37.28	1.67
		14	28.43	1.50	30.19	1.56	31.96	1.61	33.23	1.63	35.49	1.66	37.26	1.70
		20	28.41	1.52	30.17	1.58	31.94	1.64	33.21	1.66	35.46	1.69	37.23	1.72
		25	28.39	1.55	30.15	1.60	31.91	1.66	33.18	1.68	35.44	1.71	37.20	1.74
		30	28.36	1.57	30.13	1.62	31.89	1.68	33.16	1.70	35.41	1.73	37.17	1.77
		35	28.34	1.59	30.10	1.65	31.86	1.71	33.13	1.73	35.38	1.76	37.14	1.79
		40	28.32	1.61	30.08	1.67	31.84	1.73	33.11	1.75	35.36	1.78	37.11	1.82
		45	28.30	1.63	30.06	1.69	31.81	1.75	33.08	1.77	35.33	1.81	37.09	1.84
		50	28.28	1.65	30.03	1.71	31.79	1.78	33.06	1.80	35.30	1.83	37.06	1.87
		55	28.26	1.67	30.01	1.74	31.76	1.80	33.03	1.82	35.27	1.85	37.03	1.89
		60	28.23	1.70	29.99	1.76	31.74	1.82	33.01	1.84	35.25	1.88	37.00	1.92
		65	28.21	1.72	29.96	1.78	31.72	1.85	32.98	1.87	35.22	1.90	36.97	1.94
		70	28.19	1.74	29.94	1.80	31.69	1.87	32.96	1.89	35.19	1.93	36.94	1.96
		75	27.51	1.83	29.26	1.90	31.00	1.97	32.27	1.99	34.50	2.03	36.24	2.07
		80	26.83	1.93	28.58	2.00	30.32	2.07	31.58	2.09	33.80	2.13	35.54	2.18
		85	26.16	2.02	27.90	2.09	29.64	2.17	30.89	2.20	33.11	2.24	34.85	2.28
		90	25.49	2.11	27.22	2.19	28.96	2.27	30.21	2.30	32.42	2.34	34.16	2.39
		95	24.76	2.21	26.48	2.29	28.21	2.37	29.00	2.40	31.66	2.44	33.38	2.49
		100	24.16	2.30	25.88	2.39	27.61	2.47	28.62	2.50	31.06	2.55	32.78	2.60
		105	23.55	2.40	25.28	2.48	27.00	2.57	28.25	2.60	30.45	2.65	32.18	2.71
		110	22.95	2.49	24.68	2.58	26.40	2.68	27.65	2.71	29.85	2.76	31.57	2.81
		115	22.35	2.58	24.07	2.68	25.80	2.78	27.04	2.81	29.25	2.86	30.97	2.92
		118	21.99	2.64	23.71	2.74	25.44	2.84	26.68	2.87	28.88	2.92	30.61	2.98
		122	21.86	2.72	23.59	2.81	25.31	2.92	26.56	2.95	28.76	3.01	30.49	3.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 117: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 12	-4	29.49	1.46	31.33	1.51	33.16	1.56	34.48	1.58	36.82	1.61	38.65	1.64
		0	29.48	1.47	31.31	1.53	33.14	1.58	34.46	1.60	36.80	1.63	38.63	1.66
		5	29.45	1.50	31.28	1.55	33.11	1.61	34.43	1.62	36.77	1.66	38.60	1.69
		10	29.43	1.52	31.26	1.57	33.09	1.63	34.41	1.65	36.74	1.68	38.57	1.71
		14	29.41	1.54	31.24	1.60	33.06	1.65	34.38	1.67	36.71	1.70	38.54	1.74
		20	29.39	1.56	31.21	1.62	33.04	1.68	34.35	1.70	36.69	1.73	38.51	1.76
		25	29.36	1.58	31.19	1.64	33.01	1.70	34.33	1.72	36.66	1.75	38.48	1.79
		30	29.34	1.61	31.16	1.66	32.99	1.73	34.30	1.75	36.63	1.78	38.45	1.81
		35	29.32	1.63	31.14	1.69	32.96	1.75	34.28	1.77	36.60	1.80	38.42	1.84
		40	29.30	1.65	31.12	1.71	32.94	1.77	34.25	1.79	36.57	1.83	38.39	1.86
		45	29.27	1.67	31.09	1.73	32.91	1.80	34.22	1.82	36.55	1.85	38.36	1.89
		50	29.25	1.69	31.07	1.76	32.89	1.82	34.20	1.84	36.52	1.88	38.34	1.91
		55	29.23	1.72	31.04	1.78	32.86	1.84	34.17	1.87	36.49	1.90	38.31	1.94
		60	29.21	1.74	31.02	1.80	32.83	1.87	34.14	1.89	36.46	1.92	38.28	1.96
		65	29.18	1.76	31.00	1.82	32.81	1.89	34.12	1.91	36.43	1.95	38.25	1.99
		70	29.16	1.78	30.97	1.85	32.78	1.92	34.09	1.94	36.41	1.97	38.22	2.01
		75	28.46	1.88	30.27	1.95	32.07	2.02	33.38	2.04	35.69	2.08	37.49	2.12
		80	27.76	1.98	29.56	2.05	31.36	2.12	32.66	2.15	34.97	2.19	36.77	2.23
		85	27.06	2.07	28.86	2.15	30.66	2.23	31.96	2.25	34.25	2.29	36.05	2.34
		90	26.37	2.17	28.16	2.25	29.95	2.33	31.25	2.36	33.54	2.40	35.33	2.45
		95	25.61	2.26	27.40	2.35	29.18	2.43	30.00	2.46	32.75	2.51	34.53	2.56
		100	24.99	2.36	26.77	2.45	28.56	2.54	29.61	2.56	32.13	2.61	33.91	2.67
		105	24.37	2.46	26.15	2.55	27.93	2.64	29.22	2.67	31.50	2.72	33.29	2.77
		110	23.74	2.55	25.53	2.65	27.31	2.74	28.60	2.77	30.88	2.83	32.66	2.88
		115	23.12	2.65	24.90	2.75	26.69	2.85	27.98	2.88	30.26	2.93	32.04	2.99
		118	22.74	2.71	24.53	2.80	26.31	2.91	27.60	2.94	29.88	3.00	31.67	3.06
		122	22.62	2.78	24.40	2.88	26.19	2.99	27.48	3.02	29.76	3.08	31.54	3.14
	7 + 9 + 15	-4	30.48	1.49	32.37	1.55	34.26	1.60	35.63	1.62	38.05	1.65	39.94	1.68
		0	30.46	1.51	32.35	1.56	34.24	1.62	35.61	1.64	38.03	1.67	39.92	1.70
		5	30.44	1.53	32.33	1.59	34.22	1.65	35.58	1.66	38.00	1.70	39.89	1.73
		10	30.41	1.55	32.30	1.61	34.19	1.67	35.55	1.69	37.97	1.72	39.86	1.76
		14	30.39	1.58	32.28	1.63	34.16	1.69	35.53	1.71	37.94	1.75	39.83	1.78
		20	30.37	1.60	32.25	1.66	34.14	1.72	35.50	1.74	37.91	1.77	39.80	1.81
		25	30.34	1.62	32.23	1.68	34.11	1.74	35.47	1.76	37.88	1.80	39.77	1.83
		30	30.32	1.64	32.20	1.71	34.09	1.77	35.45	1.79	37.85	1.82	39.73	1.86
		35	30.30	1.67	32.18	1.73	34.06	1.79	35.42	1.81	37.82	1.85	39.70	1.88
		40	30.27	1.69	32.15	1.75	34.03	1.82	35.39	1.84	37.79	1.87	39.67	1.91
		45	30.25	1.71	32.13	1.78	34.01	1.84	35.36	1.86	37.76	1.90	39.64	1.93
		50	30.23	1.74	32.10	1.80	33.98	1.86	35.34	1.89	37.74	1.92	39.61	1.96
		55	30.20	1.76	32.08	1.82	33.96	1.89	35.31	1.91	37.71	1.95	39.58	1.99
		60	30.18	1.78	32.05	1.85	33.93	1.91	35.28	1.94	37.68	1.97	39.55	2.01
		65	30.16	1.80	32.03	1.87	33.90	1.94	35.26	1.96	37.65	2.00	39.52	2.04
		70	30.13	1.83	32.01	1.89	33.88	1.96	35.23	1.98	37.62	2.02	39.49	2.06
		75	29.41	1.92	31.28	2.00	33.14	2.07	34.49	2.09	36.88	2.13	38.74	2.17
		80	28.68	2.02	30.55	2.10	32.41	2.17	33.75	2.20	36.13	2.24	38.00	2.29
		85	27.97	2.12	29.82	2.20	31.68	2.28	33.02	2.31	35.40	2.35	37.25	2.40
		90	27.25	2.22	29.10	2.30	30.95	2.39	32.29	2.41	34.66	2.46	36.51	2.51
		95	26.47	2.32	28.31	2.40	30.15	2.49	31.00	2.52	33.84	2.57	35.69	2.62
		100	25.82	2.42	27.67	2.51	29.51	2.60	30.60	2.63	33.20	2.68	35.04	2.73
		105	25.18	2.52	27.02	2.61	28.87	2.70	30.20	2.73	32.55	2.79	34.40	2.84
		110	24.53	2.61	26.38	2.71	28.22	2.81	29.55	2.84	31.91	2.89	33.75	2.95
		115	23.89	2.71	25.73	2.81	27.58	2.91	28.91	2.95	31.26	3.00	33.11	3.06
		118	23.50	2.77	25.35	2.87	27.19	2.98	28.52	3.01	30.88	3.07	32.72	3.13
		122	23.37	2.85	25.22	2.96	27.06	3.06	28.39	3.10	30.75	3.16	32.59	3.22

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 118: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 12 + 12	-4	30.48	1.49	32.37	1.55	34.26	1.60	35.63	1.62	38.05	1.65	39.94	1.68
		0	30.46	1.51	32.35	1.56	34.24	1.62	35.61	1.64	38.03	1.67	39.92	1.70
		5	30.44	1.53	32.33	1.59	34.22	1.65	35.58	1.66	38.00	1.70	39.89	1.73
		10	30.41	1.55	32.30	1.61	34.19	1.67	35.55	1.69	37.97	1.72	39.86	1.76
		14	30.39	1.58	32.28	1.63	34.16	1.69	35.53	1.71	37.94	1.75	39.83	1.78
		20	30.37	1.60	32.25	1.66	34.14	1.72	35.50	1.74	37.91	1.77	39.80	1.81
		25	30.34	1.62	32.23	1.68	34.11	1.74	35.47	1.76	37.88	1.80	39.77	1.83
		30	30.32	1.64	32.20	1.71	34.09	1.77	35.45	1.79	37.85	1.82	39.73	1.86
		35	30.30	1.67	32.18	1.73	34.06	1.79	35.42	1.81	37.82	1.85	39.70	1.88
		40	30.27	1.69	32.15	1.75	34.03	1.82	35.39	1.84	37.79	1.87	39.67	1.91
		45	30.25	1.71	32.13	1.78	34.01	1.84	35.36	1.86	37.76	1.90	39.64	1.93
		50	30.23	1.74	32.10	1.80	33.98	1.86	35.34	1.89	37.74	1.92	39.61	1.96
		55	30.20	1.76	32.08	1.82	33.96	1.89	35.31	1.91	37.71	1.95	39.58	1.99
		60	30.18	1.78	32.05	1.85	33.93	1.91	35.28	1.94	37.68	1.97	39.55	2.01
		65	30.16	1.80	32.03	1.87	33.90	1.94	35.26	1.96	37.65	2.00	39.52	2.04
		70	30.13	1.83	32.01	1.89	33.88	1.96	35.23	1.98	37.62	2.02	39.49	2.06
		75	29.41	1.92	31.28	2.00	33.14	2.07	34.49	2.09	36.88	2.13	38.74	2.17
		80	28.68	2.02	30.55	2.10	32.41	2.17	33.75	2.20	36.13	2.24	38.00	2.29
		85	27.97	2.12	29.82	2.20	31.68	2.28	33.02	2.31	35.40	2.35	37.25	2.40
		90	27.25	2.22	29.10	2.30	30.95	2.39	32.29	2.41	34.66	2.46	36.51	2.51
		95	26.47	2.32	28.31	2.40	30.15	2.49	31.00	2.52	33.84	2.57	35.69	2.62
		100	25.82	2.42	27.67	2.51	29.51	2.60	30.60	2.63	33.20	2.68	35.04	2.73
		105	25.18	2.52	27.02	2.61	28.87	2.70	30.20	2.73	32.55	2.79	34.40	2.84
		110	24.53	2.61	26.38	2.71	28.22	2.81	29.55	2.84	31.91	2.89	33.75	2.95
		115	23.89	2.71	25.73	2.81	27.58	2.91	28.91	2.95	31.26	3.00	33.11	3.06
		118	23.50	2.77	25.35	2.87	27.19	2.98	28.52	3.01	30.88	3.07	32.72	3.13
		122	23.37	2.85	25.22	2.96	27.06	3.06	28.39	3.10	30.75	3.16	32.59	3.22
	7 + 7 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 119: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	9 + 12 + 12	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 120: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	7 + 12 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 121: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	9 + 12 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 122: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 12 + 12	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	7 + 12 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 123: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 15 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	7 + 7 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 124: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 12 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	9 + 15 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 125: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 12 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	7 + 9 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 126: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 15 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	9 + 9 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 127: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 15 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	12 + 12 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 128: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 15 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	7 + 12 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 129: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 18 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	9 + 12 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 130: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 18 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	12 + 15 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 131: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	15 + 15 + 15	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	7 + 15 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 132: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 15 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	12 + 12 + 24	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 133: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 18 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30
	15 + 15 + 18	-4	31.46	1.53	33.41	1.58	35.37	1.64	36.78	1.66	39.28	1.69	41.23	1.72
		0	31.44	1.54	33.40	1.60	35.35	1.66	36.76	1.68	39.25	1.71	41.21	1.74
		5	31.42	1.57	33.37	1.63	35.32	1.68	36.73	1.70	39.22	1.74	41.17	1.77
		10	31.39	1.59	33.34	1.65	35.29	1.71	36.70	1.73	39.19	1.76	41.14	1.80
		14	31.37	1.61	33.32	1.67	35.27	1.73	36.67	1.75	39.16	1.79	41.11	1.82
		20	31.35	1.64	33.29	1.70	35.24	1.76	36.64	1.78	39.13	1.81	41.08	1.85
		25	31.32	1.66	33.27	1.72	35.21	1.78	36.62	1.81	39.10	1.84	41.05	1.88
		30	31.30	1.68	33.24	1.75	35.19	1.81	36.59	1.83	39.07	1.86	41.02	1.90
		35	31.27	1.71	33.22	1.77	35.16	1.83	36.56	1.86	39.04	1.89	40.99	1.93
		40	31.25	1.73	33.19	1.79	35.13	1.86	36.53	1.88	39.01	1.92	40.95	1.95
		45	31.23	1.75	33.17	1.82	35.10	1.88	36.51	1.91	38.98	1.94	40.92	1.98
		50	31.20	1.78	33.14	1.84	35.08	1.91	36.48	1.93	38.95	1.97	40.89	2.01
		55	31.18	1.80	33.11	1.87	35.05	1.93	36.45	1.96	38.92	1.99	40.86	2.03
		60	31.15	1.82	33.09	1.89	35.02	1.96	36.42	1.98	38.89	2.02	40.83	2.06
		65	31.13	1.85	33.06	1.91	35.00	1.98	36.39	2.01	38.86	2.04	40.80	2.09
		70	31.11	1.87	33.04	1.94	34.97	2.01	36.37	2.03	38.83	2.07	40.77	2.11
		75	30.36	1.97	32.28	2.04	34.21	2.12	35.60	2.14	38.07	2.18	39.99	2.23
		80	29.61	2.07	31.53	2.15	33.45	2.23	34.84	2.25	37.30	2.29	39.22	2.34
		85	28.87	2.17	30.78	2.25	32.70	2.33	34.09	2.36	36.54	2.40	38.46	2.45
		90	28.13	2.27	30.04	2.36	31.95	2.44	33.33	2.47	35.78	2.52	37.69	2.57
		95	27.32	2.37	29.22	2.46	31.13	2.55	32.00	2.58	34.93	2.63	36.84	2.68
		100	26.65	2.47	28.56	2.57	30.46	2.66	31.59	2.69	34.27	2.74	36.17	2.80
		105	25.99	2.58	27.89	2.67	29.80	2.77	31.17	2.80	33.60	2.85	35.51	2.91
		110	25.32	2.68	27.23	2.77	29.13	2.88	30.51	2.91	32.94	2.96	34.84	3.02
		115	24.66	2.78	26.56	2.88	28.47	2.98	29.84	3.02	32.27	3.08	34.18	3.14
		118	24.26	2.84	26.16	2.94	28.07	3.05	29.44	3.08	31.87	3.14	33.78	3.21
		122	24.13	2.92	26.03	3.03	27.93	3.14	29.31	3.17	31.74	3.23	33.64	3.30

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 134: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 7	-4	27.53	1.30	29.24	1.35	30.95	1.40	32.18	1.41	34.37	1.44	36.08	1.47
		0	27.51	1.32	29.22	1.36	30.93	1.41	32.16	1.43	34.35	1.46	36.06	1.49
		5	27.49	1.34	29.20	1.39	30.90	1.44	32.14	1.45	34.32	1.48	36.03	1.51
		10	27.47	1.36	29.18	1.41	30.88	1.46	32.11	1.47	34.29	1.50	36.00	1.53
		14	27.45	1.38	29.15	1.43	30.86	1.48	32.09	1.50	34.27	1.52	35.97	1.55
		20	27.43	1.40	29.13	1.45	30.83	1.50	32.06	1.52	34.24	1.55	35.94	1.58
		25	27.41	1.42	29.11	1.47	30.81	1.52	32.04	1.54	34.21	1.57	35.92	1.60
		30	27.39	1.44	29.09	1.49	30.79	1.54	32.02	1.56	34.19	1.59	35.89	1.62
		35	27.36	1.46	29.06	1.51	30.76	1.56	31.99	1.58	34.16	1.61	35.86	1.64
		40	27.34	1.48	29.04	1.53	30.74	1.59	31.97	1.60	34.14	1.63	35.83	1.67
		45	27.32	1.50	29.02	1.55	30.72	1.61	31.94	1.63	34.11	1.66	35.81	1.69
		50	27.30	1.52	29.00	1.57	30.69	1.63	31.92	1.65	34.08	1.68	35.78	1.71
		55	27.28	1.54	28.98	1.59	30.67	1.65	31.89	1.67	34.06	1.70	35.75	1.73
		60	27.26	1.55	28.95	1.61	30.65	1.67	31.87	1.69	34.03	1.72	35.72	1.76
		65	27.24	1.57	28.93	1.63	30.62	1.69	31.84	1.71	34.01	1.74	35.70	1.78
		70	27.22	1.59	28.91	1.65	30.60	1.71	31.82	1.73	33.98	1.77	35.67	1.80
		75	26.56	1.68	28.25	1.74	29.94	1.81	31.15	1.83	33.31	1.86	34.99	1.90
		80	25.91	1.77	27.59	1.83	29.27	1.90	30.49	1.92	32.64	1.96	34.32	1.99
		85	25.26	1.85	26.94	1.92	28.61	1.99	29.83	2.01	31.97	2.05	33.65	2.09
		90	24.61	1.94	26.28	2.01	27.96	2.08	29.17	2.11	31.30	2.15	32.98	2.19
		95	23.91	2.02	25.57	2.10	27.24	2.17	28.00	2.20	30.57	2.24	32.23	2.29
		100	23.32	2.11	24.99	2.19	26.65	2.27	27.64	2.29	29.98	2.34	31.65	2.38
		105	22.74	2.20	24.41	2.28	26.07	2.36	27.27	2.39	29.40	2.43	31.07	2.48
		110	22.16	2.28	23.82	2.37	25.49	2.45	26.69	2.48	28.82	2.53	30.49	2.58
		115	21.58	2.37	23.24	2.45	24.91	2.54	26.11	2.57	28.24	2.62	29.90	2.67
		118	21.23	2.42	22.89	2.51	24.56	2.60	25.76	2.63	27.89	2.68	29.55	2.73
		122	21.11	2.49	22.78	2.58	24.44	2.67	25.64	2.70	27.77	2.76	29.44	2.81
	7 + 7 + 7 + 9	-4	29.49	1.39	31.33	1.44	33.16	1.49	34.48	1.51	36.82	1.54	38.65	1.57
		0	29.48	1.41	31.31	1.46	33.14	1.51	34.46	1.53	36.80	1.56	38.63	1.59
		5	29.45	1.43	31.28	1.48	33.11	1.53	34.43	1.55	36.77	1.58	38.60	1.61
		10	29.43	1.45	31.26	1.50	33.09	1.56	34.41	1.58	36.74	1.60	38.57	1.64
		14	29.41	1.47	31.24	1.52	33.06	1.58	34.38	1.60	36.71	1.63	38.54	1.66
		20	29.39	1.49	31.21	1.55	33.04	1.60	34.35	1.62	36.69	1.65	38.51	1.68
		25	29.36	1.51	31.19	1.57	33.01	1.63	34.33	1.64	36.66	1.67	38.48	1.71
		30	29.34	1.53	31.16	1.59	32.99	1.65	34.30	1.67	36.63	1.70	38.45	1.73
		35	29.32	1.56	31.14	1.61	32.96	1.67	34.28	1.69	36.60	1.72	38.42	1.76
		40	29.30	1.58	31.12	1.63	32.94	1.69	34.25	1.71	36.57	1.75	38.39	1.78
		45	29.27	1.60	31.09	1.66	32.91	1.72	34.22	1.74	36.55	1.77	38.36	1.80
		50	29.25	1.62	31.07	1.68	32.89	1.74	34.20	1.76	36.52	1.79	38.34	1.83
		55	29.23	1.64	31.04	1.70	32.86	1.76	34.17	1.78	36.49	1.82	38.31	1.85
		60	29.21	1.66	31.02	1.72	32.83	1.78	34.14	1.80	36.46	1.84	38.28	1.88
		65	29.18	1.68	31.00	1.74	32.81	1.81	34.12	1.83	36.43	1.86	38.25	1.90
		70	29.16	1.70	30.97	1.77	32.78	1.83	34.09	1.85	36.41	1.89	38.22	1.92
		75	28.46	1.79	30.27	1.86	32.07	1.93	33.38	1.95	35.69	1.99	37.49	2.03
		80	27.76	1.89	29.56	1.96	31.36	2.03	32.66	2.05	34.97	2.09	36.77	2.13
		85	27.06	1.98	28.86	2.05	30.66	2.13	31.96	2.15	34.25	2.19	36.05	2.23
		90	26.37	2.07	28.16	2.15	29.95	2.22	31.25	2.25	33.54	2.29	35.33	2.34
		95	25.61	2.16	27.40	2.24	29.18	2.32	30.00	2.35	32.75	2.39	34.53	2.44
		100	24.99	2.25	26.77	2.34	28.56	2.42	29.61	2.45	32.13	2.50	33.91	2.55
		105	24.37	2.35	26.15	2.43	27.93	2.52	29.22	2.55	31.50	2.60	33.29	2.65
		110	23.74	2.44	25.53	2.53	27.31	2.62	28.60	2.65	30.88	2.70	32.66	2.75
		115	23.12	2.53	24.90	2.62	26.69	2.72	27.98	2.75	30.26	2.80	32.04	2.86
		118	22.74	2.59	24.53	2.68	26.31	2.78	27.60	2.81	29.88	2.86	31.67	2.92
		122	22.62	2.66	24.40	2.76	26.19	2.86	27.48	2.89	29.76	2.94	31.54	3.00

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 135: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 9 + 9	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 7 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 136: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 9 + 9	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 9 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 137: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	9 + 9 + 9 + 9	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 138: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 9 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 9 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 139: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 12 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 7 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 140: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 9 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 9 + 9 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 141: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 12 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 9 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 142: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 12 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	9 + 9 + 9 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 143: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 12 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 9 + 9 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 144: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 12 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 12 + 12 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 145: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 12 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 15 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 146: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 24	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	9 + 9 + 9 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 147: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 12 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	9 + 12 + 12 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 148: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 12 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 9 + 15 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 149: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 12 + 12 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	7 + 7 + 9 + 24	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 150: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 15 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	9 + 9 + 12 + 18	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 151: LMU36CHV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 15 + 15	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14
	12 + 12 + 12 + 12	-4	31.46	1.46	33.41	1.51	35.37	1.56	36.78	1.58	39.28	1.61	41.23	1.64
		0	31.44	1.47	33.40	1.53	35.35	1.58	36.76	1.60	39.25	1.63	41.21	1.66
		5	31.42	1.50	33.37	1.55	35.32	1.61	36.73	1.63	39.22	1.66	41.17	1.69
		10	31.39	1.52	33.34	1.57	35.29	1.63	36.70	1.65	39.19	1.68	41.14	1.71
		14	31.37	1.54	33.32	1.60	35.27	1.65	36.67	1.67	39.16	1.71	41.11	1.74
		20	31.35	1.56	33.29	1.62	35.24	1.68	36.64	1.70	39.13	1.73	41.08	1.76
		25	31.32	1.58	33.27	1.64	35.21	1.70	36.62	1.72	39.10	1.75	41.05	1.79
		30	31.30	1.61	33.24	1.67	35.19	1.73	36.59	1.75	39.07	1.78	41.02	1.81
		35	31.27	1.63	33.22	1.69	35.16	1.75	36.56	1.77	39.04	1.80	40.99	1.84
		40	31.25	1.65	33.19	1.71	35.13	1.77	36.53	1.79	39.01	1.83	40.95	1.86
		45	31.23	1.67	33.17	1.73	35.10	1.80	36.51	1.82	38.98	1.85	40.92	1.89
		50	31.20	1.69	33.14	1.76	35.08	1.82	36.48	1.84	38.95	1.88	40.89	1.91
		55	31.18	1.72	33.11	1.78	35.05	1.84	36.45	1.87	38.92	1.90	40.86	1.94
		60	31.15	1.74	33.09	1.80	35.02	1.87	36.42	1.89	38.89	1.93	40.83	1.96
		65	31.13	1.76	33.06	1.83	35.00	1.89	36.39	1.91	38.86	1.95	40.80	1.99
		70	31.11	1.78	33.04	1.85	34.97	1.92	36.37	1.94	38.83	1.97	40.77	2.01
		75	30.36	1.88	32.28	1.95	34.21	2.02	35.60	2.04	38.07	2.08	39.99	2.12
		80	29.61	1.98	31.53	2.05	33.45	2.12	34.84	2.15	37.30	2.19	39.22	2.23
		85	28.87	2.07	30.78	2.15	32.70	2.23	34.09	2.25	36.54	2.29	38.46	2.34
		90	28.13	2.17	30.04	2.25	31.95	2.33	33.33	2.36	35.78	2.40	37.69	2.45
		95	27.32	2.26	29.22	2.35	31.13	2.43	32.00	2.46	34.93	2.51	36.84	2.56
		100	26.65	2.36	28.56	2.45	30.46	2.54	31.59	2.57	34.27	2.61	36.17	2.67
		105	25.99	2.46	27.89	2.55	29.80	2.64	31.17	2.67	33.60	2.72	35.51	2.77
		110	25.32	2.55	27.23	2.65	29.13	2.74	30.51	2.77	32.94	2.83	34.84	2.88
		115	24.66	2.65	26.56	2.75	28.47	2.85	29.84	2.88	32.27	2.93	34.18	2.99
		118	24.26	2.71	26.16	2.81	28.07	2.91	29.44	2.94	31.87	3.00	33.78	3.06
		122	24.13	2.78	26.03	2.89	27.93	2.99	29.31	3.03	31.74	3.08	33.64	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 152: LMU36CHV Cooling Capacity Table — Ducted Indoor Units

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 9	-4	15.48	1.05	16.45	1.09	17.41	1.13	18.10	1.14	19.33	1.17	20.29	1.19
		0	15.48	1.06	16.44	1.10	17.40	1.14	18.09	1.16	19.32	1.18	20.28	1.20
		5	15.46	1.08	16.42	1.12	17.38	1.16	18.08	1.18	19.30	1.20	20.26	1.22
		10	15.45	1.10	16.41	1.14	17.37	1.18	18.06	1.19	19.29	1.21	20.25	1.24
		14	15.44	1.11	16.40	1.15	17.36	1.20	18.05	1.21	19.28	1.23	20.23	1.26
		20	15.43	1.13	16.39	1.17	17.34	1.21	18.04	1.23	19.26	1.25	20.22	1.28
		25	15.42	1.15	16.37	1.19	17.33	1.23	18.02	1.24	19.25	1.27	20.20	1.29
		30	15.40	1.16	16.36	1.20	17.32	1.25	18.01	1.26	19.23	1.29	20.19	1.31
		35	15.39	1.18	16.35	1.22	17.30	1.26	17.99	1.28	19.22	1.30	20.17	1.33
		40	15.38	1.19	16.34	1.24	17.29	1.28	17.98	1.30	19.20	1.32	20.16	1.35
		45	15.37	1.21	16.32	1.25	17.28	1.30	17.97	1.31	19.19	1.34	20.14	1.37
		50	15.36	1.23	16.31	1.27	17.26	1.32	17.95	1.33	19.17	1.36	20.13	1.38
		55	15.35	1.24	16.30	1.29	17.25	1.33	17.94	1.35	19.16	1.37	20.11	1.40
		60	15.33	1.26	16.29	1.30	17.24	1.35	17.93	1.37	19.14	1.39	20.10	1.42
		65	15.32	1.27	16.27	1.32	17.23	1.37	17.91	1.38	19.13	1.41	20.08	1.44
		70	15.31	1.29	16.26	1.34	17.21	1.39	17.90	1.40	19.11	1.43	20.06	1.46
		75	14.94	1.36	15.89	1.41	16.84	1.46	17.52	1.48	18.74	1.50	19.68	1.53
		80	14.57	1.43	15.52	1.48	16.47	1.53	17.15	1.55	18.36	1.58	19.30	1.61
		85	14.21	1.50	15.15	1.55	16.10	1.61	16.78	1.63	17.98	1.66	18.93	1.69
		90	13.84	1.57	14.78	1.62	15.73	1.68	16.41	1.70	17.61	1.74	18.55	1.77
		95	13.45	1.64	14.38	1.70	15.32	1.76	15.75	1.78	17.19	1.81	18.13	1.85
		100	13.12	1.71	14.06	1.77	14.99	1.83	15.55	1.85	16.87	1.89	17.80	1.93
		105	12.79	1.78	13.73	1.84	14.67	1.91	15.34	1.93	16.54	1.97	17.48	2.01
		110	12.46	1.85	13.40	1.91	14.34	1.98	15.01	2.01	16.21	2.04	17.15	2.08
		115	12.14	1.92	13.07	1.99	14.01	2.06	14.69	2.08	15.88	2.12	16.82	2.16
		118	11.94	1.96	12.88	2.03	13.81	2.10	14.49	2.13	15.69	2.17	16.62	2.21
		122	11.87	2.01	12.81	2.09	13.75	2.16	14.43	2.19	15.62	2.23	16.56	2.27
	9 + 12	-4	18.07	1.21	19.19	1.25	20.31	1.30	21.12	1.31	22.55	1.33	23.67	1.36
		0	18.06	1.22	19.18	1.26	20.30	1.31	21.11	1.32	22.54	1.35	23.66	1.38
		5	18.04	1.24	19.16	1.28	20.28	1.33	21.09	1.35	22.52	1.37	23.64	1.40
		10	18.03	1.26	19.15	1.30	20.27	1.35	21.07	1.37	22.50	1.39	23.62	1.42
		14	18.01	1.28	19.13	1.32	20.25	1.37	21.06	1.39	22.49	1.41	23.61	1.44
		20	18.00	1.29	19.12	1.34	20.23	1.39	21.04	1.41	22.47	1.43	23.59	1.46
		25	17.99	1.31	19.10	1.36	20.22	1.41	21.03	1.43	22.45	1.45	23.57	1.48
		30	17.97	1.33	19.09	1.38	20.20	1.43	21.01	1.45	22.44	1.47	23.55	1.50
		35	17.96	1.35	19.07	1.40	20.19	1.45	20.99	1.47	22.42	1.49	23.53	1.52
		40	17.94	1.37	19.06	1.42	20.17	1.47	20.98	1.49	22.40	1.51	23.52	1.54
		45	17.93	1.39	19.04	1.44	20.16	1.49	20.96	1.51	22.38	1.53	23.50	1.56
		50	17.92	1.40	19.03	1.45	20.14	1.51	20.95	1.53	22.37	1.55	23.48	1.58
		55	17.90	1.42	19.01	1.47	20.13	1.53	20.93	1.55	22.35	1.57	23.46	1.61
		60	17.89	1.44	19.00	1.49	20.11	1.55	20.91	1.56	22.33	1.59	23.44	1.63
		65	17.88	1.46	18.99	1.51	20.10	1.57	20.90	1.58	22.32	1.61	23.43	1.65
		70	17.86	1.48	18.97	1.53	20.08	1.59	20.88	1.60	22.30	1.63	23.41	1.67
		75	17.43	1.56	18.54	1.61	19.65	1.67	20.44	1.69	21.86	1.72	22.96	1.76
		80	17.00	1.64	18.11	1.70	19.21	1.76	20.01	1.78	21.42	1.81	22.52	1.85
		85	16.58	1.72	17.68	1.78	18.78	1.84	19.57	1.86	20.98	1.90	22.08	1.94
		90	16.15	1.80	17.25	1.86	18.35	1.93	19.14	1.95	20.54	1.99	21.64	2.03
		95	15.69	1.87	16.78	1.94	17.87	2.01	18.38	2.04	20.06	2.08	21.15	2.12
		100	15.31	1.95	16.40	2.03	17.49	2.10	18.14	2.12	19.68	2.16	20.77	2.21
		105	14.92	2.03	16.02	2.11	17.11	2.19	17.90	2.21	19.30	2.25	20.39	2.30
		110	14.54	2.11	15.63	2.19	16.73	2.27	17.52	2.30	18.91	2.34	20.01	2.39
		115	14.16	2.19	15.25	2.27	16.35	2.36	17.13	2.38	18.53	2.43	19.62	2.48
		118	13.93	2.24	15.02	2.32	16.12	2.41	16.91	2.44	18.30	2.48	19.40	2.53
		122	13.85	2.31	14.95	2.39	16.04	2.48	16.83	2.51	18.23	2.55	19.32	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 153: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 12	-4	20.65	1.33	21.93	1.38	23.21	1.43	24.14	1.45	25.77	1.48	27.06	1.51
		0	20.63	1.35	21.92	1.40	23.20	1.45	24.12	1.47	25.76	1.49	27.04	1.52
		5	20.62	1.37	21.90	1.42	23.18	1.47	24.10	1.49	25.74	1.52	27.02	1.55
		10	20.60	1.39	21.88	1.44	23.16	1.49	24.08	1.51	25.72	1.54	27.00	1.57
		14	20.59	1.41	21.86	1.46	23.14	1.52	24.07	1.53	25.70	1.56	26.98	1.59
		20	20.57	1.43	21.85	1.48	23.13	1.54	24.05	1.56	25.68	1.58	26.96	1.62
		25	20.55	1.45	21.83	1.50	23.11	1.56	24.03	1.58	25.66	1.61	26.94	1.64
		30	20.54	1.47	21.81	1.53	23.09	1.58	24.01	1.60	25.64	1.63	26.92	1.66
		35	20.52	1.49	21.80	1.55	23.07	1.60	23.99	1.62	25.62	1.65	26.90	1.69
		40	20.51	1.51	21.78	1.57	23.05	1.62	23.97	1.64	25.60	1.67	26.88	1.71
		45	20.49	1.53	21.76	1.59	23.04	1.65	23.96	1.67	25.58	1.70	26.86	1.73
		50	20.48	1.55	21.75	1.61	23.02	1.67	23.94	1.69	25.56	1.72	26.83	1.75
		55	20.46	1.57	21.73	1.63	23.00	1.69	23.92	1.71	25.54	1.74	26.81	1.78
		60	20.44	1.59	21.71	1.65	22.98	1.71	23.90	1.73	25.52	1.76	26.79	1.80
		65	20.43	1.61	21.70	1.67	22.97	1.73	23.88	1.75	25.50	1.79	26.77	1.82
		70	20.41	1.63	21.68	1.69	22.95	1.76	23.86	1.78	25.48	1.81	26.75	1.85
		75	19.92	1.72	21.19	1.79	22.45	1.85	23.36	1.87	24.98	1.91	26.25	1.95
		80	19.43	1.81	20.69	1.88	21.95	1.94	22.87	1.97	24.48	2.00	25.74	2.04
		85	18.94	1.90	20.20	1.97	21.46	2.04	22.37	2.06	23.98	2.10	25.24	2.14
		90	18.46	1.99	19.71	2.06	20.97	2.13	21.87	2.16	23.48	2.20	24.73	2.24
		95	17.93	2.07	19.18	2.15	20.43	2.23	21.00	2.25	22.93	2.30	24.17	2.34
		100	17.49	2.16	18.74	2.24	19.99	2.32	20.73	2.35	22.49	2.39	23.74	2.44
		105	17.06	2.25	18.30	2.33	19.55	2.42	20.46	2.45	22.05	2.49	23.30	2.54
		110	16.62	2.34	17.87	2.42	19.12	2.51	20.02	2.54	21.62	2.59	22.86	2.64
		115	16.18	2.43	17.43	2.52	18.68	2.61	19.58	2.64	21.18	2.69	22.43	2.74
		118	15.92	2.48	17.17	2.57	18.42	2.66	19.32	2.70	20.92	2.75	22.17	2.80
		122	15.83	2.55	17.08	2.64	18.33	2.74	19.23	2.77	20.83	2.82	22.08	2.88
	9 + 18	-4	23.23	1.48	24.67	1.53	26.11	1.59	27.15	1.61	29.00	1.64	30.44	1.67
		0	23.21	1.50	24.66	1.55	26.10	1.61	27.14	1.63	28.98	1.66	30.42	1.69
		5	23.19	1.52	24.64	1.58	26.08	1.63	27.12	1.65	28.96	1.68	30.40	1.72
		10	23.18	1.54	24.62	1.60	26.06	1.66	27.10	1.68	28.93	1.71	30.37	1.74
		14	23.16	1.57	24.60	1.62	26.04	1.68	27.07	1.70	28.91	1.73	30.35	1.77
		20	23.14	1.59	24.58	1.65	26.02	1.71	27.05	1.73	28.89	1.76	30.33	1.79
		25	23.12	1.61	24.56	1.67	26.00	1.73	27.03	1.75	28.87	1.78	30.30	1.82
		30	23.11	1.63	24.54	1.69	25.98	1.76	27.01	1.78	28.85	1.81	30.28	1.85
		35	23.09	1.66	24.52	1.72	25.96	1.78	26.99	1.80	28.82	1.83	30.26	1.87
		40	23.07	1.68	24.50	1.74	25.94	1.80	26.97	1.82	28.80	1.86	30.24	1.90
		45	23.05	1.70	24.49	1.76	25.92	1.83	26.95	1.85	28.78	1.88	30.21	1.92
		50	23.04	1.72	24.47	1.79	25.90	1.85	26.93	1.87	28.76	1.91	30.19	1.95
		55	23.02	1.75	24.45	1.81	25.88	1.88	26.91	1.90	28.74	1.93	30.17	1.97
		60	23.00	1.77	24.43	1.83	25.86	1.90	26.89	1.92	28.71	1.96	30.14	2.00
		65	22.98	1.79	24.41	1.86	25.84	1.92	26.87	1.95	28.69	1.98	30.12	2.02
		70	22.97	1.81	24.39	1.88	25.82	1.95	26.85	1.97	28.67	2.01	30.10	2.05
		75	22.41	1.91	23.84	1.98	25.26	2.05	26.29	2.08	28.10	2.12	29.53	2.16
		80	21.86	2.01	23.28	2.08	24.70	2.16	25.72	2.18	27.54	2.22	28.96	2.27
		85	21.31	2.11	22.73	2.18	24.14	2.26	25.17	2.29	26.98	2.33	28.39	2.38
		90	20.76	2.21	22.18	2.29	23.59	2.37	24.61	2.40	26.41	2.44	27.83	2.49
		95	20.17	2.30	21.58	2.39	22.98	2.47	23.63	2.50	25.79	2.55	27.20	2.60
		100	19.68	2.40	21.08	2.49	22.49	2.58	23.32	2.61	25.30	2.66	26.70	2.71
		105	19.19	2.50	20.59	2.59	22.00	2.68	23.01	2.72	24.81	2.77	26.21	2.82
		110	18.70	2.60	20.10	2.69	21.51	2.79	22.52	2.82	24.32	2.87	25.72	2.93
		115	18.21	2.69	19.61	2.79	21.02	2.90	22.03	2.93	23.83	2.98	25.23	3.04
		118	17.91	2.75	19.32	2.85	20.72	2.96	21.74	2.99	23.53	3.05	24.94	3.11
		122	17.81	2.83	19.22	2.94	20.62	3.04	21.64	3.08	23.43	3.13	24.84	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 154: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 18	-4	25.81	1.61	27.41	1.67	29.01	1.73	30.17	1.75	32.22	1.78	33.82	1.82
		0	25.79	1.63	27.40	1.69	29.00	1.75	30.15	1.77	32.20	1.80	33.80	1.84
		5	25.77	1.65	27.37	1.71	28.97	1.78	30.13	1.80	32.17	1.83	33.77	1.87
		10	25.75	1.68	27.35	1.74	28.95	1.80	30.11	1.82	32.15	1.86	33.75	1.89
		14	25.73	1.70	27.33	1.76	28.93	1.83	30.08	1.85	32.13	1.88	33.72	1.92
		20	25.71	1.73	27.31	1.79	28.91	1.86	30.06	1.88	32.10	1.91	33.70	1.95
		25	25.69	1.75	27.29	1.82	28.88	1.88	30.04	1.90	32.08	1.94	33.67	1.98
		30	25.67	1.78	27.27	1.84	28.86	1.91	30.01	1.93	32.05	1.97	33.65	2.01
		35	25.65	1.80	27.25	1.87	28.84	1.93	29.99	1.96	32.03	1.99	33.62	2.03
		40	25.63	1.82	27.23	1.89	28.82	1.96	29.97	1.98	32.00	2.02	33.59	2.06
		45	25.62	1.85	27.21	1.92	28.80	1.99	29.95	2.01	31.98	2.05	33.57	2.09
		50	25.60	1.87	27.19	1.94	28.77	2.01	29.92	2.04	31.95	2.07	33.54	2.12
		55	25.58	1.90	27.16	1.97	28.75	2.04	29.90	2.06	31.93	2.10	33.52	2.14
		60	25.56	1.92	27.14	1.99	28.73	2.07	29.88	2.09	31.90	2.13	33.49	2.17
		65	25.54	1.95	27.12	2.02	28.71	2.09	29.85	2.12	31.88	2.16	33.47	2.20
		70	25.52	1.97	27.10	2.04	28.69	2.12	29.83	2.14	31.86	2.18	33.44	2.23
		75	24.90	2.08	26.48	2.15	28.06	2.23	29.21	2.26	31.23	2.30	32.81	2.35
		80	24.29	2.18	25.87	2.26	27.44	2.35	28.58	2.37	30.60	2.42	32.17	2.47
		85	23.68	2.29	25.25	2.37	26.83	2.46	27.96	2.49	29.97	2.54	31.55	2.59
		90	23.07	2.40	24.64	2.48	26.21	2.58	27.34	2.60	29.35	2.65	30.92	2.71
		95	22.41	2.50	23.97	2.59	25.53	2.69	26.25	2.72	28.66	2.77	30.22	2.83
		100	21.87	2.61	23.43	2.70	24.99	2.80	25.91	2.84	28.11	2.89	29.67	2.95
		105	21.32	2.72	22.88	2.82	24.44	2.92	25.57	2.95	27.56	3.01	29.13	3.07
		110	20.77	2.82	22.34	2.93	23.90	3.03	25.02	3.07	27.02	3.12	28.58	3.19
		115	20.23	2.93	21.79	3.04	23.35	3.15	24.48	3.18	26.47	3.24	28.03	3.31
		118	19.90	2.99	21.46	3.10	23.02	3.21	24.15	3.25	26.15	3.31	27.71	3.38
		122	19.79	3.08	21.35	3.19	22.91	3.31	24.04	3.34	26.04	3.41	27.60	3.48
	9 + 24	-4	27.53	1.69	29.24	1.75	30.95	1.81	32.18	1.84	34.37	1.87	36.08	1.91
		0	27.51	1.71	29.22	1.77	30.93	1.83	32.16	1.86	34.35	1.89	36.06	1.93
		5	27.49	1.74	29.20	1.80	30.90	1.86	32.14	1.89	34.32	1.92	36.03	1.96
		10	27.47	1.76	29.18	1.83	30.88	1.89	32.11	1.91	34.29	1.95	36.00	1.99
		14	27.45	1.79	29.15	1.85	30.86	1.92	32.09	1.94	34.27	1.98	35.97	2.02
		20	27.43	1.81	29.13	1.88	30.83	1.95	32.06	1.97	34.24	2.01	35.94	2.05
		25	27.41	1.84	29.11	1.90	30.81	1.97	32.04	2.00	34.21	2.03	35.92	2.08
		30	27.39	1.86	29.09	1.93	30.79	2.00	32.02	2.03	34.19	2.06	35.89	2.10
		35	27.36	1.89	29.06	1.96	30.76	2.03	31.99	2.05	34.16	2.09	35.86	2.13
		40	27.34	1.91	29.04	1.98	30.74	2.06	31.97	2.08	34.14	2.12	35.83	2.16
		45	27.32	1.94	29.02	2.01	30.72	2.08	31.94	2.11	34.11	2.15	35.81	2.19
		50	27.30	1.97	29.00	2.04	30.69	2.11	31.92	2.14	34.08	2.18	35.78	2.22
		55	27.28	1.99	28.98	2.06	30.67	2.14	31.89	2.16	34.06	2.21	35.75	2.25
		60	27.26	2.02	28.95	2.09	30.65	2.17	31.87	2.19	34.03	2.23	35.72	2.28
		65	27.24	2.04	28.93	2.12	30.62	2.20	31.84	2.22	34.01	2.26	35.70	2.31
		70	27.22	2.07	28.91	2.14	30.60	2.22	31.82	2.25	33.98	2.29	35.67	2.34
		75	26.56	2.18	28.25	2.26	29.94	2.34	31.15	2.37	33.31	2.41	34.99	2.46
		80	25.91	2.29	27.59	2.38	29.27	2.46	30.49	2.49	32.64	2.54	34.32	2.59
		85	25.26	2.40	26.94	2.49	28.61	2.58	29.83	2.61	31.97	2.66	33.65	2.71
		90	24.61	2.52	26.28	2.61	27.96	2.70	29.17	2.73	31.30	2.78	32.98	2.84
		95	23.91	2.63	25.57	2.72	27.24	2.82	28.00	2.85	30.57	2.91	32.23	2.97
		100	23.32	2.74	24.99	2.84	26.65	2.94	27.64	2.98	29.98	3.03	31.65	3.09
		105	22.74	2.85	24.41	2.95	26.07	3.06	27.27	3.10	29.40	3.16	31.07	3.22
		110	22.16	2.96	23.82	3.07	25.49	3.18	26.69	3.22	28.82	3.28	30.49	3.34
		115	21.58	3.07	23.24	3.19	24.91	3.30	26.11	3.34	28.24	3.40	29.90	3.47
		118	21.23	3.14	22.89	3.25	24.56	3.37	25.76	3.41	27.89	3.48	29.55	3.55
		122	21.11	3.23	22.78	3.35	24.44	3.47	25.64	3.51	27.77	3.58	29.44	3.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 155: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	18 + 18	-4	27.53	1.69	29.24	1.75	30.95	1.81	32.18	1.84	34.37	1.87	36.08	1.91
		0	27.51	1.71	29.22	1.77	30.93	1.83	32.16	1.86	34.35	1.89	36.06	1.93
		5	27.49	1.74	29.20	1.80	30.90	1.86	32.14	1.89	34.32	1.92	36.03	1.96
		10	27.47	1.76	29.18	1.83	30.88	1.89	32.11	1.91	34.29	1.95	36.00	1.99
		14	27.45	1.79	29.15	1.85	30.86	1.92	32.09	1.94	34.27	1.98	35.97	2.02
		20	27.43	1.81	29.13	1.88	30.83	1.95	32.06	1.97	34.24	2.01	35.94	2.05
		25	27.41	1.84	29.11	1.90	30.81	1.97	32.04	2.00	34.21	2.03	35.92	2.08
		30	27.39	1.86	29.09	1.93	30.79	2.00	32.02	2.03	34.19	2.06	35.89	2.10
		35	27.36	1.89	29.06	1.96	30.76	2.03	31.99	2.05	34.16	2.09	35.86	2.13
		40	27.34	1.91	29.04	1.98	30.74	2.06	31.97	2.08	34.14	2.12	35.83	2.16
		45	27.32	1.94	29.02	2.01	30.72	2.08	31.94	2.11	34.11	2.15	35.81	2.19
		50	27.30	1.97	29.00	2.04	30.69	2.11	31.92	2.14	34.08	2.18	35.78	2.22
		55	27.28	1.99	28.98	2.06	30.67	2.14	31.89	2.16	34.06	2.21	35.75	2.25
		60	27.26	2.02	28.95	2.09	30.65	2.17	31.87	2.19	34.03	2.23	35.72	2.28
		65	27.24	2.04	28.93	2.12	30.62	2.20	31.84	2.22	34.01	2.26	35.70	2.31
		70	27.22	2.07	28.91	2.14	30.60	2.22	31.82	2.25	33.98	2.29	35.67	2.34
		75	26.56	2.18	28.25	2.26	29.94	2.34	31.15	2.37	33.31	2.41	34.99	2.46
		80	25.91	2.29	27.59	2.38	29.27	2.46	30.49	2.49	32.64	2.54	34.32	2.59
		85	25.26	2.40	26.94	2.49	28.61	2.58	29.83	2.61	31.97	2.66	33.65	2.71
		90	24.61	2.52	26.28	2.61	27.96	2.70	29.17	2.73	31.30	2.78	32.98	2.84
		95	23.91	2.63	25.57	2.72	27.24	2.82	28.00	2.85	30.57	2.91	32.23	2.97
		100	23.32	2.74	24.99	2.84	26.65	2.94	27.64	2.98	29.98	3.03	31.65	3.09
		105	22.74	2.85	24.41	2.95	26.07	3.06	27.27	3.10	29.40	3.16	31.07	3.22
		110	22.16	2.96	23.82	3.07	25.49	3.18	26.69	3.22	28.82	3.28	30.49	3.34
		115	21.58	3.07	23.24	3.19	24.91	3.30	26.11	3.34	28.24	3.40	29.90	3.47
		118	21.23	3.14	22.89	3.25	24.56	3.37	25.76	3.41	27.89	3.48	29.55	3.55
		122	21.11	3.23	22.78	3.35	24.44	3.47	25.64	3.51	27.77	3.58	29.44	3.65
	12 + 24	-4	27.53	1.69	29.24	1.75	30.95	1.81	32.18	1.84	34.37	1.87	36.08	1.91
		0	27.51	1.71	29.22	1.77	30.93	1.83	32.16	1.86	34.35	1.89	36.06	1.93
		5	27.49	1.74	29.20	1.80	30.90	1.86	32.14	1.89	34.32	1.92	36.03	1.96
		10	27.47	1.76	29.18	1.83	30.88	1.89	32.11	1.91	34.29	1.95	36.00	1.99
		14	27.45	1.79	29.15	1.85	30.86	1.92	32.09	1.94	34.27	1.98	35.97	2.02
		20	27.43	1.81	29.13	1.88	30.83	1.95	32.06	1.97	34.24	2.01	35.94	2.05
		25	27.41	1.84	29.11	1.90	30.81	1.97	32.04	2.00	34.21	2.03	35.92	2.08
		30	27.39	1.86	29.09	1.93	30.79	2.00	32.02	2.03	34.19	2.06	35.89	2.10
		35	27.36	1.89	29.06	1.96	30.76	2.03	31.99	2.05	34.16	2.09	35.86	2.13
		40	27.34	1.91	29.04	1.98	30.74	2.06	31.97	2.08	34.14	2.12	35.83	2.16
		45	27.32	1.94	29.02	2.01	30.72	2.08	31.94	2.11	34.11	2.15	35.81	2.19
		50	27.30	1.97	29.00	2.04	30.69	2.11	31.92	2.14	34.08	2.18	35.78	2.22
		55	27.28	1.99	28.98	2.06	30.67	2.14	31.89	2.16	34.06	2.21	35.75	2.25
		60	27.26	2.02	28.95	2.09	30.65	2.17	31.87	2.19	34.03	2.23	35.72	2.28
		65	27.24	2.04	28.93	2.12	30.62	2.20	31.84	2.22	34.01	2.26	35.70	2.31
		70	27.22	2.07	28.91	2.14	30.60	2.22	31.82	2.25	33.98	2.29	35.67	2.34
		75	26.56	2.18	28.25	2.26	29.94	2.34	31.15	2.37	33.31	2.41	34.99	2.46
		80	25.91	2.29	27.59	2.38	29.27	2.46	30.49	2.49	32.64	2.54	34.32	2.59
		85	25.26	2.40	26.94	2.49	28.61	2.58	29.83	2.61	31.97	2.66	33.65	2.71
		90	24.61	2.52	26.28	2.61	27.96	2.70	29.17	2.73	31.30	2.78	32.98	2.84
		95	23.91	2.63	25.57	2.72	27.24	2.82	28.00	2.85	30.57	2.91	32.23	2.97
		100	23.32	2.74	24.99	2.84	26.65	2.94	27.64	2.98	29.98	3.03	31.65	3.09
		105	22.74	2.85	24.41	2.95	26.07	3.06	27.27	3.10	29.40	3.16	31.07	3.22
		110	22.16	2.96	23.82	3.07	25.49	3.18	26.69	3.22	28.82	3.28	30.49	3.34
		115	21.58	3.07	23.24	3.19	24.91	3.30	26.11	3.34	28.24	3.40	29.90	3.47
		118	21.23	3.14	22.89	3.25	24.56	3.37	25.76	3.41	27.89	3.48	29.55	3.55
		122	21.11	3.23	22.78	3.35	24.44	3.47	25.64	3.51	27.77	3.58	29.44	3.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 156: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 9 + 9	-4	23.23	1.41	24.67	1.46	26.11	1.51	27.15	1.53	29.00	1.56	30.44	1.59
		0	23.21	1.42	24.66	1.47	26.10	1.53	27.14	1.55	28.98	1.58	30.42	1.61
		5	23.19	1.45	24.64	1.50	26.08	1.55	27.12	1.57	28.96	1.60	30.40	1.63
		10	23.18	1.47	24.62	1.52	26.06	1.58	27.10	1.59	28.93	1.62	30.37	1.66
		14	23.16	1.49	24.60	1.54	26.04	1.60	27.07	1.62	28.91	1.65	30.35	1.68
		20	23.14	1.51	24.58	1.57	26.02	1.62	27.05	1.64	28.89	1.67	30.33	1.71
		25	23.12	1.53	24.56	1.59	26.00	1.65	27.03	1.66	28.87	1.70	30.30	1.73
		30	23.11	1.55	24.54	1.61	25.98	1.67	27.01	1.69	28.85	1.72	30.28	1.75
		35	23.09	1.57	24.52	1.63	25.96	1.69	26.99	1.71	28.82	1.74	30.26	1.78
		40	23.07	1.60	24.50	1.65	25.94	1.71	26.97	1.73	28.80	1.77	30.24	1.80
		45	23.05	1.62	24.49	1.68	25.92	1.74	26.95	1.76	28.78	1.79	30.21	1.83
		50	23.04	1.64	24.47	1.70	25.90	1.76	26.93	1.78	28.76	1.81	30.19	1.85
		55	23.02	1.66	24.45	1.72	25.88	1.78	26.91	1.80	28.74	1.84	30.17	1.87
		60	23.00	1.68	24.43	1.74	25.86	1.81	26.89	1.83	28.71	1.86	30.14	1.90
		65	22.98	1.70	24.41	1.76	25.84	1.83	26.87	1.85	28.69	1.88	30.12	1.92
		70	22.97	1.72	24.39	1.79	25.82	1.85	26.85	1.87	28.67	1.91	30.10	1.95
		75	22.41	1.82	23.84	1.88	25.26	1.95	26.29	1.97	28.10	2.01	29.53	2.05
		80	21.86	1.91	23.28	1.98	24.70	2.05	25.72	2.08	27.54	2.11	28.96	2.16
		85	21.31	2.00	22.73	2.08	24.14	2.15	25.17	2.18	26.98	2.22	28.39	2.26
		90	20.76	2.10	22.18	2.17	23.59	2.25	24.61	2.28	26.41	2.32	27.83	2.37
		95	20.17	2.19	21.58	2.27	22.98	2.35	23.63	2.38	25.79	2.42	27.20	2.47
		100	19.68	2.28	21.08	2.37	22.49	2.45	23.32	2.48	25.30	2.53	26.70	2.58
		105	19.19	2.38	20.59	2.46	22.00	2.55	23.01	2.58	24.81	2.63	26.21	2.68
		110	18.70	2.47	20.10	2.56	21.51	2.65	22.52	2.68	24.32	2.73	25.72	2.79
		115	18.21	2.56	19.61	2.65	21.02	2.75	22.03	2.78	23.83	2.84	25.23	2.89
		118	17.91	2.62	19.32	2.71	20.72	2.81	21.74	2.84	23.53	2.90	24.94	2.96
		122	17.81	2.69	19.22	2.79	20.62	2.89	21.64	2.92	23.43	2.98	24.84	3.04
	9 + 9 + 12	-4	25.81	1.51	27.41	1.56	29.01	1.62	30.17	1.64	32.22	1.67	33.82	1.70
		0	25.79	1.52	27.40	1.58	29.00	1.63	30.15	1.65	32.20	1.68	33.80	1.72
		5	25.77	1.55	27.37	1.60	28.97	1.66	30.13	1.68	32.17	1.71	33.77	1.75
		10	25.75	1.57	27.35	1.63	28.95	1.69	30.11	1.71	32.15	1.74	33.75	1.77
		14	25.73	1.59	27.33	1.65	28.93	1.71	30.08	1.73	32.13	1.76	33.72	1.80
		20	25.71	1.62	27.31	1.67	28.91	1.74	30.06	1.76	32.10	1.79	33.70	1.82
		25	25.69	1.64	27.29	1.70	28.88	1.76	30.04	1.78	32.08	1.81	33.67	1.85
		30	25.67	1.66	27.27	1.72	28.86	1.78	30.01	1.80	32.05	1.84	33.65	1.88
		35	25.65	1.68	27.25	1.75	28.84	1.81	29.99	1.83	32.03	1.86	33.62	1.90
		40	25.63	1.71	27.23	1.77	28.82	1.83	29.97	1.85	32.00	1.89	33.59	1.93
		45	25.62	1.73	27.21	1.79	28.80	1.86	29.95	1.88	31.98	1.91	33.57	1.95
		50	25.60	1.75	27.19	1.82	28.77	1.88	29.92	1.90	31.95	1.94	33.54	1.98
		55	25.58	1.78	27.16	1.84	28.75	1.91	29.90	1.93	31.93	1.97	33.52	2.00
		60	25.56	1.80	27.14	1.86	28.73	1.93	29.88	1.95	31.90	1.99	33.49	2.03
		65	25.54	1.82	27.12	1.89	28.71	1.96	29.85	1.98	31.88	2.02	33.47	2.06
		70	25.52	1.84	27.10	1.91	28.69	1.98	29.83	2.00	31.86	2.04	33.44	2.08
		75	24.90	1.94	26.48	2.01	28.06	2.09	29.21	2.11	31.23	2.15	32.81	2.19
		80	24.29	2.04	25.87	2.12	27.44	2.19	28.58	2.22	30.60	2.26	32.17	2.31
		85	23.68	2.14	25.25	2.22	26.83	2.30	27.96	2.33	29.97	2.37	31.55	2.42
		90	23.07	2.24	24.64	2.32	26.21	2.41	27.34	2.44	29.35	2.48	30.92	2.53
		95	22.41	2.34	23.97	2.43	25.53	2.52	26.25	2.54	28.66	2.59	30.22	2.64
		100	21.87	2.44	23.43	2.53	24.99	2.62	25.91	2.65	28.11	2.70	29.67	2.76
		105	21.32	2.54	22.88	2.63	24.44	2.73	25.57	2.76	27.56	2.81	29.13	2.87
		110	20.77	2.64	22.34	2.74	23.90	2.84	25.02	2.87	27.02	2.92	28.58	2.98
		115	20.23	2.74	21.79	2.84	23.35	2.94	24.48	2.98	26.47	3.03	28.03	3.09
		118	19.90	2.80	21.46	2.90	23.02	3.01	24.15	3.04	26.15	3.10	27.71	3.16
		122	19.79	2.88	21.35	2.98	22.91	3.09	24.04	3.13	26.04	3.19	27.60	3.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 157: LMU36CHV Cooling Capacity Table — Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 12 + 12	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41
	9 + 9 + 18	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 158: LMU36CHV Cooling Capacity Table — Ducted Indoor Units (continued).

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	12 + 12 + 12	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41
	9 + 12 + 18	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 159: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	12 + 12 + 18	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41
	9 + 18 + 18	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 160: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	12 + 18 + 18	-4	27.53	1.58	29.24	1.64	30.95	1.70	32.18	1.72	34.37	1.75	36.08	1.78
		0	27.51	1.60	29.22	1.65	30.93	1.72	32.16	1.73	34.35	1.77	36.06	1.80
		5	27.49	1.62	29.20	1.68	30.90	1.74	32.14	1.76	34.32	1.80	36.03	1.83
		10	27.47	1.65	29.18	1.71	30.88	1.77	32.11	1.79	34.29	1.82	36.00	1.86
		14	27.45	1.67	29.15	1.73	30.86	1.79	32.09	1.81	34.27	1.85	35.97	1.89
		20	27.43	1.69	29.13	1.76	30.83	1.82	32.06	1.84	34.24	1.88	35.94	1.91
		25	27.41	1.72	29.11	1.78	30.81	1.85	32.04	1.87	34.21	1.90	35.92	1.94
		30	27.39	1.74	29.09	1.81	30.79	1.87	32.02	1.89	34.19	1.93	35.89	1.97
		35	27.36	1.77	29.06	1.83	30.76	1.90	31.99	1.92	34.16	1.96	35.86	1.99
		40	27.34	1.79	29.04	1.86	30.74	1.92	31.97	1.95	34.14	1.98	35.83	2.02
		45	27.32	1.81	29.02	1.88	30.72	1.95	31.94	1.97	34.11	2.01	35.81	2.05
		50	27.30	1.84	29.00	1.91	30.69	1.97	31.92	2.00	34.08	2.03	35.78	2.08
		55	27.28	1.86	28.98	1.93	30.67	2.00	31.89	2.02	34.06	2.06	35.75	2.10
		60	27.26	1.89	28.95	1.95	30.65	2.03	31.87	2.05	34.03	2.09	35.72	2.13
		65	27.24	1.91	28.93	1.98	30.62	2.05	31.84	2.08	34.01	2.11	35.70	2.16
		70	27.22	1.93	28.91	2.00	30.60	2.08	31.82	2.10	33.98	2.14	35.67	2.18
		75	26.56	2.04	28.25	2.11	29.94	2.19	31.15	2.22	33.31	2.26	34.99	2.30
		80	25.91	2.14	27.59	2.22	29.27	2.30	30.49	2.33	32.64	2.37	34.32	2.42
		85	25.26	2.25	26.94	2.33	28.61	2.41	29.83	2.44	31.97	2.49	33.65	2.54
		90	24.61	2.35	26.28	2.44	27.96	2.53	29.17	2.56	31.30	2.60	32.98	2.66
		95	23.91	2.46	25.57	2.55	27.24	2.64	28.00	2.67	30.57	2.72	32.23	2.77
		100	23.32	2.56	24.99	2.65	26.65	2.75	27.64	2.78	29.98	2.83	31.65	2.89
		105	22.74	2.66	24.41	2.76	26.07	2.86	27.27	2.90	29.40	2.95	31.07	3.01
		110	22.16	2.77	23.82	2.87	25.49	2.97	26.69	3.01	28.82	3.07	30.49	3.13
		115	21.58	2.87	23.24	2.98	24.91	3.09	26.11	3.12	28.24	3.18	29.90	3.24
		118	21.23	2.94	22.89	3.04	24.56	3.15	25.76	3.19	27.89	3.25	29.55	3.32
		122	21.11	3.02	22.78	3.13	24.44	3.24	25.64	3.28	27.77	3.34	29.44	3.41
Four (4) Ducted Indoor Units	9 + 9 + 9 + 9	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 161: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 9 + 12	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25
	9 + 9 + 12 + 12	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 162: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 9 + 18	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25
	9 + 12 + 12 + 12	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 163: LMU36CHV Cooling Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 12 + 18	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25
	12 + 12 + 12 + 12	-4	27.53	1.51	29.24	1.56	30.95	1.62	32.18	1.64	34.37	1.67	36.08	1.70
		0	27.51	1.52	29.22	1.58	30.93	1.64	32.16	1.65	34.35	1.69	36.06	1.72
		5	27.49	1.55	29.20	1.60	30.90	1.66	32.14	1.68	34.32	1.71	36.03	1.75
		10	27.47	1.57	29.18	1.63	30.88	1.69	32.11	1.71	34.29	1.74	36.00	1.77
		14	27.45	1.59	29.15	1.65	30.86	1.71	32.09	1.73	34.27	1.76	35.97	1.80
		20	27.43	1.62	29.13	1.67	30.83	1.74	32.06	1.76	34.24	1.79	35.94	1.82
		25	27.41	1.64	29.11	1.70	30.81	1.76	32.04	1.78	34.21	1.81	35.92	1.85
		30	27.39	1.66	29.09	1.72	30.79	1.79	32.02	1.81	34.19	1.84	35.89	1.88
		35	27.36	1.68	29.06	1.75	30.76	1.81	31.99	1.83	34.16	1.86	35.86	1.90
		40	27.34	1.71	29.04	1.77	30.74	1.83	31.97	1.86	34.14	1.89	35.83	1.93
		45	27.32	1.73	29.02	1.79	30.72	1.86	31.94	1.88	34.11	1.92	35.81	1.95
		50	27.30	1.75	29.00	1.82	30.69	1.88	31.92	1.91	34.08	1.94	35.78	1.98
		55	27.28	1.78	28.98	1.84	30.67	1.91	31.89	1.93	34.06	1.97	35.75	2.01
		60	27.26	1.80	28.95	1.86	30.65	1.93	31.87	1.95	34.03	1.99	35.72	2.03
		65	27.24	1.82	28.93	1.89	30.62	1.96	31.84	1.98	34.01	2.02	35.70	2.06
		70	27.22	1.84	28.91	1.91	30.60	1.98	31.82	2.00	33.98	2.04	35.67	2.08
		75	26.56	1.94	28.25	2.02	29.94	2.09	31.15	2.11	33.31	2.15	34.99	2.20
		80	25.91	2.04	27.59	2.12	29.27	2.20	30.49	2.22	32.64	2.26	34.32	2.31
		85	25.26	2.14	26.94	2.22	28.61	2.30	29.83	2.33	31.97	2.37	33.65	2.42
		90	24.61	2.24	26.28	2.32	27.96	2.41	29.17	2.44	31.30	2.48	32.98	2.53
		95	23.91	2.34	25.57	2.43	27.24	2.52	28.00	2.55	30.57	2.59	32.23	2.65
		100	23.32	2.44	24.99	2.53	26.65	2.62	27.64	2.65	29.98	2.70	31.65	2.76
		105	22.74	2.54	24.41	2.63	26.07	2.73	27.27	2.76	29.40	2.81	31.07	2.87
		110	22.16	2.64	23.82	2.74	25.49	2.84	26.69	2.87	28.82	2.92	30.49	2.98
		115	21.58	2.74	23.24	2.84	24.91	2.94	26.11	2.98	28.24	3.03	29.90	3.09
		118	21.23	2.80	22.89	2.90	24.56	3.01	25.76	3.04	27.89	3.10	29.55	3.16
		122	21.11	2.88	22.78	2.98	24.44	3.09	25.64	3.13	27.77	3.19	29.44	3.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 164: LMU36CHV Cooling Capacity Table — Mixed Indoor Units

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 9	-4	14.75	0.92	15.66	0.95	16.58	0.99	17.24	1.00	18.41	1.02	19.33	1.04
		0	14.74	0.93	15.65	0.96	16.57	1.00	17.23	1.01	18.40	1.03	19.32	1.05
		5	14.73	0.95	15.64	0.98	16.56	1.02	17.22	1.03	18.39	1.05	19.30	1.07
		10	14.72	0.96	15.63	0.99	16.54	1.03	17.20	1.04	18.37	1.06	19.29	1.08
		14	14.70	0.97	15.62	1.01	16.53	1.05	17.19	1.06	18.36	1.08	19.27	1.10
		20	14.69	0.99	15.61	1.02	16.52	1.06	17.18	1.07	18.34	1.09	19.26	1.12
		25	14.68	1.00	15.59	1.04	16.51	1.08	17.16	1.09	18.33	1.11	19.24	1.13
		30	14.67	1.02	15.58	1.05	16.49	1.09	17.15	1.10	18.32	1.12	19.23	1.15
		35	14.66	1.03	15.57	1.07	16.48	1.11	17.14	1.12	18.30	1.14	19.21	1.16
		40	14.65	1.04	15.56	1.08	16.47	1.12	17.12	1.13	18.29	1.16	19.20	1.18
		45	14.64	1.06	15.55	1.10	16.46	1.14	17.11	1.15	18.27	1.17	19.18	1.19
		50	14.63	1.07	15.53	1.11	16.44	1.15	17.10	1.16	18.26	1.19	19.17	1.21
		55	14.61	1.09	15.52	1.13	16.43	1.17	17.09	1.18	18.25	1.20	19.15	1.23
		60	14.60	1.10	15.51	1.14	16.42	1.18	17.07	1.20	18.23	1.22	19.14	1.24
		65	14.59	1.11	15.50	1.15	16.40	1.20	17.06	1.21	18.22	1.23	19.12	1.26
		70	14.58	1.13	15.49	1.17	16.39	1.21	17.05	1.23	18.20	1.25	19.11	1.27
		75	14.23	1.19	15.13	1.23	16.04	1.28	16.69	1.29	17.84	1.32	18.75	1.34
		80	13.88	1.25	14.78	1.30	15.68	1.34	16.33	1.36	17.48	1.38	18.38	1.41
		85	13.53	1.31	14.43	1.36	15.33	1.41	15.98	1.42	17.13	1.45	18.03	1.48
		90	13.18	1.37	14.08	1.42	14.98	1.47	15.62	1.49	16.77	1.52	17.67	1.55
		95	12.81	1.43	13.70	1.48	14.59	1.54	15.00	1.56	16.38	1.59	17.27	1.62
		100	12.49	1.49	13.39	1.55	14.28	1.60	14.81	1.62	16.06	1.65	16.96	1.69
		105	12.18	1.55	13.07	1.61	13.97	1.67	14.61	1.69	15.75	1.72	16.64	1.75
		110	11.87	1.61	12.76	1.67	13.66	1.73	14.30	1.75	15.44	1.79	16.33	1.82
		115	11.56	1.68	12.45	1.74	13.34	1.80	13.99	1.82	15.13	1.85	16.02	1.89
		118	11.37	1.71	12.26	1.77	13.16	1.84	13.80	1.86	14.94	1.90	15.83	1.93
		122	11.31	1.76	12.20	1.82	13.09	1.89	13.74	1.91	14.88	1.95	15.77	1.99
	9 + 9	-4	16.59	1.04	17.62	1.07	18.65	1.11	19.40	1.13	20.71	1.15	21.74	1.17
		0	16.58	1.05	17.61	1.08	18.64	1.12	19.38	1.14	20.70	1.16	21.73	1.18
		5	16.57	1.06	17.60	1.10	18.63	1.14	19.37	1.16	20.68	1.18	21.71	1.20
		10	16.56	1.08	17.58	1.12	18.61	1.16	19.35	1.17	20.67	1.19	21.70	1.22
		14	16.54	1.09	17.57	1.13	18.60	1.18	19.34	1.19	20.65	1.21	21.68	1.24
		20	16.53	1.11	17.56	1.15	18.58	1.19	19.32	1.21	20.64	1.23	21.66	1.25
		25	16.52	1.13	17.54	1.17	18.57	1.21	19.31	1.22	20.62	1.25	21.65	1.27
		30	16.50	1.14	17.53	1.18	18.55	1.23	19.29	1.24	20.60	1.26	21.63	1.29
		35	16.49	1.16	17.52	1.20	18.54	1.24	19.28	1.26	20.59	1.28	21.61	1.31
		40	16.48	1.17	17.50	1.22	18.53	1.26	19.27	1.28	20.57	1.30	21.60	1.33
		45	16.47	1.19	17.49	1.23	18.51	1.28	19.25	1.29	20.56	1.32	21.58	1.34
		50	16.45	1.20	17.48	1.25	18.50	1.29	19.24	1.31	20.54	1.33	21.56	1.36
		55	16.44	1.22	17.46	1.27	18.48	1.31	19.22	1.33	20.53	1.35	21.55	1.38
		60	16.43	1.24	17.45	1.28	18.47	1.33	19.21	1.34	20.51	1.37	21.53	1.40
		65	16.42	1.25	17.44	1.30	18.46	1.35	19.19	1.36	20.49	1.39	21.51	1.41
		70	16.40	1.27	17.42	1.31	18.44	1.36	19.18	1.38	20.48	1.40	21.50	1.43
		75	16.01	1.34	17.03	1.39	18.04	1.44	18.78	1.45	20.07	1.48	21.09	1.51
		80	15.61	1.40	16.63	1.46	17.64	1.51	18.37	1.53	19.67	1.56	20.68	1.59
		85	15.22	1.47	16.23	1.53	17.25	1.58	17.98	1.60	19.27	1.63	20.28	1.66
		90	14.83	1.54	15.84	1.60	16.85	1.66	17.58	1.68	18.87	1.71	19.88	1.74
		95	14.41	1.61	15.41	1.67	16.41	1.73	16.88	1.75	18.42	1.78	19.43	1.82
		100	14.06	1.68	15.06	1.74	16.06	1.80	16.66	1.82	18.07	1.86	19.07	1.90
		105	13.71	1.75	14.71	1.81	15.71	1.88	16.44	1.90	17.72	1.93	18.72	1.97
		110	13.35	1.82	14.36	1.88	15.36	1.95	16.09	1.97	17.37	2.01	18.37	2.05
		115	13.00	1.88	14.01	1.95	15.01	2.02	15.74	2.05	17.02	2.09	18.02	2.13
		118	12.79	1.92	13.80	1.99	14.80	2.07	15.53	2.09	16.81	2.13	17.81	2.17
		122	12.72	1.98	13.73	2.05	14.73	2.13	15.46	2.15	16.74	2.19	17.74	2.24

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 165: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 12	-4	17.51	1.08	18.60	1.12	19.69	1.16	20.47	1.18	21.86	1.20	22.95	1.22
		0	17.50	1.10	18.59	1.14	19.68	1.18	20.46	1.19	21.85	1.21	22.94	1.24
		5	17.49	1.11	18.57	1.15	19.66	1.20	20.45	1.21	21.83	1.23	22.92	1.26
		10	17.48	1.13	18.56	1.17	19.65	1.21	20.43	1.23	21.82	1.25	22.90	1.28
		14	17.46	1.15	18.55	1.19	19.63	1.23	20.41	1.25	21.80	1.27	22.88	1.29
		20	17.45	1.16	18.53	1.20	19.62	1.25	20.40	1.26	21.78	1.29	22.87	1.31
		25	17.43	1.18	18.52	1.22	19.60	1.27	20.38	1.28	21.77	1.30	22.85	1.33
		30	17.42	1.20	18.50	1.24	19.59	1.28	20.37	1.30	21.75	1.32	22.83	1.35
		35	17.41	1.21	18.49	1.26	19.57	1.30	20.35	1.32	21.73	1.34	22.81	1.37
		40	17.39	1.23	18.48	1.27	19.56	1.32	20.34	1.33	21.72	1.36	22.80	1.39
		45	17.38	1.24	18.46	1.29	19.54	1.34	20.32	1.35	21.70	1.38	22.78	1.41
		50	17.37	1.26	18.45	1.31	19.53	1.35	20.30	1.37	21.68	1.40	22.76	1.42
		55	17.35	1.28	18.43	1.32	19.51	1.37	20.29	1.39	21.67	1.41	22.74	1.44
		60	17.34	1.29	18.42	1.34	19.50	1.39	20.27	1.41	21.65	1.43	22.73	1.46
		65	17.33	1.31	18.40	1.36	19.48	1.41	20.26	1.42	21.63	1.45	22.71	1.48
		70	17.32	1.33	18.39	1.38	19.47	1.43	20.24	1.44	21.62	1.47	22.69	1.50
		75	16.90	1.40	17.97	1.45	19.04	1.50	19.82	1.52	21.19	1.55	22.26	1.58
		80	16.48	1.47	17.55	1.52	18.62	1.58	19.39	1.60	20.76	1.63	21.83	1.66
		85	16.07	1.54	17.14	1.60	18.20	1.66	18.97	1.68	20.34	1.71	21.41	1.74
		90	15.66	1.61	16.72	1.67	17.79	1.73	18.55	1.75	19.91	1.79	20.98	1.82
		95	15.21	1.68	16.27	1.75	17.33	1.81	17.81	1.83	19.45	1.87	20.50	1.90
		100	14.84	1.76	15.90	1.82	16.96	1.89	17.58	1.91	19.08	1.94	20.13	1.98
		105	14.47	1.83	15.53	1.89	16.59	1.96	17.35	1.99	18.70	2.02	19.76	2.06
		110	14.10	1.90	15.16	1.97	16.22	2.04	16.98	2.06	18.33	2.10	19.39	2.15
		115	13.73	1.97	14.79	2.04	15.85	2.12	16.61	2.14	17.96	2.18	19.02	2.23
		118	13.50	2.01	14.56	2.09	15.62	2.16	16.39	2.19	17.74	2.23	18.80	2.27
		122	13.43	2.07	14.49	2.15	15.55	2.23	16.31	2.25	17.67	2.29	18.73	2.34
	9 + 12	-4	19.36	1.19	20.56	1.23	21.76	1.27	22.63	1.29	24.16	1.31	25.37	1.34
		0	19.35	1.20	20.55	1.24	21.75	1.29	22.62	1.30	24.15	1.33	25.35	1.35
		5	19.33	1.22	20.53	1.26	21.73	1.31	22.60	1.32	24.13	1.35	25.33	1.38
		10	19.31	1.24	20.51	1.28	21.71	1.33	22.58	1.34	24.11	1.37	25.31	1.40
		14	19.30	1.25	20.50	1.30	21.70	1.35	22.56	1.36	24.09	1.39	25.29	1.42
		20	19.28	1.27	20.48	1.32	21.68	1.37	22.55	1.38	24.08	1.41	25.27	1.44
		25	19.27	1.29	20.47	1.34	21.66	1.39	22.53	1.40	24.06	1.43	25.25	1.46
		30	19.26	1.31	20.45	1.36	21.65	1.41	22.51	1.42	24.04	1.45	25.23	1.48
		35	19.24	1.33	20.44	1.37	21.63	1.42	22.49	1.44	24.02	1.47	25.22	1.50
		40	19.23	1.34	20.42	1.39	21.61	1.44	22.48	1.46	24.00	1.49	25.20	1.52
		45	19.21	1.36	20.40	1.41	21.60	1.46	22.46	1.48	23.98	1.51	25.18	1.54
		50	19.20	1.38	20.39	1.43	21.58	1.48	22.44	1.50	23.97	1.53	25.16	1.56
		55	19.18	1.40	20.37	1.45	21.56	1.50	22.42	1.52	23.95	1.55	25.14	1.58
		60	19.17	1.42	20.36	1.47	21.55	1.52	22.41	1.54	23.93	1.57	25.12	1.60
		65	19.15	1.43	20.34	1.49	21.53	1.54	22.39	1.56	23.91	1.59	25.10	1.62
		70	19.14	1.45	20.33	1.51	21.51	1.56	22.37	1.58	23.89	1.61	25.08	1.64
		75	18.68	1.53	19.86	1.59	21.05	1.64	21.90	1.66	23.42	1.69	24.61	1.73
		80	18.22	1.61	19.40	1.67	20.58	1.73	21.44	1.75	22.95	1.78	24.13	1.82
		85	17.76	1.69	18.94	1.75	20.12	1.81	20.97	1.83	22.48	1.87	23.66	1.91
		90	17.30	1.77	18.48	1.83	19.66	1.90	20.51	1.92	22.01	1.95	23.19	1.99
		95	16.81	1.84	17.98	1.91	19.15	1.98	19.69	2.00	21.49	2.04	22.66	2.08
		100	16.40	1.92	17.57	1.99	18.74	2.07	19.43	2.09	21.08	2.13	22.25	2.17
		105	15.99	2.00	17.16	2.07	18.33	2.15	19.18	2.17	20.67	2.21	21.84	2.26
		110	15.58	2.08	16.75	2.15	17.92	2.23	18.77	2.26	20.26	2.30	21.44	2.35
		115	15.17	2.16	16.34	2.24	17.51	2.32	18.36	2.34	19.85	2.39	21.03	2.44
		118	14.93	2.20	16.10	2.28	17.27	2.37	18.11	2.40	19.61	2.44	20.78	2.49
		122	14.84	2.27	16.01	2.35	17.19	2.44	18.03	2.46	19.53	2.51	20.70	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 166: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 15	-4	22.12	1.31	23.49	1.36	24.87	1.41	25.86	1.43	27.62	1.45	28.99	1.48
		0	22.11	1.33	23.48	1.37	24.85	1.42	25.85	1.44	27.60	1.47	28.97	1.50
		5	22.09	1.35	23.46	1.40	24.83	1.45	25.82	1.46	27.58	1.49	28.95	1.52
		10	22.07	1.37	23.44	1.42	24.82	1.47	25.81	1.49	27.56	1.51	28.93	1.54
		14	22.06	1.39	23.43	1.44	24.80	1.49	25.79	1.51	27.54	1.54	28.91	1.57
		20	22.04	1.41	23.41	1.46	24.78	1.51	25.77	1.53	27.51	1.56	28.88	1.59
		25	22.02	1.43	23.39	1.48	24.76	1.53	25.75	1.55	27.49	1.58	28.86	1.61
		30	22.01	1.45	23.37	1.50	24.74	1.56	25.73	1.57	27.47	1.60	28.84	1.63
		35	21.99	1.47	23.36	1.52	24.72	1.58	25.71	1.59	27.45	1.62	28.82	1.66
		40	21.97	1.49	23.34	1.54	24.70	1.60	25.69	1.62	27.43	1.65	28.80	1.68
		45	21.96	1.51	23.32	1.56	24.68	1.62	25.67	1.64	27.41	1.67	28.77	1.70
		50	21.94	1.53	23.30	1.58	24.66	1.64	25.65	1.66	27.39	1.69	28.75	1.72
		55	21.92	1.55	23.28	1.60	24.65	1.66	25.63	1.68	27.37	1.71	28.73	1.75
		60	21.91	1.57	23.27	1.62	24.63	1.68	25.61	1.70	27.35	1.73	28.71	1.77
		65	21.89	1.59	23.25	1.64	24.61	1.71	25.59	1.72	27.33	1.76	28.69	1.79
		70	21.87	1.61	23.23	1.67	24.59	1.73	25.57	1.75	27.30	1.78	28.66	1.81
		75	21.35	1.69	22.70	1.76	24.06	1.82	25.03	1.84	26.77	1.88	28.12	1.91
		80	20.82	1.78	22.17	1.85	23.52	1.91	24.50	1.93	26.23	1.97	27.58	2.01
		85	20.30	1.87	21.65	1.94	22.99	2.01	23.97	2.03	25.69	2.07	27.04	2.11
		90	19.78	1.95	21.12	2.03	22.47	2.10	23.44	2.12	25.16	2.16	26.50	2.21
		95	19.21	2.04	20.55	2.11	21.89	2.19	22.50	2.22	24.56	2.26	25.90	2.30
		100	18.74	2.13	20.08	2.20	21.42	2.29	22.21	2.31	24.09	2.35	25.43	2.40
		105	18.27	2.21	19.61	2.29	20.95	2.38	21.92	2.41	23.63	2.45	24.97	2.50
		110	17.81	2.30	19.14	2.38	20.48	2.47	21.45	2.50	23.16	2.55	24.50	2.60
		115	17.34	2.39	18.68	2.47	20.01	2.56	20.98	2.59	22.69	2.64	24.03	2.70
		118	17.06	2.44	18.40	2.53	19.73	2.62	20.70	2.65	22.41	2.70	23.75	2.75
		122	16.96	2.51	18.30	2.60	19.64	2.70	20.61	2.73	22.32	2.78	23.66	2.83
	12 + 12	-4	22.12	1.31	23.49	1.36	24.87	1.41	25.86	1.43	27.62	1.45	28.99	1.48
		0	22.11	1.33	23.48	1.37	24.85	1.42	25.85	1.44	27.60	1.47	28.97	1.50
		5	22.09	1.35	23.46	1.40	24.83	1.45	25.82	1.46	27.58	1.49	28.95	1.52
		10	22.07	1.37	23.44	1.42	24.82	1.47	25.81	1.49	27.56	1.51	28.93	1.54
		14	22.06	1.39	23.43	1.44	24.80	1.49	25.79	1.51	27.54	1.54	28.91	1.57
		20	22.04	1.41	23.41	1.46	24.78	1.51	25.77	1.53	27.51	1.56	28.88	1.59
		25	22.02	1.43	23.39	1.48	24.76	1.53	25.75	1.55	27.49	1.58	28.86	1.61
		30	22.01	1.45	23.37	1.50	24.74	1.56	25.73	1.57	27.47	1.60	28.84	1.63
		35	21.99	1.47	23.36	1.52	24.72	1.58	25.71	1.59	27.45	1.62	28.82	1.66
		40	21.97	1.49	23.34	1.54	24.70	1.60	25.69	1.62	27.43	1.65	28.80	1.68
		45	21.96	1.51	23.32	1.56	24.68	1.62	25.67	1.64	27.41	1.67	28.77	1.70
		50	21.94	1.53	23.30	1.58	24.66	1.64	25.65	1.66	27.39	1.69	28.75	1.72
		55	21.92	1.55	23.28	1.60	24.65	1.66	25.63	1.68	27.37	1.71	28.73	1.75
		60	21.91	1.57	23.27	1.62	24.63	1.68	25.61	1.70	27.35	1.73	28.71	1.77
		65	21.89	1.59	23.25	1.64	24.61	1.71	25.59	1.72	27.33	1.76	28.69	1.79
		70	21.87	1.61	23.23	1.67	24.59	1.73	25.57	1.75	27.30	1.78	28.66	1.81
		75	21.35	1.69	22.70	1.76	24.06	1.82	25.03	1.84	26.77	1.88	28.12	1.91
		80	20.82	1.78	22.17	1.85	23.52	1.91	24.50	1.93	26.23	1.97	27.58	2.01
		85	20.30	1.87	21.65	1.94	22.99	2.01	23.97	2.03	25.69	2.07	27.04	2.11
		90	19.78	1.95	21.12	2.03	22.47	2.10	23.44	2.12	25.16	2.16	26.50	2.21
		95	19.21	2.04	20.55	2.11	21.89	2.19	22.50	2.22	24.56	2.26	25.90	2.30
		100	18.74	2.13	20.08	2.20	21.42	2.29	22.21	2.31	24.09	2.35	25.43	2.40
		105	18.27	2.21	19.61	2.29	20.95	2.38	21.92	2.41	23.63	2.45	24.97	2.50
		110	17.81	2.30	19.14	2.38	20.48	2.47	21.45	2.50	23.16	2.55	24.50	2.60
		115	17.34	2.39	18.68	2.47	20.01	2.56	20.98	2.59	22.69	2.64	24.03	2.70
		118	17.06	2.44	18.40	2.53	19.73	2.62	20.70	2.65	22.41	2.70	23.75	2.75
		122	16.96	2.51	18.30	2.60	19.64	2.70	20.61	2.73	22.32	2.78	23.66	2.83

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 167: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 18	-4	23.04	1.36	24.47	1.41	25.90	1.46	26.94	1.48	28.77	1.51	30.20	1.54
		0	23.03	1.38	24.46	1.43	25.89	1.48	26.92	1.49	28.75	1.52	30.18	1.55
		5	23.01	1.40	24.44	1.45	25.87	1.50	26.90	1.52	28.73	1.55	30.16	1.58
		10	22.99	1.42	24.42	1.47	25.85	1.52	26.88	1.54	28.71	1.57	30.13	1.60
		14	22.98	1.44	24.40	1.49	25.83	1.55	26.86	1.56	28.68	1.59	30.11	1.62
		20	22.96	1.46	24.38	1.51	25.81	1.57	26.84	1.59	28.66	1.62	30.09	1.65
		25	22.94	1.48	24.37	1.53	25.79	1.59	26.82	1.61	28.64	1.64	30.06	1.67
		30	22.92	1.50	24.35	1.56	25.77	1.61	26.80	1.63	28.62	1.66	30.04	1.69
		35	22.91	1.52	24.33	1.58	25.75	1.63	26.78	1.65	28.60	1.68	30.02	1.72
		40	22.89	1.54	24.31	1.60	25.73	1.66	26.76	1.68	28.57	1.71	30.00	1.74
		45	22.87	1.56	24.29	1.62	25.71	1.68	26.74	1.70	28.55	1.73	29.97	1.76
		50	22.85	1.58	24.27	1.64	25.69	1.70	26.72	1.72	28.53	1.75	29.95	1.79
		55	22.84	1.60	24.25	1.66	25.67	1.72	26.70	1.74	28.51	1.78	29.93	1.81
		60	22.82	1.62	24.24	1.68	25.65	1.75	26.68	1.77	28.49	1.80	29.90	1.83
		65	22.80	1.65	24.22	1.71	25.63	1.77	26.66	1.79	28.46	1.82	29.88	1.86
		70	22.78	1.67	24.20	1.73	25.61	1.79	26.63	1.81	28.44	1.84	29.86	1.88
		75	22.23	1.76	23.65	1.82	25.06	1.89	26.08	1.91	27.88	1.94	29.29	1.98
		80	21.69	1.85	23.09	1.91	24.50	1.98	25.52	2.01	27.32	2.04	28.73	2.08
		85	21.14	1.94	22.55	2.01	23.95	2.08	24.97	2.10	26.76	2.14	28.17	2.19
		90	20.60	2.03	22.00	2.10	23.40	2.18	24.41	2.20	26.20	2.24	27.60	2.29
		95	20.01	2.12	21.40	2.19	22.80	2.27	23.44	2.30	25.59	2.34	26.98	2.39
		100	19.52	2.21	20.92	2.29	22.31	2.37	23.13	2.40	25.10	2.44	26.49	2.49
		105	19.04	2.30	20.43	2.38	21.82	2.47	22.83	2.49	24.61	2.54	26.01	2.59
		110	18.55	2.38	19.94	2.47	21.34	2.56	22.34	2.59	24.12	2.64	25.52	2.69
		115	18.06	2.47	19.45	2.57	20.85	2.66	21.86	2.69	23.64	2.74	25.03	2.79
		118	17.77	2.53	19.16	2.62	20.56	2.72	21.56	2.75	23.34	2.80	24.74	2.86
		122	17.67	2.60	19.07	2.70	20.46	2.79	21.47	2.83	23.25	2.88	24.64	2.94
	9 + 18	-4	24.89	1.46	26.43	1.51	27.98	1.56	29.09	1.58	31.07	1.61	32.61	1.65
		0	24.87	1.47	26.42	1.53	27.96	1.58	29.08	1.60	31.05	1.63	32.60	1.66
		5	24.85	1.50	26.40	1.55	27.94	1.61	29.05	1.63	31.03	1.66	32.57	1.69
		10	24.83	1.52	26.38	1.57	27.92	1.63	29.03	1.65	31.00	1.68	32.54	1.72
		14	24.81	1.54	26.35	1.60	27.90	1.65	29.01	1.67	30.98	1.71	32.52	1.74
		20	24.79	1.56	26.33	1.62	27.87	1.68	28.99	1.70	30.95	1.73	32.49	1.76
		25	24.78	1.58	26.31	1.64	27.85	1.70	28.96	1.72	30.93	1.75	32.47	1.79
		30	24.76	1.61	26.29	1.67	27.83	1.73	28.94	1.75	30.91	1.78	32.44	1.81
		35	24.74	1.63	26.27	1.69	27.81	1.75	28.92	1.77	30.88	1.80	32.42	1.84
		40	24.72	1.65	26.25	1.71	27.79	1.77	28.90	1.79	30.86	1.83	32.40	1.86
		45	24.70	1.67	26.23	1.73	27.77	1.80	28.88	1.82	30.84	1.85	32.37	1.89
		50	24.68	1.70	26.21	1.76	27.75	1.82	28.85	1.84	30.81	1.88	32.35	1.91
		55	24.66	1.72	26.19	1.78	27.73	1.85	28.83	1.87	30.79	1.90	32.32	1.94
		60	24.64	1.74	26.17	1.80	27.70	1.87	28.81	1.89	30.77	1.93	32.30	1.96
		65	24.62	1.76	26.15	1.83	27.68	1.89	28.79	1.91	30.74	1.95	32.27	1.99
		70	24.61	1.78	26.13	1.85	27.66	1.92	28.77	1.94	30.72	1.97	32.25	2.01
		75	24.01	1.88	25.54	1.95	27.06	2.02	28.16	2.04	30.11	2.08	31.64	2.12
		80	23.42	1.98	24.94	2.05	26.46	2.12	27.56	2.15	29.50	2.19	31.02	2.23
		85	22.83	2.07	24.35	2.15	25.87	2.23	26.96	2.25	28.90	2.29	30.42	2.34
		90	22.25	2.17	23.76	2.25	25.27	2.33	26.37	2.36	28.30	2.40	29.81	2.45
		95	21.61	2.27	23.12	2.35	24.62	2.43	25.31	2.46	27.63	2.51	29.14	2.56
		100	21.08	2.36	22.59	2.45	24.10	2.54	24.98	2.57	27.11	2.61	28.61	2.67
		105	20.56	2.46	22.06	2.55	23.57	2.64	24.66	2.67	26.58	2.72	28.09	2.78
		110	20.03	2.55	21.54	2.65	23.04	2.74	24.13	2.78	26.05	2.83	27.56	2.88
		115	19.51	2.65	21.01	2.75	22.52	2.85	23.60	2.88	25.53	2.93	27.03	2.99
		118	19.19	2.71	20.70	2.81	22.20	2.91	23.29	2.94	25.21	3.00	26.72	3.06
		122	19.08	2.78	20.59	2.89	22.10	2.99	23.18	3.03	25.11	3.08	26.61	3.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 168: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 15	-4	24.89	1.46	26.43	1.51	27.98	1.56	29.09	1.58	31.07	1.61	32.61	1.65
		0	24.87	1.47	26.42	1.53	27.96	1.58	29.08	1.60	31.05	1.63	32.60	1.66
		5	24.85	1.50	26.40	1.55	27.94	1.61	29.05	1.63	31.03	1.66	32.57	1.69
		10	24.83	1.52	26.38	1.57	27.92	1.63	29.03	1.65	31.00	1.68	32.54	1.72
		14	24.81	1.54	26.35	1.60	27.90	1.65	29.01	1.67	30.98	1.71	32.52	1.74
		20	24.79	1.56	26.33	1.62	27.87	1.68	28.99	1.70	30.95	1.73	32.49	1.76
		25	24.78	1.58	26.31	1.64	27.85	1.70	28.96	1.72	30.93	1.75	32.47	1.79
		30	24.76	1.61	26.29	1.67	27.83	1.73	28.94	1.75	30.91	1.78	32.44	1.81
		35	24.74	1.63	26.27	1.69	27.81	1.75	28.92	1.77	30.88	1.80	32.42	1.84
		40	24.72	1.65	26.25	1.71	27.79	1.77	28.90	1.79	30.86	1.83	32.40	1.86
		45	24.70	1.67	26.23	1.73	27.77	1.80	28.88	1.82	30.84	1.85	32.37	1.89
		50	24.68	1.70	26.21	1.76	27.75	1.82	28.85	1.84	30.81	1.88	32.35	1.91
		55	24.66	1.72	26.19	1.78	27.73	1.85	28.83	1.87	30.79	1.90	32.32	1.94
		60	24.64	1.74	26.17	1.80	27.70	1.87	28.81	1.89	30.77	1.93	32.30	1.96
		65	24.62	1.76	26.15	1.83	27.68	1.89	28.79	1.91	30.74	1.95	32.27	1.99
		70	24.61	1.78	26.13	1.85	27.66	1.92	28.77	1.94	30.72	1.97	32.25	2.01
		75	24.01	1.88	25.54	1.95	27.06	2.02	28.16	2.04	30.11	2.08	31.64	2.12
		80	23.42	1.98	24.94	2.05	26.46	2.12	27.56	2.15	29.50	2.19	31.02	2.23
		85	22.83	2.07	24.35	2.15	25.87	2.23	26.96	2.25	28.90	2.29	30.42	2.34
		90	22.25	2.17	23.76	2.25	25.27	2.33	26.37	2.36	28.30	2.40	29.81	2.45
		95	21.61	2.27	23.12	2.35	24.62	2.43	25.31	2.46	27.63	2.51	29.14	2.56
		100	21.08	2.36	22.59	2.45	24.10	2.54	24.98	2.57	27.11	2.61	28.61	2.67
		105	20.56	2.46	22.06	2.55	23.57	2.64	24.66	2.67	26.58	2.72	28.09	2.78
		110	20.03	2.55	21.54	2.65	23.04	2.74	24.13	2.78	26.05	2.83	27.56	2.88
		115	19.51	2.65	21.01	2.75	22.52	2.85	23.60	2.88	25.53	2.93	27.03	2.99
		118	19.19	2.71	20.70	2.81	22.20	2.91	23.29	2.94	25.21	3.00	26.72	3.06
		122	19.08	2.78	20.59	2.89	22.10	2.99	23.18	3.03	25.11	3.08	26.61	3.14
	12 + 18	-4	27.65	1.58	29.37	1.64	31.09	1.70	32.33	1.72	34.52	1.75	36.24	1.79
		0	27.64	1.60	29.35	1.66	31.07	1.72	32.31	1.74	34.50	1.77	36.22	1.81
		5	27.61	1.63	29.33	1.69	31.04	1.75	32.28	1.77	34.47	1.80	36.19	1.84
		10	27.59	1.65	29.31	1.71	31.02	1.77	32.26	1.79	34.45	1.83	36.16	1.86
		14	27.57	1.67	29.28	1.74	31.00	1.80	32.23	1.82	34.42	1.85	36.13	1.89
		20	27.55	1.70	29.26	1.76	30.97	1.82	32.21	1.85	34.39	1.88	36.10	1.92
		25	27.53	1.72	29.24	1.79	30.95	1.85	32.18	1.87	34.37	1.91	36.08	1.94
		30	27.51	1.75	29.22	1.81	30.92	1.88	32.16	1.90	34.34	1.93	36.05	1.97
		35	27.49	1.77	29.19	1.83	30.90	1.90	32.13	1.92	34.31	1.96	36.02	2.00
		40	27.47	1.79	29.17	1.86	30.88	1.93	32.11	1.95	34.29	1.99	35.99	2.03
		45	27.44	1.82	29.15	1.88	30.85	1.95	32.08	1.98	34.26	2.01	35.97	2.05
		50	27.42	1.84	29.13	1.91	30.83	1.98	32.06	2.00	34.24	2.04	35.94	2.08
		55	27.40	1.87	29.10	1.93	30.81	2.01	32.04	2.03	34.21	2.07	35.91	2.11
		60	27.38	1.89	29.08	1.96	30.78	2.03	32.01	2.05	34.18	2.09	35.88	2.14
		65	27.36	1.91	29.06	1.98	30.76	2.06	31.99	2.08	34.16	2.12	35.86	2.16
		70	27.34	1.94	29.04	2.01	30.74	2.08	31.96	2.11	34.13	2.15	35.83	2.19
		75	26.68	2.04	28.38	2.12	30.07	2.20	31.29	2.22	33.46	2.26	35.15	2.31
		80	26.02	2.15	27.71	2.23	29.40	2.31	30.62	2.33	32.78	2.38	34.47	2.43
		85	25.37	2.25	27.06	2.33	28.74	2.42	29.96	2.45	32.11	2.49	33.80	2.54
		90	24.72	2.36	26.40	2.44	28.08	2.53	29.30	2.56	31.44	2.61	33.13	2.66
		95	24.01	2.46	25.68	2.55	27.36	2.64	28.13	2.68	30.70	2.73	32.38	2.78
		100	23.43	2.57	25.10	2.66	26.77	2.76	27.76	2.79	30.12	2.84	31.79	2.90
		105	22.84	2.67	24.52	2.77	26.19	2.87	27.40	2.90	29.53	2.96	31.21	3.02
		110	22.26	2.78	23.93	2.88	25.60	2.98	26.81	3.02	28.95	3.07	30.62	3.13
		115	21.67	2.88	23.35	2.99	25.02	3.09	26.23	3.13	28.36	3.19	30.04	3.25
		118	21.32	2.94	22.99	3.05	24.67	3.16	25.88	3.20	28.01	3.26	29.69	3.32
		122	21.21	3.03	22.88	3.14	24.55	3.25	25.76	3.29	27.90	3.35	29.57	3.42

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 169: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 24	-4	28.57	1.62	30.35	1.68	32.12	1.74	33.40	1.76	35.67	1.79	37.45	1.83
		0	28.56	1.64	30.33	1.70	32.10	1.76	33.39	1.78	35.65	1.81	37.43	1.85
		5	28.53	1.66	30.31	1.72	32.08	1.79	33.36	1.81	35.62	1.84	37.39	1.88
		10	28.51	1.69	30.28	1.75	32.05	1.81	33.33	1.83	35.60	1.87	37.37	1.91
		14	28.49	1.71	30.26	1.77	32.03	1.84	33.31	1.86	35.57	1.90	37.34	1.93
		20	28.47	1.74	30.24	1.80	32.00	1.87	33.28	1.89	35.54	1.92	37.31	1.96
		25	28.45	1.76	30.21	1.83	31.98	1.89	33.26	1.91	35.51	1.95	37.28	1.99
		30	28.42	1.79	30.19	1.85	31.96	1.92	33.23	1.94	35.49	1.98	37.25	2.02
		35	28.40	1.81	30.17	1.88	31.93	1.95	33.20	1.97	35.46	2.00	37.22	2.04
		40	28.38	1.84	30.14	1.90	31.91	1.97	33.18	1.99	35.43	2.03	37.19	2.07
		45	28.36	1.86	30.12	1.93	31.88	2.00	33.15	2.02	35.40	2.06	37.17	2.10
		50	28.34	1.88	30.10	1.95	31.86	2.02	33.13	2.05	35.38	2.09	37.14	2.13
		55	28.32	1.91	30.07	1.98	31.83	2.05	33.10	2.07	35.35	2.11	37.11	2.16
		60	28.29	1.93	30.05	2.00	31.81	2.08	33.08	2.10	35.32	2.14	37.08	2.18
		65	28.27	1.96	30.03	2.03	31.78	2.10	33.05	2.13	35.30	2.17	37.05	2.21
		70	28.25	1.98	30.01	2.06	31.76	2.13	33.03	2.15	35.27	2.20	37.02	2.24
		75	27.57	2.09	29.32	2.17	31.07	2.25	32.34	2.27	34.57	2.31	36.32	2.36
		80	26.89	2.20	28.64	2.28	30.38	2.36	31.64	2.39	33.87	2.43	35.62	2.48
		85	26.22	2.30	27.96	2.39	29.70	2.48	30.96	2.50	33.18	2.55	34.93	2.60
		90	25.54	2.41	27.28	2.50	29.02	2.59	30.27	2.62	32.49	2.67	34.23	2.72
		95	24.81	2.52	26.54	2.61	28.27	2.70	29.06	2.74	31.73	2.79	33.46	2.84
		100	24.21	2.62	25.94	2.72	27.67	2.82	28.69	2.85	31.12	2.91	32.85	2.96
		105	23.60	2.73	25.33	2.83	27.06	2.93	28.31	2.97	30.52	3.02	32.25	3.09
		110	23.00	2.84	24.73	2.94	26.46	3.05	27.71	3.08	29.91	3.14	31.64	3.21
		115	22.40	2.95	24.12	3.05	25.85	3.16	27.10	3.20	29.31	3.26	31.04	3.33
		118	22.03	3.01	23.76	3.12	25.49	3.23	26.74	3.27	28.95	3.33	30.68	3.40
		122	21.91	3.10	23.64	3.21	25.37	3.33	26.62	3.36	28.83	3.43	30.55	3.50
	9 + 24	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 170: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	15 + 18	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59
	18 + 18	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 171: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 24	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59
	15 + 24	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 172: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	18 + 24*	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59
	24* + 24*	-4	29.49	1.66	31.33	1.72	33.16	1.78	34.48	1.80	36.82	1.84	38.65	1.88
		0	29.48	1.68	31.31	1.74	33.14	1.80	34.46	1.82	36.80	1.86	38.63	1.90
		5	29.45	1.71	31.28	1.77	33.11	1.83	34.43	1.85	36.77	1.89	38.60	1.93
		10	29.43	1.73	31.26	1.79	33.09	1.86	34.41	1.88	36.74	1.92	38.57	1.96
		14	29.41	1.76	31.24	1.82	33.06	1.89	34.38	1.91	36.71	1.94	38.54	1.98
		20	29.39	1.78	31.21	1.85	33.04	1.91	34.35	1.94	36.69	1.97	38.51	2.01
		25	29.36	1.81	31.19	1.87	33.01	1.94	34.33	1.96	36.66	2.00	38.48	2.04
		30	29.34	1.83	31.16	1.90	32.99	1.97	34.30	1.99	36.63	2.03	38.45	2.07
		35	29.32	1.86	31.14	1.93	32.96	2.00	34.28	2.02	36.60	2.06	38.42	2.10
		40	29.30	1.88	31.12	1.95	32.94	2.02	34.25	2.05	36.57	2.08	38.39	2.13
		45	29.27	1.91	31.09	1.98	32.91	2.05	34.22	2.07	36.55	2.11	38.36	2.16
		50	29.25	1.93	31.07	2.00	32.89	2.08	34.20	2.10	36.52	2.14	38.34	2.18
		55	29.23	1.96	31.04	2.03	32.86	2.10	34.17	2.13	36.49	2.17	38.31	2.21
		60	29.21	1.98	31.02	2.06	32.83	2.13	34.14	2.16	36.46	2.20	38.28	2.24
		65	29.18	2.01	31.00	2.08	32.81	2.16	34.12	2.18	36.43	2.22	38.25	2.27
		70	29.16	2.03	30.97	2.11	32.78	2.19	34.09	2.21	36.41	2.25	38.22	2.30
		75	28.46	2.14	30.27	2.22	32.07	2.30	33.38	2.33	35.69	2.37	37.49	2.42
		80	27.76	2.25	29.56	2.34	31.36	2.42	32.66	2.45	34.97	2.50	36.77	2.55
		85	27.06	2.36	28.86	2.45	30.66	2.54	31.96	2.57	34.25	2.62	36.05	2.67
		90	26.37	2.47	28.16	2.56	29.95	2.66	31.25	2.69	33.54	2.74	35.33	2.79
		95	25.61	2.58	27.40	2.68	29.18	2.78	30.00	2.81	32.75	2.86	34.53	2.92
		100	24.99	2.69	26.77	2.79	28.56	2.89	29.61	2.93	32.13	2.98	33.91	3.04
		105	24.37	2.80	26.15	2.91	27.93	3.01	29.22	3.05	31.50	3.10	33.29	3.17
		110	23.74	2.91	25.53	3.02	27.31	3.13	28.60	3.17	30.88	3.22	32.66	3.29
		115	23.12	3.02	24.90	3.13	26.69	3.25	27.98	3.28	30.26	3.35	32.04	3.41
		118	22.74	3.09	24.53	3.20	26.31	3.32	27.60	3.36	29.88	3.42	31.67	3.49
		122	22.62	3.18	24.40	3.29	26.19	3.41	27.48	3.45	29.76	3.52	31.54	3.59

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

Table 173: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 9	-4	21.20	1.24	22.52	1.28	23.83	1.33	24.78	1.35	26.47	1.37	27.78	1.40
		0	21.19	1.25	22.50	1.30	23.82	1.35	24.77	1.36	26.45	1.39	27.77	1.42
		5	21.17	1.27	22.49	1.32	23.80	1.37	24.75	1.38	26.43	1.41	27.74	1.44
		10	21.15	1.29	22.47	1.34	23.78	1.39	24.73	1.40	26.41	1.43	27.72	1.46
		14	21.14	1.31	22.45	1.36	23.76	1.41	24.71	1.42	26.39	1.45	27.70	1.48
		20	21.12	1.33	22.43	1.38	23.75	1.43	24.69	1.45	26.37	1.47	27.68	1.50
		25	21.11	1.35	22.42	1.40	23.73	1.45	24.67	1.47	26.35	1.49	27.66	1.52
		30	21.09	1.37	22.40	1.42	23.71	1.47	24.65	1.49	26.33	1.51	27.64	1.54
		35	21.07	1.39	22.38	1.44	23.69	1.49	24.64	1.51	26.31	1.54	27.62	1.57
		40	21.06	1.41	22.36	1.46	23.67	1.51	24.62	1.53	26.29	1.56	27.60	1.59
		45	21.04	1.42	22.35	1.48	23.65	1.53	24.60	1.55	26.27	1.58	27.57	1.61
		50	21.02	1.44	22.33	1.50	23.64	1.55	24.58	1.57	26.25	1.60	27.55	1.63
		55	21.01	1.46	22.31	1.52	23.62	1.57	24.56	1.59	26.23	1.62	27.53	1.65
		60	20.99	1.48	22.30	1.53	23.60	1.59	24.54	1.61	26.21	1.64	27.51	1.67
		65	20.98	1.50	22.28	1.55	23.58	1.61	24.52	1.63	26.19	1.66	27.49	1.69
		70	20.96	1.52	22.26	1.57	23.56	1.63	24.50	1.65	26.17	1.68	27.47	1.71
		75	20.46	1.60	21.75	1.66	23.05	1.72	23.99	1.74	25.65	1.77	26.95	1.81
		80	19.95	1.68	21.25	1.74	22.54	1.81	23.48	1.83	25.13	1.86	26.43	1.90
		85	19.45	1.76	20.74	1.83	22.04	1.90	22.97	1.92	24.62	1.95	25.91	1.99
		90	18.95	1.85	20.24	1.91	21.53	1.98	22.46	2.01	24.11	2.04	25.40	2.09
		95	18.41	1.93	19.69	2.00	20.97	2.07	21.56	2.10	23.54	2.13	24.82	2.18
		100	17.96	2.01	19.24	2.08	20.53	2.16	21.28	2.18	23.09	2.23	24.37	2.27
		105	17.51	2.09	18.80	2.17	20.08	2.25	21.00	2.27	22.64	2.32	23.93	2.36
		110	17.06	2.17	18.35	2.25	19.63	2.34	20.56	2.36	22.19	2.41	23.48	2.46
		115	16.62	2.26	17.90	2.34	19.18	2.42	20.11	2.45	21.75	2.50	23.03	2.55
		118	16.35	2.30	17.63	2.39	18.91	2.48	19.84	2.50	21.48	2.55	22.76	2.60
		122	16.26	2.37	17.54	2.46	18.82	2.55	19.75	2.58	21.39	2.62	22.67	2.68
	7 + 9 + 9	-4	23.04	1.34	24.47	1.38	25.90	1.44	26.94	1.45	28.77	1.48	30.20	1.51
		0	23.03	1.35	24.46	1.40	25.89	1.45	26.92	1.47	28.75	1.50	30.18	1.53
		5	23.01	1.37	24.44	1.42	25.87	1.47	26.90	1.49	28.73	1.52	30.16	1.55
		10	22.99	1.39	24.42	1.44	25.85	1.50	26.88	1.51	28.71	1.54	30.13	1.57
		14	22.98	1.41	24.40	1.46	25.83	1.52	26.86	1.54	28.68	1.56	30.11	1.60
		20	22.96	1.43	24.38	1.49	25.81	1.54	26.84	1.56	28.66	1.59	30.09	1.62
		25	22.94	1.45	24.37	1.51	25.79	1.56	26.82	1.58	28.64	1.61	30.06	1.64
		30	22.92	1.47	24.35	1.53	25.77	1.58	26.80	1.60	28.62	1.63	30.04	1.66
		35	22.91	1.49	24.33	1.55	25.75	1.61	26.78	1.62	28.60	1.65	30.02	1.69
		40	22.89	1.51	24.31	1.57	25.73	1.63	26.76	1.65	28.57	1.68	30.00	1.71
		45	22.87	1.53	24.29	1.59	25.71	1.65	26.74	1.67	28.55	1.70	29.97	1.73
		50	22.85	1.56	24.27	1.61	25.69	1.67	26.72	1.69	28.53	1.72	29.95	1.76
		55	22.84	1.58	24.25	1.63	25.67	1.69	26.70	1.71	28.51	1.74	29.93	1.78
		60	22.82	1.60	24.24	1.65	25.65	1.71	26.68	1.73	28.49	1.77	29.90	1.80
		65	22.80	1.62	24.22	1.68	25.63	1.74	26.66	1.76	28.46	1.79	29.88	1.83
		70	22.78	1.64	24.20	1.70	25.61	1.76	26.63	1.78	28.44	1.81	29.86	1.85
		75	22.23	1.72	23.65	1.79	25.06	1.85	26.08	1.87	27.88	1.91	29.29	1.95
		80	21.69	1.81	23.09	1.88	24.50	1.95	25.52	1.97	27.32	2.01	28.73	2.05
		85	21.14	1.90	22.55	1.97	23.95	2.04	24.97	2.07	26.76	2.10	28.17	2.15
		90	20.60	1.99	22.00	2.06	23.40	2.14	24.41	2.16	26.20	2.20	27.60	2.25
		95	20.01	2.08	21.40	2.15	22.80	2.23	23.44	2.26	25.59	2.30	26.98	2.35
		100	19.52	2.17	20.92	2.25	22.31	2.33	23.13	2.35	25.10	2.40	26.49	2.45
		105	19.04	2.25	20.43	2.34	21.82	2.42	22.83	2.45	24.61	2.50	26.01	2.55
		110	18.55	2.34	19.94	2.43	21.34	2.52	22.34	2.55	24.12	2.59	25.52	2.65
		115	18.06	2.43	19.45	2.52	20.85	2.61	21.86	2.64	23.64	2.69	25.03	2.75
		118	17.77	2.48	19.16	2.57	20.56	2.67	21.56	2.70	23.34	2.75	24.74	2.81
		122	17.67	2.55	19.07	2.65	20.46	2.74	21.47	2.78	23.25	2.83	24.64	2.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 174: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 12	-4	23.96	1.36	25.45	1.41	26.94	1.46	28.02	1.48	29.92	1.51	31.41	1.54
		0	23.95	1.38	25.44	1.43	26.93	1.48	28.00	1.49	29.90	1.52	31.39	1.55
		5	23.93	1.40	25.42	1.45	26.90	1.50	27.98	1.52	29.88	1.55	31.36	1.58
		10	23.91	1.42	25.40	1.47	26.88	1.52	27.96	1.54	29.85	1.57	31.34	1.60
		14	23.89	1.44	25.38	1.49	26.86	1.55	27.93	1.56	29.83	1.59	31.31	1.62
		20	23.88	1.46	25.36	1.51	26.84	1.57	27.91	1.59	29.81	1.62	31.29	1.65
		25	23.86	1.48	25.34	1.53	26.82	1.59	27.89	1.61	29.79	1.64	31.27	1.67
		30	23.84	1.50	25.32	1.56	26.80	1.61	27.87	1.63	29.76	1.66	31.24	1.69
		35	23.82	1.52	25.30	1.58	26.78	1.63	27.85	1.65	29.74	1.68	31.22	1.72
		40	23.80	1.54	25.28	1.60	26.76	1.66	27.83	1.68	29.72	1.71	31.20	1.74
		45	23.79	1.56	25.26	1.62	26.74	1.68	27.81	1.70	29.69	1.73	31.17	1.76
		50	23.77	1.58	25.24	1.64	26.72	1.70	27.79	1.72	29.67	1.75	31.15	1.79
		55	23.75	1.60	25.22	1.66	26.70	1.72	27.76	1.74	29.65	1.78	31.12	1.81
		60	23.73	1.62	25.20	1.68	26.68	1.75	27.74	1.77	29.63	1.80	31.10	1.83
		65	23.71	1.65	25.19	1.71	26.66	1.77	27.72	1.79	29.60	1.82	31.08	1.86
		70	23.69	1.67	25.17	1.73	26.64	1.79	27.70	1.81	29.58	1.84	31.05	1.88
		75	23.12	1.76	24.59	1.82	26.06	1.89	27.12	1.91	29.00	1.94	30.46	1.98
		80	22.55	1.85	24.02	1.91	25.48	1.98	26.54	2.01	28.41	2.04	29.88	2.08
		85	21.99	1.94	23.45	2.01	24.91	2.08	25.96	2.10	27.83	2.14	29.29	2.19
		90	21.42	2.03	22.88	2.10	24.34	2.18	25.39	2.20	27.25	2.24	28.71	2.29
		95	20.81	2.12	22.26	2.19	23.71	2.27	24.38	2.30	26.61	2.34	28.06	2.39
		100	20.30	2.21	21.75	2.29	23.20	2.37	24.06	2.40	26.10	2.44	27.55	2.49
		105	19.80	2.30	21.25	2.38	22.70	2.47	23.74	2.49	25.60	2.54	27.05	2.59
		110	19.29	2.38	20.74	2.47	22.19	2.56	23.24	2.59	25.09	2.64	26.54	2.69
		115	18.78	2.47	20.23	2.57	21.68	2.66	22.73	2.69	24.58	2.74	26.03	2.79
		118	18.48	2.53	19.93	2.62	21.38	2.72	22.43	2.75	24.28	2.80	25.73	2.86
		122	18.38	2.60	19.83	2.70	21.28	2.79	22.32	2.83	24.18	2.88	25.63	2.94
	9 + 9 + 9	-4	24.89	1.38	26.43	1.43	27.98	1.49	29.09	1.50	31.07	1.53	32.61	1.56
		0	24.87	1.40	26.42	1.45	27.96	1.50	29.08	1.52	31.05	1.55	32.60	1.58
		5	24.85	1.42	26.40	1.47	27.94	1.53	29.05	1.54	31.03	1.57	32.57	1.61
		10	24.83	1.44	26.38	1.50	27.92	1.55	29.03	1.57	31.00	1.60	32.54	1.63
		14	24.81	1.46	26.35	1.52	27.90	1.57	29.01	1.59	30.98	1.62	32.52	1.65
		20	24.79	1.49	26.33	1.54	27.87	1.60	28.99	1.61	30.95	1.64	32.49	1.68
		25	24.78	1.51	26.31	1.56	27.85	1.62	28.96	1.64	30.93	1.67	32.47	1.70
		30	24.76	1.53	26.29	1.58	27.83	1.64	28.94	1.66	30.91	1.69	32.44	1.72
		35	24.74	1.55	26.27	1.60	27.81	1.66	28.92	1.68	30.88	1.71	32.42	1.75
		40	24.72	1.57	26.25	1.63	27.79	1.69	28.90	1.71	30.86	1.74	32.40	1.77
		45	24.70	1.59	26.23	1.65	27.77	1.71	28.88	1.73	30.84	1.76	32.37	1.80
		50	24.68	1.61	26.21	1.67	27.75	1.73	28.85	1.75	30.81	1.78	32.35	1.82
		55	24.66	1.63	26.19	1.69	27.73	1.75	28.83	1.77	30.79	1.81	32.32	1.84
		60	24.64	1.65	26.17	1.71	27.70	1.78	28.81	1.80	30.77	1.83	32.30	1.87
		65	24.62	1.67	26.15	1.74	27.68	1.80	28.79	1.82	30.74	1.85	32.27	1.89
		70	24.61	1.70	26.13	1.76	27.66	1.82	28.77	1.84	30.72	1.88	32.25	1.91
		75	24.01	1.79	25.54	1.85	27.06	1.92	28.16	1.94	30.11	1.98	31.64	2.02
		80	23.42	1.88	24.94	1.95	26.46	2.02	27.56	2.04	29.50	2.08	31.02	2.12
		85	22.83	1.97	24.35	2.04	25.87	2.12	26.96	2.14	28.90	2.18	30.42	2.22
		90	22.25	2.06	23.76	2.14	25.27	2.21	26.37	2.24	28.30	2.28	29.81	2.33
		95	21.61	2.15	23.12	2.23	24.62	2.31	25.31	2.34	27.63	2.38	29.14	2.43
		100	21.08	2.24	22.59	2.33	24.10	2.41	24.98	2.44	27.11	2.48	28.61	2.53
		105	20.56	2.34	22.06	2.42	23.57	2.51	24.66	2.54	26.58	2.59	28.09	2.64
		110	20.03	2.43	21.54	2.52	23.04	2.61	24.13	2.64	26.05	2.69	27.56	2.74
		115	19.51	2.52	21.01	2.61	22.52	2.71	23.60	2.74	25.53	2.79	27.03	2.84
		118	19.19	2.57	20.70	2.67	22.20	2.76	23.29	2.80	25.21	2.85	26.72	2.91
		122	19.08	2.65	20.59	2.74	22.10	2.84	23.18	2.88	25.11	2.93	26.61	2.99

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 175: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 12	-4	25.81	1.41	27.41	1.47	29.01	1.52	30.17	1.54	32.22	1.57	33.82	1.60
		0	25.79	1.43	27.40	1.48	29.00	1.54	30.15	1.55	32.20	1.58	33.80	1.61
		5	25.77	1.45	27.37	1.51	28.97	1.56	30.13	1.58	32.17	1.61	33.77	1.64
		10	25.75	1.47	27.35	1.53	28.95	1.58	30.11	1.60	32.15	1.63	33.75	1.66
		14	25.73	1.50	27.33	1.55	28.93	1.61	30.08	1.63	32.13	1.66	33.72	1.69
		20	25.71	1.52	27.31	1.57	28.91	1.63	30.06	1.65	32.10	1.68	33.70	1.71
		25	25.69	1.54	27.29	1.60	28.88	1.65	30.04	1.67	32.08	1.70	33.67	1.74
		30	25.67	1.56	27.27	1.62	28.86	1.68	30.01	1.70	32.05	1.73	33.65	1.76
		35	25.65	1.58	27.25	1.64	28.84	1.70	29.99	1.72	32.03	1.75	33.62	1.79
		40	25.63	1.60	27.23	1.66	28.82	1.72	29.97	1.74	32.00	1.78	33.59	1.81
		45	25.62	1.62	27.21	1.68	28.80	1.75	29.95	1.77	31.98	1.80	33.57	1.83
		50	25.60	1.65	27.19	1.71	28.77	1.77	29.92	1.79	31.95	1.82	33.54	1.86
		55	25.58	1.67	27.16	1.73	28.75	1.79	29.90	1.81	31.93	1.85	33.52	1.88
		60	25.56	1.69	27.14	1.75	28.73	1.81	29.88	1.84	31.90	1.87	33.49	1.91
		65	25.54	1.71	27.12	1.77	28.71	1.84	29.85	1.86	31.88	1.89	33.47	1.93
		70	25.52	1.73	27.10	1.80	28.69	1.86	29.83	1.88	31.86	1.92	33.44	1.96
		75	24.90	1.83	26.48	1.89	28.06	1.96	29.21	1.98	31.23	2.02	32.81	2.06
		80	24.29	1.92	25.87	1.99	27.44	2.06	28.58	2.09	30.60	2.12	32.17	2.17
		85	23.68	2.01	25.25	2.09	26.83	2.16	27.96	2.19	29.97	2.23	31.55	2.27
		90	23.07	2.11	24.64	2.18	26.21	2.26	27.34	2.29	29.35	2.33	30.92	2.38
		95	22.41	2.20	23.97	2.28	25.53	2.36	26.25	2.39	28.66	2.44	30.22	2.48
		100	21.87	2.29	23.43	2.38	24.99	2.46	25.91	2.49	28.11	2.54	29.67	2.59
		105	21.32	2.39	22.88	2.47	24.44	2.56	25.57	2.59	27.56	2.64	29.13	2.70
		110	20.77	2.48	22.34	2.57	23.90	2.66	25.02	2.70	27.02	2.75	28.58	2.80
		115	20.23	2.57	21.79	2.67	23.35	2.76	24.48	2.80	26.47	2.85	28.03	2.91
		118	19.90	2.63	21.46	2.73	23.02	2.82	24.15	2.86	26.15	2.91	27.71	2.97
		122	19.79	2.70	21.35	2.80	22.91	2.91	24.04	2.94	26.04	2.99	27.60	3.05
	9 + 9 + 12	-4	27.65	1.48	29.37	1.53	31.09	1.59	32.33	1.61	34.52	1.64	36.24	1.67
		0	27.64	1.50	29.35	1.55	31.07	1.61	32.31	1.63	34.50	1.66	36.22	1.69
		5	27.61	1.52	29.33	1.58	31.04	1.63	32.28	1.65	34.47	1.68	36.19	1.72
		10	27.59	1.54	29.31	1.60	31.02	1.66	32.26	1.68	34.45	1.71	36.16	1.74
		14	27.57	1.57	29.28	1.62	31.00	1.68	32.23	1.70	34.42	1.73	36.13	1.77
		20	27.55	1.59	29.26	1.65	30.97	1.71	32.21	1.73	34.39	1.76	36.10	1.79
		25	27.53	1.61	29.24	1.67	30.95	1.73	32.18	1.75	34.37	1.78	36.08	1.82
		30	27.51	1.63	29.22	1.69	30.92	1.75	32.16	1.78	34.34	1.81	36.05	1.84
		35	27.49	1.66	29.19	1.72	30.90	1.78	32.13	1.80	34.31	1.83	36.02	1.87
		40	27.47	1.68	29.17	1.74	30.88	1.80	32.11	1.82	34.29	1.86	35.99	1.90
		45	27.44	1.70	29.15	1.76	30.85	1.83	32.08	1.85	34.26	1.88	35.97	1.92
		50	27.42	1.72	29.13	1.79	30.83	1.85	32.06	1.87	34.24	1.91	35.94	1.95
		55	27.40	1.75	29.10	1.81	30.81	1.88	32.04	1.90	34.21	1.93	35.91	1.97
		60	27.38	1.77	29.08	1.83	30.78	1.90	32.01	1.92	34.18	1.96	35.88	2.00
		65	27.36	1.79	29.06	1.86	30.76	1.92	31.99	1.95	34.16	1.98	35.86	2.02
		70	27.34	1.81	29.04	1.88	30.74	1.95	31.96	1.97	34.13	2.01	35.83	2.05
		75	26.68	1.91	28.38	1.98	30.07	2.05	31.29	2.08	33.46	2.12	35.15	2.16
		80	26.02	2.01	27.71	2.08	29.40	2.16	30.62	2.18	32.78	2.22	34.47	2.27
		85	25.37	2.11	27.06	2.18	28.74	2.26	29.96	2.29	32.11	2.33	33.80	2.38
		90	24.72	2.20	26.40	2.29	28.08	2.37	29.30	2.40	31.44	2.44	33.13	2.49
		95	24.01	2.30	25.68	2.39	27.36	2.47	28.13	2.50	30.70	2.55	32.38	2.60
		100	23.43	2.40	25.10	2.49	26.77	2.58	27.76	2.61	30.12	2.66	31.79	2.71
		105	22.84	2.50	24.52	2.59	26.19	2.68	27.40	2.71	29.53	2.77	31.21	2.82
		110	22.26	2.60	23.93	2.69	25.60	2.79	26.81	2.82	28.95	2.87	30.62	2.93
		115	21.67	2.69	23.35	2.79	25.02	2.89	26.23	2.93	28.36	2.98	30.04	3.04
		118	21.32	2.75	22.99	2.85	24.67	2.96	25.88	2.99	28.01	3.05	29.69	3.11
		122	21.21	2.83	22.88	2.93	24.55	3.04	25.76	3.08	27.90	3.13	29.57	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 176: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 15	-4	28.57	1.52	30.35	1.57	32.12	1.63	33.40	1.65	35.67	1.68	37.45	1.71
		0	28.56	1.53	30.33	1.59	32.10	1.65	33.39	1.67	35.65	1.70	37.43	1.73
		5	28.53	1.56	30.31	1.61	32.08	1.67	33.36	1.69	35.62	1.72	37.39	1.76
		10	28.51	1.58	30.28	1.64	32.05	1.70	33.33	1.72	35.60	1.75	37.37	1.79
		14	28.49	1.60	30.26	1.66	32.03	1.72	33.31	1.74	35.57	1.78	37.34	1.81
		20	28.47	1.63	30.24	1.69	32.00	1.75	33.28	1.77	35.54	1.80	37.31	1.84
		25	28.45	1.65	30.21	1.71	31.98	1.77	33.26	1.79	35.51	1.83	37.28	1.86
		30	28.42	1.67	30.19	1.73	31.96	1.80	33.23	1.82	35.49	1.85	37.25	1.89
		35	28.40	1.70	30.17	1.76	31.93	1.82	33.20	1.84	35.46	1.88	37.22	1.92
		40	28.38	1.72	30.14	1.78	31.91	1.85	33.18	1.87	35.43	1.90	37.19	1.94
		45	28.36	1.74	30.12	1.81	31.88	1.87	33.15	1.89	35.40	1.93	37.17	1.97
		50	28.34	1.77	30.10	1.83	31.86	1.90	33.13	1.92	35.38	1.95	37.14	1.99
		55	28.32	1.79	30.07	1.85	31.83	1.92	33.10	1.94	35.35	1.98	37.11	2.02
		60	28.29	1.81	30.05	1.88	31.81	1.95	33.08	1.97	35.32	2.01	37.08	2.05
		65	28.27	1.83	30.03	1.90	31.78	1.97	33.05	1.99	35.30	2.03	37.05	2.07
		70	28.25	1.86	30.01	1.93	31.76	2.00	33.03	2.02	35.27	2.06	37.02	2.10
		75	27.57	1.96	29.32	2.03	31.07	2.10	32.34	2.13	34.57	2.17	36.32	2.21
		80	26.89	2.06	28.64	2.13	30.38	2.21	31.64	2.24	33.87	2.28	35.62	2.32
		85	26.22	2.16	27.96	2.24	29.70	2.32	30.96	2.35	33.18	2.39	34.93	2.44
		90	25.54	2.26	27.28	2.34	29.02	2.43	30.27	2.45	32.49	2.50	34.23	2.55
		95	24.81	2.36	26.54	2.44	28.27	2.53	29.06	2.56	31.73	2.61	33.46	2.66
		100	24.21	2.46	25.94	2.55	27.67	2.64	28.69	2.67	31.12	2.72	32.85	2.78
		105	23.60	2.56	25.33	2.65	27.06	2.75	28.31	2.78	30.52	2.83	32.25	2.89
		110	23.00	2.66	24.73	2.76	26.46	2.86	27.71	2.89	29.91	2.94	31.64	3.00
		115	22.40	2.76	24.12	2.86	25.85	2.96	27.10	3.00	29.31	3.06	31.04	3.12
		118	22.03	2.82	23.76	2.92	25.49	3.03	26.74	3.06	28.95	3.12	30.68	3.18
		122	21.91	2.90	23.64	3.01	25.37	3.12	26.62	3.15	28.83	3.21	30.55	3.27
	7 + 12 + 12	-4	28.57	1.52	30.35	1.57	32.12	1.63	33.40	1.65	35.67	1.68	37.45	1.71
		0	28.56	1.53	30.33	1.59	32.10	1.65	33.39	1.67	35.65	1.70	37.43	1.73
		5	28.53	1.56	30.31	1.61	32.08	1.67	33.36	1.69	35.62	1.72	37.39	1.76
		10	28.51	1.58	30.28	1.64	32.05	1.70	33.33	1.72	35.60	1.75	37.37	1.79
		14	28.49	1.60	30.26	1.66	32.03	1.72	33.31	1.74	35.57	1.78	37.34	1.81
		20	28.47	1.63	30.24	1.69	32.00	1.75	33.28	1.77	35.54	1.80	37.31	1.84
		25	28.45	1.65	30.21	1.71	31.98	1.77	33.26	1.79	35.51	1.83	37.28	1.86
		30	28.42	1.67	30.19	1.73	31.96	1.80	33.23	1.82	35.49	1.85	37.25	1.89
		35	28.40	1.70	30.17	1.76	31.93	1.82	33.20	1.84	35.46	1.88	37.22	1.92
		40	28.38	1.72	30.14	1.78	31.91	1.85	33.18	1.87	35.43	1.90	37.19	1.94
		45	28.36	1.74	30.12	1.81	31.88	1.87	33.15	1.89	35.40	1.93	37.17	1.97
		50	28.34	1.77	30.10	1.83	31.86	1.90	33.13	1.92	35.38	1.95	37.14	1.99
		55	28.32	1.79	30.07	1.85	31.83	1.92	33.10	1.94	35.35	1.98	37.11	2.02
		60	28.29	1.81	30.05	1.88	31.81	1.95	33.08	1.97	35.32	2.01	37.08	2.05
		65	28.27	1.83	30.03	1.90	31.78	1.97	33.05	1.99	35.30	2.03	37.05	2.07
		70	28.25	1.86	30.01	1.93	31.76	2.00	33.03	2.02	35.27	2.06	37.02	2.10
		75	27.57	1.96	29.32	2.03	31.07	2.10	32.34	2.13	34.57	2.17	36.32	2.21
		80	26.89	2.06	28.64	2.13	30.38	2.21	31.64	2.24	33.87	2.28	35.62	2.32
		85	26.22	2.16	27.96	2.24	29.70	2.32	30.96	2.35	33.18	2.39	34.93	2.44
		90	25.54	2.26	27.28	2.34	29.02	2.43	30.27	2.45	32.49	2.50	34.23	2.55
		95	24.81	2.36	26.54	2.44	28.27	2.53	29.06	2.56	31.73	2.61	33.46	2.66
		100	24.21	2.46	25.94	2.55	27.67	2.64	28.69	2.67	31.12	2.72	32.85	2.78
		105	23.60	2.56	25.33	2.65	27.06	2.75	28.31	2.78	30.52	2.83	32.25	2.89
		110	23.00	2.66	24.73	2.76	26.46	2.86	27.71	2.89	29.91	2.94	31.64	3.00
		115	22.40	2.76	24.12	2.86	25.85	2.96	27.10	3.00	29.31	3.06	31.04	3.12
		118	22.03	2.82	23.76	2.92	25.49	3.03	26.74	3.06	28.95	3.12	30.68	3.18
		122	21.91	2.90	23.64	3.01	25.37	3.12	26.62	3.15	28.83	3.21	30.55	3.27

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 177: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	9 + 9 + 15	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 178: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 12	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	7 + 9 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 179: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 15	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	9 + 9 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 180: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 15	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	12 + 12 + 12	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 181: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	7 + 7 + 24	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 182: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	9 + 15 + 15	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 183: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 12 + 15	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	7 + 9 + 24	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 184: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 15 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	9 + 9 + 24*	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

Table 185: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 15 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	12 + 12 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
70		29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15	
75		28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26	
80		27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38	
85		27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50	
90		26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61	
95		25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73	
100		24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84	
105		24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96	
110		23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07	
115		23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19	
118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26		
122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35		

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 186: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 15 + 15	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	7 + 12 + 24*	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

Table 187: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 18 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	9 + 12 + 24*	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

Table 188: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 18 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	12 + 15 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 189: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 15 + 24*	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	9 + 15 + 24*	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 190: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 12 + 24*	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35
	12 + 18 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
		122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29	31.54	3.35

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

Table 191: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	15 + 15 + 18	-4	29.49	1.55	31.33	1.61	33.16	1.67	34.48	1.69	36.82	1.72	38.65	1.75
		0	29.48	1.57	31.31	1.63	33.14	1.69	34.46	1.71	36.80	1.74	38.63	1.77
		5	29.45	1.59	31.28	1.65	33.11	1.71	34.43	1.73	36.77	1.77	38.60	1.80
		10	29.43	1.62	31.26	1.68	33.09	1.74	34.41	1.76	36.74	1.79	38.57	1.83
		14	29.41	1.64	31.24	1.70	33.06	1.76	34.38	1.78	36.71	1.82	38.54	1.85
		20	29.39	1.67	31.21	1.73	33.04	1.79	34.35	1.81	36.69	1.84	38.51	1.88
		25	29.36	1.69	31.19	1.75	33.01	1.82	34.33	1.84	36.66	1.87	38.48	1.91
		30	29.34	1.71	31.16	1.78	32.99	1.84	34.30	1.86	36.63	1.90	38.45	1.93
		35	29.32	1.74	31.14	1.80	32.96	1.87	34.28	1.89	36.60	1.92	38.42	1.96
		40	29.30	1.76	31.12	1.82	32.94	1.89	34.25	1.91	36.57	1.95	38.39	1.99
		45	29.27	1.78	31.09	1.85	32.91	1.92	34.22	1.94	36.55	1.97	38.36	2.01
		50	29.25	1.81	31.07	1.87	32.89	1.94	34.20	1.96	36.52	2.00	38.34	2.04
		55	29.23	1.83	31.04	1.90	32.86	1.97	34.17	1.99	36.49	2.03	38.31	2.07
		60	29.21	1.85	31.02	1.92	32.83	1.99	34.14	2.02	36.46	2.05	38.28	2.09
		65	29.18	1.88	31.00	1.95	32.81	2.02	34.12	2.04	36.43	2.08	38.25	2.12
		70	29.16	1.90	30.97	1.97	32.78	2.04	34.09	2.07	36.41	2.11	38.22	2.15
		75	28.46	2.00	30.27	2.08	32.07	2.15	33.38	2.18	35.69	2.22	37.49	2.26
		80	27.76	2.11	29.56	2.18	31.36	2.26	32.66	2.29	34.97	2.33	36.77	2.38
		85	27.06	2.21	28.86	2.29	30.66	2.37	31.96	2.40	34.25	2.45	36.05	2.50
		90	26.37	2.31	28.16	2.40	29.95	2.48	31.25	2.51	33.54	2.56	35.33	2.61
		95	25.61	2.41	27.40	2.50	29.18	2.59	30.00	2.62	32.75	2.67	34.53	2.73
		100	24.99	2.52	26.77	2.61	28.56	2.70	29.61	2.74	32.13	2.79	33.91	2.84
		105	24.37	2.62	26.15	2.72	27.93	2.81	29.22	2.85	31.50	2.90	33.29	2.96
		110	23.74	2.72	25.53	2.82	27.31	2.93	28.60	2.96	30.88	3.01	32.66	3.07
		115	23.12	2.83	24.90	2.93	26.69	3.04	27.98	3.07	30.26	3.13	32.04	3.19
		118	22.74	2.89	24.53	2.99	26.31	3.10	27.60	3.14	29.88	3.20	31.67	3.26
				122	22.62	2.97	24.40	3.08	26.19	3.19	27.48	3.23	29.76	3.29
Four (4) Mixed Indoor Units	7 + 7 + 7 + 9	-4	27.65	1.41	29.37	1.47	31.09	1.52	32.33	1.54	34.52	1.57	36.24	1.60
		0	27.64	1.43	29.35	1.48	31.07	1.54	32.31	1.55	34.50	1.58	36.22	1.61
		5	27.61	1.45	29.33	1.51	31.04	1.56	32.28	1.58	34.47	1.61	36.19	1.64
		10	27.59	1.47	29.31	1.53	31.02	1.58	32.26	1.60	34.45	1.63	36.16	1.66
		14	27.57	1.50	29.28	1.55	31.00	1.61	32.23	1.63	34.42	1.66	36.13	1.69
		20	27.55	1.52	29.26	1.57	30.97	1.63	32.21	1.65	34.39	1.68	36.10	1.71
		25	27.53	1.54	29.24	1.60	30.95	1.65	32.18	1.67	34.37	1.70	36.08	1.74
		30	27.51	1.56	29.22	1.62	30.92	1.68	32.16	1.70	34.34	1.73	36.05	1.76
		35	27.49	1.58	29.19	1.64	30.90	1.70	32.13	1.72	34.31	1.75	36.02	1.79
		40	27.47	1.60	29.17	1.66	30.88	1.72	32.11	1.74	34.29	1.78	35.99	1.81
		45	27.44	1.62	29.15	1.68	30.85	1.75	32.08	1.77	34.26	1.80	35.97	1.83
		50	27.42	1.65	29.13	1.71	30.83	1.77	32.06	1.79	34.24	1.82	35.94	1.86
		55	27.40	1.67	29.10	1.73	30.81	1.79	32.04	1.81	34.21	1.85	35.91	1.88
		60	27.38	1.69	29.08	1.75	30.78	1.81	32.01	1.84	34.18	1.87	35.88	1.91
		65	27.36	1.71	29.06	1.77	30.76	1.84	31.99	1.86	34.16	1.89	35.86	1.93
		70	27.34	1.73	29.04	1.80	30.74	1.86	31.96	1.88	34.13	1.92	35.83	1.96
		75	26.68	1.83	28.38	1.89	30.07	1.96	31.29	1.98	33.46	2.02	35.15	2.06
		80	26.02	1.92	27.71	1.99	29.40	2.06	30.62	2.09	32.78	2.12	34.47	2.17
		85	25.37	2.01	27.06	2.09	28.74	2.16	29.96	2.19	32.11	2.23	33.80	2.27
		90	24.72	2.11	26.40	2.18	28.08	2.26	29.30	2.29	31.44	2.33	33.13	2.38
		95	24.01	2.20	25.68	2.28	27.36	2.36	28.13	2.39	30.70	2.44	32.38	2.48
		100	23.43	2.29	25.10	2.38	26.77	2.46	27.76	2.49	30.12	2.54	31.79	2.59
		105	22.84	2.39	24.52	2.47	26.19	2.56	27.40	2.59	29.53	2.64	31.21	2.70
		110	22.26	2.48	23.93	2.57	25.60	2.66	26.81	2.70	28.95	2.75	30.62	2.80
		115	21.67	2.57	23.35	2.67	25.02	2.76	26.23	2.80	28.36	2.85	30.04	2.91
		118	21.32	2.63	22.99	2.73	24.67	2.82	25.88	2.86	28.01	2.91	29.69	2.97
				122	21.21	2.70	22.88	2.80	24.55	2.91	25.76	2.94	27.90	2.99

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 192: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 9	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 7 + 7 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 193: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 9	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 7 + 9 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 194: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 9 + 9	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 9 + 9 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 195: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 7 + 12 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 196: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 7 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	9 + 9 + 9 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 197: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 9 + 12 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 198: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 7 + 12 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 199: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 9 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	9 + 9 + 12 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 200: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 9 + 12 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 201: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 12 + 12 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 7 + 12 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 202: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 7 + 24*	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	9 + 9 + 9 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

Table 203: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 12 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	9 + 12 + 12 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 204: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 12 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 9 + 15 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 205: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 12 + 12 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	7 + 7 + 9 + 24*	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

*The indoor unit must be non-ducted type.

MULTI F LMU36CHV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 206: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 15 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	9 + 9 + 12 + 18	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 207: LMU36CHV Cooling Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
			68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 15 + 15	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20
	12 + 12 + 12 + 12	-4	29.49	1.48	31.33	1.53	33.16	1.59	34.48	1.61	36.82	1.64	38.65	1.67
		0	29.48	1.50	31.31	1.55	33.14	1.61	34.46	1.63	36.80	1.66	38.63	1.69
		5	29.45	1.52	31.28	1.58	33.11	1.63	34.43	1.65	36.77	1.68	38.60	1.72
		10	29.43	1.54	31.26	1.60	33.09	1.66	34.41	1.68	36.74	1.71	38.57	1.74
		14	29.41	1.57	31.24	1.62	33.06	1.68	34.38	1.70	36.71	1.73	38.54	1.77
		20	29.39	1.59	31.21	1.65	33.04	1.71	34.35	1.73	36.69	1.76	38.51	1.79
		25	29.36	1.61	31.19	1.67	33.01	1.73	34.33	1.75	36.66	1.78	38.48	1.82
		30	29.34	1.63	31.16	1.69	32.99	1.76	34.30	1.78	36.63	1.81	38.45	1.85
		35	29.32	1.66	31.14	1.72	32.96	1.78	34.28	1.80	36.60	1.83	38.42	1.87
		40	29.30	1.68	31.12	1.74	32.94	1.80	34.25	1.82	36.57	1.86	38.39	1.90
		45	29.27	1.70	31.09	1.76	32.91	1.83	34.22	1.85	36.55	1.88	38.36	1.92
		50	29.25	1.72	31.07	1.79	32.89	1.85	34.20	1.87	36.52	1.91	38.34	1.95
		55	29.23	1.75	31.04	1.81	32.86	1.88	34.17	1.90	36.49	1.93	38.31	1.97
		60	29.21	1.77	31.02	1.83	32.83	1.90	34.14	1.92	36.46	1.96	38.28	2.00
		65	29.18	1.79	31.00	1.86	32.81	1.92	34.12	1.95	36.43	1.98	38.25	2.02
		70	29.16	1.81	30.97	1.88	32.78	1.95	34.09	1.97	36.41	2.01	38.22	2.05
		75	28.46	1.91	30.27	1.98	32.07	2.05	33.38	2.08	35.69	2.12	37.49	2.16
		80	27.76	2.01	29.56	2.08	31.36	2.16	32.66	2.18	34.97	2.23	36.77	2.27
		85	27.06	2.11	28.86	2.18	30.66	2.26	31.96	2.29	34.25	2.33	36.05	2.38
		90	26.37	2.21	28.16	2.29	29.95	2.37	31.25	2.40	33.54	2.44	35.33	2.49
		95	25.61	2.30	27.40	2.39	29.18	2.47	30.00	2.50	32.75	2.55	34.53	2.60
		100	24.99	2.40	26.77	2.49	28.56	2.58	29.61	2.61	32.13	2.66	33.91	2.71
		105	24.37	2.50	26.15	2.59	27.93	2.69	29.22	2.72	31.50	2.77	33.29	2.82
		110	23.74	2.60	25.53	2.69	27.31	2.79	28.60	2.82	30.88	2.88	32.66	2.93
		115	23.12	2.69	24.90	2.79	26.69	2.90	27.98	2.93	30.26	2.98	32.04	3.04
		118	22.74	2.75	24.53	2.85	26.31	2.96	27.60	2.99	29.88	3.05	31.67	3.11
		122	22.62	2.83	24.40	2.94	26.19	3.04	27.48	3.08	29.76	3.14	31.54	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 208: LMU480HV Cooling Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 65 (135%)	-4	51.84	2.82	55.06	2.92	58.28	3.03	60.61	3.06	64.72	3.12	67.94	3.18
	0	51.81	2.85	55.03	2.95	58.25	3.06	60.57	3.09	64.68	3.15	67.90	3.22
	5	51.77	2.89	54.99	3.00	58.20	3.11	60.52	3.14	64.63	3.20	67.85	3.27
	10	51.73	2.94	54.94	3.04	58.16	3.15	60.48	3.19	64.58	3.25	67.79	3.32
	14	51.69	2.98	54.90	3.09	58.11	3.20	60.43	3.24	64.53	3.30	67.74	3.36
	20	51.65	3.02	54.86	3.13	58.07	3.25	60.38	3.28	64.48	3.35	67.69	3.41
	25	51.61	3.06	54.82	3.18	58.02	3.29	60.34	3.33	64.43	3.39	67.64	3.46
	30	51.57	3.11	54.78	3.22	57.98	3.34	60.29	3.38	64.38	3.44	67.59	3.51
	35	51.53	3.15	54.73	3.27	57.93	3.38	60.25	3.42	64.34	3.49	67.54	3.56
	40	51.49	3.19	54.69	3.31	57.89	3.43	60.20	3.47	64.29	3.53	67.48	3.61
	45	51.45	3.24	54.65	3.35	57.85	3.48	60.15	3.52	64.24	3.58	67.43	3.65
	50	51.42	3.28	54.61	3.40	57.80	3.52	60.11	3.56	64.19	3.63	67.38	3.70
	55	51.38	3.32	54.57	3.44	57.76	3.57	60.06	3.61	64.14	3.68	67.33	3.75
	60	51.34	3.36	54.52	3.49	57.71	3.61	60.02	3.66	64.09	3.72	67.28	3.80
	65	51.30	3.41	54.48	3.53	57.67	3.66	59.97	3.70	64.04	3.77	67.23	3.85
	70	51.26	3.45	54.44	3.58	57.62	3.71	59.92	3.75	63.99	3.82	67.17	3.90
	75	50.02	3.64	53.20	3.77	56.37	3.91	58.67	3.95	62.73	4.03	65.90	4.11
	80	48.79	3.82	51.96	3.96	55.13	4.11	57.41	4.15	61.46	4.23	64.63	4.32
	85	47.57	4.01	50.73	4.15	53.89	4.31	56.17	4.36	60.21	4.44	63.37	4.53
	90	46.35	4.19	49.50	4.35	52.65	4.51	54.93	4.56	58.95	4.64	62.11	4.74
	95	45.02	4.38	48.15	4.54	51.29	4.71	52.73	4.76	57.56	4.85	60.70	4.95
	100	43.92	4.57	47.06	4.73	50.19	4.91	52.05	4.96	56.47	5.06	59.60	5.16
	105	42.83	4.75	45.96	4.93	49.10	5.11	51.36	5.16	55.37	5.26	58.51	5.37
	110	41.73	4.94	44.87	5.12	48.00	5.31	50.27	5.37	54.27	5.47	57.41	5.58
	115	40.63	5.12	43.77	5.31	46.91	5.51	49.17	5.57	53.18	5.67	56.31	5.79
	118	39.98	5.24	43.11	5.43	46.25	5.63	48.51	5.69	52.52	5.80	55.66	5.91
Non-Ducted Indoor Units 62 (130%)	122	39.76	5.39	42.89	5.58	46.03	5.79	48.29	5.85	52.30	5.96	55.44	6.08
	-4	51.02	2.72	54.18	2.82	57.35	2.92	59.64	2.96	63.69	3.01	66.86	3.07
	0	50.99	2.75	54.15	2.85	57.32	2.96	59.61	2.99	63.65	3.05	66.82	3.11
	5	50.95	2.80	54.11	2.90	57.27	3.00	59.56	3.04	63.60	3.10	66.76	3.16
	10	50.91	2.84	54.07	2.94	57.23	3.05	59.51	3.08	63.55	3.14	66.71	3.20
	14	50.87	2.88	54.03	2.98	57.19	3.09	59.47	3.13	63.50	3.19	66.66	3.25
	20	50.83	2.92	53.99	3.03	57.14	3.14	59.42	3.17	63.46	3.23	66.61	3.30
	25	50.79	2.96	53.94	3.07	57.10	3.18	59.38	3.22	63.41	3.28	66.56	3.34
	30	50.75	3.00	53.90	3.11	57.06	3.23	59.33	3.26	63.36	3.32	66.51	3.39
	35	50.71	3.04	53.86	3.16	57.01	3.27	59.29	3.31	63.31	3.37	66.46	3.44
	40	50.67	3.09	53.82	3.20	56.97	3.31	59.24	3.35	63.26	3.42	66.41	3.48
	45	50.63	3.13	53.78	3.24	56.92	3.36	59.20	3.40	63.21	3.46	66.36	3.53
	50	50.60	3.17	53.74	3.28	56.88	3.40	59.15	3.44	63.17	3.51	66.31	3.58
	55	50.56	3.21	53.70	3.33	56.84	3.45	59.10	3.49	63.12	3.55	66.26	3.62
	60	50.52	3.25	53.66	3.37	56.79	3.49	59.06	3.53	63.07	3.60	66.21	3.67
	65	50.48	3.29	53.61	3.41	56.75	3.54	59.01	3.58	63.02	3.64	66.15	3.72
	70	50.44	3.33	53.57	3.46	56.71	3.58	58.97	3.62	62.97	3.69	66.10	3.76
	75	49.23	3.51	52.35	3.64	55.48	3.77	57.73	3.82	61.73	3.89	64.85	3.97
	80	48.01	3.69	51.13	3.83	54.25	3.97	56.50	4.01	60.48	4.09	63.60	4.17
	85	46.81	3.87	49.92	4.01	53.03	4.16	55.27	4.21	59.25	4.29	62.36	4.37
	90	45.61	4.05	48.71	4.20	51.81	4.35	54.05	4.40	58.01	4.49	61.12	4.58
	95	44.30	4.23	47.39	4.39	50.47	4.55	51.89	4.60	56.65	4.69	59.73	4.78
	100	43.22	4.41	46.31	4.57	49.40	4.74	51.22	4.80	55.57	4.89	58.65	4.98
	105	42.14	4.59	45.23	4.76	48.32	4.93	50.55	4.99	54.49	5.08	57.58	5.19
	110	41.07	4.77	44.15	4.95	47.24	5.13	49.47	5.19	53.41	5.28	56.50	5.39
	115	39.99	4.95	43.07	5.13	46.16	5.32	48.39	5.38	52.33	5.48	55.42	5.59
	118	39.34	5.06	42.43	5.24	45.51	5.44	47.74	5.50	51.68	5.60	54.77	5.71
	122	39.12	5.20	42.21	5.39	45.30	5.59	47.52	5.66	51.47	5.76	54.55	5.88

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 209: LMU480HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 58 (120%)	-4	49.92	2.59	53.02	2.69	56.12	2.78	58.36	2.82	62.33	2.87	65.43	2.93
	0	49.90	2.62	53.00	2.72	56.09	2.81	58.33	2.85	62.29	2.90	65.39	2.96
	5	49.86	2.66	52.95	2.76	56.05	2.86	58.28	2.89	62.24	2.95	65.34	3.01
	10	49.82	2.70	52.91	2.80	56.01	2.90	58.24	2.94	62.19	2.99	65.29	3.05
	14	49.78	2.74	52.87	2.84	55.96	2.94	58.20	2.98	62.15	3.03	65.24	3.10
	20	49.74	2.78	52.83	2.88	55.92	2.99	58.15	3.02	62.10	3.08	65.19	3.14
	25	49.70	2.82	52.79	2.92	55.88	3.03	58.11	3.06	62.05	3.12	65.14	3.18
	30	49.67	2.86	52.75	2.96	55.83	3.07	58.06	3.11	62.00	3.17	65.09	3.23
	35	49.63	2.90	52.71	3.00	55.79	3.11	58.02	3.15	61.96	3.21	65.04	3.27
	40	49.59	2.94	52.67	3.05	55.75	3.16	57.97	3.19	61.91	3.25	64.99	3.32
	45	49.55	2.98	52.63	3.09	55.71	3.20	57.93	3.24	61.86	3.30	64.94	3.36
	50	49.51	3.02	52.59	3.13	55.66	3.24	57.88	3.28	61.81	3.34	64.89	3.41
	55	49.48	3.06	52.55	3.17	55.62	3.28	57.84	3.32	61.77	3.38	64.84	3.45
	60	49.44	3.10	52.51	3.21	55.58	3.33	57.80	3.36	61.72	3.43	64.79	3.50
	65	49.40	3.13	52.47	3.25	55.54	3.37	57.75	3.41	61.67	3.47	64.74	3.54
	70	49.36	3.17	52.43	3.29	55.49	3.41	57.71	3.45	61.62	3.51	64.69	3.58
	75	48.17	3.35	51.23	3.47	54.29	3.59	56.50	3.64	60.41	3.70	63.46	3.78
	80	46.99	3.52	50.04	3.65	53.09	3.78	55.29	3.82	59.19	3.89	62.24	3.97
	85	45.81	3.69	48.85	3.82	51.89	3.96	54.09	4.01	57.98	4.08	61.02	4.16
	90	44.63	3.86	47.67	4.00	50.70	4.15	52.89	4.19	56.77	4.27	59.81	4.36
	95	43.35	4.03	46.37	4.18	49.39	4.33	50.78	4.38	55.43	4.46	58.46	4.55
	100	42.30	4.20	45.32	4.36	48.34	4.51	50.12	4.57	54.38	4.65	57.40	4.75
	105	41.24	4.37	44.26	4.53	47.28	4.70	49.46	4.75	53.32	4.84	56.34	4.94
	110	40.19	4.54	43.21	4.71	46.23	4.88	48.41	4.94	52.27	5.03	55.29	5.13
	115	39.13	4.72	42.15	4.89	45.17	5.07	47.35	5.12	51.21	5.22	54.23	5.33
	118	38.50	4.82	41.52	4.99	44.54	5.18	46.72	5.24	50.58	5.33	53.60	5.44
Non-Ducted Indoor Units 53 (110%)	122	38.29	4.96	41.31	5.14	44.33	5.32	46.51	5.38	50.37	5.49	53.39	5.60
	-4	48.56	2.43	51.57	2.52	54.59	2.61	56.77	2.64	60.62	2.69	63.64	2.75
	0	48.53	2.46	51.54	2.55	54.56	2.64	56.74	2.67	60.59	2.72	63.60	2.78
	5	48.49	2.50	51.50	2.59	54.51	2.68	56.69	2.71	60.54	2.77	63.55	2.82
	10	48.45	2.54	51.46	2.63	54.47	2.72	56.65	2.75	60.49	2.81	63.50	2.86
	14	48.42	2.57	51.42	2.67	54.43	2.76	56.60	2.80	60.44	2.85	63.45	2.90
	20	48.38	2.61	51.38	2.70	54.39	2.80	56.56	2.84	60.40	2.89	63.40	2.95
	25	48.34	2.65	51.35	2.74	54.35	2.84	56.52	2.88	60.35	2.93	63.35	2.99
	30	48.31	2.68	51.31	2.78	54.31	2.88	56.47	2.92	60.31	2.97	63.31	3.03
	35	48.27	2.72	51.27	2.82	54.26	2.92	56.43	2.96	60.26	3.01	63.26	3.07
	40	48.23	2.76	51.23	2.86	54.22	2.96	56.39	3.00	60.21	3.05	63.21	3.11
	45	48.20	2.79	51.19	2.90	54.18	3.00	56.34	3.04	60.17	3.09	63.16	3.16
	50	48.16	2.83	51.15	2.93	54.14	3.04	56.30	3.08	60.12	3.13	63.11	3.20
	55	48.12	2.87	51.11	2.97	54.10	3.08	56.26	3.12	60.08	3.17	63.06	3.24
	60	48.08	2.90	51.07	3.01	54.06	3.12	56.21	3.16	60.03	3.22	63.02	3.28
	65	48.05	2.94	51.03	3.05	54.02	3.16	56.17	3.20	59.98	3.26	62.97	3.32
	70	48.01	2.98	50.99	3.09	53.97	3.20	56.13	3.24	59.94	3.30	62.92	3.36
	75	46.86	3.14	49.83	3.25	52.80	3.37	54.95	3.41	58.75	3.48	61.73	3.55
	80	45.70	3.30	48.67	3.42	51.63	3.55	53.78	3.59	57.57	3.65	60.53	3.73
	85	44.55	3.46	47.51	3.59	50.47	3.72	52.61	3.76	56.39	3.83	59.35	3.91
	90	43.41	3.62	46.36	3.75	49.31	3.89	51.45	3.94	55.22	4.01	58.17	4.09
	95	42.17	3.78	45.10	3.92	48.04	4.06	49.39	4.11	53.92	4.19	56.86	4.27
	100	41.14	3.94	44.08	4.09	47.02	4.24	48.75	4.28	52.89	4.36	55.83	4.45
	105	40.11	4.10	43.05	4.25	45.99	4.41	48.11	4.46	51.86	4.54	54.80	4.63
	110	39.09	4.26	42.02	4.42	44.96	4.58	47.08	4.63	50.84	4.72	53.77	4.82
	115	38.06	4.42	41.00	4.59	43.93	4.75	46.06	4.81	49.81	4.90	52.75	5.00
	118	37.44	4.52	40.38	4.69	43.32	4.86	45.44	4.91	49.19	5.01	52.13	5.11
	122	37.24	4.65	40.18	4.82	43.11	5.00	45.24	5.05	48.99	5.15	51.93	5.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 210: LMU480HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h/[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 48 (100%)	-4	47.19	2.27	50.12	2.35	53.05	2.44	55.17	2.47	58.91	2.52	61.84	2.57
	0	47.16	2.30	50.09	2.38	53.02	2.47	55.14	2.50	58.88	2.54	61.81	2.59
	5	47.13	2.33	50.05	2.42	52.98	2.51	55.09	2.54	58.83	2.58	61.76	2.64
	10	47.09	2.37	50.01	2.46	52.94	2.54	55.05	2.57	58.79	2.62	61.71	2.67
	14	47.05	2.40	49.98	2.49	52.90	2.58	55.01	2.61	58.74	2.66	61.67	2.71
	20	47.02	2.44	49.94	2.53	52.86	2.62	54.97	2.65	58.70	2.70	61.62	2.75
	25	46.98	2.47	49.90	2.56	52.82	2.66	54.93	2.69	58.65	2.74	61.57	2.79
	30	46.95	2.51	49.86	2.60	52.78	2.69	54.88	2.72	58.61	2.78	61.52	2.83
	35	46.91	2.54	49.82	2.63	52.74	2.73	54.84	2.76	58.56	2.81	61.48	2.87
	40	46.87	2.58	49.79	2.67	52.70	2.77	54.80	2.80	58.52	2.85	61.43	2.91
	45	46.84	2.61	49.75	2.71	52.66	2.80	54.76	2.84	58.47	2.89	61.38	2.95
	50	46.80	2.64	49.71	2.74	52.62	2.84	54.72	2.87	58.43	2.93	61.34	2.99
	55	46.77	2.68	49.67	2.78	52.58	2.88	54.67	2.91	58.38	2.97	61.29	3.03
	60	46.73	2.71	49.63	2.81	52.54	2.92	54.63	2.95	58.34	3.00	61.24	3.06
	65	46.70	2.75	49.60	2.85	52.50	2.95	54.59	2.99	58.30	3.04	61.20	3.10
	70	46.66	2.78	49.56	2.88	52.46	2.99	54.55	3.02	58.25	3.08	61.15	3.14
	75	45.54	2.93	48.43	3.04	51.32	3.15	53.41	3.19	57.10	3.25	59.99	3.31
	80	44.41	3.08	47.30	3.20	50.18	3.31	52.26	3.35	55.95	3.41	58.83	3.48
	85	43.30	3.23	46.18	3.35	49.05	3.47	51.13	3.51	54.81	3.58	57.68	3.65
	90	42.19	3.38	45.06	3.51	47.93	3.63	50.00	3.68	53.66	3.75	56.53	3.82
	95	40.98	3.53	43.84	3.66	46.69	3.80	48.00	3.84	52.40	3.91	55.25	3.99
	100	39.98	3.68	42.84	3.82	45.69	3.96	47.38	4.00	51.40	4.08	54.26	4.16
	105	38.98	3.83	41.84	3.97	44.69	4.12	46.76	4.17	50.40	4.24	53.26	4.33
	110	37.99	3.98	40.84	4.13	43.70	4.28	45.76	4.33	49.41	4.41	52.26	4.50
	115	36.99	4.13	39.84	4.29	42.70	4.44	44.76	4.49	48.41	4.58	51.26	4.67
	118	36.39	4.22	39.24	4.38	42.10	4.54	44.16	4.59	47.81	4.68	50.66	4.77
Non-Ducted Indoor Units 43 (90%)	122	36.19	4.34	39.05	4.50	41.90	4.67	43.96	4.72	47.61	4.81	50.46	4.91
	-4	42.27	1.98	44.90	2.06	47.53	2.13	49.42	2.16	52.78	2.20	55.40	2.24
	0	42.25	2.01	44.88	2.08	47.50	2.15	49.40	2.18	52.75	2.22	55.37	2.26
	5	42.22	2.04	44.84	2.11	47.46	2.19	49.35	2.21	52.70	2.26	55.33	2.30
	10	42.18	2.07	44.80	2.14	47.42	2.22	49.32	2.25	52.66	2.29	55.28	2.34
	14	42.15	2.10	44.77	2.17	47.39	2.25	49.28	2.28	52.62	2.32	55.24	2.37
	20	42.12	2.13	44.74	2.21	47.35	2.29	49.24	2.31	52.58	2.36	55.20	2.40
	25	42.09	2.16	44.70	2.24	47.32	2.32	49.20	2.35	52.54	2.39	55.16	2.44
	30	42.06	2.19	44.67	2.27	47.28	2.35	49.17	2.38	52.50	2.42	55.12	2.47
	35	42.02	2.22	44.63	2.30	47.24	2.38	49.13	2.41	52.46	2.46	55.07	2.51
	40	41.99	2.25	44.60	2.33	47.21	2.42	49.09	2.44	52.42	2.49	55.03	2.54
	45	41.96	2.28	44.57	2.36	47.17	2.45	49.05	2.48	52.38	2.52	54.99	2.57
	50	41.93	2.31	44.53	2.39	47.14	2.48	49.02	2.51	52.34	2.56	54.95	2.61
	55	41.90	2.34	44.50	2.42	47.10	2.51	48.98	2.54	52.30	2.59	54.91	2.64
	60	41.86	2.37	44.46	2.46	47.06	2.55	48.94	2.57	52.26	2.62	54.86	2.68
	65	41.83	2.40	44.43	2.49	47.03	2.58	48.90	2.61	52.22	2.66	54.82	2.71
	70	41.80	2.43	44.40	2.52	46.99	2.61	48.87	2.64	52.18	2.69	54.78	2.74
	75	40.79	2.56	43.38	2.65	45.97	2.75	47.84	2.78	51.15	2.83	53.74	2.89
	80	39.79	2.69	42.37	2.79	44.95	2.89	46.82	2.93	50.12	2.98	52.70	3.04
	85	38.79	2.82	41.37	2.93	43.94	3.03	45.80	3.07	49.10	3.13	51.67	3.19
	90	37.79	2.95	40.36	3.06	42.93	3.17	44.79	3.21	48.07	3.27	50.65	3.34
	95	36.71	3.08	39.27	3.20	41.83	3.31	43.00	3.35	46.94	3.42	49.50	3.48
	100	35.82	3.22	38.38	3.33	40.93	3.46	42.44	3.49	46.05	3.56	48.61	3.63
	105	34.92	3.35	37.48	3.47	40.04	3.60	41.89	3.64	45.15	3.71	47.71	3.78
	110	34.03	3.48	36.59	3.61	39.14	3.74	40.99	3.78	44.26	3.85	46.82	3.93
	115	33.14	3.61	35.69	3.74	38.25	3.88	40.10	3.92	43.37	4.00	45.92	4.08
	118	32.60	3.69	35.16	3.82	37.71	3.96	39.56	4.01	42.83	4.08	45.39	4.16
	122	32.42	3.79	34.98	3.93	37.54	4.07	39.38	4.12	42.65	4.20	45.21	4.28

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 211: LMU480HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 38 (80%)	-4	37.36	1.70	39.68	1.76	42.00	1.82	43.68	1.85	46.64	1.88	48.96	1.92
	0	37.34	1.72	39.66	1.78	41.98	1.84	43.65	1.87	46.61	1.90	48.93	1.94
	5	37.31	1.74	39.63	1.81	41.94	1.87	43.62	1.90	46.58	1.93	48.89	1.97
	10	37.28	1.77	39.59	1.83	41.91	1.90	43.58	1.92	46.54	1.96	48.86	2.00
	14	37.25	1.80	39.56	1.86	41.88	1.93	43.55	1.95	46.51	1.99	48.82	2.03
	20	37.22	1.82	39.53	1.89	41.85	1.96	43.52	1.98	46.47	2.02	48.78	2.06
	25	37.19	1.85	39.50	1.92	41.81	1.99	43.48	2.01	46.43	2.05	48.74	2.09
	30	37.17	1.87	39.47	1.94	41.78	2.01	43.45	2.04	46.40	2.07	48.71	2.12
	35	37.14	1.90	39.44	1.97	41.75	2.04	43.42	2.06	46.36	2.10	48.67	2.14
	40	37.11	1.93	39.41	2.00	41.72	2.07	43.38	2.09	46.33	2.13	48.63	2.17
	45	37.08	1.95	39.38	2.02	41.69	2.10	43.35	2.12	46.29	2.16	48.60	2.20
	50	37.05	1.98	39.35	2.05	41.65	2.12	43.32	2.15	46.26	2.19	48.56	2.23
	55	37.02	2.00	39.32	2.08	41.62	2.15	43.28	2.18	46.22	2.22	48.52	2.26
	60	37.00	2.03	39.29	2.10	41.59	2.18	43.25	2.20	46.19	2.25	48.48	2.29
	65	36.97	2.05	39.26	2.13	41.56	2.21	43.22	2.23	46.15	2.27	48.45	2.32
	70	36.94	2.08	39.23	2.16	41.53	2.23	43.18	2.26	46.12	2.30	48.41	2.35
	75	36.05	2.19	38.34	2.27	40.63	2.36	42.28	2.38	45.20	2.43	47.49	2.48
	80	35.16	2.30	37.44	2.39	39.73	2.48	41.38	2.50	44.29	2.55	46.57	2.60
	85	34.28	2.42	36.56	2.50	38.83	2.60	40.48	2.63	43.39	2.68	45.67	2.73
	90	33.40	2.53	35.67	2.62	37.94	2.72	39.58	2.75	42.48	2.80	44.76	2.86
	95	32.44	2.64	34.70	2.74	36.96	2.84	38.00	2.87	41.48	2.92	43.74	2.98
	100	31.65	2.75	33.91	2.85	36.17	2.96	37.51	2.99	40.69	3.05	42.95	3.11
	105	30.86	2.87	33.12	2.97	35.38	3.08	37.02	3.11	39.90	3.17	42.16	3.24
	110	30.07	2.98	32.33	3.09	34.59	3.20	36.23	3.24	39.11	3.30	41.37	3.36
	115	29.28	3.09	31.54	3.20	33.80	3.32	35.44	3.36	38.32	3.42	40.58	3.49
	118	28.81	3.16	31.07	3.27	33.33	3.39	34.96	3.43	37.85	3.50	40.11	3.57
	122	28.65	3.25	30.91	3.37	33.17	3.49	34.80	3.53	37.69	3.59	39.95	3.67
Non-Ducted Indoor Units 34 (70%)	-4	32.44	1.41	34.46	1.46	36.47	1.51	37.93	1.53	40.50	1.56	42.52	1.59
	0	32.43	1.42	34.44	1.48	36.45	1.53	37.91	1.55	40.48	1.58	42.49	1.61
	5	32.40	1.45	34.41	1.50	36.42	1.55	37.88	1.57	40.45	1.60	42.46	1.63
	10	32.37	1.47	34.39	1.52	36.40	1.58	37.85	1.60	40.42	1.63	42.43	1.66
	14	32.35	1.49	34.36	1.54	36.37	1.60	37.82	1.62	40.39	1.65	42.40	1.68
	20	32.33	1.51	34.33	1.57	36.34	1.62	37.79	1.64	40.36	1.67	42.36	1.71
	25	32.30	1.53	34.31	1.59	36.31	1.65	37.76	1.67	40.32	1.70	42.33	1.73
	30	32.28	1.55	34.28	1.61	36.28	1.67	37.73	1.69	40.29	1.72	42.30	1.75
	35	32.25	1.58	34.25	1.63	36.26	1.69	37.70	1.71	40.26	1.74	42.27	1.78
	40	32.23	1.60	34.23	1.65	36.23	1.72	37.67	1.73	40.23	1.77	42.23	1.80
	45	32.20	1.62	34.20	1.68	36.20	1.74	37.65	1.76	40.20	1.79	42.20	1.83
	50	32.18	1.64	34.18	1.70	36.17	1.76	37.62	1.78	40.17	1.81	42.17	1.85
	55	32.15	1.66	34.15	1.72	36.15	1.78	37.59	1.80	40.14	1.84	42.14	1.88
	60	32.13	1.68	34.12	1.74	36.12	1.81	37.56	1.83	40.11	1.86	42.10	1.90
	65	32.10	1.70	34.10	1.77	36.09	1.83	37.53	1.85	40.08	1.89	42.07	1.92
	70	32.08	1.72	34.07	1.79	36.06	1.85	37.50	1.87	40.05	1.91	42.04	1.95
	75	31.31	1.82	33.29	1.88	35.28	1.95	36.72	1.98	39.26	2.01	41.24	2.05
	80	30.53	1.91	32.52	1.98	34.50	2.05	35.93	2.08	38.46	2.12	40.45	2.16
	85	29.77	2.00	31.75	2.08	33.72	2.15	35.15	2.18	37.68	2.22	39.66	2.26
	90	29.00	2.10	30.98	2.17	32.95	2.25	34.37	2.28	36.89	2.32	38.87	2.37
	95	28.17	2.19	30.14	2.27	32.10	2.35	33.00	2.38	36.03	2.42	37.99	2.47
	100	27.49	2.28	29.45	2.37	31.41	2.45	32.57	2.48	35.34	2.53	37.30	2.58
	105	26.80	2.38	28.76	2.46	30.73	2.55	32.14	2.58	34.65	2.63	36.62	2.68
	110	26.12	2.47	28.08	2.56	30.04	2.65	31.46	2.68	33.97	2.73	35.93	2.79
	115	25.43	2.56	27.39	2.66	29.36	2.75	30.77	2.78	33.28	2.84	35.24	2.89
	118	25.02	2.62	26.98	2.71	28.94	2.81	30.36	2.85	32.87	2.90	34.83	2.96
	122	24.88	2.69	26.84	2.79	28.81	2.89	30.22	2.93	32.73	2.98	34.69	3.04

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 212: LMU480HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 29 (60%)	-4	28.51	1.18	30.28	1.22	32.05	1.26	33.33	1.28	35.59	1.30	37.36	1.33
	0	28.50	1.19	30.27	1.23	32.03	1.28	33.31	1.29	35.57	1.32	37.34	1.34
	5	28.47	1.21	30.24	1.25	32.01	1.30	33.29	1.31	35.54	1.34	37.31	1.36
	10	28.45	1.23	30.22	1.27	31.98	1.32	33.26	1.33	35.52	1.36	37.28	1.38
	14	28.43	1.24	30.19	1.29	31.96	1.34	33.23	1.35	35.49	1.38	37.26	1.40
	20	28.41	1.26	30.17	1.31	31.94	1.36	33.21	1.37	35.46	1.40	37.23	1.42
	25	28.39	1.28	30.15	1.33	31.91	1.37	33.18	1.39	35.44	1.42	37.20	1.45
	30	28.36	1.30	30.13	1.34	31.89	1.39	33.16	1.41	35.41	1.44	37.17	1.47
	35	28.34	1.32	30.10	1.36	31.86	1.41	33.13	1.43	35.38	1.46	37.14	1.49
	40	28.32	1.33	30.08	1.38	31.84	1.43	33.11	1.45	35.36	1.48	37.11	1.51
	45	28.30	1.35	30.06	1.40	31.81	1.45	33.08	1.47	35.33	1.50	37.09	1.53
	50	28.28	1.37	30.03	1.42	31.79	1.47	33.06	1.49	35.30	1.52	37.06	1.55
	55	28.26	1.39	30.01	1.44	31.76	1.49	33.03	1.51	35.27	1.54	37.03	1.57
	60	28.23	1.40	29.99	1.46	31.74	1.51	33.01	1.53	35.25	1.56	37.00	1.59
	65	28.21	1.42	29.96	1.47	31.72	1.53	32.98	1.55	35.22	1.57	36.97	1.61
	70	28.19	1.44	29.94	1.49	31.69	1.55	32.96	1.57	35.19	1.59	36.94	1.63
	75	27.51	1.52	29.26	1.57	31.00	1.63	32.27	1.65	34.50	1.68	36.24	1.71
	80	26.83	1.60	28.58	1.65	30.32	1.71	31.58	1.73	33.80	1.77	35.54	1.80
	85	26.16	1.67	27.90	1.73	29.64	1.80	30.89	1.82	33.11	1.85	34.85	1.89
	90	25.49	1.75	27.22	1.82	28.96	1.88	30.21	1.90	32.42	1.94	34.16	1.98
	95	24.76	1.83	26.48	1.90	28.21	1.96	29.00	1.99	31.66	2.02	33.38	2.07
	100	24.16	1.91	25.88	1.98	27.61	2.05	28.62	2.07	31.06	2.11	32.78	2.15
	105	23.55	1.98	25.28	2.06	27.00	2.13	28.25	2.16	30.45	2.20	32.18	2.24
	110	22.95	2.06	24.68	2.14	26.40	2.22	27.65	2.24	29.85	2.28	31.57	2.33
	115	22.35	2.14	24.07	2.22	25.80	2.30	27.04	2.33	29.25	2.37	30.97	2.42
	118	21.99	2.19	23.71	2.27	25.44	2.35	26.68	2.38	28.88	2.42	30.61	2.47
	122	21.86	2.25	23.59	2.33	25.31	2.42	26.56	2.44	28.76	2.49	30.49	2.54
Non-Ducted Indoor Units 24 (50%)	-4	23.60	0.89	25.06	0.92	26.53	0.95	27.58	0.96	29.46	0.98	30.92	1.00
	0	23.58	0.90	25.05	0.93	26.51	0.96	27.57	0.97	29.44	0.99	30.91	1.01
	5	23.56	0.91	25.03	0.95	26.49	0.98	27.55	0.99	29.42	1.01	30.88	1.03
	10	23.55	0.93	25.01	0.96	26.47	0.99	27.53	1.01	29.39	1.02	30.86	1.04
	14	23.53	0.94	24.99	0.97	26.45	1.01	27.50	1.02	29.37	1.04	30.83	1.06
	20	23.51	0.95	24.97	0.99	26.43	1.02	27.48	1.03	29.35	1.05	30.81	1.08
	25	23.49	0.97	24.95	1.00	26.41	1.04	27.46	1.05	29.33	1.07	30.79	1.09
	30	23.47	0.98	24.93	1.01	26.39	1.05	27.44	1.06	29.30	1.08	30.76	1.11
	35	23.46	0.99	24.91	1.03	26.37	1.07	27.42	1.08	29.28	1.10	30.74	1.12
	40	23.44	1.01	24.89	1.04	26.35	1.08	27.40	1.09	29.26	1.11	30.72	1.14
	45	23.42	1.02	24.87	1.06	26.33	1.10	27.38	1.11	29.24	1.13	30.69	1.15
	50	23.40	1.03	24.85	1.07	26.31	1.11	27.36	1.12	29.21	1.14	30.67	1.17
	55	23.38	1.05	24.84	1.08	26.29	1.12	27.34	1.14	29.19	1.16	30.64	1.18
	60	23.37	1.06	24.82	1.10	26.27	1.14	27.32	1.15	29.17	1.17	30.62	1.20
	65	23.35	1.07	24.80	1.11	26.25	1.15	27.29	1.17	29.15	1.19	30.60	1.21
	70	23.33	1.09	24.78	1.13	26.23	1.17	27.27	1.18	29.13	1.20	30.57	1.23
	75	22.77	1.15	24.21	1.19	25.66	1.23	26.70	1.25	28.55	1.27	29.99	1.29
	80	22.21	1.20	23.65	1.25	25.09	1.29	26.13	1.31	27.97	1.33	29.42	1.36
	85	21.65	1.26	23.09	1.31	24.53	1.36	25.57	1.37	27.40	1.40	28.84	1.43
	90	21.09	1.32	22.53	1.37	23.96	1.42	25.00	1.44	26.83	1.46	28.27	1.49
	95	20.49	1.38	21.92	1.43	23.35	1.48	24.00	1.50	26.20	1.53	27.63	1.56
	100	19.99	1.44	21.42	1.49	22.85	1.55	23.69	1.56	25.70	1.59	27.13	1.63
	105	19.49	1.50	20.92	1.55	22.35	1.61	23.38	1.63	25.20	1.66	26.63	1.69
	110	18.99	1.56	20.42	1.61	21.85	1.67	22.88	1.69	24.70	1.72	26.13	1.76
	115	18.49	1.61	19.92	1.67	21.35	1.73	22.38	1.75	24.20	1.79	25.63	1.82
	118	18.19	1.65	19.62	1.71	21.05	1.77	22.08	1.79	23.90	1.83	25.33	1.86
	122	18.10	1.70	19.52	1.76	20.95	1.82	21.98	1.84	23.81	1.88	25.23	1.92

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 213: LMU480HV Cooling Capacity Table — Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 65 (135%)	-4	47.52	2.99	50.47	3.10	53.42	3.21	55.55	3.25	59.32	3.31	62.27	3.37
	0	47.49	3.02	50.44	3.13	53.39	3.25	55.52	3.28	59.29	3.34	62.24	3.41
	5	47.45	3.07	50.40	3.18	53.34	3.30	55.47	3.34	59.24	3.40	62.18	3.47
	10	47.41	3.11	50.36	3.23	53.30	3.35	55.43	3.39	59.19	3.45	62.14	3.52
	14	47.38	3.16	50.32	3.28	53.26	3.40	55.39	3.43	59.15	3.50	62.09	3.57
	20	47.34	3.21	50.28	3.32	53.22	3.44	55.35	3.48	59.10	3.55	62.04	3.62
	25	47.31	3.25	50.24	3.37	53.18	3.49	55.30	3.53	59.06	3.60	61.99	3.67
	30	47.27	3.30	50.21	3.42	53.14	3.54	55.26	3.58	59.01	3.65	61.95	3.72
	35	47.23	3.34	50.17	3.46	53.10	3.59	55.22	3.63	58.97	3.70	61.90	3.77
	40	47.20	3.39	50.13	3.51	53.06	3.64	55.18	3.68	58.92	3.75	61.85	3.83
	45	47.16	3.43	50.09	3.56	53.02	3.69	55.13	3.73	58.88	3.80	61.81	3.88
	50	47.12	3.48	50.05	3.61	52.98	3.74	55.09	3.78	58.83	3.85	61.76	3.93
	55	47.09	3.52	50.01	3.65	52.94	3.79	55.05	3.83	58.79	3.90	61.71	3.98
	60	47.05	3.57	49.97	3.70	52.90	3.83	55.01	3.88	58.74	3.95	61.66	4.03
	65	47.02	3.61	49.94	3.75	52.86	3.88	54.97	3.93	58.70	4.00	61.62	4.08
	70	46.98	3.66	49.90	3.79	52.82	3.93	54.92	3.98	58.65	4.05	61.57	4.13
	75	45.85	3.86	48.76	4.00	51.67	4.14	53.77	4.19	57.49	4.27	60.40	4.36
	80	44.72	4.05	47.62	4.20	50.53	4.36	52.62	4.41	56.33	4.49	59.24	4.58
	85	43.60	4.25	46.49	4.41	49.39	4.57	51.48	4.62	55.18	4.71	58.08	4.80
	90	42.48	4.45	45.37	4.61	48.26	4.78	50.34	4.84	54.03	4.93	56.92	5.03
	95	41.26	4.65	44.14	4.82	47.01	4.99	48.33	5.05	52.76	5.14	55.63	5.25
	100	40.26	4.84	43.13	5.02	46.01	5.20	47.70	5.26	51.76	5.36	54.63	5.47
	105	39.25	5.04	42.13	5.23	45.00	5.42	47.08	5.48	50.75	5.58	53.63	5.69
	110	38.25	5.24	41.12	5.43	44.00	5.63	46.07	5.69	49.75	5.80	52.62	5.92
	115	37.24	5.44	40.12	5.64	42.99	5.84	45.07	5.91	48.74	6.02	51.62	6.14
	118	36.64	5.56	39.51	5.76	42.39	5.97	44.47	6.04	48.14	6.15	51.01	6.27
Ducted Indoor Units 62 (130%)	122	36.44	5.71	39.31	5.92	42.19	6.14	44.26	6.21	47.94	6.32	50.81	6.45
	-4	46.77	2.89	49.67	2.99	52.58	3.10	54.67	3.14	58.39	3.20	61.29	3.26
	0	46.74	2.92	49.65	3.03	52.55	3.14	54.64	3.17	58.35	3.23	61.26	3.30
	5	46.70	2.97	49.60	3.07	52.50	3.19	54.60	3.22	58.31	3.28	61.21	3.35
	10	46.67	3.01	49.57	3.12	52.46	3.23	54.56	3.27	58.26	3.33	61.16	3.40
	14	46.63	3.05	49.53	3.17	52.42	3.28	54.52	3.32	58.22	3.38	61.11	3.45
	20	46.60	3.10	49.49	3.21	52.38	3.33	54.48	3.37	58.17	3.43	61.07	3.50
	25	46.56	3.14	49.45	3.26	52.34	3.38	54.43	3.41	58.13	3.48	61.02	3.55
	30	46.53	3.19	49.42	3.30	52.31	3.42	54.39	3.46	58.08	3.53	60.97	3.60
	35	46.49	3.23	49.38	3.35	52.27	3.47	54.35	3.51	58.04	3.58	60.93	3.65
	40	46.45	3.27	49.34	3.39	52.23	3.52	54.31	3.56	58.00	3.62	60.88	3.70
	45	46.42	3.32	49.30	3.44	52.19	3.56	54.27	3.60	57.95	3.67	60.83	3.75
	50	46.38	3.36	49.26	3.48	52.15	3.61	54.23	3.65	57.91	3.72	60.79	3.80
	55	46.35	3.40	49.23	3.53	52.11	3.66	54.18	3.70	57.86	3.77	60.74	3.85
	60	46.31	3.45	49.19	3.57	52.07	3.71	54.14	3.75	57.82	3.82	60.69	3.89
	65	46.28	3.49	49.15	3.62	52.03	3.75	54.10	3.80	57.77	3.87	60.65	3.94
	70	46.24	3.54	49.11	3.67	51.99	3.80	54.06	3.84	57.73	3.92	60.60	3.99
	75	45.13	3.73	47.99	3.86	50.86	4.00	52.93	4.05	56.59	4.13	59.45	4.21
	80	44.02	3.92	46.87	4.06	49.73	4.21	51.80	4.26	55.45	4.34	58.30	4.42
	85	42.91	4.11	45.76	4.26	48.61	4.41	50.67	4.47	54.32	4.55	57.17	4.64
	90	41.81	4.30	44.65	4.46	47.50	4.62	49.55	4.67	53.18	4.76	56.03	4.86
	95	40.61	4.49	43.44	4.65	46.27	4.82	47.57	4.88	51.93	4.97	54.76	5.07
	100	39.62	4.68	42.45	4.85	45.28	5.03	46.95	5.09	50.94	5.18	53.77	5.29
	105	38.64	4.87	41.46	5.05	44.29	5.23	46.34	5.29	49.95	5.39	52.78	5.50
	110	37.65	5.06	40.48	5.25	43.30	5.44	45.35	5.50	48.96	5.61	51.79	5.72
	115	36.66	5.25	39.49	5.45	42.32	5.64	44.36	5.71	47.97	5.82	50.80	5.93
	118	36.06	5.37	38.89	5.56	41.72	5.77	43.77	5.83	47.38	5.94	50.21	6.06
	122	35.87	5.52	38.70	5.72	41.52	5.93	43.57	6.00	47.18	6.11	50.01	6.23

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 214: LMU480HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 58 (120%)	-4	45.77	2.75	48.61	2.85	51.45	2.96	53.50	2.99	57.13	3.05	59.98	3.11
	0	45.74	2.78	48.58	2.88	51.42	2.99	53.47	3.02	57.10	3.08	59.94	3.14
	5	45.70	2.83	48.54	2.93	51.38	3.04	53.43	3.07	57.06	3.13	59.89	3.19
	10	45.67	2.87	48.50	2.97	51.34	3.08	53.39	3.12	57.01	3.18	59.85	3.24
	14	45.63	2.91	48.47	3.02	51.30	3.13	53.35	3.16	56.97	3.22	59.80	3.29
	20	45.60	2.95	48.43	3.06	51.26	3.17	53.31	3.21	56.93	3.27	59.76	3.33
	25	45.56	2.99	48.39	3.10	51.22	3.22	53.27	3.25	56.88	3.31	59.71	3.38
	30	45.53	3.04	48.36	3.15	51.18	3.26	53.23	3.30	56.84	3.36	59.67	3.43
	35	45.49	3.08	48.32	3.19	51.14	3.31	53.18	3.34	56.80	3.41	59.62	3.48
	40	45.46	3.12	48.28	3.23	51.11	3.35	53.14	3.39	56.75	3.45	59.57	3.52
	45	45.42	3.16	48.25	3.28	51.07	3.40	53.10	3.43	56.71	3.50	59.53	3.57
	50	45.39	3.20	48.21	3.32	51.03	3.44	53.06	3.48	56.66	3.55	59.48	3.62
	55	45.35	3.24	48.17	3.36	50.99	3.49	53.02	3.53	56.62	3.59	59.44	3.66
	60	45.32	3.29	48.13	3.41	50.95	3.53	52.98	3.57	56.58	3.64	59.39	3.71
	65	45.28	3.33	48.10	3.45	50.91	3.58	52.94	3.62	56.53	3.68	59.35	3.76
	70	45.25	3.37	48.06	3.49	50.87	3.62	52.90	3.66	56.49	3.73	59.30	3.81
	75	44.16	3.55	46.96	3.68	49.77	3.82	51.79	3.86	55.37	3.93	58.18	4.01
	80	43.07	3.73	45.87	3.87	48.66	4.01	50.68	4.06	54.26	4.13	57.05	4.22
	85	41.99	3.92	44.78	4.06	47.57	4.21	49.59	4.25	53.15	4.33	55.94	4.42
	90	40.91	4.10	43.70	4.25	46.48	4.40	48.49	4.45	52.04	4.54	54.83	4.63
	95	39.74	4.28	42.51	4.44	45.28	4.60	46.55	4.65	50.82	4.74	53.59	4.83
	100	38.77	4.46	41.54	4.62	44.31	4.79	45.95	4.85	49.85	4.94	52.62	5.04
	105	37.81	4.64	40.58	4.81	43.34	4.99	45.34	5.05	48.88	5.14	51.65	5.24
	110	36.84	4.82	39.61	5.00	42.38	5.18	44.38	5.24	47.91	5.34	50.68	5.45
	115	35.87	5.01	38.64	5.19	41.41	5.38	43.41	5.44	46.95	5.54	49.71	5.65
	118	35.29	5.12	38.06	5.30	40.83	5.50	42.83	5.56	46.37	5.66	49.13	5.78
Ducted Indoor Units 53 (110%)	122	35.10	5.26	37.87	5.45	40.63	5.65	42.63	5.72	46.17	5.82	48.94	5.94
	-4	44.51	2.58	47.27	2.67	50.03	2.77	52.03	2.80	55.56	2.86	58.33	2.91
	0	44.48	2.61	47.24	2.70	50.01	2.80	52.00	2.83	55.53	2.89	58.30	2.95
	5	44.45	2.65	47.21	2.75	49.97	2.85	51.96	2.88	55.49	2.93	58.25	2.99
	10	44.41	2.69	47.17	2.79	49.93	2.89	51.92	2.92	55.44	2.98	58.20	3.04
	14	44.38	2.73	47.13	2.83	49.89	2.93	51.88	2.97	55.40	3.02	58.16	3.08
	20	44.34	2.77	47.10	2.87	49.85	2.97	51.84	3.01	55.36	3.06	58.11	3.13
	25	44.31	2.81	47.06	2.91	49.81	3.02	51.80	3.05	55.32	3.11	58.07	3.17
	30	44.28	2.85	47.03	2.95	49.78	3.06	51.76	3.09	55.28	3.15	58.03	3.21
	35	44.24	2.89	46.99	2.99	49.74	3.10	51.72	3.14	55.23	3.19	57.98	3.26
	40	44.21	2.92	46.95	3.03	49.70	3.14	51.68	3.18	55.19	3.24	57.94	3.30
	45	44.17	2.96	46.92	3.07	49.66	3.18	51.64	3.22	55.15	3.28	57.89	3.35
	50	44.14	3.00	46.88	3.11	49.62	3.23	51.60	3.26	55.11	3.32	57.85	3.39
	55	44.11	3.04	46.85	3.15	49.59	3.27	51.56	3.31	55.06	3.37	57.80	3.44
	60	44.07	3.08	46.81	3.19	49.55	3.31	51.52	3.35	55.02	3.41	57.76	3.48
	65	44.04	3.12	46.77	3.23	49.51	3.35	51.49	3.39	54.98	3.45	57.71	3.52
	70	44.01	3.16	46.74	3.28	49.47	3.39	51.45	3.43	54.94	3.50	57.67	3.57
	75	42.95	3.33	45.67	3.45	48.40	3.58	50.37	3.62	53.85	3.69	56.58	3.76
	80	41.89	3.50	44.61	3.63	47.33	3.76	49.29	3.80	52.77	3.88	55.49	3.95
	85	40.84	3.67	43.55	3.81	46.26	3.94	48.22	3.99	51.69	4.06	54.40	4.15
	90	39.79	3.84	42.49	3.98	45.20	4.13	47.16	4.17	50.61	4.25	53.32	4.34
	95	38.65	4.01	41.34	4.16	44.03	4.31	45.27	4.36	49.42	4.44	52.11	4.53
	100	37.71	4.18	40.40	4.34	43.09	4.49	44.68	4.55	48.48	4.63	51.17	4.72
	105	36.77	4.35	39.46	4.51	42.15	4.68	44.10	4.73	47.54	4.82	50.23	4.92
	110	35.83	4.52	38.52	4.69	41.21	4.86	43.16	4.92	46.60	5.01	49.29	5.11
	115	34.88	4.69	37.58	4.87	40.27	5.04	42.21	5.10	45.66	5.20	48.35	5.30
	118	34.32	4.80	37.01	4.97	39.71	5.15	41.65	5.21	45.09	5.31	47.78	5.42
	122	34.13	4.93	36.82	5.11	39.52	5.30	41.46	5.36	44.90	5.46	47.59	5.57

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 215: LMU480HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 48 (100%)	-4	43.26	2.41	45.94	2.50	48.63	2.59	50.57	2.62	54.00	2.67	56.69	2.72
	0	43.23	2.43	45.92	2.52	48.60	2.62	50.54	2.65	53.97	2.69	56.66	2.75
	5	43.20	2.47	45.88	2.56	48.56	2.66	50.50	2.69	53.93	2.74	56.61	2.79
	10	43.17	2.51	45.85	2.60	48.53	2.70	50.46	2.73	53.89	2.78	56.57	2.84
	14	43.13	2.55	45.81	2.64	48.49	2.74	50.43	2.77	53.85	2.82	56.53	2.88
	20	43.10	2.58	45.78	2.68	48.45	2.78	50.39	2.81	53.81	2.86	56.48	2.92
	25	43.07	2.62	45.74	2.72	48.42	2.82	50.35	2.85	53.77	2.90	56.44	2.96
	30	43.03	2.66	45.71	2.75	48.38	2.85	50.31	2.89	53.72	2.94	56.40	3.00
	35	43.00	2.69	45.67	2.79	48.34	2.89	50.27	2.93	53.68	2.98	56.35	3.04
	40	42.97	2.73	45.64	2.83	48.31	2.93	50.23	2.97	53.64	3.02	56.31	3.08
	45	42.94	2.77	45.60	2.87	48.27	2.97	50.19	3.01	53.60	3.06	56.27	3.12
	50	42.90	2.80	45.57	2.91	48.23	3.01	50.16	3.05	53.56	3.10	56.23	3.17
	55	42.87	2.84	45.53	2.94	48.19	3.05	50.12	3.09	53.52	3.14	56.18	3.21
	60	42.84	2.88	45.50	2.98	48.16	3.09	50.08	3.13	53.48	3.18	56.14	3.25
	65	42.80	2.91	45.46	3.02	48.12	3.13	50.04	3.17	53.44	3.22	56.10	3.29
	70	42.77	2.95	45.43	3.06	48.08	3.17	50.00	3.21	53.40	3.27	56.05	3.33
	75	41.74	3.11	44.39	3.22	47.04	3.34	48.96	3.38	52.34	3.44	54.99	3.51
	80	40.71	3.27	43.36	3.39	46.00	3.51	47.91	3.55	51.29	3.62	53.93	3.69
	85	39.69	3.43	42.33	3.55	44.97	3.68	46.87	3.72	50.24	3.79	52.88	3.87
	90	38.67	3.59	41.30	3.72	43.93	3.85	45.83	3.90	49.19	3.97	51.82	4.05
	95	37.57	3.75	40.18	3.88	42.80	4.02	44.00	4.07	48.03	4.15	50.65	4.23
	100	36.65	3.90	39.27	4.05	41.88	4.19	43.43	4.24	47.12	4.32	49.74	4.41
	105	35.74	4.06	38.35	4.21	40.97	4.37	42.86	4.42	46.20	4.50	48.82	4.59
	110	34.82	4.22	37.44	4.38	40.06	4.54	41.95	4.59	45.29	4.67	47.91	4.77
	115	33.91	4.38	36.52	4.54	39.14	4.71	41.03	4.76	44.37	4.85	46.99	4.95
	118	33.36	4.48	35.97	4.64	38.59	4.81	40.48	4.87	43.83	4.96	46.44	5.06
	122	33.17	4.60	35.79	4.77	38.41	4.95	40.30	5.00	43.64	5.10	46.26	5.20
Ducted Indoor Units 43 (90%)	-4	38.76	2.09	41.16	2.16	43.57	2.24	45.31	2.27	48.38	2.31	50.79	2.36
	0	38.73	2.11	41.14	2.19	43.55	2.27	45.28	2.29	48.36	2.34	50.76	2.38
	5	38.70	2.15	41.11	2.22	43.51	2.31	45.25	2.33	48.32	2.38	50.72	2.42
	10	38.67	2.18	41.07	2.26	43.48	2.34	45.21	2.37	48.28	2.41	50.68	2.46
	14	38.64	2.21	41.04	2.29	43.44	2.37	45.18	2.40	48.24	2.45	50.64	2.49
	20	38.61	2.24	41.01	2.32	43.41	2.41	45.14	2.44	48.21	2.48	50.60	2.53
	25	38.58	2.27	40.98	2.36	43.38	2.44	45.11	2.47	48.17	2.52	50.57	2.57
	30	38.55	2.30	40.95	2.39	43.34	2.48	45.07	2.50	48.13	2.55	50.53	2.60
	35	38.53	2.34	40.92	2.42	43.31	2.51	45.04	2.54	48.10	2.59	50.49	2.64
	40	38.50	2.37	40.89	2.45	43.28	2.54	45.00	2.57	48.06	2.62	50.45	2.67
	45	38.47	2.40	40.86	2.49	43.24	2.58	44.97	2.61	48.02	2.66	50.41	2.71
	50	38.44	2.43	40.82	2.52	43.21	2.61	44.94	2.64	47.99	2.69	50.37	2.75
	55	38.41	2.46	40.79	2.55	43.18	2.65	44.90	2.68	47.95	2.73	50.33	2.78
	60	38.38	2.49	40.76	2.59	43.14	2.68	44.87	2.71	47.91	2.76	50.30	2.82
	65	38.35	2.53	40.73	2.62	43.11	2.71	44.83	2.75	47.88	2.80	50.26	2.85
	70	38.32	2.56	40.70	2.65	43.08	2.75	44.80	2.78	47.84	2.83	50.22	2.89
	75	37.40	2.70	39.77	2.79	42.14	2.90	43.86	2.93	46.89	2.98	49.27	3.04
	80	36.47	2.83	38.84	2.94	41.21	3.04	42.92	3.08	45.95	3.14	48.32	3.20
	85	35.56	2.97	37.92	3.08	40.29	3.19	41.99	3.23	45.01	3.29	47.37	3.36
	90	34.65	3.11	37.00	3.22	39.36	3.34	41.06	3.38	44.07	3.44	46.43	3.51
	95	33.66	3.25	36.00	3.37	38.34	3.49	39.42	3.53	43.03	3.60	45.38	3.67
	100	32.84	3.39	35.18	3.51	37.52	3.64	38.91	3.68	42.21	3.75	44.56	3.82
	105	32.02	3.52	34.36	3.65	36.71	3.79	38.40	3.83	41.39	3.90	43.74	3.98
	110	31.20	3.66	33.54	3.80	35.89	3.93	37.58	3.98	40.57	4.05	42.92	4.14
	115	30.38	3.80	32.72	3.94	35.07	4.08	36.76	4.13	39.76	4.21	42.10	4.29
	118	29.89	3.88	32.23	4.02	34.57	4.17	36.27	4.22	39.26	4.30	41.61	4.39
	122	29.72	3.99	32.07	4.14	34.41	4.29	36.10	4.34	39.10	4.42	41.44	4.51

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 216: LMU480HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 38 (80%)	-4	34.24	1.76	36.37	1.83	38.50	1.89	40.03	1.92	42.75	1.95	44.88	1.99
	0	34.22	1.78	36.35	1.85	38.47	1.91	40.01	1.94	42.73	1.97	44.85	2.01
	5	34.20	1.81	36.32	1.88	38.44	1.95	39.98	1.97	42.69	2.01	44.81	2.05
	10	34.17	1.84	36.29	1.91	38.41	1.97	39.95	2.00	42.66	2.03	44.78	2.08
	14	34.14	1.86	36.26	1.93	38.38	2.00	39.92	2.03	42.63	2.06	44.75	2.11
	20	34.12	1.89	36.24	1.96	38.36	2.03	39.89	2.06	42.59	2.09	44.71	2.14
	25	34.09	1.92	36.21	1.99	38.33	2.06	39.86	2.08	42.56	2.12	44.68	2.17
	30	34.07	1.95	36.18	2.02	38.30	2.09	39.82	2.11	42.53	2.15	44.64	2.20
	35	34.04	1.97	36.15	2.04	38.27	2.12	39.79	2.14	42.50	2.18	44.61	2.23
	40	34.01	2.00	36.13	2.07	38.24	2.15	39.76	2.17	42.46	2.21	44.58	2.26
	45	33.99	2.03	36.10	2.10	38.21	2.18	39.73	2.20	42.43	2.24	44.54	2.29
	50	33.96	2.05	36.07	2.13	38.18	2.21	39.70	2.23	42.40	2.27	44.51	2.32
	55	33.94	2.08	36.04	2.16	38.15	2.23	39.67	2.26	42.37	2.30	44.47	2.35
	60	33.91	2.11	36.02	2.18	38.12	2.26	39.64	2.29	42.33	2.33	44.44	2.38
	65	33.88	2.13	35.99	2.21	38.09	2.29	39.61	2.32	42.30	2.36	44.40	2.41
	70	33.86	2.16	35.96	2.24	38.06	2.32	39.58	2.35	42.27	2.39	44.37	2.44
	75	33.04	2.28	35.14	2.36	37.24	2.45	38.75	2.47	41.43	2.52	43.53	2.57
	80	32.23	2.39	34.32	2.48	36.41	2.57	37.92	2.60	40.60	2.65	42.69	2.70
	85	31.42	2.51	33.51	2.60	35.59	2.70	37.10	2.73	39.77	2.78	41.86	2.83
	90	30.61	2.63	32.69	2.72	34.78	2.82	36.28	2.85	38.94	2.91	41.02	2.97
	95	29.74	2.74	31.81	2.84	33.88	2.95	34.83	2.98	38.02	3.04	40.09	3.10
	100	29.01	2.86	31.08	2.96	33.16	3.07	34.38	3.11	37.30	3.16	39.37	3.23
	105	28.29	2.98	30.36	3.08	32.43	3.20	33.93	3.23	36.57	3.29	38.65	3.36
	110	27.56	3.09	29.64	3.20	31.71	3.32	33.20	3.36	35.85	3.42	37.92	3.49
	115	26.84	3.21	28.91	3.33	30.98	3.45	32.48	3.49	35.13	3.55	37.20	3.62
	118	26.41	3.28	28.48	3.40	30.55	3.52	32.04	3.56	34.69	3.63	36.76	3.70
	122	26.26	3.37	28.33	3.49	30.40	3.62	31.90	3.66	34.55	3.73	36.62	3.81
Ducted Indoor Units 34 (70%)	-4	30.64	1.50	32.55	1.56	34.45	1.61	35.83	1.63	38.26	1.66	40.16	1.70
	0	30.63	1.52	32.53	1.57	34.43	1.63	35.81	1.65	38.24	1.68	40.14	1.72
	5	30.60	1.54	32.50	1.60	34.40	1.66	35.78	1.68	38.20	1.71	40.11	1.74
	10	30.58	1.57	32.48	1.62	34.38	1.68	35.75	1.70	38.18	1.73	40.07	1.77
	14	30.56	1.59	32.45	1.65	34.35	1.71	35.72	1.73	38.15	1.76	40.04	1.80
	20	30.53	1.61	32.43	1.67	34.32	1.73	35.69	1.75	38.12	1.79	40.01	1.82
	25	30.51	1.64	32.40	1.69	34.30	1.76	35.67	1.78	38.09	1.81	39.98	1.85
	30	30.49	1.66	32.38	1.72	34.27	1.78	35.64	1.80	38.06	1.84	39.95	1.87
	35	30.46	1.68	32.35	1.74	34.25	1.81	35.61	1.83	38.03	1.86	39.92	1.90
	40	30.44	1.70	32.33	1.77	34.22	1.83	35.59	1.85	38.00	1.89	39.89	1.92
	45	30.42	1.73	32.31	1.79	34.19	1.85	35.56	1.88	37.97	1.91	39.86	1.95
	50	30.39	1.75	32.28	1.81	34.17	1.88	35.53	1.90	37.94	1.94	39.83	1.98
	55	30.37	1.77	32.26	1.84	34.14	1.90	35.50	1.93	37.91	1.96	39.80	2.00
	60	30.35	1.80	32.23	1.86	34.12	1.93	35.48	1.95	37.88	1.99	39.77	2.03
	65	30.32	1.82	32.21	1.88	34.09	1.95	35.45	1.98	37.86	2.01	39.74	2.05
	70	30.30	1.84	32.18	1.91	34.06	1.98	35.42	2.00	37.83	2.04	39.71	2.08
	75	29.57	1.94	31.45	2.01	33.32	2.08	34.68	2.11	37.08	2.15	38.96	2.19
	80	28.84	2.04	30.71	2.11	32.59	2.19	33.94	2.22	36.33	2.26	38.20	2.30
	85	28.12	2.14	29.99	2.22	31.85	2.30	33.20	2.32	35.59	2.37	37.46	2.42
	90	27.40	2.24	29.26	2.32	31.12	2.40	32.47	2.43	34.85	2.48	36.71	2.53
	95	26.61	2.34	28.47	2.42	30.32	2.51	31.17	2.54	34.03	2.59	35.88	2.64
	100	25.96	2.44	27.82	2.53	29.67	2.62	30.77	2.65	33.38	2.70	35.23	2.75
	105	25.32	2.54	27.17	2.63	29.02	2.72	30.36	2.76	32.73	2.81	34.59	2.86
	110	24.67	2.64	26.52	2.73	28.38	2.83	29.71	2.86	32.08	2.92	33.94	2.98
	115	24.02	2.73	25.87	2.83	27.73	2.94	29.07	2.97	31.44	3.03	33.29	3.09
	118	23.63	2.79	25.48	2.90	27.34	3.00	28.68	3.04	31.05	3.09	32.90	3.16
	122	23.50	2.87	25.35	2.98	27.21	3.09	28.55	3.12	30.92	3.18	32.77	3.25

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 217: LMU480HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 29 (60%)	-4	26.13	1.18	27.75	1.23	29.38	1.27	30.55	1.29	32.62	1.31	34.25	1.34
	0	26.12	1.20	27.74	1.24	29.36	1.29	30.53	1.30	32.61	1.32	34.23	1.35
	5	26.10	1.22	27.72	1.26	29.34	1.31	30.51	1.32	32.58	1.35	34.20	1.37
	10	26.08	1.23	27.70	1.28	29.32	1.33	30.48	1.34	32.55	1.37	34.17	1.39
	14	26.06	1.25	27.67	1.30	29.29	1.34	30.46	1.36	32.53	1.39	34.15	1.41
	20	26.04	1.27	27.65	1.32	29.27	1.36	30.44	1.38	32.50	1.41	34.12	1.43
	25	26.02	1.29	27.63	1.33	29.25	1.38	30.41	1.40	32.48	1.43	34.10	1.45
	30	26.00	1.31	27.61	1.35	29.23	1.40	30.39	1.42	32.45	1.45	34.07	1.47
	35	25.98	1.32	27.59	1.37	29.20	1.42	30.37	1.44	32.43	1.47	34.04	1.49
	40	25.96	1.34	27.57	1.39	29.18	1.44	30.35	1.46	32.41	1.49	34.02	1.52
	45	25.94	1.36	27.55	1.41	29.16	1.46	30.32	1.48	32.38	1.51	33.99	1.54
	50	25.92	1.38	27.53	1.43	29.14	1.48	30.30	1.50	32.36	1.52	33.97	1.56
	55	25.90	1.40	27.51	1.45	29.11	1.50	30.28	1.52	32.33	1.54	33.94	1.58
	60	25.88	1.41	27.48	1.47	29.09	1.52	30.25	1.54	32.31	1.56	33.91	1.60
	65	25.86	1.43	27.46	1.48	29.07	1.54	30.23	1.56	32.28	1.58	33.89	1.62
	70	25.84	1.45	27.44	1.50	29.05	1.56	30.21	1.58	32.26	1.60	33.86	1.64
	75	25.22	1.53	26.82	1.58	28.42	1.64	29.57	1.66	31.62	1.69	33.22	1.73
	80	24.59	1.61	26.19	1.66	27.79	1.73	28.94	1.75	30.98	1.78	32.58	1.81
	85	23.98	1.68	25.57	1.75	27.16	1.81	28.31	1.83	30.35	1.86	31.94	1.90
	90	23.36	1.76	24.95	1.83	26.54	1.89	27.69	1.92	29.72	1.95	31.31	1.99
	95	22.69	1.84	24.27	1.91	25.85	1.98	26.58	2.00	29.02	2.04	30.60	2.08
	100	22.14	1.92	23.72	1.99	25.30	2.06	26.24	2.08	28.46	2.12	30.04	2.17
	105	21.59	2.00	23.17	2.07	24.75	2.15	25.89	2.17	27.91	2.21	29.49	2.26
	110	21.04	2.07	22.62	2.15	24.20	2.23	25.34	2.25	27.36	2.30	28.94	2.34
	115	20.48	2.15	22.06	2.23	23.64	2.31	24.79	2.34	26.81	2.38	28.39	2.43
	118	20.15	2.20	21.73	2.28	23.31	2.36	24.45	2.39	26.47	2.44	28.06	2.48
Ducted Indoor Units 24 (50%)	122	20.04	2.26	21.62	2.35	23.20	2.43	24.34	2.46	26.36	2.50	27.94	2.56
	-4	21.63	0.86	22.97	0.89	24.32	0.92	25.29	0.93	27.00	0.95	28.35	0.97
	0	21.62	0.87	22.96	0.90	24.30	0.93	25.27	0.94	26.99	0.96	28.33	0.98
	5	21.60	0.88	22.94	0.91	24.28	0.95	25.25	0.96	26.97	0.98	28.31	1.00
	10	21.58	0.89	22.92	0.93	24.26	0.96	25.23	0.97	26.94	0.99	28.29	1.01
	14	21.57	0.91	22.91	0.94	24.25	0.97	25.21	0.99	26.92	1.00	28.26	1.02
	20	21.55	0.92	22.89	0.95	24.23	0.99	25.19	1.00	26.90	1.02	28.24	1.04
	25	21.53	0.93	22.87	0.97	24.21	1.00	25.17	1.01	26.88	1.03	28.22	1.05
	30	21.52	0.95	22.85	0.98	24.19	1.02	25.15	1.03	26.86	1.05	28.20	1.07
	35	21.50	0.96	22.84	0.99	24.17	1.03	25.14	1.04	26.84	1.06	28.18	1.08
	40	21.48	0.97	22.82	1.01	24.15	1.04	25.12	1.06	26.82	1.08	28.16	1.10
	45	21.47	0.99	22.80	1.02	24.13	1.06	25.10	1.07	26.80	1.09	28.13	1.11
	50	21.45	1.00	22.78	1.04	24.12	1.07	25.08	1.09	26.78	1.11	28.11	1.13
	55	21.43	1.01	22.77	1.05	24.10	1.09	25.06	1.10	26.76	1.12	28.09	1.14
	60	21.42	1.02	22.75	1.06	24.08	1.10	25.04	1.11	26.74	1.13	28.07	1.16
	65	21.40	1.04	22.73	1.08	24.06	1.11	25.02	1.13	26.72	1.15	28.05	1.17
	70	21.39	1.05	22.71	1.09	24.04	1.13	25.00	1.14	26.70	1.16	28.03	1.19
	75	20.87	1.11	22.20	1.15	23.52	1.19	24.48	1.20	26.17	1.23	27.50	1.25
	80	20.36	1.16	21.68	1.21	23.00	1.25	23.95	1.27	25.64	1.29	26.96	1.31
	85	19.85	1.22	21.16	1.27	22.48	1.31	23.44	1.33	25.12	1.35	26.44	1.38
	90	19.34	1.28	20.65	1.32	21.97	1.37	22.92	1.39	24.60	1.41	25.91	1.44
	95	18.78	1.33	20.09	1.38	21.40	1.43	22.00	1.45	24.02	1.48	25.33	1.51
	100	18.33	1.39	19.63	1.44	20.94	1.49	21.71	1.51	23.56	1.54	24.87	1.57
	105	17.87	1.45	19.18	1.50	20.48	1.56	21.43	1.57	23.10	1.60	24.41	1.63
	110	17.41	1.50	18.72	1.56	20.03	1.62	20.97	1.63	22.64	1.67	23.95	1.70
	115	16.95	1.56	18.26	1.62	19.57	1.68	20.52	1.70	22.19	1.73	23.50	1.76
	118	16.68	1.60	17.99	1.65	19.30	1.71	20.24	1.73	21.91	1.77	23.22	1.80
	122	16.59	1.64	17.90	1.70	19.20	1.76	20.15	1.78	21.82	1.82	23.13	1.85

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 218: LMU480HV Cooling Capacity Table — Mixed Indoor Units.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 65 (135%)	-4	49.68	2.90	52.76	3.01	55.85	3.12	58.08	3.16	62.02	3.22	65.10	3.28
	0	49.65	2.94	52.73	3.04	55.82	3.16	58.04	3.19	61.98	3.25	65.07	3.32
	5	49.61	2.98	52.69	3.09	55.77	3.21	58.00	3.24	61.93	3.30	65.02	3.37
	10	49.57	3.03	52.65	3.14	55.73	3.25	57.95	3.29	61.89	3.35	64.97	3.42
	14	49.53	3.07	52.61	3.18	55.69	3.30	57.91	3.34	61.84	3.40	64.92	3.47
	20	49.50	3.12	52.57	3.23	55.64	3.35	57.86	3.39	61.79	3.45	64.87	3.52
	25	49.46	3.16	52.53	3.28	55.60	3.40	57.82	3.44	61.75	3.50	64.82	3.57
	30	49.42	3.21	52.49	3.32	55.56	3.44	57.78	3.48	61.70	3.55	64.77	3.62
	35	49.38	3.25	52.45	3.37	55.52	3.49	57.73	3.53	61.65	3.60	64.72	3.67
	40	49.35	3.29	52.41	3.41	55.47	3.54	57.69	3.58	61.60	3.65	64.67	3.72
	45	49.31	3.34	52.37	3.46	55.43	3.59	57.64	3.63	61.56	3.69	64.62	3.77
	50	49.27	3.38	52.33	3.51	55.39	3.63	57.60	3.68	61.51	3.74	64.57	3.82
	55	49.23	3.43	52.29	3.55	55.35	3.68	57.56	3.72	61.46	3.79	64.52	3.87
	60	49.19	3.47	52.25	3.60	55.30	3.73	57.51	3.77	61.42	3.84	64.47	3.92
	65	49.16	3.51	52.21	3.64	55.26	3.78	57.47	3.82	61.37	3.89	64.42	3.97
	70	49.12	3.56	52.17	3.69	55.22	3.82	57.42	3.87	61.32	3.94	64.37	4.02
	75	47.94	3.75	50.98	3.89	54.02	4.03	56.22	4.08	60.11	4.15	63.15	4.24
	80	46.75	3.94	49.79	4.09	52.83	4.24	55.02	4.28	58.90	4.36	61.93	4.45
	85	45.58	4.13	48.61	4.29	51.64	4.44	53.83	4.49	57.70	4.58	60.72	4.67
	90	44.41	4.33	47.43	4.48	50.45	4.65	52.63	4.70	56.49	4.79	59.51	4.89
	95	43.14	4.52	46.15	4.68	49.15	4.85	50.53	4.91	55.16	5.00	58.17	5.10
	100	42.09	4.71	45.10	4.88	48.10	5.06	49.88	5.12	54.11	5.21	57.12	5.32
	105	41.04	4.90	44.04	5.08	47.05	5.27	49.22	5.33	53.06	5.43	56.07	5.54
	110	39.99	5.09	42.99	5.28	46.00	5.47	48.17	5.54	52.01	5.64	55.02	5.75
	115	38.94	5.29	41.94	5.48	44.95	5.68	47.12	5.74	50.96	5.85	53.97	5.97
	118	38.31	5.40	41.31	5.60	44.32	5.80	46.49	5.87	50.33	5.98	53.33	6.10
Mixed Indoor Units 62 (130%)	122	38.10	5.55	41.10	5.76	44.11	5.97	46.28	6.04	50.12	6.15	53.12	6.27
	-4	48.89	2.80	51.93	2.91	54.96	3.01	57.16	3.05	61.04	3.10	64.07	3.17
	0	48.86	2.84	51.90	2.94	54.93	3.05	57.13	3.08	61.00	3.14	64.04	3.20
	5	48.82	2.88	51.86	2.99	54.89	3.10	57.08	3.13	60.95	3.19	63.99	3.25
	10	48.79	2.92	51.82	3.03	54.85	3.14	57.04	3.18	60.91	3.24	63.94	3.30
	14	48.75	2.97	51.78	3.07	54.81	3.19	56.99	3.22	60.86	3.28	63.89	3.35
	20	48.71	3.01	51.74	3.12	54.76	3.23	56.95	3.27	60.81	3.33	63.84	3.40
	25	48.68	3.05	51.70	3.16	54.72	3.28	56.91	3.32	60.77	3.38	63.79	3.45
	30	48.64	3.09	51.66	3.21	54.68	3.32	56.86	3.36	60.72	3.43	63.74	3.49
	35	48.60	3.14	51.62	3.25	54.64	3.37	56.82	3.41	60.67	3.47	63.69	3.54
	40	48.56	3.18	51.58	3.30	54.60	3.42	56.77	3.46	60.63	3.52	63.64	3.59
	45	48.53	3.22	51.54	3.34	54.55	3.46	56.73	3.50	60.58	3.57	63.60	3.64
	50	48.49	3.26	51.50	3.38	54.51	3.51	56.69	3.55	60.54	3.61	63.55	3.69
	55	48.45	3.31	51.46	3.43	54.47	3.55	56.64	3.59	60.49	3.66	63.50	3.74
	60	48.42	3.35	51.42	3.47	54.43	3.60	56.60	3.64	60.44	3.71	63.45	3.78
	65	48.38	3.39	51.38	3.52	54.39	3.64	56.56	3.69	60.40	3.76	63.40	3.83
	70	48.34	3.44	51.34	3.56	54.35	3.69	56.51	3.73	60.35	3.80	63.35	3.88
	75	47.18	3.62	50.17	3.75	53.17	3.89	55.33	3.93	59.16	4.01	62.15	4.09
	80	46.01	3.81	49.00	3.94	51.99	4.09	54.15	4.14	57.96	4.21	60.95	4.30
	85	44.86	3.99	47.84	4.14	50.82	4.29	52.97	4.34	56.78	4.42	59.76	4.51
	90	43.71	4.18	46.68	4.33	49.65	4.49	51.80	4.54	55.60	4.62	58.57	4.72
	95	42.46	4.36	45.42	4.52	48.37	4.69	49.73	4.74	54.29	4.83	57.25	4.93
	100	41.42	4.55	44.38	4.71	47.34	4.89	49.09	4.94	53.25	5.03	56.21	5.14
	105	40.39	4.73	43.35	4.91	46.31	5.08	48.44	5.14	52.22	5.24	55.18	5.34
	110	39.36	4.92	42.31	5.10	45.27	5.28	47.41	5.34	51.19	5.44	54.14	5.55
	115	38.32	5.10	41.28	5.29	44.24	5.48	46.37	5.55	50.15	5.65	53.11	5.76
	118	37.70	5.21	40.66	5.40	43.62	5.60	45.75	5.67	49.53	5.77	52.49	5.89
	122	37.49	5.36	40.45	5.56	43.41	5.76	45.55	5.83	49.33	5.94	52.28	6.06

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 219: LMU480HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 58 (120%)	-4	47.84	2.67	50.81	2.77	53.78	2.87	55.93	2.90	59.72	2.95	62.69	3.01
	0	47.81	2.70	50.78	2.80	53.75	2.90	55.90	2.93	59.69	2.99	62.66	3.05
	5	47.77	2.74	50.74	2.84	53.71	2.95	55.85	2.98	59.64	3.03	62.61	3.10
	10	47.74	2.78	50.70	2.88	53.67	2.99	55.81	3.02	59.60	3.08	62.56	3.14
	14	47.70	2.82	50.66	2.93	53.63	3.03	55.77	3.07	59.55	3.12	62.51	3.19
	20	47.66	2.86	50.63	2.97	53.59	3.08	55.72	3.11	59.51	3.17	62.47	3.23
	25	47.63	2.90	50.59	3.01	53.54	3.12	55.68	3.16	59.46	3.21	62.42	3.28
	30	47.59	2.94	50.55	3.05	53.50	3.16	55.64	3.20	59.41	3.26	62.37	3.32
	35	47.56	2.98	50.51	3.09	53.46	3.21	55.60	3.24	59.37	3.30	62.32	3.37
	40	47.52	3.03	50.47	3.14	53.42	3.25	55.55	3.29	59.32	3.35	62.28	3.42
	45	47.48	3.07	50.43	3.18	53.38	3.29	55.51	3.33	59.28	3.39	62.23	3.46
	50	47.45	3.11	50.39	3.22	53.34	3.34	55.47	3.38	59.23	3.44	62.18	3.51
	55	47.41	3.15	50.35	3.26	53.30	3.38	55.43	3.42	59.19	3.48	62.13	3.55
	60	47.37	3.19	50.32	3.30	53.26	3.42	55.38	3.46	59.14	3.53	62.08	3.60
	65	47.34	3.23	50.28	3.35	53.22	3.47	55.34	3.51	59.10	3.57	62.04	3.65
	70	47.30	3.27	50.24	3.39	53.18	3.51	55.30	3.55	59.05	3.62	61.99	3.69
	75	46.16	3.44	49.09	3.57	52.02	3.70	54.14	3.74	57.88	3.81	60.81	3.89
	80	45.02	3.62	47.95	3.75	50.87	3.89	52.98	3.94	56.72	4.01	59.64	4.09
	85	43.90	3.80	46.81	3.94	49.73	4.08	51.83	4.13	55.56	4.20	58.48	4.29
	90	42.77	3.97	45.68	4.12	48.59	4.27	50.69	4.32	54.40	4.40	57.31	4.49
	95	41.54	4.15	44.44	4.30	47.33	4.46	48.66	4.51	53.12	4.59	56.01	4.69
	100	40.53	4.33	43.43	4.48	46.32	4.65	48.03	4.70	52.11	4.79	55.00	4.89
	105	39.52	4.50	42.41	4.67	45.31	4.84	47.40	4.89	51.10	4.98	53.99	5.09
	110	38.51	4.68	41.40	4.85	44.30	5.03	46.39	5.08	50.09	5.18	52.98	5.28
	115	37.50	4.86	40.39	5.03	43.29	5.22	45.38	5.28	49.07	5.38	51.97	5.48
	118	36.89	4.96	39.78	5.14	42.68	5.33	44.77	5.39	48.47	5.49	51.36	5.60
	122	36.69	5.10	39.58	5.29	42.48	5.48	44.57	5.54	48.26	5.65	51.16	5.76
Mixed Indoor Units 53 (110%)	-4	46.53	2.51	49.42	2.60	52.31	2.70	54.40	2.73	58.09	2.78	60.98	2.83
	0	46.51	2.54	49.39	2.63	52.28	2.72	54.37	2.76	58.06	2.81	60.95	2.86
	5	46.47	2.58	49.35	2.67	52.24	2.77	54.32	2.80	58.01	2.85	60.90	2.91
	10	46.43	2.62	49.32	2.71	52.20	2.81	54.28	2.84	57.97	2.90	60.85	2.95
	14	46.40	2.65	49.28	2.75	52.16	2.85	54.24	2.88	57.92	2.94	60.80	3.00
	20	46.36	2.69	49.24	2.79	52.12	2.89	54.20	2.92	57.88	2.98	60.76	3.04
	25	46.33	2.73	49.20	2.83	52.08	2.93	54.16	2.97	57.84	3.02	60.71	3.08
	30	46.29	2.77	49.17	2.87	52.04	2.97	54.12	3.01	57.79	3.06	60.67	3.13
	35	46.26	2.81	49.13	2.91	52.00	3.01	54.08	3.05	57.75	3.11	60.62	3.17
	40	46.22	2.84	49.09	2.95	51.96	3.06	54.03	3.09	57.70	3.15	60.57	3.21
	45	46.19	2.88	49.05	2.99	51.92	3.10	53.99	3.13	57.66	3.19	60.53	3.25
	50	46.15	2.92	49.02	3.03	51.88	3.14	53.95	3.17	57.61	3.23	60.48	3.30
	55	46.11	2.96	48.98	3.07	51.84	3.18	53.91	3.21	57.57	3.28	60.43	3.34
	60	46.08	3.00	48.94	3.11	51.80	3.22	53.87	3.26	57.53	3.32	60.39	3.38
	65	46.04	3.03	48.90	3.15	51.76	3.26	53.83	3.30	57.48	3.36	60.34	3.43
	70	46.01	3.07	48.87	3.18	51.72	3.30	53.79	3.34	57.44	3.40	60.29	3.47
	75	44.90	3.24	47.75	3.36	50.60	3.48	52.66	3.52	56.30	3.59	59.15	3.66
	80	43.79	3.40	46.64	3.53	49.48	3.66	51.53	3.70	55.17	3.77	58.01	3.84
	85	42.70	3.57	45.53	3.70	48.37	3.84	50.42	3.88	54.04	3.95	56.88	4.03
	90	41.60	3.74	44.43	3.87	47.26	4.01	49.30	4.06	52.92	4.14	55.75	4.22
	95	40.41	3.90	43.22	4.04	46.04	4.19	47.33	4.24	51.67	4.32	54.48	4.41
	100	39.42	4.07	42.24	4.22	45.05	4.37	46.72	4.42	50.68	4.50	53.50	4.59
	105	38.44	4.23	41.26	4.39	44.07	4.55	46.10	4.60	49.70	4.69	52.52	4.78
	110	37.46	4.40	40.27	4.56	43.09	4.73	45.12	4.78	48.72	4.87	51.53	4.97
	115	36.47	4.56	39.29	4.73	42.10	4.90	44.14	4.96	47.73	5.05	50.55	5.16
	118	35.88	4.66	38.70	4.83	41.51	5.01	43.55	5.07	47.14	5.16	49.96	5.27
	122	35.69	4.80	38.50	4.97	41.32	5.15	43.35	5.21	46.95	5.31	49.76	5.42

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 220: LMU480HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 48 (100%)	-4	45.22	2.34	48.03	2.43	50.84	2.52	52.87	2.55	56.46	2.59	59.27	2.65
	0	45.20	2.37	48.01	2.45	50.81	2.54	52.84	2.57	56.43	2.62	59.24	2.67
	5	45.16	2.41	47.97	2.49	50.77	2.59	52.80	2.62	56.38	2.66	59.19	2.72
	10	45.13	2.44	47.93	2.53	50.73	2.62	52.76	2.65	56.34	2.70	59.14	2.76
	14	45.09	2.48	47.89	2.57	50.69	2.66	52.72	2.69	56.30	2.74	59.10	2.80
	20	45.06	2.51	47.86	2.61	50.66	2.70	52.68	2.73	56.25	2.78	59.05	2.84
	25	45.02	2.55	47.82	2.64	50.62	2.74	52.64	2.77	56.21	2.82	59.01	2.88
	30	44.99	2.58	47.78	2.68	50.58	2.78	52.60	2.81	56.17	2.86	58.96	2.92
	35	44.96	2.62	47.75	2.72	50.54	2.82	52.56	2.85	56.12	2.90	58.92	2.96
	40	44.92	2.66	47.71	2.75	50.50	2.85	52.52	2.89	56.08	2.94	58.87	3.00
	45	44.89	2.69	47.68	2.79	50.46	2.89	52.48	2.93	56.04	2.98	58.83	3.04
	50	44.85	2.73	47.64	2.83	50.42	2.93	52.44	2.96	56.00	3.02	58.78	3.08
	55	44.82	2.76	47.60	2.86	50.39	2.97	52.40	3.00	55.95	3.06	58.74	3.12
	60	44.78	2.80	47.57	2.90	50.35	3.01	52.36	3.04	55.91	3.10	58.69	3.16
	65	44.75	2.83	47.53	2.94	50.31	3.04	52.32	3.08	55.87	3.14	58.65	3.20
	70	44.72	2.87	47.49	2.97	50.27	3.08	52.28	3.12	55.82	3.18	58.60	3.24
	75	43.64	3.02	46.41	3.14	49.18	3.25	51.18	3.29	54.72	3.35	57.49	3.42
	80	42.56	3.18	45.33	3.30	48.09	3.42	50.09	3.46	53.62	3.52	56.38	3.59
	85	41.50	3.33	44.25	3.46	47.01	3.58	49.00	3.62	52.52	3.69	55.28	3.77
	90	40.43	3.49	43.18	3.62	45.93	3.75	47.92	3.79	51.43	3.86	54.18	3.94
	95	39.27	3.64	42.01	3.78	44.74	3.91	46.00	3.96	50.22	4.03	52.95	4.12
	100	38.32	3.80	41.05	3.94	43.79	4.08	45.40	4.13	49.26	4.21	52.00	4.29
	105	37.36	3.95	40.10	4.10	42.83	4.25	44.81	4.30	48.30	4.38	51.04	4.47
	110	36.40	4.11	39.14	4.26	41.88	4.41	43.85	4.46	47.35	4.55	50.08	4.64
	115	35.45	4.26	38.18	4.42	40.92	4.58	42.90	4.63	46.39	4.72	49.13	4.81
	118	34.87	4.36	37.61	4.52	40.35	4.68	42.32	4.73	45.82	4.82	48.55	4.92
	122	34.68	4.48	37.42	4.64	40.15	4.81	42.13	4.87	45.63	4.96	48.36	5.06
Mixed Indoor Units 43 (90%)	-4	40.52	2.04	43.03	2.11	45.55	2.19	47.36	2.21	50.58	2.25	53.10	2.30
	0	40.49	2.06	43.01	2.13	45.52	2.21	47.34	2.24	50.55	2.28	53.07	2.32
	5	40.46	2.09	42.97	2.17	45.49	2.25	47.30	2.27	50.51	2.31	53.02	2.36
	10	40.43	2.12	42.94	2.20	45.45	2.28	47.26	2.31	50.47	2.35	52.98	2.40
	14	40.40	2.15	42.91	2.23	45.42	2.31	47.23	2.34	50.43	2.38	52.94	2.43
	20	40.37	2.18	42.87	2.26	45.38	2.35	47.19	2.37	50.40	2.42	52.90	2.47
	25	40.34	2.21	42.84	2.30	45.35	2.38	47.16	2.41	50.36	2.45	52.86	2.50
	30	40.31	2.25	42.81	2.33	45.31	2.41	47.12	2.44	50.32	2.49	52.82	2.54
	35	40.27	2.28	42.78	2.36	45.28	2.45	47.08	2.47	50.28	2.52	52.78	2.57
	40	40.24	2.31	42.74	2.39	45.24	2.48	47.05	2.51	50.24	2.55	52.74	2.61
	45	40.21	2.34	42.71	2.42	45.21	2.51	47.01	2.54	50.20	2.59	52.70	2.64
	50	40.18	2.37	42.68	2.46	45.17	2.55	46.98	2.57	50.16	2.62	52.66	2.68
	55	40.15	2.40	42.65	2.49	45.14	2.58	46.94	2.61	50.13	2.66	52.62	2.71
	60	40.12	2.43	42.61	2.52	45.10	2.61	46.90	2.64	50.09	2.69	52.58	2.75
	65	40.09	2.46	42.58	2.55	45.07	2.65	46.87	2.68	50.05	2.73	52.54	2.78
	70	40.06	2.49	42.55	2.58	45.03	2.68	46.83	2.71	50.01	2.76	52.50	2.82
	75	39.10	2.63	41.58	2.72	44.06	2.82	45.85	2.86	49.02	2.91	51.50	2.97
	80	38.13	2.76	40.61	2.86	43.08	2.97	44.87	3.00	48.03	3.06	50.51	3.12
	85	37.18	2.90	39.65	3.00	42.11	3.11	43.90	3.15	47.05	3.21	49.52	3.27
	90	36.22	3.03	38.68	3.14	41.15	3.26	42.93	3.29	46.07	3.36	48.54	3.42
	95	35.18	3.17	37.63	3.28	40.09	3.40	41.21	3.44	44.99	3.50	47.44	3.57
	100	34.33	3.30	36.78	3.42	39.23	3.55	40.68	3.59	44.13	3.65	46.58	3.73
	105	33.47	3.43	35.92	3.56	38.37	3.69	40.14	3.73	43.27	3.80	45.73	3.88
	110	32.61	3.57	35.06	3.70	37.52	3.83	39.29	3.88	42.42	3.95	44.87	4.03
	115	31.76	3.70	34.21	3.84	36.66	3.98	38.43	4.02	41.56	4.10	44.01	4.18
	118	31.24	3.78	33.69	3.92	36.14	4.07	37.91	4.11	41.05	4.19	43.50	4.27
	122	31.07	3.89	33.52	4.03	35.97	4.18	37.74	4.23	40.88	4.31	43.33	4.40

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 221: LMU480HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 38 (80%)	-4	35.81	1.73	38.03	1.79	40.25	1.86	41.86	1.88	44.70	1.91	46.92	1.95
	0	35.79	1.75	38.01	1.81	40.23	1.88	41.84	1.90	44.68	1.93	46.90	1.97
	5	35.76	1.77	37.98	1.84	40.20	1.91	41.80	1.93	44.64	1.96	46.86	2.00
	10	35.73	1.80	37.95	1.87	40.17	1.93	41.77	1.96	44.61	1.99	46.82	2.03
	14	35.70	1.83	37.92	1.89	40.14	1.96	41.74	1.99	44.57	2.02	46.79	2.06
	20	35.68	1.85	37.89	1.92	40.11	1.99	41.71	2.01	44.54	2.05	46.75	2.09
	25	35.65	1.88	37.86	1.95	40.08	2.02	41.67	2.04	44.50	2.08	46.72	2.12
	30	35.62	1.91	37.83	1.98	40.05	2.05	41.64	2.07	44.47	2.11	46.68	2.15
	35	35.59	1.93	37.80	2.00	40.01	2.08	41.61	2.10	44.44	2.14	46.65	2.18
	40	35.57	1.96	37.78	2.03	39.98	2.10	41.58	2.13	44.40	2.17	46.61	2.21
	45	35.54	1.98	37.75	2.06	39.95	2.13	41.55	2.16	44.37	2.20	46.57	2.24
	50	35.51	2.01	37.72	2.08	39.92	2.16	41.52	2.19	44.33	2.23	46.54	2.27
	55	35.48	2.04	37.69	2.11	39.89	2.19	41.48	2.21	44.30	2.26	46.50	2.30
	60	35.46	2.06	37.66	2.14	39.86	2.22	41.45	2.24	44.27	2.28	46.47	2.33
	65	35.43	2.09	37.63	2.17	39.83	2.25	41.42	2.27	44.23	2.31	46.43	2.36
	70	35.40	2.12	37.60	2.19	39.80	2.27	41.39	2.30	44.20	2.34	46.40	2.39
	75	34.55	2.23	36.74	2.31	38.94	2.40	40.52	2.42	43.32	2.47	45.52	2.52
	80	33.70	2.34	35.89	2.43	38.07	2.52	39.65	2.55	42.45	2.60	44.64	2.65
	85	32.85	2.46	35.04	2.55	37.22	2.64	38.80	2.67	41.58	2.72	43.77	2.78
	90	32.01	2.57	34.19	2.67	36.36	2.76	37.94	2.80	40.72	2.85	42.90	2.91
	95	31.09	2.69	33.26	2.79	35.43	2.89	36.42	2.92	39.76	2.97	41.92	3.03
	100	30.34	2.80	32.50	2.90	34.67	3.01	35.95	3.04	39.00	3.10	41.17	3.16
	105	29.58	2.92	31.75	3.02	33.91	3.13	35.48	3.17	38.24	3.23	40.41	3.29
	110	28.82	3.03	30.99	3.14	33.15	3.25	34.72	3.29	37.49	3.35	39.65	3.42
	115	28.07	3.14	30.23	3.26	32.40	3.38	33.96	3.42	36.73	3.48	38.90	3.55
	118	27.61	3.21	29.78	3.33	31.94	3.45	33.51	3.49	36.28	3.56	38.44	3.63
Mixed Indoor Units 34 (70%)	122	27.46	3.30	29.63	3.42	31.79	3.55	33.36	3.59	36.12	3.66	38.29	3.73
	-4	32.03	1.48	34.02	1.54	36.01	1.60	37.45	1.61	39.99	1.64	41.98	1.68
	0	32.01	1.50	34.00	1.56	35.99	1.61	37.43	1.63	39.97	1.66	41.95	1.70
	5	31.99	1.53	33.97	1.58	35.96	1.64	37.39	1.66	39.93	1.69	41.92	1.72
	10	31.96	1.55	33.95	1.60	35.93	1.66	37.37	1.68	39.90	1.71	41.89	1.75
	14	31.94	1.57	33.92	1.63	35.91	1.69	37.34	1.71	39.87	1.74	41.86	1.77
	20	31.91	1.59	33.90	1.65	35.88	1.71	37.31	1.73	39.84	1.76	41.82	1.80
	25	31.89	1.62	33.87	1.67	35.85	1.74	37.28	1.76	39.81	1.79	41.79	1.82
	30	31.87	1.64	33.84	1.70	35.82	1.76	37.25	1.78	39.78	1.81	41.76	1.85
	35	31.84	1.66	33.82	1.72	35.80	1.78	37.22	1.81	39.75	1.84	41.73	1.88
	40	31.82	1.68	33.79	1.75	35.77	1.81	37.20	1.83	39.72	1.86	41.70	1.90
	45	31.79	1.71	33.77	1.77	35.74	1.83	37.17	1.85	39.69	1.89	41.66	1.93
	50	31.77	1.73	33.74	1.79	35.71	1.86	37.14	1.88	39.66	1.91	41.63	1.95
	55	31.74	1.75	33.71	1.82	35.69	1.88	37.11	1.90	39.63	1.94	41.60	1.98
	60	31.72	1.77	33.69	1.84	35.66	1.91	37.08	1.93	39.60	1.96	41.57	2.00
	65	31.69	1.80	33.66	1.86	35.63	1.93	37.05	1.95	39.57	1.99	41.54	2.03
	70	31.67	1.82	33.64	1.89	35.60	1.95	37.02	1.98	39.54	2.01	41.50	2.05
	75	30.91	1.92	32.87	1.99	34.83	2.06	36.25	2.08	38.76	2.12	40.72	2.17
	80	30.15	2.02	32.10	2.09	34.06	2.17	35.47	2.19	37.97	2.23	39.93	2.28
	85	29.39	2.11	31.34	2.19	33.30	2.27	34.71	2.30	37.20	2.34	39.15	2.39
	90	28.64	2.21	30.58	2.29	32.53	2.38	33.94	2.40	36.43	2.45	38.37	2.50
	95	27.82	2.31	29.75	2.39	31.69	2.48	32.58	2.51	35.57	2.56	37.50	2.61
	100	27.14	2.41	29.08	2.50	31.01	2.59	32.16	2.62	34.89	2.67	36.83	2.72
	105	26.46	2.51	28.40	2.60	30.34	2.69	31.74	2.72	34.21	2.77	36.15	2.83
	110	25.78	2.60	27.72	2.70	29.66	2.80	31.06	2.83	33.53	2.88	35.47	2.94
	115	25.11	2.70	27.04	2.80	28.98	2.90	30.38	2.94	32.86	2.99	34.79	3.05
	118	24.70	2.76	26.64	2.86	28.58	2.97	29.97	3.00	32.45	3.06	34.39	3.12
	122	24.56	2.84	26.50	2.94	28.44	3.05	29.84	3.09	32.32	3.14	34.25	3.21

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU480HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 222: LMU480HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 29 (60%)	-4	27.32	1.18	29.02	1.22	30.72	1.26	31.94	1.28	34.11	1.30	35.81	1.33
	0	27.31	1.19	29.00	1.23	30.70	1.28	31.92	1.29	34.09	1.32	35.79	1.34
	5	27.28	1.21	28.98	1.25	30.67	1.30	31.90	1.31	34.06	1.34	35.76	1.37
	10	27.26	1.23	28.96	1.27	30.65	1.32	31.87	1.33	34.04	1.36	35.73	1.39
	14	27.24	1.25	28.93	1.29	30.63	1.34	31.85	1.35	34.01	1.38	35.70	1.41
	20	27.22	1.26	28.91	1.31	30.60	1.36	31.82	1.37	33.98	1.40	35.67	1.43
	25	27.20	1.28	28.89	1.33	30.58	1.38	31.80	1.39	33.96	1.42	35.65	1.45
	30	27.18	1.30	28.87	1.35	30.56	1.40	31.78	1.41	33.93	1.44	35.62	1.47
	35	27.16	1.32	28.85	1.36	30.53	1.41	31.75	1.43	33.91	1.46	35.59	1.49
	40	27.14	1.33	28.82	1.38	30.51	1.43	31.73	1.45	33.88	1.48	35.57	1.51
	45	27.12	1.35	28.80	1.40	30.49	1.45	31.70	1.47	33.85	1.50	35.54	1.53
	50	27.10	1.37	28.78	1.42	30.46	1.47	31.68	1.49	33.83	1.52	35.51	1.55
	55	27.08	1.39	28.76	1.44	30.44	1.49	31.65	1.51	33.80	1.54	35.48	1.57
	60	27.06	1.41	28.74	1.46	30.42	1.51	31.63	1.53	33.78	1.56	35.46	1.59
	65	27.03	1.42	28.71	1.48	30.39	1.53	31.61	1.55	33.75	1.58	35.43	1.61
	70	27.01	1.44	28.69	1.49	30.37	1.55	31.58	1.57	33.72	1.60	35.40	1.63
	75	26.36	1.52	28.04	1.58	29.71	1.63	30.92	1.65	33.06	1.68	34.73	1.72
	80	25.71	1.60	27.38	1.66	29.05	1.72	30.26	1.74	32.39	1.77	34.06	1.80
	85	25.07	1.68	26.73	1.74	28.40	1.80	29.60	1.82	31.73	1.85	33.40	1.89
	90	24.43	1.75	26.09	1.82	27.75	1.88	28.95	1.91	31.07	1.94	32.73	1.98
	95	23.73	1.83	25.38	1.90	27.03	1.97	27.79	1.99	30.34	2.03	31.99	2.07
	100	23.15	1.91	24.80	1.98	26.45	2.05	27.43	2.07	29.76	2.11	31.41	2.16
	105	22.57	1.99	24.22	2.06	25.88	2.13	27.07	2.16	29.18	2.20	30.83	2.24
	110	21.99	2.06	23.65	2.14	25.30	2.22	26.49	2.24	28.60	2.29	30.26	2.33
	115	21.41	2.14	23.07	2.22	24.72	2.30	25.91	2.33	28.03	2.37	29.68	2.42
	118	21.07	2.19	22.72	2.27	24.37	2.35	25.57	2.38	27.68	2.42	29.33	2.47
	122	20.95	2.25	22.61	2.33	24.26	2.42	25.45	2.45	27.56	2.49	29.22	2.54
Mixed Indoor Units 24 (50%)	-4	22.61	0.88	24.02	0.91	25.42	0.94	26.44	0.95	28.23	0.97	29.63	0.99
	0	22.60	0.89	24.00	0.92	25.41	0.95	26.42	0.96	28.21	0.98	29.62	1.00
	5	22.58	0.90	23.98	0.93	25.39	0.97	26.40	0.98	28.19	1.00	29.59	1.02
	10	22.56	0.91	23.97	0.95	25.37	0.98	26.38	0.99	28.17	1.01	29.57	1.03
	14	22.55	0.93	23.95	0.96	25.35	1.00	26.36	1.01	28.15	1.03	29.55	1.05
	20	22.53	0.94	23.93	0.97	25.33	1.01	26.34	1.02	28.13	1.04	29.53	1.06
	25	22.51	0.95	23.91	0.99	25.31	1.02	26.32	1.04	28.10	1.05	29.50	1.08
	30	22.50	0.97	23.89	1.00	25.29	1.04	26.30	1.05	28.08	1.07	29.48	1.09
	35	22.48	0.98	23.87	1.02	25.27	1.05	26.28	1.06	28.06	1.08	29.46	1.11
	40	22.46	0.99	23.86	1.03	25.25	1.07	26.26	1.08	28.04	1.10	29.44	1.12
	45	22.44	1.01	23.84	1.04	25.23	1.08	26.24	1.09	28.02	1.11	29.41	1.14
	50	22.43	1.02	23.82	1.06	25.21	1.10	26.22	1.11	28.00	1.13	29.39	1.15
	55	22.41	1.03	23.80	1.07	25.19	1.11	26.20	1.12	27.98	1.14	29.37	1.17
	60	22.39	1.05	23.78	1.08	25.17	1.12	26.18	1.14	27.95	1.16	29.35	1.18
	65	22.37	1.06	23.76	1.10	25.15	1.14	26.16	1.15	27.93	1.17	29.32	1.20
	70	22.36	1.07	23.75	1.11	25.13	1.15	26.14	1.17	27.91	1.19	29.30	1.21
	75	21.82	1.13	23.20	1.17	24.59	1.21	25.59	1.23	27.36	1.25	28.75	1.28
	80	21.28	1.19	22.66	1.23	24.04	1.28	25.04	1.29	26.81	1.32	28.19	1.34
	85	20.75	1.25	22.13	1.29	23.50	1.34	24.50	1.35	26.26	1.38	27.64	1.41
	90	20.22	1.30	21.59	1.35	22.96	1.40	23.96	1.42	25.71	1.44	27.09	1.47
	95	19.64	1.36	21.00	1.41	22.37	1.46	23.00	1.48	25.11	1.51	26.48	1.54
	100	19.16	1.42	20.53	1.47	21.89	1.53	22.70	1.54	24.63	1.57	26.00	1.60
	105	18.68	1.48	20.05	1.53	21.42	1.59	22.40	1.61	24.15	1.64	25.52	1.67
	110	18.20	1.54	19.57	1.59	20.94	1.65	21.93	1.67	23.67	1.70	25.04	1.73
	115	17.72	1.59	19.09	1.65	20.46	1.71	21.45	1.73	23.20	1.76	24.56	1.80
	118	17.44	1.63	18.80	1.69	20.17	1.75	21.16	1.77	22.91	1.80	24.28	1.84
	122	17.34	1.67	18.71	1.74	20.08	1.80	21.07	1.82	22.81	1.85	24.18	1.89

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 223: LMU540HV Cooling Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 73 (135%)	-4	54.71	3.36	58.11	3.48	61.51	3.61	63.96	3.65	68.30	3.72	71.70	3.80
	0	54.68	3.40	58.08	3.52	61.47	3.65	63.93	3.69	68.27	3.76	71.66	3.84
	5	54.64	3.45	58.03	3.58	61.42	3.71	63.87	3.75	68.21	3.82	71.60	3.90
	10	54.60	3.50	57.99	3.63	61.38	3.76	63.83	3.81	68.16	3.88	71.55	3.96
	14	54.55	3.55	57.94	3.68	61.33	3.82	63.78	3.86	68.11	3.94	71.49	4.01
	20	54.51	3.61	57.90	3.74	61.28	3.87	63.73	3.92	68.05	3.99	71.44	4.07
	25	54.47	3.66	57.85	3.79	61.24	3.93	63.68	3.97	68.00	4.05	71.38	4.13
	30	54.43	3.71	57.81	3.84	61.19	3.98	63.63	4.03	67.95	4.10	71.33	4.19
	35	54.39	3.76	57.76	3.90	61.14	4.04	63.58	4.08	67.90	4.16	71.28	4.25
	40	54.35	3.81	57.72	3.95	61.10	4.09	63.53	4.14	67.85	4.22	71.22	4.30
	45	54.30	3.86	57.68	4.00	61.05	4.15	63.48	4.20	67.79	4.27	71.17	4.36
	50	54.26	3.91	57.63	4.05	61.00	4.20	63.44	4.25	67.74	4.33	71.11	4.42
	55	54.22	3.96	57.59	4.11	60.96	4.26	63.39	4.31	67.69	4.39	71.06	4.48
	60	54.18	4.01	57.54	4.16	60.91	4.31	63.34	4.36	67.64	4.44	71.00	4.53
	65	54.14	4.07	57.50	4.21	60.86	4.37	63.29	4.42	67.59	4.50	70.95	4.59
	70	54.10	4.12	57.46	4.27	60.82	4.42	63.24	4.47	67.53	4.56	70.89	4.65
	75	52.79	4.34	56.15	4.50	59.50	4.66	61.92	4.71	66.20	4.80	69.55	4.90
	80	51.49	4.56	54.84	4.73	58.18	4.90	60.59	4.96	64.86	5.05	68.21	5.15
	85	50.20	4.78	53.54	4.96	56.87	5.14	59.28	5.20	63.54	5.29	66.88	5.40
	90	48.91	5.00	52.24	5.19	55.56	5.38	57.97	5.44	62.22	5.54	65.54	5.65
	95	47.51	5.23	50.82	5.42	54.13	5.62	55.65	5.68	60.75	5.79	64.06	5.90
	100	46.35	5.45	49.66	5.65	52.97	5.85	54.93	5.92	59.59	6.03	62.90	6.15
	105	45.20	5.67	48.51	5.88	51.82	6.09	54.21	6.16	58.44	6.28	61.75	6.40
	110	44.04	5.89	47.35	6.11	50.66	6.33	53.05	6.40	57.28	6.52	60.59	6.66
	115	42.88	6.11	46.19	6.34	49.50	6.57	51.89	6.65	56.12	6.77	59.43	6.91
	118	42.19	6.25	45.50	6.48	48.81	6.71	51.20	6.79	55.43	6.92	58.74	7.06
	122	41.96	6.43	45.27	6.66	48.58	6.90	50.97	6.98	55.20	7.11	58.51	7.26
Non-Ducted Indoor Units 70 (130%)	-4	54.22	3.31	57.59	3.43	60.95	3.55	63.39	3.59	67.69	3.66	71.06	3.74
	0	54.19	3.34	57.56	3.47	60.92	3.59	63.35	3.63	67.65	3.70	71.02	3.78
	5	54.15	3.40	57.51	3.52	60.87	3.65	63.30	3.69	67.60	3.76	70.96	3.84
	10	54.10	3.45	57.46	3.57	60.82	3.70	63.25	3.75	67.55	3.82	70.91	3.89
	14	54.06	3.50	57.42	3.63	60.78	3.76	63.20	3.80	67.49	3.87	70.85	3.95
	20	54.02	3.55	57.38	3.68	60.73	3.81	63.16	3.86	67.44	3.93	70.80	4.01
	25	53.98	3.60	57.33	3.73	60.69	3.87	63.11	3.91	67.39	3.98	70.74	4.06
	30	53.94	3.65	57.29	3.78	60.64	3.92	63.06	3.97	67.34	4.04	70.69	4.12
	35	53.90	3.70	57.25	3.83	60.59	3.97	63.01	4.02	67.29	4.10	70.64	4.18
	40	53.86	3.75	57.20	3.89	60.55	4.03	62.96	4.07	67.24	4.15	70.58	4.23
	45	53.82	3.80	57.16	3.94	60.50	4.08	62.91	4.13	67.18	4.21	70.53	4.29
	50	53.77	3.85	57.11	3.99	60.45	4.14	62.87	4.18	67.13	4.26	70.47	4.35
	55	53.73	3.90	57.07	4.04	60.41	4.19	62.82	4.24	67.08	4.32	70.42	4.40
	60	53.69	3.95	57.03	4.09	60.36	4.24	62.77	4.29	67.03	4.37	70.36	4.46
	65	53.65	4.00	56.98	4.15	60.31	4.30	62.72	4.35	66.98	4.43	70.31	4.52
	70	53.61	4.05	56.94	4.20	60.27	4.35	62.67	4.40	66.93	4.48	70.26	4.58
	75	52.32	4.27	55.64	4.43	58.96	4.59	61.36	4.64	65.60	4.73	68.93	4.82
	80	51.03	4.49	54.34	4.65	57.66	4.82	60.05	4.88	64.28	4.97	67.59	5.07
	85	49.75	4.71	53.06	4.88	56.36	5.06	58.75	5.11	62.97	5.21	66.28	5.32
	90	48.47	4.93	51.77	5.11	55.07	5.29	57.45	5.35	61.66	5.45	64.96	5.56
	95	47.08	5.14	50.36	5.33	53.65	5.53	55.15	5.59	60.21	5.69	63.49	5.81
	100	45.94	5.36	49.22	5.56	52.50	5.76	54.44	5.83	59.06	5.94	62.34	6.06
	105	44.79	5.58	48.07	5.78	51.35	6.00	53.72	6.07	57.91	6.18	61.19	6.30
	110	43.64	5.80	46.93	6.01	50.21	6.23	52.57	6.30	56.77	6.42	60.05	6.55
	115	42.50	6.02	45.78	6.24	49.06	6.47	51.43	6.54	55.62	6.66	58.90	6.80
	118	41.81	6.15	45.09	6.37	48.37	6.61	50.74	6.68	54.93	6.81	58.21	6.94
	122	41.58	6.32	44.86	6.55	48.14	6.79	50.51	6.87	54.70	7.00	57.98	7.14

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).
Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).
The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 224: LMU540HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 65 (120%)	-4	53.40	3.22	56.72	3.34	60.04	3.46	62.43	3.50	66.67	3.56	69.99	3.63
	0	53.37	3.25	56.69	3.37	60.00	3.50	62.40	3.54	66.63	3.60	69.95	3.67
	5	53.33	3.31	56.64	3.43	59.96	3.55	62.35	3.59	66.58	3.66	69.89	3.73
	10	53.29	3.36	56.60	3.48	59.91	3.60	62.30	3.65	66.53	3.71	69.84	3.79
	14	53.25	3.40	56.56	3.53	59.86	3.66	62.25	3.70	66.48	3.77	69.79	3.84
	20	53.21	3.45	56.51	3.58	59.82	3.71	62.20	3.75	66.43	3.82	69.73	3.90
	25	53.17	3.50	56.47	3.63	59.77	3.76	62.16	3.81	66.38	3.88	69.68	3.96
	30	53.13	3.55	56.43	3.68	59.73	3.82	62.11	3.86	66.33	3.93	69.63	4.01
	35	53.09	3.60	56.38	3.73	59.68	3.87	62.06	3.91	66.28	3.99	69.57	4.07
	40	53.05	3.65	56.34	3.78	59.64	3.92	62.01	3.97	66.22	4.04	69.52	4.12
	45	53.01	3.70	56.30	3.83	59.59	3.97	61.97	4.02	66.17	4.09	69.47	4.18
	50	52.97	3.75	56.25	3.88	59.54	4.03	61.92	4.07	66.12	4.15	69.41	4.23
	55	52.92	3.80	56.21	3.93	59.50	4.08	61.87	4.12	66.07	4.20	69.36	4.29
	60	52.88	3.84	56.17	3.98	59.45	4.13	61.82	4.18	66.02	4.26	69.31	4.34
	65	52.84	3.89	56.13	4.04	59.41	4.18	61.78	4.23	65.97	4.31	69.25	4.40
	70	52.80	3.94	56.08	4.09	59.36	4.24	61.73	4.28	65.92	4.36	69.20	4.45
	75	51.53	4.16	54.80	4.31	58.07	4.46	60.44	4.52	64.62	4.60	67.89	4.69
	80	50.26	4.37	53.52	4.53	56.79	4.69	59.14	4.75	63.31	4.84	66.58	4.93
	85	49.00	4.58	52.26	4.75	55.51	4.92	57.86	4.98	62.02	5.07	65.28	5.17
	90	47.74	4.79	50.99	4.97	54.24	5.15	56.58	5.21	60.73	5.31	63.98	5.41
	95	46.38	5.01	49.61	5.19	52.84	5.38	54.32	5.44	59.30	5.54	62.53	5.65
	100	45.25	5.22	48.48	5.41	51.71	5.61	53.62	5.67	58.17	5.78	61.40	5.89
	105	44.12	5.43	47.35	5.63	50.58	5.84	52.91	5.90	57.04	6.01	60.27	6.13
	110	42.99	5.64	46.22	5.85	49.45	6.06	51.78	6.13	55.91	6.25	59.14	6.37
	115	41.86	5.86	45.09	6.07	48.32	6.29	50.65	6.36	54.78	6.48	58.01	6.61
	118	41.18	5.98	44.41	6.20	47.64	6.43	49.98	6.50	54.10	6.63	57.34	6.76
Non-Ducted Indoor Units 59 (110%)	122	40.96	6.15	44.19	6.38	47.42	6.61	49.75	6.69	53.88	6.81	57.11	6.95
	-4	52.43	3.11	55.69	3.22	58.94	3.34	61.29	3.38	65.46	3.44	68.71	3.51
	0	52.40	3.14	55.66	3.25	58.91	3.37	61.26	3.41	65.42	3.48	68.67	3.55
	5	52.36	3.19	55.61	3.31	58.86	3.43	61.21	3.47	65.37	3.53	68.62	3.60
	10	52.32	3.24	55.57	3.36	58.82	3.48	61.16	3.52	65.32	3.58	68.57	3.66
	14	52.28	3.29	55.53	3.41	58.77	3.53	61.12	3.57	65.27	3.64	68.51	3.71
	20	52.24	3.33	55.48	3.45	58.73	3.58	61.07	3.62	65.22	3.69	68.46	3.76
	25	52.20	3.38	55.44	3.50	58.68	3.63	61.02	3.67	65.17	3.74	68.41	3.82
	30	52.16	3.43	55.40	3.55	58.64	3.68	60.98	3.72	65.12	3.79	68.36	3.87
	35	52.12	3.47	55.36	3.60	58.59	3.73	60.93	3.78	65.07	3.85	68.30	3.92
	40	52.08	3.52	55.31	3.65	58.55	3.78	60.88	3.83	65.02	3.90	68.25	3.98
	45	52.04	3.57	55.27	3.70	58.50	3.83	60.84	3.88	64.97	3.95	68.20	4.03
	50	52.00	3.62	55.23	3.75	58.46	3.88	60.79	3.93	64.92	4.00	68.15	4.08
	55	51.96	3.66	55.19	3.80	58.41	3.94	60.74	3.98	64.87	4.06	68.10	4.14
	60	51.92	3.71	55.14	3.85	58.37	3.99	60.70	4.03	64.82	4.11	68.04	4.19
	65	51.88	3.76	55.10	3.89	58.32	4.04	60.65	4.08	64.77	4.16	67.99	4.24
	70	51.84	3.80	55.06	3.94	58.28	4.09	60.60	4.13	64.72	4.21	67.94	4.30
	75	50.59	4.01	53.80	4.16	57.02	4.31	59.34	4.36	63.44	4.44	66.65	4.53
	80	49.35	4.22	52.55	4.37	55.75	4.53	58.07	4.58	62.16	4.67	65.36	4.76
	85	48.11	4.42	51.30	4.58	54.50	4.75	56.81	4.80	60.89	4.89	64.09	4.99
	90	46.87	4.63	50.06	4.79	53.25	4.97	55.55	5.03	59.62	5.12	62.81	5.22
	95	45.53	4.83	48.70	5.01	51.87	5.19	53.33	5.25	58.22	5.35	61.39	5.46
	100	44.42	5.04	47.59	5.22	50.77	5.41	52.64	5.47	57.11	5.58	60.28	5.69
	105	43.31	5.24	46.49	5.43	49.66	5.63	51.95	5.70	56.00	5.80	59.17	5.92
	110	42.20	5.45	45.38	5.65	48.55	5.85	50.84	5.92	54.89	6.03	58.06	6.15
	115	41.10	5.65	44.27	5.86	47.44	6.07	49.73	6.14	53.78	6.26	56.96	6.38
	118	40.43	5.78	43.60	5.99	46.77	6.20	49.07	6.28	53.12	6.39	56.29	6.52
	122	40.21	5.94	43.38	6.16	46.55	6.38	48.84	6.45	52.90	6.58	56.07	6.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 225: LMU540HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 54 (100%)	-4	51.61	3.02	54.82	3.13	58.03	3.24	60.34	3.28	64.44	3.34	67.64	3.41
	0	51.59	3.05	54.79	3.16	57.99	3.28	60.31	3.31	64.40	3.38	67.61	3.44
	5	51.54	3.10	54.75	3.21	57.95	3.33	60.26	3.37	64.35	3.43	67.55	3.50
	10	51.50	3.15	54.70	3.26	57.90	3.38	60.21	3.42	64.30	3.48	67.50	3.55
	14	51.47	3.19	54.66	3.31	57.86	3.43	60.17	3.47	64.25	3.53	67.45	3.60
	20	51.43	3.24	54.62	3.36	57.81	3.48	60.12	3.52	64.20	3.58	67.40	3.66
	25	51.39	3.28	54.58	3.40	57.77	3.53	60.07	3.57	64.15	3.63	67.34	3.71
	30	51.35	3.33	54.54	3.45	57.73	3.58	60.03	3.62	64.10	3.69	67.29	3.76
	35	51.31	3.38	54.50	3.50	57.68	3.63	59.98	3.67	64.05	3.74	67.24	3.81
	40	51.27	3.42	54.45	3.55	57.64	3.68	59.94	3.72	64.01	3.79	67.19	3.86
	45	51.23	3.47	54.41	3.59	57.59	3.72	59.89	3.77	63.96	3.84	67.14	3.92
	50	51.19	3.51	54.37	3.64	57.55	3.77	59.85	3.82	63.91	3.89	67.09	3.97
	55	51.15	3.56	54.33	3.69	57.51	3.82	59.80	3.87	63.86	3.94	67.04	4.02
	60	51.11	3.60	54.29	3.74	57.46	3.87	59.75	3.92	63.81	3.99	66.98	4.07
	65	51.07	3.65	54.24	3.78	57.42	3.92	59.71	3.97	63.76	4.04	66.93	4.12
	70	51.03	3.70	54.20	3.83	57.37	3.97	59.66	4.02	63.71	4.09	66.88	4.17
	75	49.81	3.90	52.97	4.04	56.13	4.19	58.41	4.23	62.45	4.31	65.61	4.40
	80	48.58	4.09	51.73	4.24	54.89	4.40	57.16	4.45	61.19	4.53	64.35	4.62
	85	47.36	4.29	50.51	4.45	53.65	4.61	55.92	4.67	59.94	4.75	63.09	4.85
	90	46.14	4.49	49.28	4.66	52.42	4.83	54.69	4.88	58.70	4.97	61.83	5.07
	95	44.82	4.69	47.94	4.86	51.07	5.04	52.50	5.10	57.31	5.20	60.44	5.30
	100	43.73	4.89	46.85	5.07	49.98	5.26	51.82	5.32	56.22	5.42	59.34	5.53
	105	42.64	5.09	45.76	5.28	48.88	5.47	51.14	5.53	55.13	5.64	58.25	5.75
	110	41.55	5.29	44.67	5.48	47.79	5.68	50.05	5.75	54.04	5.86	57.16	5.98
	115	40.46	5.49	43.58	5.69	46.70	5.90	48.96	5.97	52.95	6.08	56.07	6.20
	118	39.80	5.61	42.92	5.82	46.05	6.03	48.30	6.10	52.29	6.21	55.41	6.34
	122	39.58	5.77	42.71	5.98	45.83	6.20	48.08	6.27	52.07	6.39	55.20	6.52
Non-Ducted Indoor Units 49 (90%)	-4	48.17	2.67	51.17	2.77	54.16	2.87	56.32	2.90	60.14	2.95	63.13	3.01
	0	48.15	2.70	51.14	2.80	54.13	2.90	56.29	2.93	60.11	2.99	63.10	3.05
	5	48.11	2.74	51.10	2.84	54.08	2.95	56.24	2.98	60.06	3.03	63.05	3.10
	10	48.07	2.78	51.06	2.88	54.04	2.99	56.20	3.02	60.01	3.08	63.00	3.14
	14	48.03	2.82	51.02	2.93	54.00	3.03	56.16	3.07	59.97	3.12	62.95	3.19
	20	48.00	2.86	50.98	2.97	53.96	3.08	56.11	3.11	59.92	3.17	62.90	3.23
	25	47.96	2.90	50.94	3.01	53.92	3.12	56.07	3.16	59.88	3.21	62.85	3.28
	30	47.92	2.94	50.90	3.05	53.88	3.16	56.03	3.20	59.83	3.26	62.81	3.32
	35	47.89	2.98	50.86	3.09	53.84	3.21	55.98	3.24	59.78	3.30	62.76	3.37
	40	47.85	3.03	50.82	3.14	53.79	3.25	55.94	3.29	59.74	3.35	62.71	3.42
	45	47.81	3.07	50.78	3.18	53.75	3.29	55.90	3.33	59.69	3.39	62.66	3.46
	50	47.78	3.11	50.75	3.22	53.71	3.34	55.86	3.38	59.65	3.44	62.61	3.51
	55	47.74	3.15	50.71	3.26	53.67	3.38	55.81	3.42	59.60	3.48	62.57	3.55
	60	47.70	3.19	50.67	3.30	53.63	3.42	55.77	3.46	59.56	3.53	62.52	3.60
	65	47.67	3.23	50.63	3.35	53.59	3.47	55.73	3.51	59.51	3.57	62.47	3.65
	70	47.63	3.27	50.59	3.39	53.55	3.51	55.68	3.55	59.46	3.62	62.42	3.69
	75	46.49	3.44	49.44	3.57	52.39	3.70	54.52	3.74	58.29	3.81	61.24	3.89
	80	45.34	3.62	48.28	3.75	51.23	3.89	53.35	3.94	57.11	4.01	60.06	4.09
	85	44.20	3.80	47.14	3.94	50.08	4.08	52.20	4.13	55.95	4.20	58.88	4.29
	90	43.07	3.97	46.00	4.12	48.93	4.27	51.04	4.32	54.78	4.40	57.71	4.49
	95	41.83	4.15	44.75	4.30	47.66	4.46	49.00	4.51	53.49	4.59	56.41	4.69
	100	40.82	4.33	43.73	4.48	46.64	4.65	48.37	4.70	52.47	4.79	55.39	4.89
	105	39.80	4.50	42.71	4.67	45.63	4.84	47.73	4.89	51.45	4.98	54.37	5.09
	110	38.78	4.68	41.69	4.85	44.61	5.03	46.71	5.08	50.44	5.18	53.35	5.28
	115	37.76	4.86	40.67	5.03	43.59	5.22	45.69	5.28	49.42	5.38	52.33	5.48
	118	37.15	4.96	40.06	5.14	42.98	5.33	45.08	5.39	48.81	5.49	51.72	5.60
	122	36.94	5.10	39.86	5.29	42.77	5.48	44.88	5.54	48.60	5.65	51.52	5.76

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 226: LMU540HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 43 (80%)	-4	42.27	2.25	44.90	2.33	47.53	2.42	49.42	2.44	52.78	2.49	55.40	2.54
	0	42.25	2.27	44.88	2.36	47.50	2.44	49.40	2.47	52.75	2.52	55.37	2.57
	5	42.22	2.31	44.84	2.39	47.46	2.48	49.35	2.51	52.70	2.56	55.33	2.61
	10	42.18	2.34	44.80	2.43	47.42	2.52	49.32	2.55	52.66	2.59	55.28	2.65
	14	42.15	2.38	44.77	2.46	47.39	2.55	49.28	2.58	52.62	2.63	55.24	2.69
	20	42.12	2.41	44.74	2.50	47.35	2.59	49.24	2.62	52.58	2.67	55.20	2.72
	25	42.09	2.45	44.70	2.54	47.32	2.63	49.20	2.66	52.54	2.71	55.16	2.76
	30	42.06	2.48	44.67	2.57	47.28	2.66	49.17	2.70	52.50	2.75	55.12	2.80
	35	42.02	2.51	44.63	2.61	47.24	2.70	49.13	2.73	52.46	2.78	55.07	2.84
	40	41.99	2.55	44.60	2.64	47.21	2.74	49.09	2.77	52.42	2.82	55.03	2.88
	45	41.96	2.58	44.57	2.68	47.17	2.78	49.05	2.81	52.38	2.86	54.99	2.92
	50	41.93	2.62	44.53	2.71	47.14	2.81	49.02	2.84	52.34	2.90	54.95	2.96
	55	41.90	2.65	44.50	2.75	47.10	2.85	48.98	2.88	52.30	2.94	54.91	2.99
	60	41.86	2.69	44.46	2.78	47.06	2.89	48.94	2.92	52.26	2.97	54.86	3.03
	65	41.83	2.72	44.43	2.82	47.03	2.92	48.90	2.96	52.22	3.01	54.82	3.07
	70	41.80	2.75	44.40	2.85	46.99	2.96	48.87	2.99	52.18	3.05	54.78	3.11
	75	40.79	2.90	43.38	3.01	45.97	3.12	47.84	3.15	51.15	3.21	53.74	3.28
	80	39.79	3.05	42.37	3.16	44.95	3.28	46.82	3.32	50.12	3.38	52.70	3.45
	85	38.79	3.20	41.37	3.32	43.94	3.44	45.80	3.48	49.10	3.54	51.67	3.61
	90	37.79	3.35	40.36	3.47	42.93	3.60	44.79	3.64	48.07	3.71	50.65	3.78
	95	36.71	3.50	39.27	3.62	41.83	3.76	43.00	3.80	46.94	3.87	49.50	3.95
	100	35.82	3.65	38.38	3.78	40.93	3.92	42.44	3.96	46.05	4.04	48.61	4.12
	105	34.92	3.79	37.48	3.93	40.04	4.08	41.89	4.12	45.15	4.20	47.71	4.28
	110	34.03	3.94	36.59	4.09	39.14	4.24	40.99	4.28	44.26	4.36	46.82	4.45
	115	33.14	4.09	35.69	4.24	38.25	4.40	40.10	4.45	43.37	4.53	45.92	4.62
	118	32.60	4.18	35.16	4.33	37.71	4.49	39.56	4.54	42.83	4.63	45.39	4.72
	122	32.42	4.30	34.98	4.46	37.54	4.62	39.38	4.67	42.65	4.76	45.21	4.86
Non-Ducted Indoor Units 38 (70%)	-4	37.36	1.90	39.68	1.97	42.00	2.04	43.68	2.06	46.64	2.10	48.96	2.14
	0	37.34	1.92	39.66	1.99	41.98	2.06	43.65	2.09	46.61	2.13	48.93	2.17
	5	37.31	1.95	39.63	2.02	41.94	2.10	43.62	2.12	46.58	2.16	48.89	2.20
	10	37.28	1.98	39.59	2.05	41.91	2.13	43.58	2.15	46.54	2.19	48.86	2.24
	14	37.25	2.01	39.56	2.08	41.88	2.16	43.55	2.18	46.51	2.22	48.82	2.27
	20	37.22	2.04	39.53	2.11	41.85	2.19	43.52	2.21	46.47	2.26	48.78	2.30
	25	37.19	2.07	39.50	2.14	41.81	2.22	43.48	2.25	46.43	2.29	48.74	2.33
	30	37.17	2.10	39.47	2.17	41.78	2.25	43.45	2.28	46.40	2.32	48.71	2.37
	35	37.14	2.12	39.44	2.20	41.75	2.28	43.42	2.31	46.36	2.35	48.67	2.40
	40	37.11	2.15	39.41	2.23	41.72	2.31	43.38	2.34	46.33	2.38	48.63	2.43
	45	37.08	2.18	39.38	2.26	41.69	2.34	43.35	2.37	46.29	2.42	48.60	2.46
	50	37.05	2.21	39.35	2.29	41.65	2.38	43.32	2.40	46.26	2.45	48.56	2.50
	55	37.02	2.24	39.32	2.32	41.62	2.41	43.28	2.43	46.22	2.48	48.52	2.53
	60	37.00	2.27	39.29	2.35	41.59	2.44	43.25	2.47	46.19	2.51	48.48	2.56
	65	36.97	2.30	39.26	2.38	41.56	2.47	43.22	2.50	46.15	2.54	48.45	2.59
	70	36.94	2.33	39.23	2.41	41.53	2.50	43.18	2.53	46.12	2.58	48.41	2.63
	75	36.05	2.45	38.34	2.54	40.63	2.63	42.28	2.66	45.20	2.71	47.49	2.77
	80	35.16	2.58	37.44	2.67	39.73	2.77	41.38	2.80	44.29	2.85	46.57	2.91
	85	34.28	2.70	36.56	2.80	38.83	2.90	40.48	2.94	43.39	2.99	45.67	3.05
	90	33.40	2.83	35.67	2.93	37.94	3.04	39.58	3.07	42.48	3.13	44.76	3.19
	95	32.44	2.95	34.70	3.06	36.96	3.17	38.00	3.21	41.48	3.27	43.74	3.34
	100	31.65	3.08	33.91	3.19	36.17	3.31	37.51	3.35	40.69	3.41	42.95	3.48
	105	30.86	3.20	33.12	3.32	35.38	3.44	37.02	3.48	39.90	3.55	42.16	3.62
	110	30.07	3.33	32.33	3.45	34.59	3.58	36.23	3.62	39.11	3.69	41.37	3.76
	115	29.28	3.46	31.54	3.58	33.80	3.71	35.44	3.76	38.32	3.83	40.58	3.90
	118	28.81	3.53	31.07	3.66	33.33	3.79	34.96	3.84	37.85	3.91	40.11	3.99
	122	28.65	3.63	30.91	3.76	33.17	3.90	34.80	3.95	37.69	4.02	39.95	4.10

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 227: LMU540HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 32 (60%)	-4	31.46	1.48	33.41	1.53	35.37	1.59	36.78	1.61	39.28	1.64	41.23	1.67
	0	31.44	1.50	33.40	1.55	35.35	1.61	36.76	1.62	39.25	1.66	41.21	1.69
	5	31.42	1.52	33.37	1.58	35.32	1.63	36.73	1.65	39.22	1.68	41.17	1.72
	10	31.39	1.54	33.34	1.60	35.29	1.66	36.70	1.68	39.19	1.71	41.14	1.74
	14	31.37	1.56	33.32	1.62	35.27	1.68	36.67	1.70	39.16	1.73	41.11	1.77
	20	31.35	1.59	33.29	1.64	35.24	1.70	36.64	1.72	39.13	1.76	41.08	1.79
	25	31.32	1.61	33.27	1.67	35.21	1.73	36.62	1.75	39.10	1.78	41.05	1.82
	30	31.30	1.63	33.24	1.69	35.19	1.75	36.59	1.77	39.07	1.81	41.02	1.84
	35	31.27	1.65	33.22	1.71	35.16	1.78	36.56	1.80	39.04	1.83	40.99	1.87
	40	31.25	1.68	33.19	1.74	35.13	1.80	36.53	1.82	39.01	1.86	40.95	1.89
	45	31.23	1.70	33.17	1.76	35.10	1.83	36.51	1.85	38.98	1.88	40.92	1.92
	50	31.20	1.72	33.14	1.78	35.08	1.85	36.48	1.87	38.95	1.91	40.89	1.94
	55	31.18	1.74	33.11	1.81	35.05	1.87	36.45	1.90	38.92	1.93	40.86	1.97
	60	31.15	1.77	33.09	1.83	35.02	1.90	36.42	1.92	38.89	1.96	40.83	2.00
	65	31.13	1.79	33.06	1.85	35.00	1.92	36.39	1.94	38.86	1.98	40.80	2.02
	70	31.11	1.81	33.04	1.88	34.97	1.95	36.37	1.97	38.83	2.01	40.77	2.05
	75	30.36	1.91	32.28	1.98	34.21	2.05	35.60	2.08	38.07	2.11	39.99	2.16
	80	29.61	2.01	31.53	2.08	33.45	2.16	34.84	2.18	37.30	2.22	39.22	2.27
	85	28.87	2.10	30.78	2.18	32.70	2.26	34.09	2.29	36.54	2.33	38.46	2.38
	90	28.13	2.20	30.04	2.28	31.95	2.37	33.33	2.39	35.78	2.44	37.69	2.49
	95	27.32	2.30	29.22	2.38	31.13	2.47	32.00	2.50	34.93	2.55	36.84	2.60
	100	26.65	2.40	28.56	2.49	30.46	2.58	31.59	2.61	34.27	2.66	36.17	2.71
	105	25.99	2.50	27.89	2.59	29.80	2.68	31.17	2.71	33.60	2.76	35.51	2.82
	110	25.32	2.59	27.23	2.69	29.13	2.79	30.51	2.82	32.94	2.87	34.84	2.93
	115	24.66	2.69	26.56	2.79	28.47	2.89	29.84	2.92	32.27	2.98	34.18	3.04
	118	24.26	2.75	26.16	2.85	28.07	2.95	29.44	2.99	31.87	3.04	33.78	3.11
	122	24.13	2.83	26.03	2.93	27.93	3.04	29.31	3.07	31.74	3.13	33.64	3.19
Non-Ducted Indoor Units 27 (50%)	-4	26.54	1.12	28.19	1.17	29.84	1.21	31.03	1.22	33.14	1.24	34.79	1.27
	0	26.53	1.14	28.18	1.18	29.83	1.22	31.02	1.23	33.12	1.26	34.77	1.28
	5	26.51	1.15	28.15	1.20	29.80	1.24	30.99	1.26	33.09	1.28	34.74	1.30
	10	26.49	1.17	28.13	1.21	29.78	1.26	30.97	1.27	33.07	1.30	34.71	1.32
	14	26.47	1.19	28.11	1.23	29.76	1.28	30.94	1.29	33.04	1.32	34.69	1.34
	20	26.45	1.21	28.09	1.25	29.73	1.30	30.92	1.31	33.02	1.34	34.66	1.36
	25	26.43	1.22	28.07	1.27	29.71	1.31	30.90	1.33	32.99	1.35	34.63	1.38
	30	26.41	1.24	28.05	1.29	29.69	1.33	30.87	1.35	32.97	1.37	34.61	1.40
	35	26.39	1.26	28.03	1.30	29.66	1.35	30.85	1.37	32.94	1.39	34.58	1.42
	40	26.37	1.27	28.00	1.32	29.64	1.37	30.82	1.38	32.92	1.41	34.55	1.44
	45	26.35	1.29	27.98	1.34	29.62	1.39	30.80	1.40	32.89	1.43	34.53	1.46
	50	26.33	1.31	27.96	1.36	29.60	1.41	30.78	1.42	32.87	1.45	34.50	1.48
	55	26.31	1.33	27.94	1.37	29.57	1.42	30.75	1.44	32.84	1.47	34.48	1.50
	60	26.29	1.34	27.92	1.39	29.55	1.44	30.73	1.46	32.82	1.49	34.45	1.52
	65	26.27	1.36	27.90	1.41	29.53	1.46	30.71	1.48	32.79	1.51	34.42	1.54
	70	26.25	1.38	27.88	1.43	29.51	1.48	30.68	1.50	32.77	1.52	34.40	1.56
	75	25.61	1.45	27.24	1.50	28.87	1.56	30.04	1.58	32.12	1.61	33.74	1.64
	80	24.98	1.53	26.60	1.58	28.23	1.64	29.40	1.66	31.47	1.69	33.09	1.72
	85	24.36	1.60	25.97	1.66	27.59	1.72	28.76	1.74	30.83	1.77	32.45	1.81
	90	23.73	1.67	25.34	1.74	26.96	1.80	28.12	1.82	30.19	1.85	31.80	1.89
	95	23.05	1.75	24.66	1.81	26.26	1.88	27.00	1.90	29.48	1.94	31.08	1.97
	100	22.49	1.82	24.10	1.89	25.70	1.96	26.65	1.98	28.91	2.02	30.52	2.06
	105	21.93	1.90	23.53	1.97	25.14	2.04	26.30	2.06	28.35	2.10	29.96	2.14
	110	21.37	1.97	22.97	2.04	24.58	2.12	25.74	2.14	27.79	2.18	29.40	2.23
	115	20.81	2.05	22.41	2.12	24.02	2.20	25.18	2.22	27.23	2.26	28.84	2.31
	118	20.47	2.09	22.08	2.17	23.68	2.25	24.84	2.27	26.89	2.31	28.50	2.36
	122	20.36	2.15	21.96	2.23	23.57	2.31	24.73	2.34	26.78	2.38	28.39	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 228: LMU540HV Cooling Capacity Table — Non-Ducted, continued / Ducted Indoor Units.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 24 (40%)	-4	23.60	0.92	25.06	0.95	26.53	0.99	27.58	1.00	29.46	1.02	30.92	1.04
	0	23.58	0.93	25.05	0.96	26.51	1.00	27.57	1.01	29.44	1.03	30.91	1.05
	5	23.56	0.94	25.03	0.98	26.49	1.01	27.55	1.02	29.42	1.04	30.88	1.06
	10	23.55	0.96	25.01	0.99	26.47	1.03	27.53	1.04	29.39	1.06	30.86	1.08
	14	23.53	0.97	24.99	1.01	26.45	1.04	27.50	1.05	29.37	1.07	30.83	1.10
	20	23.51	0.98	24.97	1.02	26.43	1.06	27.48	1.07	29.35	1.09	30.81	1.11
	25	23.49	1.00	24.95	1.03	26.41	1.07	27.46	1.08	29.33	1.10	30.79	1.13
	30	23.47	1.01	24.93	1.05	26.39	1.09	27.44	1.10	29.30	1.12	30.76	1.14
	35	23.46	1.03	24.91	1.06	26.37	1.10	27.42	1.11	29.28	1.14	30.74	1.16
	40	23.44	1.04	24.89	1.08	26.35	1.12	27.40	1.13	29.26	1.15	30.72	1.17
	45	23.42	1.05	24.87	1.09	26.33	1.13	27.38	1.14	29.24	1.17	30.69	1.19
	50	23.40	1.07	24.85	1.11	26.31	1.15	27.36	1.16	29.21	1.18	30.67	1.21
	55	23.38	1.08	24.84	1.12	26.29	1.16	27.34	1.18	29.19	1.20	30.64	1.22
	60	23.37	1.10	24.82	1.14	26.27	1.18	27.32	1.19	29.17	1.21	30.62	1.24
	65	23.35	1.11	24.80	1.15	26.25	1.19	27.29	1.21	29.15	1.23	30.60	1.25
	70	23.33	1.12	24.78	1.16	26.23	1.21	27.27	1.22	29.13	1.24	30.57	1.27
	75	22.77	1.18	24.21	1.23	25.66	1.27	26.70	1.29	28.55	1.31	29.99	1.34
	80	22.21	1.24	23.65	1.29	25.09	1.34	26.13	1.35	27.97	1.38	29.42	1.41
	85	21.65	1.31	23.09	1.35	24.53	1.40	25.57	1.42	27.40	1.44	28.84	1.47
	90	21.09	1.37	22.53	1.42	23.96	1.47	25.00	1.48	26.83	1.51	28.27	1.54
	95	20.49	1.43	21.92	1.48	23.35	1.53	24.00	1.55	26.20	1.58	27.63	1.61
	100	19.99	1.49	21.42	1.54	22.85	1.60	23.69	1.62	25.70	1.65	27.13	1.68
	105	19.49	1.55	20.92	1.60	22.35	1.66	23.38	1.68	25.20	1.71	26.63	1.75
	110	18.99	1.61	20.42	1.67	21.85	1.73	22.88	1.75	24.70	1.78	26.13	1.82
	115	18.49	1.67	19.92	1.73	21.35	1.79	22.38	1.81	24.20	1.85	25.63	1.88
	118	18.19	1.71	19.62	1.77	21.05	1.83	22.08	1.85	23.90	1.89	25.33	1.93
Ducted Indoor Units 73 (135%)	122	18.10	1.75	19.52	1.82	20.95	1.88	21.98	1.91	23.81	1.94	25.23	1.98
	-4	53.15	3.36	56.45	3.48	59.75	3.61	62.13	3.65	66.35	3.72	69.65	3.80
	0	53.12	3.40	56.42	3.52	59.72	3.65	62.10	3.69	66.32	3.76	69.61	3.84
	5	53.08	3.45	56.37	3.58	59.67	3.71	62.05	3.75	66.26	3.82	69.56	3.90
	10	53.04	3.50	56.33	3.63	59.62	3.76	62.00	3.81	66.21	3.88	69.50	3.96
	14	52.99	3.55	56.29	3.68	59.58	3.82	61.95	3.86	66.16	3.94	69.45	4.01
	20	52.95	3.61	56.24	3.74	59.53	3.87	61.91	3.92	66.11	3.99	69.40	4.07
	25	52.91	3.66	56.20	3.79	59.49	3.93	61.86	3.97	66.06	4.05	69.35	4.13
	30	52.87	3.71	56.16	3.84	59.44	3.98	61.81	4.03	66.01	4.10	69.29	4.19
	35	52.83	3.76	56.11	3.90	59.40	4.04	61.77	4.08	65.96	4.16	69.24	4.25
	40	52.79	3.81	56.07	3.95	59.35	4.09	61.72	4.14	65.91	4.22	69.19	4.30
	45	52.75	3.86	56.03	4.00	59.30	4.15	61.67	4.20	65.86	4.27	69.13	4.36
	50	52.71	3.91	55.99	4.05	59.26	4.20	61.62	4.25	65.81	4.33	69.08	4.42
	55	52.67	3.96	55.94	4.11	59.21	4.26	61.58	4.31	65.76	4.39	69.03	4.48
	60	52.63	4.01	55.90	4.16	59.17	4.31	61.53	4.36	65.71	4.44	68.97	4.53
	65	52.59	4.07	55.86	4.21	59.12	4.37	61.48	4.42	65.66	4.50	68.92	4.59
	70	52.55	4.12	55.81	4.27	59.08	4.42	61.43	4.47	65.60	4.56	68.87	4.65
	75	51.29	4.34	54.54	4.50	57.80	4.66	60.15	4.71	64.31	4.80	67.56	4.90
	80	50.02	4.56	53.27	4.73	56.52	4.90	58.86	4.96	63.01	5.05	66.26	5.15
	85	48.77	4.78	52.01	4.96	55.25	5.14	57.59	5.20	61.73	5.29	64.97	5.40
	90	47.51	5.00	50.75	5.19	53.98	5.38	56.31	5.44	60.44	5.54	63.67	5.65
	95	46.15	5.23	49.37	5.42	52.58	5.62	54.06	5.68	59.02	5.79	62.23	5.90
	100	45.03	5.45	48.25	5.65	51.46	5.85	53.36	5.92	57.89	6.03	61.11	6.15
	105	43.91	5.67	47.12	5.88	50.34	6.09	52.66	6.16	56.77	6.28	59.98	6.40
	110	42.78	5.89	46.00	6.11	49.21	6.33	51.54	6.40	55.64	6.52	58.86	6.66
	115	41.66	6.11	44.87	6.34	48.09	6.57	50.41	6.65	54.52	6.77	57.74	6.91
	118	40.98	6.25	44.20	6.48	47.41	6.71	49.74	6.79	53.85	6.92	57.06	7.06
	122	40.76	6.43	43.97	6.66	47.19	6.90	49.51	6.98	53.62	7.11	56.84	7.26

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 229: LMU540HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 70 (130%)	-4	52.68	3.31	55.95	3.43	59.22	3.55	61.58	3.59	65.76	3.66	69.03	3.74
	0	52.65	3.34	55.92	3.47	59.19	3.59	61.55	3.63	65.73	3.70	69.00	3.78
	5	52.60	3.40	55.87	3.52	59.14	3.65	61.50	3.69	65.67	3.76	68.94	3.84
	10	52.56	3.45	55.83	3.57	59.09	3.70	61.45	3.75	65.62	3.82	68.89	3.89
	14	52.52	3.50	55.79	3.63	59.05	3.76	61.40	3.80	65.57	3.87	68.83	3.95
	20	52.48	3.55	55.74	3.68	59.00	3.81	61.36	3.86	65.52	3.93	68.78	4.01
	25	52.44	3.60	55.70	3.73	58.96	3.87	61.31	3.91	65.47	3.98	68.73	4.06
	30	52.40	3.65	55.66	3.78	58.91	3.92	61.26	3.97	65.42	4.04	68.68	4.12
	35	52.36	3.70	55.62	3.83	58.87	3.97	61.22	4.02	65.37	4.10	68.62	4.18
	40	52.32	3.75	55.57	3.89	58.82	4.03	61.17	4.07	65.32	4.15	68.57	4.23
	45	52.28	3.80	55.53	3.94	58.78	4.08	61.12	4.13	65.27	4.21	68.52	4.29
	50	52.24	3.85	55.49	3.99	58.73	4.14	61.08	4.18	65.22	4.26	68.47	4.35
	55	52.20	3.90	55.45	4.04	58.69	4.19	61.03	4.24	65.17	4.32	68.41	4.40
	60	52.16	3.95	55.40	4.09	58.64	4.24	60.98	4.29	65.12	4.37	68.36	4.46
	65	52.12	4.00	55.36	4.15	58.60	4.30	60.94	4.35	65.07	4.43	68.31	4.52
	70	52.08	4.05	55.32	4.20	58.55	4.35	60.89	4.40	65.02	4.48	68.26	4.58
	75	50.83	4.27	54.06	4.43	57.28	4.59	59.61	4.64	63.74	4.73	66.96	4.82
	80	49.58	4.49	52.80	4.65	56.01	4.82	58.34	4.88	62.45	4.97	65.67	5.07
	85	48.33	4.71	51.55	4.88	54.76	5.06	57.08	5.11	61.18	5.21	64.39	5.32
	90	47.09	4.93	50.30	5.11	53.50	5.29	55.81	5.35	59.90	5.45	63.11	5.56
	95	45.74	5.14	48.93	5.33	52.12	5.53	53.58	5.59	58.49	5.69	61.68	5.81
	100	44.63	5.36	47.82	5.56	51.00	5.76	52.89	5.83	57.38	5.94	60.56	6.06
	105	43.52	5.58	46.70	5.78	49.89	6.00	52.19	6.07	56.26	6.18	59.45	6.30
	110	42.40	5.80	45.59	6.01	48.78	6.23	51.08	6.30	55.15	6.42	58.34	6.55
	115	41.29	6.02	44.48	6.24	47.66	6.47	49.96	6.54	54.04	6.66	57.22	6.80
	118	40.62	6.15	43.81	6.37	46.99	6.61	49.30	6.68	53.37	6.81	56.55	6.94
	122	40.40	6.32	43.58	6.55	46.77	6.79	49.07	6.87	53.14	7.00	56.33	7.14
Ducted Indoor Units 65 (120%)	-4	51.88	3.22	55.10	3.34	58.32	3.46	60.65	3.50	64.77	3.56	67.99	3.63
	0	51.85	3.25	55.07	3.37	58.29	3.50	60.62	3.54	64.73	3.60	67.95	3.67
	5	51.81	3.31	55.03	3.43	58.24	3.55	60.57	3.59	64.68	3.66	67.90	3.73
	10	51.77	3.36	54.98	3.48	58.20	3.60	60.52	3.65	64.63	3.71	67.85	3.79
	14	51.73	3.40	54.94	3.53	58.16	3.66	60.48	3.70	64.58	3.77	67.79	3.84
	20	51.69	3.45	54.90	3.58	58.11	3.71	60.43	3.75	64.53	3.82	67.74	3.90
	25	51.65	3.50	54.86	3.63	58.07	3.76	60.38	3.81	64.48	3.88	67.69	3.96
	30	51.61	3.55	54.82	3.68	58.02	3.82	60.34	3.86	64.43	3.93	67.64	4.01
	35	51.57	3.60	54.78	3.73	57.98	3.87	60.29	3.91	64.38	3.99	67.59	4.07
	40	51.53	3.65	54.73	3.78	57.93	3.92	60.25	3.97	64.33	4.04	67.54	4.12
	45	51.49	3.70	54.69	3.83	57.89	3.97	60.20	4.02	64.29	4.09	67.48	4.18
	50	51.45	3.75	54.65	3.88	57.85	4.03	60.15	4.07	64.24	4.15	67.43	4.23
	55	51.41	3.80	54.61	3.93	57.80	4.08	60.11	4.12	64.19	4.20	67.38	4.29
	60	51.38	3.84	54.57	3.98	57.76	4.13	60.06	4.18	64.14	4.26	67.33	4.34
	65	51.34	3.89	54.52	4.04	57.71	4.18	60.01	4.23	64.09	4.31	67.28	4.40
	70	51.30	3.94	54.48	4.09	57.67	4.24	59.97	4.28	64.04	4.36	67.22	4.45
	75	50.06	4.16	53.24	4.31	56.42	4.46	58.71	4.52	62.77	4.60	65.95	4.69
	80	48.83	4.37	52.00	4.53	55.17	4.69	57.46	4.75	61.51	4.84	64.68	4.93
	85	47.60	4.58	50.77	4.75	53.93	4.92	56.21	4.98	60.25	5.07	63.41	5.17
	90	46.38	4.79	49.53	4.97	52.69	5.15	54.97	5.21	59.00	5.31	62.15	5.41
	95	45.05	5.01	48.19	5.19	51.33	5.38	52.77	5.44	57.61	5.54	60.75	5.65
	100	43.96	5.22	47.09	5.41	50.23	5.61	52.09	5.67	56.51	5.78	59.65	5.89
	105	42.86	5.43	46.00	5.63	49.14	5.84	51.40	5.90	55.41	6.01	58.55	6.13
	110	41.76	5.64	44.90	5.85	48.04	6.06	50.31	6.13	54.32	6.25	57.45	6.37
	115	40.66	5.86	43.80	6.07	46.94	6.29	49.21	6.36	53.22	6.48	56.36	6.61
	118	40.01	5.98	43.14	6.20	46.28	6.43	48.55	6.50	52.56	6.63	55.70	6.76
	122	39.79	6.15	42.93	6.38	46.06	6.61	48.33	6.69	52.34	6.81	55.48	6.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 230: LMU540HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h/[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 59 (110%)	-4	50.94	3.11	54.10	3.22	57.26	3.34	59.55	3.38	63.59	3.44	66.75	3.51
	0	50.91	3.14	54.07	3.25	57.23	3.37	59.52	3.41	63.56	3.48	66.72	3.55
	5	50.87	3.19	54.03	3.31	57.18	3.43	59.47	3.47	63.50	3.53	66.66	3.60
	10	50.83	3.24	53.98	3.36	57.14	3.48	59.42	3.52	63.45	3.58	66.61	3.66
	14	50.79	3.29	53.94	3.41	57.10	3.53	59.38	3.57	63.41	3.64	66.56	3.71
	20	50.75	3.33	53.90	3.45	57.05	3.58	59.33	3.62	63.36	3.69	66.51	3.76
	25	50.71	3.38	53.86	3.50	57.01	3.63	59.29	3.67	63.31	3.74	66.46	3.82
	30	50.67	3.43	53.82	3.55	56.97	3.68	59.24	3.72	63.26	3.79	66.41	3.87
	35	50.63	3.47	53.78	3.60	56.92	3.73	59.19	3.78	63.21	3.85	66.36	3.92
	40	50.60	3.52	53.74	3.65	56.88	3.78	59.15	3.83	63.16	3.90	66.31	3.98
	45	50.56	3.57	53.70	3.70	56.84	3.83	59.10	3.88	63.12	3.95	66.26	4.03
	50	50.52	3.62	53.66	3.75	56.79	3.88	59.06	3.93	63.07	4.00	66.21	4.08
	55	50.48	3.66	53.61	3.80	56.75	3.94	59.01	3.98	63.02	4.06	66.15	4.14
	60	50.44	3.71	53.57	3.85	56.71	3.99	58.97	4.03	62.97	4.11	66.10	4.19
	65	50.40	3.76	53.53	3.89	56.66	4.04	58.92	4.08	62.92	4.16	66.05	4.24
	70	50.36	3.80	53.49	3.94	56.62	4.09	58.88	4.13	62.87	4.21	66.00	4.30
	75	49.15	4.01	52.27	4.16	55.39	4.31	57.64	4.36	61.63	4.44	64.75	4.53
	80	47.94	4.22	51.05	4.37	54.16	4.53	56.41	4.58	60.39	4.67	63.50	4.76
	85	46.74	4.42	49.84	4.58	52.95	4.75	55.19	4.80	59.16	4.89	62.26	4.99
	90	45.54	4.63	48.63	4.79	51.73	4.97	53.97	5.03	57.92	5.12	61.02	5.22
	95	44.23	4.83	47.31	5.01	50.40	5.19	51.81	5.25	56.56	5.35	59.64	5.46
	100	43.16	5.04	46.24	5.22	49.32	5.41	51.14	5.47	55.48	5.58	58.56	5.69
	105	42.08	5.24	45.16	5.43	48.24	5.63	50.47	5.70	54.41	5.80	57.49	5.92
	110	41.00	5.45	44.08	5.65	47.16	5.85	49.39	5.92	53.33	6.03	56.41	6.15
	115	39.92	5.65	43.01	5.86	46.09	6.07	48.31	6.14	52.25	6.26	55.33	6.38
	118	39.28	5.78	42.36	5.99	45.44	6.20	47.67	6.28	51.60	6.39	54.69	6.52
	122	39.06	5.94	42.14	6.16	45.23	6.38	47.45	6.45	51.39	6.58	54.47	6.71
Ducted Indoor Units 54 (100%)	-4	50.14	3.02	53.25	3.13	56.37	3.24	58.62	3.28	62.60	3.34	65.71	3.41
	0	50.11	3.05	53.22	3.16	56.34	3.28	58.58	3.31	62.56	3.38	65.67	3.44
	5	50.07	3.10	53.18	3.21	56.29	3.33	58.54	3.37	62.51	3.43	65.62	3.50
	10	50.03	3.15	53.14	3.26	56.25	3.38	58.49	3.42	62.46	3.48	65.57	3.55
	14	50.00	3.19	53.10	3.31	56.21	3.43	58.45	3.47	62.41	3.53	65.52	3.60
	20	49.96	3.24	53.06	3.36	56.16	3.48	58.40	3.52	62.37	3.58	65.47	3.66
	25	49.92	3.28	53.02	3.40	56.12	3.53	58.36	3.57	62.32	3.63	65.42	3.71
	30	49.88	3.33	52.98	3.45	56.08	3.58	58.31	3.62	62.27	3.69	65.37	3.76
	35	49.84	3.38	52.94	3.50	56.03	3.63	58.27	3.67	62.22	3.74	65.32	3.81
	40	49.80	3.42	52.90	3.55	55.99	3.68	58.22	3.72	62.18	3.79	65.27	3.86
	45	49.77	3.47	52.86	3.59	55.95	3.72	58.18	3.77	62.13	3.84	65.22	3.92
	50	49.73	3.51	52.82	3.64	55.90	3.77	58.14	3.82	62.08	3.89	65.17	3.97
	55	49.69	3.56	52.78	3.69	55.86	3.82	58.09	3.87	62.03	3.94	65.12	4.02
	60	49.65	3.60	52.74	3.74	55.82	3.87	58.05	3.92	61.99	3.99	65.07	4.07
	65	49.61	3.65	52.70	3.78	55.78	3.92	58.00	3.97	61.94	4.04	65.02	4.12
	70	49.58	3.70	52.65	3.83	55.73	3.97	57.96	4.02	61.89	4.09	64.97	4.17
	75	48.38	3.90	51.45	4.04	54.53	4.19	56.74	4.23	60.67	4.31	63.74	4.40
	80	47.19	4.09	50.25	4.24	53.32	4.40	55.53	4.45	59.44	4.53	62.51	4.62
	85	46.01	4.29	49.06	4.45	52.12	4.61	54.33	4.67	58.23	4.75	61.29	4.85
	90	44.82	4.49	47.87	4.66	50.92	4.83	53.12	4.88	57.02	4.97	60.07	5.07
	95	43.54	4.69	46.57	4.86	49.61	5.04	51.00	5.10	55.68	5.20	58.71	5.30
	100	42.48	4.89	45.51	5.07	48.55	5.26	50.34	5.32	54.61	5.42	57.65	5.53
	105	41.42	5.09	44.45	5.28	47.49	5.47	49.68	5.53	53.55	5.64	56.59	5.75
	110	40.36	5.29	43.39	5.48	46.43	5.68	48.62	5.75	52.49	5.86	55.53	5.98
	115	39.30	5.49	42.33	5.69	45.37	5.90	47.56	5.97	51.43	6.08	54.47	6.20
	118	38.66	5.61	41.70	5.82	44.73	6.03	46.92	6.10	50.80	6.21	53.83	6.34
	122	38.45	5.77	41.49	5.98	44.52	6.20	46.71	6.27	50.59	6.39	53.62	6.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 231: LMU540HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 49 (90%)	-4	46.80	2.67	49.70	2.77	52.61	2.87	54.71	2.90	58.42	2.95	61.33	3.01
	0	46.77	2.70	49.68	2.80	52.58	2.90	54.68	2.93	58.39	2.99	61.30	3.05
	5	46.73	2.74	49.64	2.84	52.54	2.95	54.63	2.98	58.34	3.03	61.25	3.10
	10	46.70	2.78	49.60	2.88	52.50	2.99	54.59	3.02	58.30	3.08	61.20	3.14
	14	46.66	2.82	49.56	2.93	52.46	3.03	54.55	3.07	58.25	3.12	61.15	3.19
	20	46.63	2.86	49.52	2.97	52.42	3.08	54.51	3.11	58.21	3.17	61.11	3.23
	25	46.59	2.90	49.48	3.01	52.38	3.12	54.47	3.16	58.17	3.21	61.06	3.28
	30	46.56	2.94	49.45	3.05	52.34	3.16	54.43	3.20	58.12	3.26	61.01	3.32
	35	46.52	2.98	49.41	3.09	52.30	3.21	54.38	3.24	58.08	3.30	60.97	3.37
	40	46.48	3.03	49.37	3.14	52.26	3.25	54.34	3.29	58.03	3.35	60.92	3.42
	45	46.45	3.07	49.33	3.18	52.22	3.29	54.30	3.33	57.99	3.39	60.87	3.46
	50	46.41	3.11	49.30	3.22	52.18	3.34	54.26	3.38	57.94	3.44	60.83	3.51
	55	46.38	3.15	49.26	3.26	52.14	3.38	54.22	3.42	57.90	3.48	60.78	3.55
	60	46.34	3.19	49.22	3.30	52.10	3.42	54.18	3.46	57.85	3.53	60.73	3.60
	65	46.31	3.23	49.18	3.35	52.06	3.47	54.13	3.51	57.81	3.57	60.69	3.65
	70	46.27	3.27	49.14	3.39	52.02	3.51	54.09	3.55	57.77	3.62	60.64	3.69
	75	45.16	3.44	48.02	3.57	50.89	3.70	52.96	3.74	56.62	3.81	59.49	3.89
	80	44.04	3.62	46.90	3.75	49.76	3.89	51.83	3.94	55.48	4.01	58.34	4.09
	85	42.94	3.80	45.79	3.94	48.64	4.08	50.70	4.13	54.35	4.20	57.20	4.29
	90	41.84	3.97	44.68	4.12	47.53	4.27	49.58	4.32	53.22	4.40	56.06	4.49
	95	40.64	4.15	43.47	4.30	46.30	4.46	47.60	4.51	51.96	4.59	54.79	4.69
	100	39.65	4.33	42.48	4.48	45.31	4.65	46.98	4.70	50.97	4.79	53.80	4.89
	105	38.66	4.50	41.49	4.67	44.32	4.84	46.37	4.89	49.98	4.98	52.82	5.09
	110	37.67	4.68	40.50	4.85	43.33	5.03	45.38	5.08	48.99	5.18	51.83	5.28
	115	36.68	4.86	39.51	5.03	42.34	5.22	44.39	5.28	48.00	5.38	50.84	5.48
	118	36.09	4.96	38.92	5.14	41.75	5.33	43.79	5.39	47.41	5.49	50.24	5.60
	122	35.89	5.10	38.72	5.29	41.55	5.48	43.60	5.54	47.21	5.65	50.04	5.76
Ducted Indoor Units 43 (80%)	-4	41.07	2.25	43.62	2.33	46.17	2.42	48.01	2.44	51.27	2.49	53.82	2.54
	0	41.04	2.27	43.59	2.36	46.14	2.44	47.98	2.47	51.24	2.52	53.79	2.57
	5	41.01	2.31	43.56	2.39	46.10	2.48	47.94	2.51	51.20	2.56	53.74	2.61
	10	40.98	2.34	43.52	2.43	46.07	2.52	47.91	2.55	51.16	2.59	53.70	2.65
	14	40.95	2.38	43.49	2.46	46.03	2.55	47.87	2.58	51.12	2.63	53.66	2.69
	20	40.92	2.41	43.46	2.50	46.00	2.59	47.83	2.62	51.08	2.67	53.62	2.72
	25	40.88	2.45	43.42	2.54	45.96	2.63	47.80	2.66	51.04	2.71	53.58	2.76
	30	40.85	2.48	43.39	2.57	45.93	2.66	47.76	2.70	51.00	2.75	53.54	2.80
	35	40.82	2.51	43.36	2.61	45.89	2.70	47.72	2.73	50.96	2.78	53.50	2.84
	40	40.79	2.55	43.32	2.64	45.86	2.74	47.69	2.77	50.92	2.82	53.46	2.88
	45	40.76	2.58	43.29	2.68	45.82	2.78	47.65	2.81	50.89	2.86	53.42	2.92
	50	40.73	2.62	43.26	2.71	45.79	2.81	47.61	2.84	50.85	2.90	53.38	2.96
	55	40.70	2.65	43.22	2.75	45.75	2.85	47.58	2.88	50.81	2.94	53.33	2.99
	60	40.67	2.69	43.19	2.78	45.72	2.89	47.54	2.92	50.77	2.97	53.29	3.03
	65	40.63	2.72	43.16	2.82	45.68	2.92	47.50	2.96	50.73	3.01	53.25	3.07
	70	40.60	2.75	43.13	2.85	45.65	2.96	47.47	2.99	50.69	3.05	53.21	3.11
	75	39.63	2.90	42.14	3.01	44.66	3.12	46.47	3.15	49.69	3.21	52.20	3.28
	80	38.65	3.05	41.16	3.16	43.67	3.28	45.48	3.32	48.69	3.38	51.20	3.45
	85	37.68	3.20	40.18	3.32	42.69	3.44	44.49	3.48	47.69	3.54	50.20	3.61
	90	36.71	3.35	39.21	3.47	41.71	3.60	43.51	3.64	46.70	3.71	49.20	3.78
	95	35.66	3.50	38.15	3.62	40.63	3.76	41.77	3.80	45.60	3.87	48.08	3.95
	100	34.79	3.65	37.28	3.78	39.76	3.92	41.23	3.96	44.73	4.04	47.21	4.12
	105	33.92	3.79	36.41	3.93	38.89	4.08	40.69	4.12	43.86	4.20	46.35	4.28
	110	33.06	3.94	35.54	4.09	38.02	4.24	39.82	4.28	42.99	4.36	45.48	4.45
	115	32.19	4.09	34.67	4.24	37.16	4.40	38.95	4.45	42.13	4.53	44.61	4.62
	118	31.67	4.18	34.15	4.33	36.64	4.49	38.43	4.54	41.60	4.63	44.09	4.72
	122	31.49	4.30	33.98	4.46	36.46	4.62	38.26	4.67	41.43	4.76	43.92	4.86

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 232: LMU540HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 38 (70%)	-4	36.29	1.90	38.54	1.97	40.79	2.04	42.42	2.06	45.30	2.10	47.56	2.14
	0	36.27	1.92	38.52	1.99	40.77	2.06	42.40	2.09	45.28	2.13	47.53	2.17
	5	36.24	1.95	38.49	2.02	40.74	2.10	42.36	2.12	45.24	2.16	47.49	2.20
	10	36.21	1.98	38.46	2.05	40.71	2.13	42.33	2.15	45.21	2.19	47.45	2.24
	14	36.18	2.01	38.43	2.08	40.68	2.16	42.30	2.18	45.17	2.22	47.42	2.27
	20	36.16	2.04	38.40	2.11	40.65	2.19	42.27	2.21	45.14	2.26	47.38	2.30
	25	36.13	2.07	38.37	2.14	40.61	2.22	42.24	2.25	45.10	2.29	47.35	2.33
	30	36.10	2.10	38.34	2.17	40.58	2.25	42.20	2.28	45.07	2.32	47.31	2.37
	35	36.07	2.12	38.31	2.20	40.55	2.28	42.17	2.31	45.03	2.35	47.27	2.40
	40	36.04	2.15	38.28	2.23	40.52	2.31	42.14	2.34	45.00	2.38	47.24	2.43
	45	36.02	2.18	38.25	2.26	40.49	2.34	42.11	2.37	44.96	2.42	47.20	2.46
	50	35.99	2.21	38.22	2.29	40.46	2.38	42.07	2.40	44.93	2.45	47.17	2.50
	55	35.96	2.24	38.20	2.32	40.43	2.41	42.04	2.43	44.90	2.48	47.13	2.53
	60	35.93	2.27	38.17	2.35	40.40	2.44	42.01	2.47	44.86	2.51	47.09	2.56
	65	35.91	2.30	38.14	2.38	40.37	2.47	41.98	2.50	44.83	2.54	47.06	2.59
	70	35.88	2.33	38.11	2.41	40.34	2.50	41.95	2.53	44.79	2.58	47.02	2.63
	75	35.02	2.45	37.24	2.54	39.46	2.63	41.07	2.66	43.91	2.71	46.13	2.77
	80	34.15	2.58	36.37	2.67	38.59	2.77	40.19	2.80	43.02	2.85	45.24	2.91
	85	33.30	2.70	35.51	2.80	37.72	2.90	39.32	2.94	42.14	2.99	44.36	3.05
	90	32.44	2.83	34.65	2.93	36.85	3.04	38.45	3.07	41.27	3.13	43.47	3.19
	95	31.51	2.95	33.71	3.06	35.90	3.17	36.91	3.21	40.29	3.27	42.49	3.34
	100	30.74	3.08	32.94	3.19	35.14	3.31	36.43	3.35	39.53	3.41	41.72	3.48
	105	29.98	3.20	32.17	3.32	34.37	3.44	35.95	3.48	38.76	3.55	40.95	3.62
	110	29.21	3.33	31.41	3.45	33.60	3.58	35.19	3.62	37.99	3.69	40.19	3.76
	115	28.44	3.46	30.64	3.58	32.83	3.71	34.42	3.76	37.22	3.83	39.42	3.90
	118	27.98	3.53	30.18	3.66	32.37	3.79	33.96	3.84	36.76	3.91	38.96	3.99
Ducted Indoor Units 32 (60%)	122	27.83	3.63	30.02	3.76	32.22	3.90	33.80	3.95	36.61	4.02	38.81	4.10
	-4	30.57	1.48	32.46	1.53	34.36	1.59	35.73	1.61	38.16	1.64	40.06	1.67
	0	30.55	1.50	32.45	1.55	34.34	1.61	35.71	1.62	38.14	1.66	40.04	1.69
	5	30.52	1.52	32.42	1.58	34.32	1.63	35.68	1.65	38.11	1.68	40.00	1.72
	10	30.50	1.54	32.39	1.60	34.29	1.66	35.66	1.68	38.08	1.71	39.97	1.74
	14	30.48	1.56	32.37	1.62	34.26	1.68	35.63	1.70	38.05	1.73	39.94	1.77
	20	30.45	1.59	32.35	1.64	34.24	1.70	35.60	1.72	38.02	1.76	39.91	1.79
	25	30.43	1.61	32.32	1.67	34.21	1.73	35.58	1.75	37.99	1.78	39.88	1.82
	30	30.41	1.63	32.30	1.69	34.18	1.75	35.55	1.77	37.96	1.81	39.85	1.84
	35	30.38	1.65	32.27	1.71	34.16	1.78	35.52	1.80	37.93	1.83	39.82	1.87
	40	30.36	1.68	32.25	1.74	34.13	1.80	35.49	1.82	37.90	1.86	39.79	1.89
	45	30.34	1.70	32.22	1.76	34.11	1.83	35.47	1.85	37.87	1.88	39.76	1.92
	50	30.31	1.72	32.20	1.78	34.08	1.85	35.44	1.87	37.85	1.91	39.73	1.94
	55	30.29	1.74	32.17	1.81	34.05	1.87	35.41	1.90	37.82	1.93	39.70	1.97
	60	30.27	1.77	32.15	1.83	34.03	1.90	35.39	1.92	37.79	1.96	39.67	2.00
	65	30.24	1.79	32.12	1.85	34.00	1.92	35.36	1.94	37.76	1.98	39.64	2.02
	70	30.22	1.81	32.10	1.88	33.98	1.95	35.33	1.97	37.73	2.01	39.61	2.05
	75	29.49	1.91	31.37	1.98	33.24	2.05	34.59	2.08	36.98	2.11	38.86	2.16
	80	28.77	2.01	30.63	2.08	32.50	2.16	33.85	2.18	36.24	2.22	38.11	2.27
	85	28.05	2.10	29.91	2.18	31.77	2.26	33.12	2.29	35.50	2.33	37.36	2.38
	90	27.33	2.20	29.18	2.28	31.04	2.37	32.38	2.39	34.76	2.44	36.62	2.49
	95	26.54	2.30	28.39	2.38	30.24	2.47	31.09	2.50	33.94	2.55	35.79	2.60
	100	25.90	2.40	27.75	2.49	29.60	2.58	30.69	2.61	33.29	2.66	35.14	2.71
	105	25.25	2.50	27.10	2.59	28.95	2.68	30.28	2.71	32.65	2.76	34.50	2.82
	110	24.60	2.59	26.45	2.69	28.30	2.79	29.64	2.82	32.00	2.87	33.85	2.93
	115	23.96	2.69	25.81	2.79	27.66	2.89	28.99	2.92	31.35	2.98	33.20	3.04
	118	23.57	2.75	25.42	2.85	27.27	2.95	28.60	2.99	30.97	3.04	32.82	3.11
	122	23.44	2.83	25.29	2.93	27.14	3.04	28.47	3.07	30.84	3.13	32.69	3.19

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 233: LMU540HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 27 (50%)	-4	25.79	1.13	27.39	1.17	28.99	1.21	30.15	1.23	32.19	1.25	33.80	1.28
	0	25.77	1.14	27.37	1.18	28.97	1.23	30.13	1.24	32.18	1.26	33.78	1.29
	5	25.75	1.16	27.35	1.20	28.95	1.25	30.11	1.26	32.15	1.29	33.75	1.31
	10	25.73	1.18	27.33	1.22	28.93	1.27	30.08	1.28	32.13	1.30	33.72	1.33
	14	25.71	1.20	27.31	1.24	28.91	1.28	30.06	1.30	32.10	1.32	33.70	1.35
	20	25.69	1.21	27.29	1.26	28.88	1.30	30.04	1.32	32.08	1.34	33.67	1.37
	25	25.67	1.23	27.27	1.27	28.86	1.32	30.01	1.34	32.05	1.36	33.65	1.39
	30	25.65	1.25	27.25	1.29	28.84	1.34	29.99	1.35	32.03	1.38	33.62	1.41
	35	25.63	1.26	27.23	1.31	28.82	1.36	29.97	1.37	32.00	1.40	33.59	1.43
	40	25.62	1.28	27.21	1.33	28.80	1.38	29.95	1.39	31.98	1.42	33.57	1.45
	45	25.60	1.30	27.19	1.35	28.77	1.39	29.92	1.41	31.95	1.44	33.54	1.47
	50	25.58	1.32	27.16	1.36	28.75	1.41	29.90	1.43	31.93	1.46	33.52	1.49
	55	25.56	1.33	27.14	1.38	28.73	1.43	29.88	1.45	31.90	1.48	33.49	1.51
	60	25.54	1.35	27.12	1.40	28.71	1.45	29.85	1.47	31.88	1.49	33.47	1.52
	65	25.52	1.37	27.10	1.42	28.69	1.47	29.83	1.49	31.86	1.51	33.44	1.54
	70	25.50	1.38	27.08	1.43	28.66	1.49	29.81	1.50	31.83	1.53	33.41	1.56
	75	24.88	1.46	26.46	1.51	28.04	1.57	29.18	1.59	31.20	1.62	32.78	1.65
	80	24.27	1.53	25.85	1.59	27.42	1.65	28.56	1.67	30.57	1.70	32.15	1.73
	85	23.66	1.61	25.23	1.67	26.81	1.73	27.94	1.75	29.95	1.78	31.52	1.82
	90	23.05	1.68	24.62	1.74	26.19	1.81	27.32	1.83	29.33	1.86	30.89	1.90
	95	22.39	1.76	23.95	1.82	25.51	1.89	26.23	1.91	28.63	1.95	30.19	1.98
	100	21.85	1.83	23.41	1.90	24.97	1.97	25.89	1.99	28.09	2.03	29.65	2.07
	105	21.30	1.91	22.86	1.98	24.42	2.05	25.55	2.07	27.54	2.11	29.10	2.15
	110	20.76	1.98	22.32	2.05	23.88	2.13	25.01	2.15	27.00	2.19	28.56	2.24
	115	20.21	2.06	21.77	2.13	23.33	2.21	24.46	2.23	26.45	2.28	28.01	2.32
	118	19.89	2.10	21.45	2.18	23.01	2.26	24.13	2.28	26.13	2.33	27.69	2.37
Ducted Indoor Units 24 (40%)	122	19.78	2.16	21.34	2.24	22.90	2.32	24.02	2.35	26.02	2.39	27.58	2.44
	-4	22.92	0.92	24.34	0.95	25.76	0.99	26.79	1.00	28.61	1.02	30.03	1.04
	0	22.90	0.93	24.33	0.96	25.75	1.00	26.78	1.01	28.59	1.03	30.02	1.05
	5	22.89	0.94	24.31	0.98	25.73	1.01	26.75	1.02	28.57	1.04	29.99	1.06
	10	22.87	0.96	24.29	0.99	25.71	1.03	26.73	1.04	28.55	1.06	29.97	1.08
	14	22.85	0.97	24.27	1.01	25.69	1.04	26.71	1.05	28.53	1.07	29.95	1.10
	20	22.83	0.98	24.25	1.02	25.67	1.06	26.69	1.07	28.51	1.09	29.92	1.11
	25	22.82	1.00	24.23	1.03	25.65	1.07	26.67	1.08	28.48	1.10	29.90	1.13
	30	22.80	1.01	24.21	1.05	25.63	1.09	26.65	1.10	28.46	1.12	29.88	1.14
	35	22.78	1.03	24.20	1.06	25.61	1.10	26.63	1.11	28.44	1.14	29.86	1.16
	40	22.76	1.04	24.18	1.08	25.59	1.12	26.61	1.13	28.42	1.15	29.83	1.17
	45	22.75	1.05	24.16	1.09	25.57	1.13	26.59	1.14	28.40	1.17	29.81	1.19
	50	22.73	1.07	24.14	1.11	25.55	1.15	26.57	1.16	28.37	1.18	29.79	1.21
	55	22.71	1.08	24.12	1.12	25.53	1.16	26.55	1.18	28.35	1.20	29.76	1.22
	60	22.69	1.10	24.10	1.14	25.51	1.18	26.53	1.19	28.33	1.21	29.74	1.24
	65	22.68	1.11	24.08	1.15	25.49	1.19	26.51	1.21	28.31	1.23	29.72	1.25
	70	22.66	1.12	24.07	1.16	25.47	1.21	26.49	1.22	28.29	1.24	29.70	1.27
	75	22.11	1.18	23.52	1.23	24.92	1.27	25.94	1.29	27.73	1.31	29.13	1.34
	80	21.57	1.24	22.97	1.29	24.37	1.34	25.38	1.35	27.17	1.38	28.57	1.41
	85	21.03	1.31	22.42	1.35	23.82	1.40	24.83	1.42	26.62	1.44	28.01	1.47
	90	20.49	1.37	21.88	1.42	23.27	1.47	24.28	1.48	26.06	1.51	27.45	1.54
	95	19.90	1.43	21.29	1.48	22.67	1.53	23.31	1.55	25.45	1.58	26.83	1.61
	100	19.42	1.49	20.80	1.54	22.19	1.60	23.01	1.62	24.96	1.65	26.35	1.68
	105	18.93	1.55	20.32	1.60	21.70	1.66	22.71	1.68	24.48	1.71	25.86	1.75
	110	18.45	1.61	19.83	1.67	21.22	1.73	22.22	1.75	23.99	1.78	25.38	1.82
	115	17.96	1.67	19.35	1.73	20.74	1.79	21.74	1.81	23.51	1.85	24.89	1.88
	118	17.67	1.71	19.06	1.77	20.44	1.83	21.45	1.85	23.22	1.89	24.60	1.93
	122	17.57	1.75	18.96	1.82	20.35	1.88	21.35	1.91	23.12	1.94	24.51	1.98

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 234: LMU540HV Cooling Capacity Table — Mixed Indoor Units.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 73 (135%)	-4	53.94	3.36	57.28	3.48	60.63	3.61	63.05	3.65	67.33	3.72	70.68	3.80
	0	53.91	3.40	57.25	3.52	60.60	3.65	63.02	3.69	67.30	3.76	70.64	3.84
	5	53.86	3.45	57.21	3.58	60.55	3.71	62.97	3.75	67.24	3.82	70.59	3.90
	10	53.82	3.50	57.16	3.63	60.51	3.76	62.92	3.81	67.19	3.88	70.53	3.96
	14	53.78	3.55	57.12	3.68	60.46	3.82	62.87	3.86	67.14	3.94	70.48	4.01
	20	53.74	3.61	57.08	3.74	60.41	3.87	62.82	3.92	67.09	3.99	70.43	4.07
	25	53.70	3.66	57.03	3.79	60.37	3.93	62.78	3.97	67.04	4.05	70.37	4.13
	30	53.66	3.71	56.99	3.84	60.32	3.98	62.73	4.03	66.99	4.10	70.32	4.19
	35	53.62	3.76	56.94	3.90	60.27	4.04	62.68	4.08	66.93	4.16	70.26	4.25
	40	53.57	3.81	56.90	3.95	60.23	4.09	62.63	4.14	66.88	4.22	70.21	4.30
	45	53.53	3.86	56.86	4.00	60.18	4.15	62.58	4.20	66.83	4.27	70.16	4.36
	50	53.49	3.91	56.81	4.05	60.14	4.20	62.54	4.25	66.78	4.33	70.10	4.42
	55	53.45	3.96	56.77	4.11	60.09	4.26	62.49	4.31	66.73	4.39	70.05	4.48
	60	53.41	4.01	56.73	4.16	60.04	4.31	62.44	4.36	66.68	4.44	69.99	4.53
	65	53.37	4.07	56.68	4.21	60.00	4.37	62.39	4.42	66.63	4.50	69.94	4.59
	70	53.33	4.12	56.64	4.27	59.95	4.42	62.34	4.47	66.58	4.56	69.89	4.65
	75	52.04	4.34	55.35	4.50	58.65	4.66	61.04	4.71	65.26	4.80	68.56	4.90
	80	50.76	4.56	54.06	4.73	57.35	4.90	59.73	4.96	63.94	5.05	67.24	5.15
	85	49.49	4.78	52.78	4.96	56.06	5.14	58.44	5.20	62.64	5.29	65.93	5.40
	90	48.22	5.00	51.50	5.19	54.78	5.38	57.14	5.44	61.33	5.54	64.61	5.65
	95	46.84	5.23	50.10	5.42	53.36	5.62	54.86	5.68	59.89	5.79	63.15	5.90
	100	45.70	5.45	48.96	5.65	52.22	5.85	54.15	5.92	58.75	6.03	62.01	6.15
	105	44.56	5.67	47.82	5.88	51.08	6.09	53.44	6.16	57.61	6.28	60.87	6.40
	110	43.42	5.89	46.68	6.11	49.94	6.33	52.30	6.40	56.47	6.52	59.73	6.66
	115	42.27	6.11	45.54	6.34	48.80	6.57	51.16	6.65	55.33	6.77	58.59	6.91
	118	41.59	6.25	44.85	6.48	48.12	6.71	50.47	6.79	54.64	6.92	57.91	7.06
Mixed Indoor Units 70 (130%)	122	41.36	6.43	44.63	6.66	47.89	6.90	50.24	6.98	54.41	7.11	57.68	7.26
	-4	53.44	3.31	56.76	3.43	60.08	3.55	62.48	3.59	66.72	3.66	70.04	3.74
	0	53.41	3.34	56.73	3.47	60.05	3.59	62.44	3.63	66.68	3.70	70.00	3.78
	5	53.37	3.40	56.68	3.52	60.00	3.65	62.39	3.69	66.63	3.76	69.94	3.84
	10	53.33	3.45	56.64	3.57	59.95	3.70	62.35	3.75	66.58	3.82	69.89	3.89
	14	53.29	3.50	56.60	3.63	59.91	3.76	62.30	3.80	66.53	3.87	69.84	3.95
	20	53.25	3.55	56.56	3.68	59.86	3.81	62.25	3.86	66.48	3.93	69.78	4.01
	25	53.21	3.60	56.51	3.73	59.82	3.87	62.20	3.91	66.43	3.98	69.73	4.06
	30	53.17	3.65	56.47	3.78	59.77	3.92	62.16	3.97	66.37	4.04	69.68	4.12
	35	53.13	3.70	56.43	3.83	59.73	3.97	62.11	4.02	66.32	4.10	69.62	4.18
	40	53.09	3.75	56.38	3.89	59.68	4.03	62.06	4.07	66.27	4.15	69.57	4.23
	45	53.05	3.80	56.34	3.94	59.63	4.08	62.01	4.13	66.22	4.21	69.52	4.29
	50	53.00	3.85	56.30	3.99	59.59	4.14	61.97	4.18	66.17	4.26	69.46	4.35
	55	52.96	3.90	56.25	4.04	59.54	4.19	61.92	4.24	66.12	4.32	69.41	4.40
	60	52.92	3.95	56.21	4.09	59.50	4.24	61.87	4.29	66.07	4.37	69.36	4.46
	65	52.88	4.00	56.17	4.15	59.45	4.30	61.82	4.35	66.02	4.43	69.30	4.52
	70	52.84	4.05	56.12	4.20	59.41	4.35	61.78	4.40	65.97	4.48	69.25	4.58
	75	51.57	4.27	54.84	4.43	58.12	4.59	60.48	4.64	64.66	4.73	67.94	4.82
	80	50.30	4.49	53.56	4.65	56.83	4.82	59.19	4.88	63.36	4.97	66.63	5.07
	85	49.04	4.71	52.30	4.88	55.55	5.06	57.91	5.11	62.07	5.21	65.33	5.32
	90	47.78	4.93	51.03	5.11	54.28	5.29	56.62	5.35	60.78	5.45	64.02	5.56
	95	46.41	5.14	49.64	5.33	52.88	5.53	54.36	5.59	59.34	5.69	62.58	5.81
	100	45.28	5.36	48.51	5.56	51.75	5.76	53.66	5.83	58.21	5.94	61.45	6.06
	105	44.15	5.58	47.38	5.78	50.62	6.00	52.95	6.07	57.08	6.18	60.32	6.30
	110	43.02	5.80	46.25	6.01	49.49	6.23	51.82	6.30	55.95	6.42	59.19	6.55
	115	41.89	6.02	45.12	6.24	48.36	6.47	50.69	6.54	54.82	6.66	58.06	6.80
	118	41.21	6.15	44.44	6.37	47.68	6.61	50.01	6.68	54.14	6.81	57.38	6.94
	122	40.99	6.32	44.22	6.55	47.45	6.79	49.79	6.87	53.92	7.00	57.15	7.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 235: LMU540HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 65 (120%)	-4	52.65	3.22	55.92	3.34	59.19	3.46	61.55	3.50	65.73	3.56	69.00	3.63
	0	52.62	3.25	55.89	3.37	59.15	3.50	61.51	3.54	65.69	3.60	68.96	3.67
	5	52.58	3.31	55.84	3.43	59.11	3.55	61.46	3.59	65.64	3.66	68.90	3.73
	10	52.53	3.36	55.80	3.48	59.06	3.60	61.42	3.65	65.59	3.71	68.85	3.79
	14	52.49	3.40	55.76	3.53	59.02	3.66	61.37	3.70	65.54	3.77	68.80	3.84
	20	52.45	3.45	55.71	3.58	58.97	3.71	61.32	3.75	65.49	3.82	68.74	3.90
	25	52.41	3.50	55.67	3.63	58.93	3.76	61.28	3.81	65.44	3.88	68.69	3.96
	30	52.37	3.55	55.63	3.68	58.88	3.82	61.23	3.86	65.39	3.93	68.64	4.01
	35	52.33	3.60	55.58	3.73	58.84	3.87	61.18	3.91	65.34	3.99	68.59	4.07
	40	52.29	3.65	55.54	3.78	58.79	3.92	61.14	3.97	65.29	4.04	68.53	4.12
	45	52.25	3.70	55.50	3.83	58.75	3.97	61.09	4.02	65.24	4.09	68.48	4.18
	50	52.21	3.75	55.46	3.88	58.70	4.03	61.04	4.07	65.19	4.15	68.43	4.23
	55	52.17	3.80	55.41	3.93	58.66	4.08	61.00	4.12	65.14	4.20	68.38	4.29
	60	52.13	3.84	55.37	3.98	58.61	4.13	60.95	4.18	65.09	4.26	68.32	4.34
	65	52.09	3.89	55.33	4.04	58.57	4.18	60.90	4.23	65.04	4.31	68.27	4.40
	70	52.05	3.94	55.29	4.09	58.52	4.24	60.85	4.28	64.99	4.36	68.22	4.45
	75	50.80	4.16	54.03	4.31	57.25	4.46	59.58	4.52	63.70	4.60	66.93	4.69
	80	49.55	4.37	52.77	4.53	55.98	4.69	58.31	4.75	62.42	4.84	65.63	4.93
	85	48.31	4.58	51.52	4.75	54.73	4.92	57.04	4.98	61.14	5.07	64.35	5.17
	90	47.07	4.79	50.27	4.97	53.47	5.15	55.78	5.21	59.87	5.31	63.07	5.41
	95	45.72	5.01	48.90	5.19	52.09	5.38	53.55	5.44	58.46	5.54	61.64	5.65
	100	44.61	5.22	47.79	5.41	50.98	5.61	52.86	5.67	57.35	5.78	60.53	5.89
	105	43.49	5.43	46.68	5.63	49.86	5.84	52.16	5.90	56.23	6.01	59.42	6.13
	110	42.38	5.64	45.56	5.85	48.75	6.06	51.05	6.13	55.12	6.25	58.30	6.37
	115	41.27	5.86	44.45	6.07	47.64	6.29	49.94	6.36	54.01	6.48	57.19	6.61
	118	40.60	5.98	43.78	6.20	46.97	6.43	49.27	6.50	53.34	6.63	56.52	6.76
Mixed Indoor Units 59 (110%)	122	40.37	6.15	43.56	6.38	46.74	6.61	49.05	6.69	53.11	6.81	56.30	6.95
	-4	51.68	3.11	54.89	3.22	58.10	3.34	60.42	3.38	64.52	3.44	67.73	3.51
	0	51.66	3.14	54.86	3.25	58.07	3.37	60.39	3.41	64.49	3.48	67.70	3.55
	5	51.61	3.19	54.82	3.31	58.02	3.43	60.34	3.47	64.43	3.53	67.64	3.60
	10	51.57	3.24	54.78	3.36	57.98	3.48	60.29	3.52	64.39	3.58	67.59	3.66
	14	51.53	3.29	54.73	3.41	57.94	3.53	60.25	3.57	64.34	3.64	67.54	3.71
	20	51.49	3.33	54.69	3.45	57.89	3.58	60.20	3.62	64.29	3.69	67.49	3.76
	25	51.46	3.38	54.65	3.50	57.85	3.63	60.15	3.67	64.24	3.74	67.43	3.82
	30	51.42	3.43	54.61	3.55	57.80	3.68	60.11	3.72	64.19	3.79	67.38	3.87
	35	51.38	3.47	54.57	3.60	57.76	3.73	60.06	3.78	64.14	3.85	67.33	3.92
	40	51.34	3.52	54.53	3.65	57.71	3.78	60.02	3.83	64.09	3.90	67.28	3.98
	45	51.30	3.57	54.48	3.70	57.67	3.83	59.97	3.88	64.04	3.95	67.23	4.03
	50	51.26	3.62	54.44	3.75	57.63	3.88	59.93	3.93	63.99	4.00	67.18	4.08
	55	51.22	3.66	54.40	3.80	57.58	3.94	59.88	3.98	63.94	4.06	67.12	4.14
	60	51.18	3.71	54.36	3.85	57.54	3.99	59.83	4.03	63.89	4.11	67.07	4.19
	65	51.14	3.76	54.32	3.89	57.49	4.04	59.79	4.08	63.85	4.16	67.02	4.24
	70	51.10	3.80	54.28	3.94	57.45	4.09	59.74	4.13	63.80	4.21	66.97	4.30
	75	49.87	4.01	53.04	4.16	56.20	4.31	58.49	4.36	62.54	4.44	65.70	4.53
	80	48.64	4.22	51.80	4.37	54.96	4.53	57.24	4.58	61.27	4.67	64.43	4.76
	85	47.42	4.42	50.57	4.58	53.72	4.75	56.00	4.80	60.02	4.89	63.17	4.99
	90	46.20	4.63	49.35	4.79	52.49	4.97	54.76	5.03	58.77	5.12	61.92	5.22
	95	44.88	4.83	48.01	5.01	51.14	5.19	52.57	5.25	57.39	5.35	60.52	5.46
	100	43.79	5.04	46.92	5.22	50.04	5.41	51.89	5.47	56.30	5.58	59.42	5.69
	105	42.70	5.24	45.82	5.43	48.95	5.63	51.21	5.70	55.20	5.80	58.33	5.92
	110	41.60	5.45	44.73	5.65	47.86	5.85	50.11	5.92	54.11	6.03	57.24	6.15
	115	40.51	5.65	43.64	5.86	46.76	6.07	49.02	6.14	53.02	6.26	56.14	6.38
	118	39.85	5.78	42.98	5.99	46.11	6.20	48.37	6.28	52.36	6.39	55.49	6.52
	122	39.64	5.94	42.76	6.16	45.89	6.38	48.15	6.45	52.14	6.58	55.27	6.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 236: LMU540HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 54 (100%)	-4	50.88	3.02	54.04	3.13	57.20	3.24	59.48	3.28	63.52	3.34	66.68	3.41
	0	50.85	3.05	54.01	3.16	57.17	3.28	59.45	3.31	63.48	3.38	66.64	3.44
	5	50.81	3.10	53.96	3.21	57.12	3.33	59.40	3.37	63.43	3.43	66.58	3.50
	10	50.77	3.15	53.92	3.26	57.08	3.38	59.35	3.42	63.38	3.48	66.53	3.55
	14	50.73	3.19	53.88	3.31	57.03	3.43	59.31	3.47	63.33	3.53	66.48	3.60
	20	50.69	3.24	53.84	3.36	56.99	3.48	59.26	3.52	63.28	3.58	66.43	3.66
	25	50.65	3.28	53.80	3.40	56.94	3.53	59.22	3.57	63.24	3.63	66.38	3.71
	30	50.61	3.33	53.76	3.45	56.90	3.58	59.17	3.62	63.19	3.69	66.33	3.76
	35	50.58	3.38	53.72	3.50	56.86	3.63	59.13	3.67	63.14	3.74	66.28	3.81
	40	50.54	3.42	53.68	3.55	56.81	3.68	59.08	3.72	63.09	3.79	66.23	3.86
	45	50.50	3.47	53.63	3.59	56.77	3.72	59.04	3.77	63.04	3.84	66.18	3.92
	50	50.46	3.51	53.59	3.64	56.73	3.77	58.99	3.82	62.99	3.89	66.13	3.97
	55	50.42	3.56	53.55	3.69	56.68	3.82	58.95	3.87	62.95	3.94	66.08	4.02
	60	50.38	3.60	53.51	3.74	56.64	3.87	58.90	3.92	62.90	3.99	66.03	4.07
	65	50.34	3.65	53.47	3.78	56.60	3.92	58.85	3.97	62.85	4.04	65.98	4.12
	70	50.30	3.70	53.43	3.83	56.55	3.97	58.81	4.02	62.80	4.09	65.93	4.17
	75	49.09	3.90	52.21	4.04	55.33	4.19	57.58	4.23	61.56	4.31	64.68	4.40
	80	47.88	4.09	50.99	4.24	54.10	4.40	56.35	4.45	60.32	4.53	63.43	4.62
	85	46.68	4.29	49.78	4.45	52.89	4.61	55.13	4.67	59.09	4.75	62.19	4.85
	90	45.48	4.49	48.58	4.66	51.67	4.83	53.90	4.88	57.86	4.97	60.95	5.07
	95	44.18	4.69	47.26	4.86	50.34	5.04	51.75	5.10	56.49	5.20	59.57	5.30
	100	43.11	4.89	46.18	5.07	49.26	5.26	51.08	5.32	55.42	5.42	58.50	5.53
	105	42.03	5.09	45.11	5.28	48.19	5.47	50.41	5.53	54.34	5.64	57.42	5.75
	110	40.95	5.29	44.03	5.48	47.11	5.68	49.33	5.75	53.27	5.86	56.34	5.98
	115	39.88	5.49	42.96	5.69	46.03	5.90	48.26	5.97	52.19	6.08	55.27	6.20
	118	39.23	5.61	42.31	5.82	45.39	6.03	47.61	6.10	51.54	6.21	54.62	6.34
Mixed Indoor Units 49 (90%)	122	39.02	5.77	42.10	5.98	45.17	6.20	47.40	6.27	51.33	6.39	54.41	6.52
	-4	47.49	2.67	50.43	2.77	53.38	2.87	55.51	2.90	59.28	2.95	62.23	3.01
	0	47.46	2.70	50.41	2.80	53.35	2.90	55.48	2.93	59.25	2.99	62.20	3.05
	5	47.42	2.74	50.37	2.84	53.31	2.95	55.44	2.98	59.20	3.03	62.15	3.10
	10	47.38	2.78	50.33	2.88	53.27	2.99	55.40	3.02	59.16	3.08	62.10	3.14
	14	47.35	2.82	50.29	2.93	53.23	3.03	55.35	3.07	59.11	3.12	62.05	3.19
	20	47.31	2.86	50.25	2.97	53.19	3.08	55.31	3.11	59.07	3.17	62.00	3.23
	25	47.28	2.90	50.21	3.01	53.15	3.12	55.27	3.16	59.02	3.21	61.96	3.28
	30	47.24	2.94	50.17	3.05	53.11	3.16	55.23	3.20	58.98	3.26	61.91	3.32
	35	47.20	2.98	50.14	3.09	53.07	3.21	55.18	3.24	58.93	3.30	61.86	3.37
	40	47.17	3.03	50.10	3.14	53.03	3.25	55.14	3.29	58.89	3.35	61.81	3.42
	45	47.13	3.07	50.06	3.18	52.99	3.29	55.10	3.33	58.84	3.39	61.77	3.46
	50	47.10	3.11	50.02	3.22	52.95	3.34	55.06	3.38	58.79	3.44	61.72	3.51
	55	47.06	3.15	49.98	3.26	52.90	3.38	55.02	3.42	58.75	3.48	61.67	3.55
	60	47.02	3.19	49.94	3.30	52.86	3.42	54.97	3.46	58.70	3.53	61.63	3.60
	65	46.99	3.23	49.91	3.35	52.82	3.47	54.93	3.51	58.66	3.57	61.58	3.65
	70	46.95	3.27	49.87	3.39	52.78	3.51	54.89	3.55	58.61	3.62	61.53	3.69
	75	45.82	3.44	48.73	3.57	51.64	3.70	53.74	3.74	57.46	3.81	60.36	3.89
	80	44.69	3.62	47.59	3.75	50.49	3.89	52.59	3.94	56.30	4.01	59.20	4.09
	85	43.57	3.80	46.47	3.94	49.36	4.08	51.45	4.13	55.15	4.20	58.04	4.29
	90	42.45	3.97	45.34	4.12	48.23	4.27	50.31	4.32	54.00	4.40	56.89	4.49
	95	41.24	4.15	44.11	4.30	46.98	4.46	48.30	4.51	52.73	4.59	55.60	4.69
	100	40.23	4.33	43.11	4.48	45.98	4.65	47.67	4.70	51.72	4.79	54.60	4.89
	105	39.23	4.50	42.10	4.67	44.97	4.84	47.05	4.89	50.72	4.98	53.59	5.09
	110	38.22	4.68	41.10	4.85	43.97	5.03	46.04	5.08	49.72	5.18	52.59	5.28
	115	37.22	4.86	40.09	5.03	42.97	5.22	45.04	5.28	48.71	5.38	51.58	5.48
	118	36.62	4.96	39.49	5.14	42.36	5.33	44.44	5.39	48.11	5.49	50.98	5.60
	122	36.42	5.10	39.29	5.29	42.16	5.48	44.24	5.54	47.91	5.65	50.78	5.76

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 237: LMU540HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 43 (80%)	-4	41.68	2.25	44.26	2.33	46.85	2.42	48.72	2.44	52.03	2.49	54.62	2.54
	0	41.65	2.27	44.24	2.36	46.83	2.44	48.69	2.47	52.00	2.52	54.59	2.57
	5	41.62	2.31	44.20	2.39	46.79	2.48	48.65	2.51	51.96	2.56	54.54	2.61
	10	41.59	2.34	44.17	2.43	46.75	2.52	48.62	2.55	51.92	2.59	54.50	2.65
	14	41.55	2.38	44.14	2.46	46.72	2.55	48.58	2.58	51.88	2.63	54.46	2.69
	20	41.52	2.41	44.10	2.50	46.68	2.59	48.54	2.62	51.84	2.67	54.42	2.72
	25	41.49	2.45	44.07	2.54	46.65	2.63	48.51	2.66	51.80	2.71	54.38	2.76
	30	41.46	2.48	44.03	2.57	46.61	2.66	48.47	2.70	51.76	2.75	54.33	2.80
	35	41.43	2.51	44.00	2.61	46.57	2.70	48.43	2.73	51.72	2.78	54.29	2.84
	40	41.40	2.55	43.97	2.64	46.54	2.74	48.39	2.77	51.68	2.82	54.25	2.88
	45	41.36	2.58	43.93	2.68	46.50	2.78	48.36	2.81	51.64	2.86	54.21	2.92
	50	41.33	2.62	43.90	2.71	46.47	2.81	48.32	2.84	51.60	2.90	54.17	2.96
	55	41.30	2.65	43.87	2.75	46.43	2.85	48.28	2.88	51.56	2.94	54.13	2.99
	60	41.27	2.69	43.83	2.78	46.40	2.89	48.25	2.92	51.52	2.97	54.08	3.03
	65	41.24	2.72	43.80	2.82	46.36	2.92	48.21	2.96	51.48	3.01	54.04	3.07
	70	41.21	2.75	43.77	2.85	46.32	2.96	48.17	2.99	51.44	3.05	54.00	3.11
	75	40.21	2.90	42.77	3.01	45.32	3.12	47.16	3.15	50.43	3.21	52.98	3.28
	80	39.22	3.05	41.77	3.16	44.32	3.28	46.16	3.32	49.41	3.38	51.96	3.45
	85	38.24	3.20	40.78	3.32	43.32	3.44	45.16	3.48	48.40	3.54	50.94	3.61
	90	37.26	3.35	39.79	3.47	42.33	3.60	44.16	3.64	47.39	3.71	49.93	3.78
	95	36.19	3.50	38.71	3.62	41.23	3.76	42.39	3.80	46.28	3.87	48.80	3.95
	100	35.31	3.65	37.83	3.78	40.35	3.92	41.84	3.96	45.39	4.04	47.92	4.12
	105	34.43	3.79	36.95	3.93	39.47	4.08	41.29	4.12	44.51	4.20	47.03	4.28
	110	33.55	3.94	36.07	4.09	38.59	4.24	40.41	4.28	43.63	4.36	46.15	4.45
	115	32.67	4.09	35.19	4.24	37.71	4.40	39.53	4.45	42.75	4.53	45.27	4.62
	118	32.14	4.18	34.66	4.33	37.18	4.49	39.00	4.54	42.22	4.63	44.74	4.72
	122	31.96	4.30	34.48	4.46	37.00	4.62	38.82	4.67	42.05	4.76	44.57	4.86
Mixed Indoor Units 38 (70%)	-4	36.83	1.90	39.12	1.97	41.40	2.04	43.05	2.06	45.98	2.10	48.26	2.14
	0	36.81	1.92	39.09	1.99	41.38	2.06	43.03	2.09	45.95	2.13	48.24	2.17
	5	36.78	1.95	39.06	2.02	41.35	2.10	43.00	2.12	45.91	2.16	48.20	2.20
	10	36.75	1.98	39.03	2.05	41.31	2.13	42.96	2.15	45.88	2.19	48.16	2.24
	14	36.72	2.01	39.00	2.08	41.28	2.16	42.93	2.18	45.84	2.22	48.12	2.27
	20	36.69	2.04	38.97	2.11	41.25	2.19	42.90	2.21	45.81	2.26	48.09	2.30
	25	36.67	2.07	38.94	2.14	41.22	2.22	42.86	2.25	45.77	2.29	48.05	2.33
	30	36.64	2.10	38.91	2.17	41.19	2.25	42.83	2.28	45.74	2.32	48.01	2.37
	35	36.61	2.12	38.88	2.20	41.16	2.28	42.80	2.31	45.70	2.35	47.98	2.40
	40	36.58	2.15	38.85	2.23	41.13	2.31	42.77	2.34	45.67	2.38	47.94	2.43
	45	36.55	2.18	38.82	2.26	41.09	2.34	42.73	2.37	45.63	2.42	47.90	2.46
	50	36.53	2.21	38.79	2.29	41.06	2.38	42.70	2.40	45.60	2.45	47.87	2.50
	55	36.50	2.24	38.76	2.32	41.03	2.41	42.67	2.43	45.56	2.48	47.83	2.53
	60	36.47	2.27	38.73	2.35	41.00	2.44	42.64	2.47	45.53	2.51	47.79	2.56
	65	36.44	2.30	38.71	2.38	40.97	2.47	42.60	2.50	45.49	2.54	47.76	2.59
	70	36.41	2.33	38.68	2.41	40.94	2.50	42.57	2.53	45.46	2.58	47.72	2.63
	75	35.54	2.45	37.79	2.54	40.05	2.63	41.68	2.66	44.56	2.71	46.82	2.77
	80	34.66	2.58	36.91	2.67	39.16	2.77	40.79	2.80	43.66	2.85	45.91	2.91
	85	33.79	2.70	36.04	2.80	38.28	2.90	39.90	2.94	42.77	2.99	45.02	3.05
	90	32.92	2.83	35.16	2.93	37.40	3.04	39.02	3.07	41.88	3.13	44.12	3.19
	95	31.98	2.95	34.21	3.06	36.44	3.17	37.46	3.21	40.89	3.27	43.12	3.34
	100	31.20	3.08	33.43	3.19	35.66	3.31	36.97	3.35	40.12	3.41	42.34	3.48
	105	30.42	3.20	32.65	3.32	34.88	3.44	36.49	3.48	39.34	3.55	41.56	3.62
	110	29.65	3.33	31.87	3.45	34.10	3.58	35.71	3.62	38.56	3.69	40.79	3.76
	115	28.87	3.46	31.09	3.58	33.32	3.71	34.93	3.76	37.78	3.83	40.01	3.90
	118	28.40	3.53	30.63	3.66	32.86	3.79	34.46	3.84	37.31	3.91	39.54	3.99
	122	28.24	3.63	30.47	3.76	32.70	3.90	34.31	3.95	37.16	4.02	39.38	4.10

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU540HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 238: LMU540HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 32 (60%)	-4	31.01	1.48	32.93	1.53	34.86	1.59	36.25	1.61	38.71	1.64	40.64	1.67
	0	30.99	1.50	32.92	1.55	34.84	1.61	36.23	1.62	38.69	1.66	40.61	1.69
	5	30.97	1.52	32.89	1.58	34.81	1.63	36.20	1.65	38.66	1.68	40.58	1.72
	10	30.94	1.54	32.86	1.60	34.79	1.66	36.17	1.68	38.63	1.71	40.55	1.74
	14	30.92	1.56	32.84	1.62	34.76	1.68	36.15	1.70	38.60	1.73	40.52	1.77
	20	30.90	1.59	32.81	1.64	34.73	1.70	36.12	1.72	38.57	1.76	40.49	1.79
	25	30.87	1.61	32.79	1.67	34.71	1.73	36.09	1.75	38.54	1.78	40.46	1.82
	30	30.85	1.63	32.76	1.69	34.68	1.75	36.06	1.77	38.51	1.81	40.43	1.84
	35	30.82	1.65	32.74	1.71	34.65	1.78	36.04	1.80	38.48	1.83	40.40	1.87
	40	30.80	1.68	32.71	1.74	34.63	1.80	36.01	1.82	38.45	1.86	40.36	1.89
	45	30.78	1.70	32.69	1.76	34.60	1.83	35.98	1.85	38.42	1.88	40.33	1.92
	50	30.75	1.72	32.66	1.78	34.57	1.85	35.95	1.87	38.39	1.91	40.30	1.94
	55	30.73	1.74	32.64	1.81	34.55	1.87	35.93	1.90	38.36	1.93	40.27	1.97
	60	30.71	1.77	32.61	1.83	34.52	1.90	35.90	1.92	38.33	1.96	40.24	2.00
	65	30.68	1.79	32.59	1.85	34.49	1.92	35.87	1.94	38.30	1.98	40.21	2.02
	70	30.66	1.81	32.56	1.88	34.47	1.95	35.84	1.97	38.28	2.01	40.18	2.05
	75	29.92	1.91	31.82	1.98	33.72	2.05	35.09	2.08	37.52	2.11	39.42	2.16
	80	29.18	2.01	31.08	2.08	32.97	2.16	34.34	2.18	36.76	2.22	38.66	2.27
	85	28.45	2.10	30.34	2.18	32.23	2.26	33.60	2.29	36.01	2.33	37.90	2.38
	90	27.72	2.20	29.61	2.28	31.49	2.37	32.85	2.39	35.26	2.44	37.15	2.49
	95	26.93	2.30	28.80	2.38	30.68	2.47	31.54	2.50	34.43	2.55	36.31	2.60
	100	26.27	2.40	28.15	2.49	30.02	2.58	31.13	2.61	33.78	2.66	35.65	2.71
	105	25.62	2.50	27.49	2.59	29.37	2.68	30.72	2.71	33.12	2.76	35.00	2.82
	110	24.96	2.59	26.84	2.69	28.71	2.79	30.07	2.82	32.46	2.87	34.34	2.93
	115	24.30	2.69	26.18	2.79	28.06	2.89	29.41	2.92	31.81	2.98	33.68	3.04
	118	23.91	2.75	25.79	2.85	27.66	2.95	29.02	2.99	31.41	3.04	33.29	3.11
Mixed Indoor Units 27 (50%)	122	23.78	2.83	25.66	2.93	27.53	3.04	28.89	3.07	31.28	3.13	33.16	3.19
	-4	26.16	1.12	27.79	1.17	29.41	1.21	30.58	1.22	32.66	1.24	34.29	1.27
	0	26.15	1.14	27.77	1.18	29.39	1.22	30.57	1.23	32.64	1.26	34.27	1.28
	5	26.13	1.15	27.75	1.20	29.37	1.24	30.54	1.26	32.62	1.28	34.24	1.30
	10	26.11	1.17	27.73	1.21	29.35	1.26	30.52	1.27	32.59	1.30	34.21	1.32
	14	26.09	1.19	27.71	1.23	29.33	1.28	30.50	1.29	32.57	1.32	34.19	1.34
	20	26.07	1.21	27.68	1.25	29.30	1.30	30.47	1.31	32.54	1.34	34.16	1.36
	25	26.05	1.22	27.66	1.27	29.28	1.31	30.45	1.33	32.52	1.35	34.13	1.38
	30	26.03	1.24	27.64	1.29	29.26	1.33	30.43	1.35	32.49	1.37	34.11	1.40
	35	26.01	1.26	27.62	1.30	29.24	1.35	30.40	1.37	32.47	1.39	34.08	1.42
	40	25.99	1.27	27.60	1.32	29.21	1.37	30.38	1.38	32.44	1.41	34.06	1.44
	45	25.97	1.29	27.58	1.34	29.19	1.39	30.36	1.40	32.42	1.43	34.03	1.46
	50	25.95	1.31	27.56	1.36	29.17	1.41	30.33	1.42	32.39	1.45	34.00	1.48
	55	25.93	1.33	27.54	1.37	29.15	1.42	30.31	1.44	32.37	1.47	33.98	1.50
	60	25.91	1.34	27.52	1.39	29.12	1.44	30.29	1.46	32.34	1.49	33.95	1.52
	65	25.89	1.36	27.49	1.41	29.10	1.46	30.26	1.48	32.32	1.51	33.93	1.54
	70	25.87	1.38	27.47	1.43	29.08	1.48	30.24	1.50	32.29	1.52	33.90	1.56
	75	25.24	1.45	26.85	1.50	28.45	1.56	29.61	1.58	31.65	1.61	33.26	1.64
	80	24.62	1.53	26.22	1.58	27.82	1.64	28.97	1.66	31.02	1.69	32.61	1.72
	85	24.00	1.60	25.60	1.66	27.19	1.72	28.35	1.74	30.38	1.77	31.98	1.81
	90	23.39	1.67	24.98	1.74	26.57	1.80	27.72	1.82	29.75	1.85	31.34	1.89
	95	22.72	1.75	24.30	1.81	25.88	1.88	26.61	1.90	29.05	1.94	30.63	1.97
	100	22.17	1.82	23.75	1.89	25.33	1.96	26.27	1.98	28.50	2.02	30.08	2.06
	105	21.61	1.90	23.19	1.97	24.78	2.04	25.92	2.06	27.94	2.10	29.53	2.14
	110	21.06	1.97	22.64	2.04	24.22	2.12	25.37	2.14	27.39	2.18	28.97	2.23
	115	20.51	2.05	22.09	2.12	23.67	2.20	24.81	2.22	26.84	2.26	28.42	2.31
	118	20.17	2.09	21.76	2.17	23.34	2.25	24.48	2.27	26.50	2.31	28.09	2.36
	122	20.06	2.15	21.65	2.23	23.23	2.31	24.37	2.34	26.39	2.38	27.98	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 239: LMU540HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 24 (40%)	-4	23.26	0.92	24.71	0.95	26.15	0.99	27.19	1.00	29.04	1.02	30.48	1.04
	0	23.25	0.93	24.69	0.96	26.14	1.00	27.18	1.01	29.02	1.03	30.47	1.05
	5	23.23	0.94	24.67	0.98	26.11	1.01	27.16	1.02	29.00	1.04	30.44	1.06
	10	23.21	0.96	24.65	0.99	26.09	1.03	27.14	1.04	28.98	1.06	30.42	1.08
	14	23.19	0.97	24.63	1.01	26.07	1.04	27.12	1.05	28.96	1.07	30.40	1.10
	20	23.18	0.98	24.62	1.02	26.05	1.06	27.09	1.07	28.93	1.09	30.37	1.11
	25	23.16	1.00	24.60	1.03	26.03	1.07	27.07	1.08	28.91	1.10	30.35	1.13
	30	23.14	1.01	24.58	1.05	26.02	1.09	27.05	1.10	28.89	1.12	30.33	1.14
	35	23.12	1.03	24.56	1.06	26.00	1.10	27.03	1.11	28.87	1.14	30.30	1.16
	40	23.11	1.04	24.54	1.08	25.98	1.12	27.01	1.13	28.85	1.15	30.28	1.17
	45	23.09	1.05	24.52	1.09	25.96	1.13	26.99	1.14	28.82	1.17	30.26	1.19
	50	23.07	1.07	24.50	1.11	25.94	1.15	26.97	1.16	28.80	1.18	30.23	1.21
	55	23.05	1.08	24.48	1.12	25.92	1.16	26.95	1.18	28.78	1.20	30.21	1.22
	60	23.03	1.10	24.47	1.14	25.90	1.18	26.93	1.19	28.76	1.21	30.19	1.24
	65	23.02	1.11	24.45	1.15	25.88	1.19	26.91	1.21	28.73	1.23	30.16	1.25
	70	23.00	1.12	24.43	1.16	25.86	1.21	26.89	1.22	28.71	1.24	30.14	1.27
	75	22.45	1.18	23.87	1.23	25.30	1.27	26.32	1.29	28.15	1.31	29.57	1.34
	80	21.89	1.24	23.31	1.29	24.73	1.34	25.76	1.35	27.58	1.38	29.00	1.41
	85	21.34	1.31	22.76	1.35	24.18	1.40	25.20	1.42	27.01	1.44	28.43	1.47
	90	20.80	1.37	22.21	1.42	23.62	1.47	24.65	1.48	26.45	1.51	27.87	1.54
	95	20.20	1.43	21.61	1.48	23.01	1.53	23.66	1.55	25.83	1.58	27.24	1.61
	100	19.71	1.49	21.12	1.54	22.52	1.60	23.35	1.62	25.34	1.65	26.74	1.68
	105	19.22	1.55	20.62	1.60	22.03	1.66	23.05	1.68	24.85	1.71	26.25	1.75
	110	18.72	1.61	20.13	1.67	21.54	1.73	22.56	1.75	24.35	1.78	25.76	1.82
	115	18.23	1.67	19.64	1.73	21.05	1.79	22.06	1.81	23.86	1.85	25.27	1.88
	118	17.94	1.71	19.34	1.77	20.75	1.83	21.77	1.85	23.57	1.89	24.97	1.93
	122	17.84	1.75	19.25	1.82	20.65	1.88	21.67	1.91	23.47	1.94	24.88	1.98

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 240: LMU600HV Cooling Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 81 (135%)	-4	62.92	3.32	66.83	3.44	70.74	3.57	73.56	3.61	78.55	3.67	82.46	3.75
	0	62.89	3.36	66.79	3.48	70.70	3.60	73.52	3.65	78.51	3.71	82.41	3.79
	5	62.83	3.41	66.74	3.53	70.64	3.66	73.46	3.71	78.44	3.77	82.35	3.85
	10	62.79	3.46	66.69	3.59	70.59	3.72	73.40	3.76	78.38	3.83	82.28	3.91
	14	62.74	3.51	66.64	3.64	70.53	3.77	73.35	3.82	78.32	3.89	82.22	3.96
	20	62.69	3.56	66.58	3.69	70.48	3.83	73.29	3.87	78.26	3.94	82.16	4.02
	25	62.64	3.61	66.53	3.74	70.42	3.88	73.23	3.92	78.21	4.00	82.10	4.08
	30	62.60	3.66	66.48	3.80	70.37	3.93	73.18	3.98	78.15	4.05	82.03	4.14
	35	62.55	3.71	66.43	3.85	70.32	3.99	73.12	4.03	78.09	4.11	81.97	4.19
	40	62.50	3.76	66.38	3.90	70.26	4.04	73.07	4.09	78.03	4.17	81.91	4.25
	45	62.45	3.81	66.33	3.95	70.21	4.10	73.01	4.14	77.97	4.22	81.84	4.31
	50	62.40	3.86	66.28	4.00	70.16	4.15	72.95	4.20	77.91	4.28	81.78	4.36
	55	62.36	3.91	66.23	4.06	70.10	4.21	72.90	4.25	77.85	4.33	81.72	4.42
	60	62.31	3.96	66.18	4.11	70.05	4.26	72.84	4.31	77.79	4.39	81.66	4.48
	65	62.26	4.02	66.13	4.16	69.99	4.31	72.79	4.36	77.73	4.45	81.59	4.53
	70	62.21	4.07	66.08	4.21	69.94	4.37	72.73	4.42	77.67	4.50	81.53	4.59
	75	60.72	4.28	64.57	4.44	68.42	4.60	71.21	4.66	76.13	4.74	79.99	4.84
	80	59.22	4.50	63.06	4.67	66.91	4.84	69.68	4.89	74.60	4.99	78.44	5.09
	85	57.73	4.72	61.57	4.90	65.40	5.07	68.17	5.13	73.08	5.23	76.91	5.33
	90	56.25	4.94	60.08	5.12	63.90	5.31	66.67	5.37	71.55	5.47	75.38	5.58
	95	54.64	5.16	58.45	5.35	62.25	5.55	64.00	5.61	69.87	5.72	73.67	5.83
	100	53.31	5.38	57.12	5.58	60.92	5.78	63.17	5.85	68.54	5.96	72.34	6.08
	105	51.98	5.60	55.79	5.81	59.59	6.02	62.34	6.09	67.21	6.20	71.01	6.33
	110	50.65	5.82	54.46	6.03	58.26	6.25	61.01	6.33	65.88	6.44	69.68	6.57
	115	49.32	6.04	53.12	6.26	56.93	6.49	59.68	6.56	64.54	6.69	68.35	6.82
	118	48.52	6.17	52.33	6.40	56.13	6.63	58.88	6.71	63.75	6.83	67.55	6.97
	122	48.25	6.35	52.06	6.58	55.87	6.82	58.62	6.90	63.48	7.03	67.29	7.17
Non-Ducted Indoor Units 78 (130%)	-4	62.36	3.29	66.23	3.41	70.10	3.53	72.90	3.58	77.85	3.64	81.72	3.72
	0	62.32	3.33	66.20	3.45	70.07	3.57	72.86	3.61	77.81	3.68	81.68	3.76
	5	62.27	3.38	66.14	3.50	70.01	3.63	72.80	3.67	77.74	3.74	81.61	3.82
	10	62.23	3.43	66.09	3.55	69.96	3.68	72.75	3.73	77.68	3.80	81.55	3.87
	14	62.18	3.48	66.04	3.61	69.90	3.74	72.69	3.78	77.63	3.85	81.49	3.93
	20	62.13	3.53	65.99	3.66	69.85	3.79	72.64	3.84	77.57	3.91	81.42	3.99
	25	62.08	3.58	65.94	3.71	69.80	3.85	72.58	3.89	77.51	3.96	81.36	4.04
	30	62.04	3.63	65.89	3.76	69.74	3.90	72.52	3.94	77.45	4.02	81.30	4.10
	35	61.99	3.68	65.84	3.81	69.69	3.95	72.47	4.00	77.39	4.07	81.24	4.16
	40	61.94	3.73	65.79	3.87	69.64	4.01	72.41	4.05	77.33	4.13	81.18	4.21
	45	61.89	3.78	65.74	3.92	69.58	4.06	72.36	4.11	77.27	4.18	81.11	4.27
	50	61.85	3.83	65.69	3.97	69.53	4.11	72.30	4.16	77.21	4.24	81.05	4.33
	55	61.80	3.88	65.64	4.02	69.48	4.17	72.25	4.22	77.15	4.30	80.99	4.38
	60	61.75	3.93	65.59	4.07	69.42	4.22	72.19	4.27	77.09	4.35	80.93	4.44
	65	61.70	3.98	65.54	4.12	69.37	4.28	72.14	4.32	77.03	4.41	80.87	4.49
	70	61.66	4.03	65.49	4.18	69.32	4.33	72.08	4.38	76.97	4.46	80.80	4.55
	75	60.17	4.25	63.99	4.40	67.81	4.56	70.57	4.62	75.45	4.70	79.27	4.80
	80	58.69	4.46	62.50	4.63	66.31	4.80	69.06	4.85	73.93	4.94	77.74	5.04
	85	57.22	4.68	61.02	4.85	64.82	5.03	67.57	5.09	72.42	5.18	76.22	5.29
	90	55.75	4.90	59.54	5.08	63.33	5.26	66.07	5.32	70.91	5.42	74.71	5.53
	95	54.15	5.12	57.93	5.30	61.70	5.50	63.43	5.56	69.24	5.66	73.02	5.78
	100	52.83	5.33	56.61	5.53	60.38	5.73	62.61	5.80	67.92	5.91	71.70	6.02
	105	51.52	5.55	55.29	5.75	59.06	5.96	61.79	6.03	66.61	6.15	70.38	6.27
	110	50.20	5.77	53.97	5.98	57.74	6.20	60.47	6.27	65.29	6.39	69.06	6.52
	115	48.88	5.99	52.65	6.20	56.42	6.43	59.15	6.51	63.97	6.63	67.74	6.76
	118	48.09	6.12	51.86	6.34	55.63	6.57	58.36	6.65	63.18	6.77	66.95	6.91
	122	47.82	6.29	51.60	6.52	55.37	6.76	58.09	6.84	62.91	6.96	66.69	7.10

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 241: LMU600HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 72 (120%)	-4	61.24	3.23	65.04	3.35	68.84	3.47	71.59	3.51	76.45	3.58	80.25	3.65
	0	61.20	3.27	65.00	3.39	68.80	3.51	71.55	3.55	76.41	3.62	80.21	3.69
	5	61.15	3.32	64.95	3.44	68.75	3.57	71.49	3.61	76.34	3.67	80.14	3.75
	10	61.11	3.37	64.90	3.49	68.69	3.62	71.44	3.66	76.28	3.73	80.08	3.80
	14	61.06	3.42	64.85	3.54	68.64	3.67	71.38	3.71	76.23	3.78	80.02	3.86
	20	61.01	3.47	64.80	3.59	68.59	3.72	71.33	3.77	76.17	3.84	79.96	3.92
	25	60.97	3.52	64.75	3.64	68.54	3.78	71.27	3.82	76.11	3.89	79.90	3.97
	30	60.92	3.56	64.70	3.70	68.49	3.83	71.22	3.87	76.05	3.95	79.84	4.03
	35	60.87	3.61	64.65	3.75	68.43	3.88	71.16	3.93	75.99	4.00	79.77	4.08
	40	60.83	3.66	64.60	3.80	68.38	3.94	71.11	3.98	75.94	4.06	79.71	4.14
	45	60.78	3.71	64.55	3.85	68.33	3.99	71.05	4.03	75.88	4.11	79.65	4.19
	50	60.73	3.76	64.50	3.90	68.28	4.04	71.00	4.09	75.82	4.16	79.59	4.25
	55	60.69	3.81	64.45	3.95	68.22	4.09	70.95	4.14	75.76	4.22	79.53	4.30
	60	60.64	3.86	64.41	4.00	68.17	4.15	70.89	4.19	75.70	4.27	79.47	4.36
	65	60.59	3.91	64.36	4.05	68.12	4.20	70.84	4.25	75.65	4.33	79.41	4.41
	70	60.55	3.96	64.31	4.10	68.07	4.25	70.78	4.30	75.59	4.38	79.35	4.47
	75	59.09	4.17	62.84	4.32	66.59	4.48	69.30	4.53	74.09	4.62	77.84	4.71
	80	57.63	4.38	61.37	4.54	65.12	4.71	67.82	4.77	72.60	4.85	76.34	4.95
	85	56.19	4.60	59.92	4.77	63.65	4.94	66.35	5.00	71.12	5.09	74.85	5.19
	90	54.74	4.81	58.47	4.99	62.19	5.17	64.88	5.23	69.64	5.33	73.36	5.43
	95	53.18	5.03	56.88	5.21	60.59	5.40	62.29	5.46	68.00	5.56	71.70	5.68
	100	51.88	5.24	55.59	5.43	59.29	5.63	61.48	5.69	66.70	5.80	70.41	5.92
	105	50.59	5.45	54.29	5.65	58.00	5.86	60.67	5.93	65.41	6.04	69.11	6.16
	110	49.29	5.67	53.00	5.87	56.70	6.09	59.38	6.16	64.11	6.27	67.82	6.40
	115	48.00	5.88	51.70	6.09	55.41	6.32	58.08	6.39	62.82	6.51	66.52	6.64
	118	47.22	6.01	50.92	6.23	54.63	6.45	57.30	6.53	62.04	6.65	65.74	6.78
	122	46.96	6.18	50.67	6.40	54.37	6.64	57.05	6.71	61.78	6.84	65.48	6.98
Non-Ducted Indoor Units 66 (110%)	-4	60.11	3.17	63.85	3.29	67.58	3.41	70.27	3.45	75.04	3.51	78.78	3.58
	0	60.08	3.21	63.81	3.32	67.54	3.45	70.24	3.49	75.00	3.55	78.73	3.62
	5	60.03	3.26	63.76	3.38	67.49	3.50	70.18	3.54	74.94	3.61	78.67	3.68
	10	59.98	3.31	63.71	3.43	67.43	3.55	70.12	3.59	74.89	3.66	78.61	3.74
	14	59.94	3.36	63.66	3.48	67.38	3.61	70.07	3.65	74.83	3.71	78.55	3.79
	20	59.89	3.40	63.61	3.53	67.33	3.66	70.02	3.70	74.77	3.77	78.49	3.84
	25	59.85	3.45	63.56	3.58	67.28	3.71	69.96	3.75	74.71	3.82	78.43	3.90
	30	59.80	3.50	63.51	3.63	67.23	3.76	69.91	3.80	74.66	3.88	78.37	3.95
	35	59.76	3.55	63.47	3.68	67.18	3.81	69.86	3.86	74.60	3.93	78.31	4.01
	40	59.71	3.60	63.42	3.73	67.13	3.86	69.80	3.91	74.54	3.98	78.25	4.06
	45	59.66	3.64	63.37	3.78	67.07	3.92	69.75	3.96	74.49	4.04	78.19	4.12
	50	59.62	3.69	63.32	3.83	67.02	3.97	69.70	4.01	74.43	4.09	78.13	4.17
	55	59.57	3.74	63.27	3.88	66.97	4.02	69.64	4.07	74.37	4.14	78.07	4.23
	60	59.53	3.79	63.22	3.93	66.92	4.07	69.59	4.12	74.31	4.20	78.01	4.28
	65	59.48	3.84	63.18	3.98	66.87	4.12	69.54	4.17	74.26	4.25	77.95	4.33
	70	59.44	3.89	63.13	4.03	66.82	4.17	69.48	4.22	74.20	4.30	77.89	4.39
	75	58.01	4.10	61.69	4.25	65.37	4.40	68.03	4.45	72.73	4.53	76.42	4.63
	80	56.57	4.31	60.25	4.46	63.92	4.63	66.57	4.68	71.27	4.77	74.94	4.86
	85	55.16	4.51	58.82	4.68	62.49	4.85	65.13	4.91	69.81	5.00	73.48	5.10
	90	53.74	4.72	57.39	4.90	61.05	5.08	63.69	5.13	68.36	5.23	72.01	5.34
	95	52.20	4.93	55.84	5.11	59.47	5.30	61.14	5.36	66.75	5.46	70.38	5.57
	100	50.93	5.14	54.57	5.33	58.20	5.53	60.35	5.59	65.48	5.69	69.11	5.81
	105	49.66	5.35	53.30	5.55	56.93	5.75	59.56	5.82	64.21	5.93	67.84	6.05
	110	48.39	5.56	52.02	5.77	55.66	5.98	58.29	6.05	62.93	6.16	66.57	6.28
	115	47.12	5.77	50.75	5.98	54.39	6.20	57.02	6.27	61.66	6.39	65.30	6.52
	118	46.35	5.90	49.99	6.11	53.63	6.34	56.25	6.41	60.90	6.53	64.54	6.66
	122	46.10	6.07	49.74	6.29	53.37	6.52	56.00	6.59	60.65	6.72	64.28	6.85

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 242: LMU600HV Cooling Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 60 (100%)	-4	58.99	3.11	62.65	3.23	66.32	3.35	68.96	3.38	73.64	3.45	77.31	3.52
	0	58.96	3.15	62.62	3.26	66.28	3.38	68.92	3.42	73.60	3.48	77.26	3.56
	5	58.91	3.20	62.57	3.32	66.22	3.44	68.87	3.48	73.54	3.54	77.20	3.61
	10	58.86	3.25	62.52	3.36	66.17	3.49	68.81	3.53	73.49	3.59	77.14	3.67
	14	58.82	3.29	62.47	3.41	66.12	3.54	68.76	3.58	73.43	3.65	77.08	3.72
	20	58.77	3.34	62.42	3.46	66.07	3.59	68.71	3.63	73.37	3.70	77.02	3.77
	25	58.73	3.39	62.38	3.51	66.02	3.64	68.66	3.68	73.32	3.75	76.96	3.83
	30	58.68	3.44	62.33	3.56	65.97	3.69	68.60	3.73	73.26	3.80	76.91	3.88
	35	58.64	3.48	62.28	3.61	65.92	3.74	68.55	3.78	73.21	3.86	76.85	3.93
	40	58.59	3.53	62.23	3.66	65.87	3.79	68.50	3.84	73.15	3.91	76.79	3.99
	45	58.55	3.58	62.18	3.71	65.82	3.84	68.45	3.89	73.09	3.96	76.73	4.04
	50	58.50	3.62	62.14	3.76	65.77	3.89	68.39	3.94	73.04	4.01	76.67	4.09
	55	58.46	3.67	62.09	3.81	65.72	3.95	68.34	3.99	72.98	4.07	76.61	4.15
	60	58.41	3.72	62.04	3.86	65.67	4.00	68.29	4.04	72.93	4.12	76.55	4.20
	65	58.37	3.77	61.99	3.90	65.62	4.05	68.24	4.09	72.87	4.17	76.49	4.25
	70	58.32	3.81	61.95	3.95	65.57	4.10	68.18	4.14	72.81	4.22	76.44	4.31
	75	56.92	4.02	60.53	4.17	64.15	4.32	66.76	4.37	71.37	4.45	74.99	4.54
	80	55.52	4.23	59.12	4.38	62.73	4.54	65.33	4.59	69.93	4.68	73.54	4.77
	85	54.13	4.43	57.72	4.59	61.32	4.76	63.91	4.82	68.51	4.91	72.10	5.00
	90	52.74	4.64	56.32	4.81	59.91	4.98	62.50	5.04	67.08	5.13	70.67	5.24
	95	51.23	4.84	54.79	5.02	58.36	5.20	60.00	5.26	65.50	5.36	69.07	5.47
	100	49.98	5.05	53.55	5.23	57.12	5.42	59.22	5.49	64.25	5.59	67.82	5.70
	105	48.73	5.25	52.30	5.45	55.87	5.65	58.45	5.71	63.01	5.82	66.57	5.93
	110	47.48	5.46	51.05	5.66	54.62	5.87	57.20	5.93	61.76	6.04	65.33	6.17
	115	46.24	5.67	49.80	5.87	53.37	6.09	55.95	6.16	60.51	6.27	64.08	6.40
	118	45.49	5.79	49.06	6.00	52.62	6.22	55.20	6.29	59.76	6.41	63.33	6.54
Non-Ducted Indoor Units 54 (90%)	122	45.24	5.95	48.81	6.17	52.38	6.40	54.95	6.47	59.51	6.59	63.08	6.72
	-4	53.09	2.74	56.39	2.84	59.68	2.95	62.06	2.98	66.28	3.04	69.58	3.10
	0	53.06	2.77	56.36	2.88	59.65	2.98	62.03	3.02	66.24	3.07	69.54	3.13
	5	53.02	2.82	56.31	2.92	59.60	3.03	61.98	3.06	66.19	3.12	69.48	3.18
	10	52.98	2.86	56.27	2.97	59.56	3.07	61.93	3.11	66.14	3.17	69.43	3.23
	14	52.94	2.90	56.22	3.01	59.51	3.12	61.89	3.15	66.09	3.21	69.37	3.28
	20	52.90	2.94	56.18	3.05	59.47	3.16	61.84	3.20	66.04	3.26	69.32	3.33
	25	52.86	2.99	56.14	3.10	59.42	3.21	61.79	3.25	65.99	3.31	69.27	3.37
	30	52.81	3.03	56.09	3.14	59.38	3.25	61.74	3.29	65.94	3.35	69.22	3.42
	35	52.77	3.07	56.05	3.18	59.33	3.30	61.70	3.34	65.88	3.40	69.16	3.47
	40	52.73	3.11	56.01	3.23	59.28	3.34	61.65	3.38	65.83	3.44	69.11	3.51
	45	52.69	3.15	55.97	3.27	59.24	3.39	61.60	3.43	65.78	3.49	69.06	3.56
	50	52.65	3.20	55.92	3.31	59.19	3.43	61.56	3.47	65.73	3.54	69.00	3.61
	55	52.61	3.24	55.88	3.36	59.15	3.48	61.51	3.52	65.68	3.58	68.95	3.66
	60	52.57	3.28	55.84	3.40	59.10	3.52	61.46	3.56	65.63	3.63	68.90	3.70
	65	52.53	3.32	55.79	3.44	59.06	3.57	61.41	3.61	65.58	3.68	68.84	3.75
	70	52.49	3.36	55.75	3.48	59.01	3.61	61.37	3.65	65.53	3.72	68.79	3.80
	75	51.23	3.54	54.48	3.67	57.73	3.81	60.08	3.85	64.24	3.92	67.49	4.00
	80	49.97	3.72	53.21	3.86	56.45	4.00	58.80	4.05	62.94	4.12	66.19	4.21
	85	48.71	3.91	51.95	4.05	55.19	4.20	57.52	4.24	61.66	4.32	64.89	4.41
	90	47.46	4.09	50.69	4.24	53.92	4.39	56.25	4.44	60.37	4.53	63.60	4.62
	95	46.10	4.27	49.31	4.42	52.53	4.59	54.00	4.64	58.95	4.73	62.16	4.82
	100	44.98	4.45	48.19	4.61	51.40	4.78	53.30	4.84	57.83	4.93	61.04	5.03
	105	43.86	4.63	47.07	4.80	50.28	4.98	52.60	5.03	56.70	5.13	59.92	5.23
	110	42.73	4.81	45.95	4.99	49.16	5.17	51.48	5.23	55.58	5.33	58.79	5.44
	115	41.61	4.99	44.82	5.18	48.04	5.37	50.36	5.43	54.46	5.53	57.67	5.64
	118	40.94	5.10	44.15	5.29	47.36	5.48	49.68	5.55	53.79	5.65	57.00	5.76
	122	40.71	5.25	43.93	5.44	47.14	5.64	49.46	5.70	53.56	5.81	56.77	5.93

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 243: LMU600HV Cooling Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 48 (80%)	-4	47.19	2.38	50.12	2.46	53.05	2.55	55.17	2.58	58.91	2.63	61.84	2.68
	0	47.16	2.40	50.09	2.49	53.02	2.58	55.14	2.61	58.88	2.66	61.81	2.71
	5	47.13	2.44	50.05	2.53	52.98	2.62	55.09	2.65	58.83	2.70	61.76	2.76
	10	47.09	2.48	50.01	2.57	52.94	2.66	55.05	2.69	58.79	2.74	61.71	2.80
	14	47.05	2.51	49.98	2.60	52.90	2.70	55.01	2.73	58.74	2.78	61.67	2.84
	20	47.02	2.55	49.94	2.64	52.86	2.74	54.97	2.77	58.70	2.82	61.62	2.88
	25	46.98	2.59	49.90	2.68	52.82	2.78	54.93	2.81	58.65	2.86	61.57	2.92
	30	46.95	2.62	49.86	2.72	52.78	2.82	54.88	2.85	58.61	2.90	61.52	2.96
	35	46.91	2.66	49.82	2.75	52.74	2.85	54.84	2.89	58.56	2.94	61.48	3.00
	40	46.87	2.69	49.79	2.79	52.70	2.89	54.80	2.93	58.52	2.98	61.43	3.04
	45	46.84	2.73	49.75	2.83	52.66	2.93	54.76	2.97	58.47	3.02	61.38	3.08
	50	46.80	2.77	49.71	2.87	52.62	2.97	54.72	3.01	58.43	3.06	61.34	3.12
	55	46.77	2.80	49.67	2.90	52.58	3.01	54.67	3.04	58.38	3.10	61.29	3.16
	60	46.73	2.84	49.63	2.94	52.54	3.05	54.63	3.08	58.34	3.14	61.24	3.20
	65	46.70	2.87	49.60	2.98	52.50	3.09	54.59	3.12	58.30	3.18	61.20	3.25
	70	46.66	2.91	49.56	3.02	52.46	3.13	54.55	3.16	58.25	3.22	61.15	3.29
	75	45.54	3.07	48.43	3.18	51.32	3.29	53.41	3.33	57.10	3.40	59.99	3.46
	80	44.41	3.22	47.30	3.34	50.18	3.46	52.26	3.50	55.95	3.57	58.83	3.64
	85	43.30	3.38	46.18	3.50	49.05	3.63	51.13	3.67	54.81	3.74	57.68	3.82
	90	42.19	3.54	45.06	3.67	47.93	3.80	50.00	3.84	53.66	3.92	56.53	4.00
	95	40.98	3.69	43.84	3.83	46.69	3.97	48.00	4.02	52.40	4.09	55.25	4.17
	100	39.98	3.85	42.84	3.99	45.69	4.14	47.38	4.19	51.40	4.26	54.26	4.35
	105	38.98	4.01	41.84	4.16	44.69	4.31	46.76	4.36	50.40	4.44	53.26	4.53
	110	37.99	4.17	40.84	4.32	43.70	4.48	45.76	4.53	49.41	4.61	52.26	4.70
	115	36.99	4.32	39.84	4.48	42.70	4.64	44.76	4.70	48.41	4.79	51.26	4.88
	118	36.39	4.42	39.24	4.58	42.10	4.75	44.16	4.80	47.81	4.89	50.66	4.99
	122	36.19	4.54	39.05	4.71	41.90	4.88	43.96	4.94	47.61	5.03	50.46	5.13
Non-Ducted Indoor Units 42 (70%)	-4	41.29	2.01	43.86	2.08	46.42	2.16	48.27	2.18	51.55	2.22	54.11	2.27
	0	41.27	2.03	43.83	2.10	46.40	2.18	48.25	2.20	51.52	2.25	54.08	2.29
	5	41.24	2.06	43.80	2.14	46.36	2.21	48.21	2.24	51.48	2.28	54.04	2.33
	10	41.20	2.09	43.76	2.17	46.32	2.25	48.17	2.27	51.44	2.32	54.00	2.36
	14	41.17	2.12	43.73	2.20	46.29	2.28	48.13	2.31	51.40	2.35	53.96	2.40
	20	41.14	2.15	43.70	2.23	46.25	2.31	48.10	2.34	51.36	2.38	53.92	2.43
	25	41.11	2.18	43.66	2.26	46.22	2.35	48.06	2.37	51.32	2.42	53.88	2.47
	30	41.08	2.21	43.63	2.29	46.18	2.38	48.02	2.41	51.28	2.45	53.83	2.50
	35	41.05	2.24	43.60	2.33	46.15	2.41	47.99	2.44	51.24	2.48	53.79	2.53
	40	41.02	2.27	43.56	2.36	46.11	2.44	47.95	2.47	51.20	2.52	53.75	2.57
	45	40.98	2.31	43.53	2.39	46.07	2.48	47.91	2.51	51.17	2.55	53.71	2.60
	50	40.95	2.34	43.50	2.42	46.04	2.51	47.88	2.54	51.13	2.59	53.67	2.64
	55	40.92	2.37	43.46	2.45	46.00	2.54	47.84	2.57	51.09	2.62	53.63	2.67
	60	40.89	2.40	43.43	2.48	45.97	2.58	47.80	2.60	51.05	2.65	53.59	2.71
	65	40.86	2.43	43.40	2.52	45.93	2.61	47.77	2.64	51.01	2.69	53.55	2.74
	70	40.83	2.46	43.36	2.55	45.90	2.64	47.73	2.67	50.97	2.72	53.50	2.78
	75	39.84	2.59	42.37	2.69	44.90	2.78	46.73	2.82	49.96	2.87	52.49	2.93
	80	38.86	2.72	41.39	2.82	43.91	2.93	45.73	2.96	48.95	3.01	51.48	3.08
	85	37.89	2.86	40.41	2.96	42.92	3.07	44.74	3.10	47.96	3.16	50.47	3.23
	90	36.91	2.99	39.43	3.10	41.94	3.21	43.75	3.25	46.96	3.31	49.47	3.37
	95	35.86	3.12	38.36	3.23	40.85	3.35	42.00	3.39	45.85	3.46	48.35	3.52
	100	34.98	3.25	37.48	3.37	39.98	3.50	41.46	3.54	44.98	3.60	47.47	3.67
	105	34.11	3.39	36.61	3.51	39.11	3.64	40.91	3.68	44.10	3.75	46.60	3.82
	110	33.24	3.52	35.74	3.65	38.23	3.78	40.04	3.82	43.23	3.90	45.73	3.97
	115	32.37	3.65	34.86	3.78	37.36	3.92	39.17	3.97	42.36	4.04	44.86	4.12
	118	31.84	3.73	34.34	3.87	36.84	4.01	38.64	4.05	41.83	4.13	44.33	4.21
	122	31.67	3.84	34.16	3.98	36.66	4.12	38.47	4.17	41.66	4.25	44.16	4.33

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 244: LMU600HV Cooling Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 36 (60%)	-4	35.39	1.64	37.59	1.70	39.79	1.76	41.38	1.78	44.19	1.81	46.38	1.85
	0	35.37	1.66	37.57	1.72	39.77	1.78	41.35	1.80	44.16	1.83	46.36	1.87
	5	35.34	1.68	37.54	1.74	39.73	1.81	41.32	1.83	44.12	1.86	46.32	1.90
	10	35.32	1.71	37.51	1.77	39.70	1.83	41.29	1.86	44.09	1.89	46.28	1.93
	14	35.29	1.73	37.48	1.80	39.67	1.86	41.26	1.88	44.06	1.92	46.25	1.96
	20	35.26	1.76	37.45	1.82	39.64	1.89	41.23	1.91	44.02	1.95	46.21	1.98
	25	35.24	1.78	37.43	1.85	39.61	1.91	41.19	1.94	43.99	1.97	46.18	2.01
	30	35.21	1.81	37.40	1.87	39.58	1.94	41.16	1.96	43.96	2.00	46.14	2.04
	35	35.18	1.83	37.37	1.90	39.55	1.97	41.13	1.99	43.92	2.03	46.11	2.07
	40	35.16	1.86	37.34	1.92	39.52	1.99	41.10	2.02	43.89	2.06	46.07	2.10
	45	35.13	1.88	37.31	1.95	39.49	2.02	41.07	2.04	43.86	2.08	46.04	2.12
	50	35.10	1.91	37.28	1.98	39.46	2.05	41.04	2.07	43.82	2.11	46.00	2.15
	55	35.08	1.93	37.25	2.00	39.43	2.07	41.01	2.10	43.79	2.14	45.97	2.18
	60	35.05	1.96	37.23	2.03	39.40	2.10	40.97	2.13	43.76	2.17	45.93	2.21
	65	35.02	1.98	37.20	2.05	39.37	2.13	40.94	2.15	43.72	2.19	45.90	2.24
	70	34.99	2.01	37.17	2.08	39.34	2.15	40.91	2.18	43.69	2.22	45.86	2.27
	75	34.15	2.11	36.32	2.19	38.49	2.27	40.05	2.30	42.82	2.34	44.99	2.39
	80	33.31	2.22	35.47	2.30	37.64	2.39	39.20	2.41	41.96	2.46	44.12	2.51
	85	32.48	2.33	34.63	2.42	36.79	2.50	38.35	2.53	41.10	2.58	43.26	2.63
	90	31.64	2.44	33.79	2.53	35.94	2.62	37.50	2.65	40.25	2.70	42.40	2.75
	95	30.74	2.55	32.88	2.64	35.02	2.74	36.00	2.77	39.30	2.82	41.44	2.88
	100	29.99	2.65	32.13	2.75	34.27	2.85	35.53	2.89	38.55	2.94	40.69	3.00
	105	29.24	2.76	31.38	2.86	33.52	2.97	35.07	3.00	37.80	3.06	39.94	3.12
	110	28.49	2.87	30.63	2.98	32.77	3.08	34.32	3.12	37.05	3.18	39.20	3.24
	115	27.74	2.98	29.88	3.09	32.02	3.20	33.57	3.24	36.31	3.30	38.45	3.37
	118	27.29	3.04	29.43	3.16	31.57	3.27	33.12	3.31	35.86	3.37	38.00	3.44
Non-Ducted Indoor Units 30 (50%)	122	27.14	3.13	29.28	3.25	31.43	3.36	32.97	3.40	35.71	3.47	37.85	3.54
	-4	29.49	1.27	31.33	1.31	33.16	1.36	34.48	1.38	36.82	1.40	38.65	1.43
	0	29.48	1.28	31.31	1.33	33.14	1.38	34.46	1.39	36.80	1.42	38.63	1.45
	5	29.45	1.30	31.28	1.35	33.11	1.40	34.43	1.42	36.77	1.44	38.60	1.47
	10	29.43	1.32	31.26	1.37	33.09	1.42	34.41	1.44	36.74	1.46	38.57	1.49
	14	29.41	1.34	31.24	1.39	33.06	1.44	34.38	1.46	36.71	1.49	38.54	1.52
	20	29.39	1.36	31.21	1.41	33.04	1.46	34.35	1.48	36.69	1.51	38.51	1.54
	25	29.36	1.38	31.19	1.43	33.01	1.48	34.33	1.50	36.66	1.53	38.48	1.56
	30	29.34	1.40	31.16	1.45	32.99	1.50	34.30	1.52	36.63	1.55	38.45	1.58
	35	29.32	1.42	31.14	1.47	32.96	1.52	34.28	1.54	36.60	1.57	38.42	1.60
	40	29.30	1.44	31.12	1.49	32.94	1.54	34.25	1.56	36.57	1.59	38.39	1.62
	45	29.27	1.46	31.09	1.51	32.91	1.57	34.22	1.58	36.55	1.61	38.36	1.65
	50	29.25	1.48	31.07	1.53	32.89	1.59	34.20	1.60	36.52	1.63	38.34	1.67
	55	29.23	1.50	31.04	1.55	32.86	1.61	34.17	1.63	36.49	1.66	38.31	1.69
	60	29.21	1.52	31.02	1.57	32.83	1.63	34.14	1.65	36.46	1.68	38.28	1.71
	65	29.18	1.53	31.00	1.59	32.81	1.65	34.12	1.67	36.43	1.70	38.25	1.73
	70	29.16	1.55	30.97	1.61	32.78	1.67	34.09	1.69	36.41	1.72	38.22	1.75
	75	28.46	1.64	30.27	1.70	32.07	1.76	33.38	1.78	35.69	1.81	37.49	1.85
	80	27.76	1.72	29.56	1.78	31.36	1.85	32.66	1.87	34.97	1.91	36.77	1.94
	85	27.06	1.81	28.86	1.87	30.66	1.94	31.96	1.96	34.25	2.00	36.05	2.04
	90	26.37	1.89	28.16	1.96	29.95	2.03	31.25	2.05	33.54	2.09	35.33	2.13
	95	25.61	1.97	27.40	2.04	29.18	2.12	30.00	2.14	32.75	2.18	34.53	2.23
	100	24.99	2.06	26.77	2.13	28.56	2.21	29.61	2.23	32.13	2.28	33.91	2.32
	105	24.37	2.14	26.15	2.22	27.93	2.30	29.22	2.33	31.50	2.37	33.29	2.42
	110	23.74	2.22	25.53	2.31	27.31	2.39	28.60	2.42	30.88	2.46	32.66	2.51
	115	23.12	2.31	24.90	2.39	26.69	2.48	27.98	2.51	30.26	2.56	32.04	2.61
	118	22.74	2.36	24.53	2.44	26.31	2.53	27.60	2.56	29.88	2.61	31.67	2.66
	122	22.62	2.43	24.40	2.51	26.19	2.61	27.48	2.64	29.76	2.69	31.54	2.74

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 245: LMU600HV Cooling Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 24 (40%)	-4	23.60	0.90	25.06	0.93	26.53	0.97	27.58	0.98	29.46	1.00	30.92	1.02
	0	23.58	0.91	25.05	0.94	26.51	0.98	27.57	0.99	29.44	1.01	30.91	1.03
	5	23.56	0.92	25.03	0.96	26.49	0.99	27.55	1.00	29.42	1.02	30.88	1.04
	10	23.55	0.94	25.01	0.97	26.47	1.01	27.53	1.02	29.39	1.04	30.86	1.06
	14	23.53	0.95	24.99	0.99	26.45	1.02	27.50	1.03	29.37	1.05	30.83	1.07
	20	23.51	0.96	24.97	1.00	26.43	1.04	27.48	1.05	29.35	1.07	30.81	1.09
	25	23.49	0.98	24.95	1.01	26.41	1.05	27.46	1.06	29.33	1.08	30.79	1.11
	30	23.47	0.99	24.93	1.03	26.39	1.07	27.44	1.08	29.30	1.10	30.76	1.12
	35	23.46	1.01	24.91	1.04	26.37	1.08	27.42	1.09	29.28	1.11	30.74	1.14
	40	23.44	1.02	24.89	1.06	26.35	1.10	27.40	1.11	29.26	1.13	30.72	1.15
	45	23.42	1.03	24.87	1.07	26.33	1.11	27.38	1.12	29.24	1.14	30.69	1.17
	50	23.40	1.05	24.85	1.09	26.31	1.12	27.36	1.14	29.21	1.16	30.67	1.18
	55	23.38	1.06	24.84	1.10	26.29	1.14	27.34	1.15	29.19	1.17	30.64	1.20
	60	23.37	1.07	24.82	1.11	26.27	1.15	27.32	1.17	29.17	1.19	30.62	1.21
	65	23.35	1.09	24.80	1.13	26.25	1.17	27.29	1.18	29.15	1.20	30.60	1.23
	70	23.33	1.10	24.78	1.14	26.23	1.18	27.27	1.20	29.13	1.22	30.57	1.24
	75	22.77	1.16	24.21	1.20	25.66	1.25	26.70	1.26	28.55	1.29	29.99	1.31
	80	22.21	1.22	23.65	1.26	25.09	1.31	26.13	1.33	27.97	1.35	29.42	1.38
	85	21.65	1.28	23.09	1.33	24.53	1.37	25.57	1.39	27.40	1.42	28.84	1.45
	90	21.09	1.34	22.53	1.39	23.96	1.44	25.00	1.46	26.83	1.48	28.27	1.51
	95	20.49	1.40	21.92	1.45	23.35	1.50	24.00	1.52	26.20	1.55	27.63	1.58
	100	19.99	1.46	21.42	1.51	22.85	1.57	23.69	1.58	25.70	1.61	27.13	1.65
	105	19.49	1.52	20.92	1.57	22.35	1.63	23.38	1.65	25.20	1.68	26.63	1.71
	110	18.99	1.58	20.42	1.63	21.85	1.69	22.88	1.71	24.70	1.75	26.13	1.78
	115	18.49	1.64	19.92	1.70	21.35	1.76	22.38	1.78	24.20	1.81	25.63	1.85
	118	18.19	1.67	19.62	1.73	21.05	1.80	22.08	1.82	23.90	1.85	25.33	1.89
	122	18.10	1.72	19.52	1.78	20.95	1.85	21.98	1.87	23.81	1.90	25.23	1.94
Ducted Indoor Units 81 (135%)	-4	60.56	3.48	64.32	3.61	68.08	3.74	70.80	3.79	75.61	3.86	79.37	3.93
	0	60.53	3.52	64.29	3.65	68.05	3.78	70.76	3.83	75.56	3.90	79.32	3.98
	5	60.48	3.58	64.23	3.71	67.99	3.85	70.70	3.89	75.50	3.96	79.26	4.04
	10	60.43	3.63	64.19	3.76	67.94	3.90	70.65	3.95	75.44	4.02	79.20	4.10
	14	60.39	3.68	64.14	3.82	67.89	3.96	70.60	4.00	75.39	4.08	79.14	4.16
	20	60.34	3.74	64.09	3.87	67.84	4.02	70.54	4.06	75.33	4.14	79.08	4.22
	25	60.29	3.79	64.04	3.93	67.78	4.07	70.49	4.12	75.27	4.20	79.02	4.28
	30	60.25	3.84	63.99	3.98	67.73	4.13	70.43	4.18	75.21	4.26	78.96	4.34
	35	60.20	3.90	63.94	4.04	67.68	4.19	70.38	4.23	75.16	4.31	78.90	4.40
	40	60.16	3.95	63.89	4.09	67.63	4.24	70.33	4.29	75.10	4.37	78.84	4.46
	45	60.11	4.00	63.84	4.15	67.58	4.30	70.27	4.35	75.04	4.43	78.78	4.52
	50	60.06	4.06	63.79	4.20	67.52	4.36	70.22	4.41	74.98	4.49	78.72	4.58
	55	60.02	4.11	63.75	4.26	67.47	4.41	70.16	4.46	74.93	4.55	78.65	4.64
	60	59.97	4.16	63.70	4.31	67.42	4.47	70.11	4.52	74.87	4.61	78.59	4.70
	65	59.93	4.21	63.65	4.37	67.37	4.53	70.06	4.58	74.81	4.67	78.53	4.76
	70	59.88	4.27	63.60	4.42	67.32	4.58	70.00	4.64	74.75	4.72	78.47	4.82
	75	58.44	4.50	62.15	4.66	65.86	4.83	68.54	4.89	73.28	4.98	76.99	5.08
	80	57.00	4.73	60.70	4.90	64.40	5.08	67.07	5.14	71.80	5.23	75.50	5.34
	85	55.57	4.96	59.26	5.14	62.95	5.33	65.62	5.39	70.33	5.49	74.03	5.60
	90	54.14	5.19	57.82	5.38	61.51	5.57	64.17	5.64	68.87	5.74	72.55	5.86
	95	52.59	5.42	56.26	5.62	59.92	5.82	61.60	5.89	67.25	6.00	70.91	6.12
	100	51.31	5.65	54.97	5.85	58.64	6.07	60.80	6.14	65.97	6.25	69.63	6.38
	105	50.03	5.88	53.69	6.09	57.36	6.32	60.00	6.39	64.69	6.51	68.35	6.64
	110	48.75	6.11	52.41	6.33	56.08	6.56	58.72	6.64	63.40	6.76	67.07	6.90
	115	47.47	6.34	51.13	6.57	54.80	6.81	57.44	6.89	62.12	7.02	65.79	7.16
	118	46.70	6.48	50.36	6.71	54.03	6.96	56.67	7.04	61.36	7.17	65.02	7.32
	122	46.44	6.66	50.11	6.90	53.77	7.16	56.42	7.24	61.10	7.37	64.76	7.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 246: LMU600HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 78 (130%)	-4	60.06	3.45	63.79	3.58	67.52	3.71	70.21	3.75	74.97	3.82	78.70	3.90
	0	60.02	3.49	63.75	3.62	67.48	3.75	70.17	3.79	74.93	3.86	78.66	3.94
	5	59.97	3.55	63.70	3.68	67.42	3.81	70.11	3.85	74.87	3.93	78.60	4.01
	10	59.93	3.60	63.65	3.73	67.37	3.87	70.06	3.91	74.82	3.99	78.54	4.07
	14	59.88	3.65	63.60	3.79	67.32	3.92	70.01	3.97	74.76	4.04	78.48	4.12
	20	59.84	3.70	63.55	3.84	67.27	3.98	69.95	4.03	74.70	4.10	78.42	4.18
	25	59.79	3.76	63.50	3.89	67.22	4.04	69.90	4.08	74.64	4.16	78.36	4.24
	30	59.75	3.81	63.46	3.95	67.17	4.09	69.85	4.14	74.59	4.22	78.30	4.30
	35	59.70	3.86	63.41	4.00	67.11	4.15	69.79	4.20	74.53	4.28	78.24	4.36
	40	59.65	3.91	63.36	4.06	67.06	4.21	69.74	4.25	74.47	4.33	78.18	4.42
	45	59.61	3.97	63.31	4.11	67.01	4.26	69.69	4.31	74.42	4.39	78.12	4.48
	50	59.56	4.02	63.26	4.17	66.96	4.32	69.63	4.37	74.36	4.45	78.06	4.54
	55	59.52	4.07	63.21	4.22	66.91	4.37	69.58	4.43	74.30	4.51	78.00	4.60
	60	59.47	4.12	63.16	4.28	66.86	4.43	69.53	4.48	74.24	4.57	77.94	4.66
	65	59.43	4.18	63.12	4.33	66.81	4.49	69.47	4.54	74.19	4.62	77.88	4.72
	70	59.38	4.23	63.07	4.38	66.76	4.54	69.42	4.60	74.13	4.68	77.82	4.78
	75	57.95	4.46	61.63	4.62	65.31	4.79	67.96	4.84	72.67	4.94	76.34	5.03
	80	56.52	4.69	60.19	4.86	63.86	5.03	66.51	5.09	71.20	5.19	74.87	5.29
	85	55.11	4.91	58.77	5.09	62.43	5.28	65.07	5.34	69.75	5.44	73.41	5.55
	90	53.69	5.14	57.34	5.33	60.99	5.52	63.63	5.59	68.30	5.69	71.95	5.81
	95	52.15	5.37	55.79	5.57	59.42	5.77	61.09	5.84	66.69	5.95	70.32	6.07
	100	50.88	5.60	54.52	5.80	58.15	6.01	60.29	6.08	65.42	6.20	69.05	6.32
	105	49.61	5.83	53.25	6.04	56.88	6.26	59.50	6.33	64.15	6.45	67.78	6.58
	110	48.34	6.05	51.98	6.28	55.61	6.51	58.23	6.58	62.88	6.70	66.51	6.84
	115	47.07	6.28	50.71	6.51	54.34	6.75	56.96	6.83	61.61	6.96	65.24	7.10
	118	46.31	6.42	49.94	6.65	53.58	6.90	56.20	6.98	60.84	7.11	64.48	7.25
	122	46.06	6.60	49.69	6.84	53.32	7.09	55.95	7.18	60.59	7.31	64.22	7.46
Ducted Indoor Units 72 (120%)	-4	59.04	3.39	62.71	3.52	66.38	3.64	69.03	3.69	73.71	3.75	77.38	3.83
	0	59.01	3.43	62.68	3.55	66.34	3.68	68.99	3.73	73.67	3.80	77.34	3.87
	5	58.96	3.48	62.63	3.61	66.29	3.74	68.93	3.79	73.61	3.86	77.27	3.93
	10	58.92	3.54	62.58	3.66	66.24	3.80	68.88	3.84	73.56	3.91	77.21	3.99
	14	58.87	3.59	62.53	3.72	66.19	3.85	68.83	3.90	73.50	3.97	77.16	4.05
	20	58.83	3.64	62.48	3.77	66.14	3.91	68.77	3.95	73.44	4.03	77.10	4.11
	25	58.78	3.69	62.43	3.82	66.09	3.96	68.72	4.01	73.39	4.09	77.04	4.17
	30	58.74	3.74	62.39	3.88	66.04	4.02	68.67	4.07	73.33	4.14	76.98	4.23
	35	58.69	3.79	62.34	3.93	65.98	4.08	68.62	4.12	73.27	4.20	76.92	4.28
	40	58.65	3.84	62.29	3.99	65.93	4.13	68.56	4.18	73.22	4.26	76.86	4.34
	45	58.60	3.90	62.24	4.04	65.88	4.19	68.51	4.23	73.16	4.31	76.80	4.40
	50	58.56	3.95	62.20	4.09	65.83	4.24	68.46	4.29	73.11	4.37	76.74	4.46
	55	58.51	4.00	62.15	4.15	65.78	4.30	68.41	4.35	73.05	4.43	76.68	4.52
	60	58.47	4.05	62.10	4.20	65.73	4.35	68.35	4.40	72.99	4.48	76.63	4.58
	65	58.42	4.10	62.05	4.25	65.68	4.41	68.30	4.46	72.94	4.54	76.57	4.63
	70	58.38	4.15	62.01	4.31	65.63	4.46	68.25	4.51	72.88	4.60	76.51	4.69
	75	56.98	4.38	60.59	4.54	64.21	4.70	66.82	4.76	71.44	4.85	75.06	4.94
	80	55.57	4.60	59.18	4.77	62.79	4.94	65.39	5.00	70.00	5.10	73.61	5.20
	85	54.18	4.83	57.78	5.00	61.38	5.19	63.97	5.25	68.57	5.34	72.17	5.45
	90	52.79	5.05	56.38	5.23	59.97	5.43	62.56	5.49	67.15	5.59	70.74	5.70
	95	51.27	5.27	54.85	5.47	58.42	5.67	60.06	5.73	65.56	5.84	69.13	5.96
	100	50.03	5.50	53.60	5.70	57.17	5.91	59.28	5.98	64.31	6.09	67.89	6.21
	105	48.78	5.72	52.35	5.93	55.92	6.15	58.50	6.22	63.07	6.34	66.64	6.46
	110	47.53	5.95	51.10	6.16	54.67	6.39	57.25	6.46	61.82	6.58	65.39	6.72
	115	46.28	6.17	49.85	6.40	53.42	6.63	56.00	6.71	60.57	6.83	64.14	6.97
	118	45.53	6.31	49.10	6.54	52.67	6.77	55.25	6.85	59.82	6.98	63.39	7.12
	122	45.28	6.48	48.85	6.72	52.43	6.97	55.00	7.05	59.57	7.18	63.14	7.32

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 247: LMU600HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 66 (110%)	-4	58.03	3.33	61.64	3.45	65.24	3.58	67.84	3.62	72.45	3.69	76.05	3.76
	0	58.00	3.37	61.60	3.49	65.21	3.62	67.81	3.66	72.41	3.73	76.01	3.80
	5	57.95	3.42	61.55	3.55	65.15	3.68	67.75	3.72	72.35	3.79	75.95	3.86
	10	57.91	3.47	61.51	3.60	65.10	3.73	67.70	3.77	72.30	3.84	75.89	3.92
	14	57.87	3.52	61.46	3.65	65.05	3.78	67.65	3.83	72.24	3.90	75.83	3.98
	20	57.82	3.57	61.41	3.70	65.00	3.84	67.60	3.88	72.19	3.96	75.78	4.03
	25	57.78	3.62	61.37	3.76	64.95	3.89	67.55	3.94	72.13	4.01	75.72	4.09
	30	57.73	3.67	61.32	3.81	64.90	3.95	67.49	3.99	72.08	4.07	75.66	4.15
	35	57.69	3.72	61.27	3.86	64.85	4.00	67.44	4.05	72.02	4.12	75.60	4.21
	40	57.64	3.78	61.22	3.91	64.80	4.06	67.39	4.10	71.96	4.18	75.54	4.26
	45	57.60	3.83	61.18	3.97	64.76	4.11	67.34	4.16	71.91	4.24	75.49	4.32
	50	57.56	3.88	61.13	4.02	64.71	4.16	67.29	4.21	71.85	4.29	75.43	4.38
	55	57.51	3.93	61.08	4.07	64.66	4.22	67.24	4.27	71.80	4.35	75.37	4.43
	60	57.47	3.98	61.04	4.12	64.61	4.27	67.18	4.32	71.74	4.40	75.31	4.49
	65	57.42	4.03	60.99	4.18	64.56	4.33	67.13	4.38	71.69	4.46	75.26	4.55
	70	57.38	4.08	60.94	4.23	64.51	4.38	67.08	4.43	71.63	4.52	75.20	4.61
	75	56.00	4.30	59.55	4.46	63.11	4.62	65.68	4.67	70.22	4.76	73.77	4.85
	80	54.62	4.52	58.16	4.68	61.71	4.85	64.27	4.91	68.80	5.00	72.35	5.10
	85	53.25	4.74	56.79	4.91	60.32	5.09	62.88	5.15	67.40	5.25	70.94	5.35
	90	51.88	4.96	55.41	5.14	58.94	5.33	61.49	5.39	66.00	5.49	69.52	5.60
	95	50.40	5.18	53.91	5.37	57.42	5.56	59.03	5.63	64.44	5.73	67.95	5.85
	100	49.17	5.40	52.68	5.60	56.19	5.80	58.26	5.87	63.21	5.98	66.72	6.10
	105	47.94	5.62	51.45	5.82	54.96	6.04	57.50	6.11	61.99	6.22	65.50	6.35
	110	46.71	5.84	50.23	6.05	53.74	6.27	56.27	6.35	60.76	6.46	64.27	6.59
	115	45.49	6.06	49.00	6.28	52.51	6.51	55.04	6.58	59.53	6.71	63.04	6.84
	118	44.75	6.19	48.26	6.42	51.77	6.65	54.31	6.73	58.79	6.85	62.31	6.99
	122	44.51	6.37	48.02	6.60	51.53	6.84	54.06	6.92	58.55	7.05	62.06	7.19
Ducted Indoor Units 60 (100%)	-4	57.02	3.27	60.56	3.39	64.10	3.51	66.66	3.55	71.19	3.62	74.73	3.69
	0	56.99	3.30	60.53	3.42	64.07	3.55	66.63	3.59	71.15	3.66	74.69	3.73
	5	56.94	3.36	60.48	3.48	64.02	3.61	66.57	3.65	71.09	3.72	74.63	3.79
	10	56.90	3.41	60.43	3.53	63.97	3.66	66.52	3.70	71.04	3.77	74.57	3.85
	14	56.86	3.46	60.39	3.58	63.92	3.71	66.47	3.76	70.98	3.83	74.51	3.90
	20	56.81	3.51	60.34	3.63	63.87	3.77	66.42	3.81	70.93	3.88	74.46	3.96
	25	56.77	3.56	60.30	3.69	63.82	3.82	66.37	3.86	70.87	3.94	74.40	4.02
	30	56.73	3.61	60.25	3.74	63.77	3.87	66.32	3.92	70.82	3.99	74.34	4.07
	35	56.68	3.66	60.20	3.79	63.72	3.93	66.27	3.97	70.77	4.05	74.29	4.13
	40	56.64	3.71	60.16	3.84	63.68	3.98	66.22	4.03	70.71	4.10	74.23	4.18
	45	56.60	3.75	60.11	3.89	63.63	4.03	66.17	4.08	70.66	4.16	74.17	4.24
	50	56.55	3.80	60.07	3.94	63.58	4.09	66.11	4.13	70.60	4.21	74.11	4.30
	55	56.51	3.85	60.02	3.99	63.53	4.14	66.06	4.19	70.55	4.27	74.06	4.35
	60	56.47	3.90	59.97	4.05	63.48	4.19	66.01	4.24	70.49	4.32	74.00	4.41
	65	56.42	3.95	59.93	4.10	63.43	4.25	65.96	4.30	70.44	4.38	73.94	4.47
	70	56.38	4.00	59.88	4.15	63.38	4.30	65.91	4.35	70.39	4.43	73.89	4.52
	75	55.02	4.22	58.52	4.37	62.01	4.53	64.53	4.59	68.99	4.67	72.49	4.77
	80	53.67	4.44	57.15	4.60	60.64	4.76	63.15	4.82	67.60	4.91	71.09	5.01
	85	52.32	4.65	55.80	4.82	59.27	5.00	61.78	5.05	66.22	5.15	69.70	5.25
	90	50.98	4.87	54.44	5.04	57.91	5.23	60.42	5.29	64.85	5.39	68.31	5.50
	95	49.52	5.08	52.97	5.27	56.42	5.46	58.00	5.52	63.32	5.63	66.77	5.74
	100	48.31	5.30	51.76	5.49	55.21	5.69	57.25	5.76	62.11	5.87	65.56	5.98
	105	47.11	5.52	50.56	5.72	54.01	5.93	56.50	5.99	60.91	6.11	64.35	6.23
	110	45.90	5.73	49.35	5.94	52.80	6.16	55.29	6.23	59.70	6.34	63.15	6.47
	115	44.69	5.95	48.14	6.16	51.59	6.39	54.09	6.46	58.49	6.58	61.94	6.72
	118	43.97	6.08	47.42	6.30	50.87	6.53	53.36	6.60	57.77	6.73	61.22	6.86
	122	43.73	6.25	47.18	6.48	50.63	6.71	53.12	6.79	57.53	6.92	60.98	7.06

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 248: LMU600HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 54 (90%)	-4	51.64	2.88	54.85	2.99	58.05	3.09	60.37	3.13	64.47	3.19	67.67	3.25
	0	51.61	2.91	54.82	3.02	58.02	3.13	60.34	3.16	64.43	3.22	67.64	3.29
	5	51.57	2.96	54.77	3.07	57.97	3.18	60.29	3.22	64.38	3.28	67.58	3.34
	10	51.53	3.00	54.73	3.11	57.93	3.23	60.24	3.26	64.33	3.32	67.53	3.39
	14	51.49	3.05	54.69	3.16	57.89	3.27	60.19	3.31	64.28	3.37	67.48	3.44
	20	51.45	3.09	54.65	3.20	57.84	3.32	60.15	3.36	64.23	3.42	67.43	3.49
	25	51.41	3.13	54.60	3.25	57.80	3.37	60.10	3.41	64.18	3.47	67.38	3.54
	30	51.37	3.18	54.56	3.29	57.75	3.41	60.06	3.45	64.13	3.52	67.32	3.59
	35	51.33	3.22	54.52	3.34	57.71	3.46	60.01	3.50	64.08	3.57	67.27	3.64
	40	51.29	3.27	54.48	3.39	57.66	3.51	59.97	3.55	64.04	3.62	67.22	3.69
	45	51.25	3.31	54.44	3.43	57.62	3.56	59.92	3.60	63.99	3.66	67.17	3.74
	50	51.22	3.35	54.40	3.48	57.58	3.60	59.87	3.64	63.94	3.71	67.12	3.79
	55	51.18	3.40	54.35	3.52	57.53	3.65	59.83	3.69	63.89	3.76	67.07	3.84
	60	51.14	3.44	54.31	3.57	57.49	3.70	59.78	3.74	63.84	3.81	67.02	3.89
	65	51.10	3.48	54.27	3.61	57.44	3.74	59.74	3.79	63.79	3.86	66.96	3.94
	70	51.06	3.53	54.23	3.66	57.40	3.79	59.69	3.83	63.74	3.91	66.91	3.99
	75	49.83	3.72	52.99	3.85	56.16	4.00	58.44	4.04	62.48	4.12	65.64	4.20
	80	48.60	3.91	51.76	4.05	54.91	4.20	57.19	4.25	61.22	4.33	64.38	4.42
	85	47.38	4.10	50.53	4.25	53.68	4.40	55.95	4.46	59.97	4.54	63.12	4.63
	90	46.17	4.29	49.30	4.45	52.44	4.61	54.71	4.66	58.72	4.75	61.86	4.85
	95	44.84	4.48	47.97	4.64	51.09	4.81	52.52	4.87	57.34	4.96	60.46	5.06
	100	43.75	4.67	46.88	4.84	50.00	5.02	51.84	5.08	56.25	5.17	59.37	5.28
	105	42.66	4.86	45.78	5.04	48.91	5.22	51.16	5.28	55.16	5.38	58.28	5.49
	110	41.57	5.05	44.69	5.24	47.82	5.43	50.07	5.49	54.06	5.59	57.19	5.71
	115	40.48	5.24	43.60	5.43	46.72	5.63	48.98	5.70	52.97	5.80	56.10	5.92
	118	39.82	5.36	42.94	5.55	46.07	5.75	48.32	5.82	52.32	5.93	55.44	6.05
Ducted Indoor Units 48 (80%)	122	39.60	5.51	42.73	5.71	45.85	5.92	48.11	5.99	52.10	6.10	55.22	6.22
	-4	45.99	2.49	48.84	2.58	51.70	2.68	53.76	2.71	57.41	2.76	60.27	2.82
	0	45.96	2.52	48.82	2.61	51.67	2.71	53.73	2.74	57.38	2.79	60.23	2.85
	5	45.92	2.56	48.78	2.66	51.63	2.75	53.69	2.78	57.33	2.84	60.18	2.89
	10	45.89	2.60	48.74	2.69	51.59	2.79	53.65	2.82	57.29	2.88	60.14	2.94
	14	45.85	2.64	48.70	2.73	51.55	2.83	53.61	2.87	57.25	2.92	60.09	2.98
	20	45.82	2.68	48.66	2.77	51.51	2.87	53.57	2.91	57.20	2.96	60.05	3.02
	25	45.78	2.71	48.63	2.81	51.47	2.91	53.52	2.95	57.16	3.00	60.00	3.06
	30	45.75	2.75	48.59	2.85	51.43	2.96	53.48	2.99	57.11	3.05	59.96	3.11
	35	45.71	2.79	48.55	2.89	51.39	3.00	53.44	3.03	57.07	3.09	59.91	3.15
	40	45.68	2.83	48.52	2.93	51.35	3.04	53.40	3.07	57.03	3.13	59.86	3.19
	45	45.64	2.86	48.48	2.97	51.31	3.08	53.36	3.11	56.98	3.17	59.82	3.24
	50	45.61	2.90	48.44	3.01	51.27	3.12	53.32	3.15	56.94	3.21	59.77	3.28
	55	45.57	2.94	48.40	3.05	51.24	3.16	53.28	3.20	56.90	3.26	59.73	3.32
	60	45.54	2.98	48.37	3.09	51.20	3.20	53.24	3.24	56.85	3.30	59.68	3.36
	65	45.50	3.02	48.33	3.13	51.16	3.24	53.20	3.28	56.81	3.34	59.63	3.41
	70	45.47	3.05	48.29	3.17	51.12	3.28	53.16	3.32	56.76	3.38	59.59	3.45
	75	44.38	3.22	47.19	3.34	50.01	3.46	52.04	3.50	55.64	3.56	58.46	3.64
	80	43.28	3.38	46.09	3.51	48.90	3.64	50.93	3.68	54.52	3.75	57.33	3.82
	85	42.20	3.55	45.00	3.68	47.80	3.81	49.83	3.86	53.41	3.93	56.21	4.01
	90	41.11	3.71	43.91	3.85	46.70	3.99	48.72	4.04	52.30	4.11	55.09	4.19
	95	39.94	3.88	42.72	4.02	45.50	4.17	46.78	4.21	51.06	4.29	53.85	4.38
	100	38.96	4.04	41.74	4.19	44.53	4.34	46.17	4.39	50.09	4.48	52.87	4.57
	105	37.99	4.21	40.77	4.36	43.55	4.52	45.56	4.57	49.12	4.66	51.90	4.75
	110	37.02	4.37	39.80	4.53	42.58	4.70	44.59	4.75	48.15	4.84	50.93	4.94
	115	36.05	4.54	38.83	4.70	41.61	4.87	43.62	4.93	47.17	5.02	49.96	5.12
	118	35.46	4.64	38.24	4.81	41.03	4.98	43.04	5.04	46.59	5.13	49.37	5.24
	122	35.27	4.77	38.05	4.94	40.83	5.12	42.84	5.18	46.40	5.28	49.18	5.38

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 249: LMU600HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°F])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 42 (70%)	-4	40.34	2.11	42.84	2.18	45.35	2.26	47.15	2.29	50.36	2.33	52.86	2.38
	0	40.31	2.13	42.82	2.21	45.32	2.29	47.13	2.31	50.33	2.36	52.83	2.40
	5	40.28	2.16	42.78	2.24	45.28	2.32	47.09	2.35	50.29	2.40	52.79	2.44
	10	40.25	2.20	42.75	2.28	45.25	2.36	47.05	2.39	50.25	2.43	52.75	2.48
	14	40.22	2.23	42.72	2.31	45.21	2.39	47.02	2.42	50.21	2.47	52.71	2.52
	20	40.19	2.26	42.68	2.34	45.18	2.43	46.98	2.46	50.17	2.50	52.67	2.55
	25	40.16	2.29	42.65	2.38	45.15	2.46	46.95	2.49	50.13	2.54	52.63	2.59
	30	40.13	2.32	42.62	2.41	45.11	2.50	46.91	2.53	50.09	2.57	52.59	2.62
	35	40.10	2.36	42.59	2.44	45.08	2.53	46.87	2.56	50.06	2.61	52.55	2.66
	40	40.07	2.39	42.55	2.47	45.04	2.57	46.84	2.59	50.02	2.64	52.51	2.70
	45	40.03	2.42	42.52	2.51	45.01	2.60	46.80	2.63	49.98	2.68	52.47	2.73
	50	40.00	2.45	42.49	2.54	44.97	2.63	46.77	2.66	49.94	2.71	52.43	2.77
	55	39.97	2.48	42.46	2.57	44.94	2.67	46.73	2.70	49.90	2.75	52.39	2.80
	60	39.94	2.52	42.42	2.61	44.90	2.70	46.70	2.73	49.86	2.79	52.35	2.84
	65	39.91	2.55	42.39	2.64	44.87	2.74	46.66	2.77	49.83	2.82	52.31	2.88
	70	39.88	2.58	42.36	2.67	44.83	2.77	46.62	2.80	49.79	2.86	52.27	2.91
	75	38.92	2.72	41.39	2.82	43.86	2.92	45.65	2.95	48.80	3.01	51.27	3.07
	80	37.96	2.86	40.43	2.96	42.89	3.07	44.67	3.11	47.82	3.16	50.28	3.23
	85	37.01	3.00	39.47	3.11	41.93	3.22	43.70	3.26	46.84	3.32	49.30	3.38
	90	36.06	3.14	38.51	3.25	40.96	3.37	42.74	3.41	45.87	3.47	48.32	3.54
	95	35.03	3.28	37.47	3.40	39.91	3.52	41.03	3.56	44.79	3.63	47.23	3.70
	100	34.17	3.41	36.61	3.54	39.05	3.67	40.50	3.71	43.93	3.78	46.37	3.86
	105	33.32	3.55	35.76	3.68	38.20	3.82	39.96	3.86	43.08	3.93	45.52	4.01
	110	32.47	3.69	34.91	3.83	37.35	3.97	39.11	4.01	42.23	4.09	44.67	4.17
	115	31.62	3.83	34.06	3.97	36.50	4.12	38.26	4.16	41.38	4.24	43.82	4.33
	118	31.10	3.92	33.54	4.06	35.98	4.21	37.75	4.26	40.86	4.34	43.30	4.42
Ducted Indoor Units 36 (60%)	122	30.93	4.03	33.37	4.17	35.81	4.33	37.58	4.38	40.69	4.46	43.13	4.55
	-4	34.68	1.72	36.84	1.78	38.99	1.85	40.55	1.87	43.30	1.90	45.45	1.94
	0	34.66	1.74	36.82	1.80	38.97	1.87	40.52	1.89	43.28	1.92	45.43	1.96
	5	34.64	1.77	36.79	1.83	38.94	1.90	40.49	1.92	43.24	1.95	45.39	1.99
	10	34.61	1.79	36.76	1.86	38.91	1.92	40.46	1.95	43.21	1.98	45.36	2.02
	14	34.58	1.82	36.73	1.88	38.88	1.95	40.43	1.98	43.17	2.01	45.32	2.05
	20	34.56	1.84	36.70	1.91	38.85	1.98	40.40	2.00	43.14	2.04	45.29	2.08
	25	34.53	1.87	36.67	1.94	38.82	2.01	40.37	2.03	43.11	2.07	45.25	2.11
	30	34.50	1.90	36.65	1.97	38.79	2.04	40.34	2.06	43.08	2.10	45.22	2.14
	35	34.48	1.92	36.62	1.99	38.76	2.07	40.31	2.09	43.04	2.13	45.18	2.17
	40	34.45	1.95	36.59	2.02	38.73	2.09	40.28	2.12	43.01	2.16	45.15	2.20
	45	34.42	1.97	36.56	2.05	38.70	2.12	40.24	2.15	42.98	2.19	45.11	2.23
	50	34.40	2.00	36.53	2.07	38.67	2.15	40.21	2.17	42.94	2.21	45.08	2.26
	55	34.37	2.03	36.51	2.10	38.64	2.18	40.18	2.20	42.91	2.24	45.05	2.29
	60	34.35	2.05	36.48	2.13	38.61	2.21	40.15	2.23	42.88	2.27	45.01	2.32
	65	34.32	2.08	36.45	2.15	38.58	2.23	40.12	2.26	42.84	2.30	44.98	2.35
	70	34.29	2.11	36.42	2.18	38.55	2.26	40.09	2.29	42.81	2.33	44.94	2.38
	75	33.47	2.22	35.59	2.30	37.72	2.38	39.25	2.41	41.97	2.46	44.09	2.51
	80	32.64	2.33	34.76	2.42	36.88	2.51	38.41	2.53	41.12	2.58	43.24	2.63
	85	31.82	2.45	33.94	2.54	36.05	2.63	37.58	2.66	40.28	2.71	42.39	2.76
	90	31.01	2.56	33.12	2.65	35.22	2.75	36.75	2.78	39.44	2.83	41.55	2.89
	95	30.12	2.67	32.22	2.77	34.32	2.87	35.28	2.90	38.51	2.96	40.61	3.02
	100	29.39	2.79	31.48	2.89	33.58	2.99	34.82	3.03	37.78	3.09	39.88	3.15
	105	28.65	2.90	30.75	3.01	32.85	3.12	34.36	3.15	37.04	3.21	39.14	3.28
	110	27.92	3.01	30.02	3.12	32.11	3.24	33.63	3.28	36.31	3.34	38.41	3.40
	115	27.19	3.13	29.28	3.24	31.38	3.36	32.90	3.40	35.58	3.46	37.68	3.53
	118	26.74	3.20	28.84	3.31	30.94	3.43	32.46	3.47	35.14	3.54	37.24	3.61
	122	26.60	3.29	28.70	3.41	30.79	3.53	32.31	3.57	34.99	3.64	37.09	3.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 250: LMU600HV Cooling Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 30 (50%)	-4	29.03	1.33	30.83	1.38	32.64	1.43	33.94	1.45	36.24	1.47	38.05	1.50
	0	29.02	1.35	30.82	1.39	32.62	1.45	33.92	1.46	36.22	1.49	38.03	1.52
	5	28.99	1.37	30.79	1.42	32.59	1.47	33.89	1.49	36.19	1.51	37.99	1.54
	10	28.97	1.39	30.77	1.44	32.57	1.49	33.87	1.51	36.17	1.54	37.96	1.57
	14	28.95	1.41	30.74	1.46	32.54	1.51	33.84	1.53	36.14	1.56	37.94	1.59
	20	28.93	1.43	30.72	1.48	32.52	1.53	33.82	1.55	36.11	1.58	37.91	1.61
	25	28.90	1.45	30.70	1.50	32.49	1.56	33.79	1.57	36.08	1.60	37.88	1.64
	30	28.88	1.47	30.67	1.52	32.47	1.58	33.76	1.60	36.06	1.63	37.85	1.66
	35	28.86	1.49	30.65	1.54	32.44	1.60	33.74	1.62	36.03	1.65	37.82	1.68
	40	28.84	1.51	30.63	1.56	32.42	1.62	33.71	1.64	36.00	1.67	37.79	1.70
	45	28.81	1.53	30.60	1.59	32.39	1.64	33.69	1.66	35.97	1.69	37.76	1.73
	50	28.79	1.55	30.58	1.61	32.37	1.66	33.66	1.68	35.95	1.72	37.73	1.75
	55	28.77	1.57	30.56	1.63	32.34	1.69	33.63	1.71	35.92	1.74	37.70	1.77
	60	28.75	1.59	30.53	1.65	32.32	1.71	33.61	1.73	35.89	1.76	37.68	1.80
	65	28.73	1.61	30.51	1.67	32.29	1.73	33.58	1.75	35.86	1.78	37.65	1.82
	70	28.70	1.63	30.49	1.69	32.27	1.75	33.56	1.77	35.83	1.81	37.62	1.84
	75	28.01	1.72	29.79	1.78	31.57	1.85	32.85	1.87	35.13	1.90	36.90	1.94
	80	27.32	1.81	29.10	1.87	30.87	1.94	32.15	1.96	34.42	2.00	36.19	2.04
	85	26.64	1.89	28.41	1.96	30.18	2.04	31.46	2.06	33.72	2.10	35.49	2.14
	90	25.95	1.98	27.72	2.05	29.48	2.13	30.76	2.15	33.01	2.19	34.78	2.24
	95	25.21	2.07	26.97	2.15	28.72	2.22	29.53	2.25	32.24	2.29	33.99	2.34
	100	24.60	2.16	26.35	2.24	28.11	2.32	29.15	2.35	31.62	2.39	33.38	2.44
	105	23.98	2.25	25.74	2.33	27.50	2.41	28.76	2.44	31.01	2.49	32.76	2.54
	110	23.37	2.33	25.13	2.42	26.88	2.51	28.15	2.54	30.39	2.58	32.15	2.64
	115	22.75	2.42	24.51	2.51	26.27	2.60	27.54	2.63	29.78	2.68	31.54	2.74
	118	22.39	2.48	24.14	2.57	25.90	2.66	27.17	2.69	29.41	2.74	31.17	2.80
Ducted Indoor Units 24 (40%)	122	22.26	2.55	24.02	2.64	25.78	2.73	27.04	2.77	29.29	2.82	31.05	2.87
	-4	23.38	0.94	24.83	0.98	26.28	1.01	27.33	1.03	29.19	1.04	30.64	1.07
	0	23.37	0.95	24.82	0.99	26.27	1.03	27.32	1.04	29.17	1.06	30.62	1.08
	5	23.35	0.97	24.80	1.01	26.25	1.04	27.29	1.05	29.15	1.07	30.60	1.10
	10	23.33	0.98	24.78	1.02	26.23	1.06	27.27	1.07	29.12	1.09	30.57	1.11
	14	23.31	1.00	24.76	1.03	26.21	1.07	27.25	1.08	29.10	1.11	30.55	1.13
	20	23.29	1.01	24.74	1.05	26.19	1.09	27.23	1.10	29.08	1.12	30.53	1.14
	25	23.28	1.03	24.72	1.06	26.17	1.10	27.21	1.12	29.06	1.14	30.50	1.16
	30	23.26	1.04	24.70	1.08	26.15	1.12	27.19	1.13	29.04	1.15	30.48	1.18
	35	23.24	1.06	24.68	1.09	26.13	1.13	27.17	1.15	29.01	1.17	30.46	1.19
	40	23.22	1.07	24.66	1.11	26.11	1.15	27.15	1.16	28.99	1.18	30.43	1.21
	45	23.20	1.08	24.65	1.12	26.09	1.17	27.13	1.18	28.97	1.20	30.41	1.22
	50	23.19	1.10	24.63	1.14	26.07	1.18	27.11	1.19	28.95	1.22	30.39	1.24
	55	23.17	1.11	24.61	1.15	26.05	1.20	27.09	1.21	28.92	1.23	30.36	1.26
	60	23.15	1.13	24.59	1.17	26.03	1.21	27.07	1.23	28.90	1.25	30.34	1.27
	65	23.13	1.14	24.57	1.18	26.01	1.23	27.04	1.24	28.88	1.26	30.32	1.29
	70	23.12	1.16	24.55	1.20	25.99	1.24	27.02	1.26	28.86	1.28	30.29	1.31
	75	22.56	1.22	23.99	1.26	25.42	1.31	26.46	1.32	28.29	1.35	29.72	1.38
	80	22.00	1.28	23.43	1.33	24.86	1.38	25.89	1.39	27.72	1.42	29.15	1.45
	85	21.45	1.34	22.88	1.39	24.30	1.44	25.33	1.46	27.15	1.49	28.58	1.52
	90	20.90	1.41	22.32	1.46	23.74	1.51	24.77	1.53	26.59	1.56	28.01	1.59
	95	20.30	1.47	21.72	1.52	23.13	1.58	23.78	1.60	25.96	1.63	27.37	1.66
	100	19.81	1.53	21.22	1.59	22.64	1.64	23.47	1.66	25.47	1.69	26.88	1.73
	105	19.31	1.59	20.73	1.65	22.14	1.71	23.16	1.73	24.97	1.76	26.39	1.80
	110	18.82	1.66	20.23	1.72	21.65	1.78	22.67	1.80	24.48	1.83	25.89	1.87
	115	18.32	1.72	19.74	1.78	21.15	1.85	22.18	1.87	23.98	1.90	25.40	1.94
	118	18.03	1.75	19.44	1.82	20.86	1.89	21.88	1.91	23.69	1.94	25.10	1.98
	122	17.93	1.80	19.34	1.87	20.76	1.94	21.78	1.96	23.59	2.00	25.00	2.04

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 251: LMU600HV Cooling Capacity Table — Mixed Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 81 (135%)	-4	61.74	3.40	65.58	3.53	69.41	3.65	72.18	3.70	77.08	3.77	80.91	3.84
	0	61.71	3.44	65.54	3.56	69.37	3.69	72.14	3.74	77.04	3.81	80.87	3.88
	5	61.66	3.49	65.49	3.62	69.31	3.75	72.08	3.80	76.97	3.87	80.80	3.95
	10	61.61	3.55	65.44	3.68	69.26	3.81	72.03	3.85	76.91	3.93	80.74	4.00
	14	61.56	3.60	65.39	3.73	69.21	3.87	71.97	3.91	76.86	3.98	80.68	4.06
	20	61.52	3.65	65.34	3.78	69.16	3.92	71.92	3.97	76.80	4.04	80.62	4.12
	25	61.47	3.70	65.29	3.84	69.10	3.98	71.86	4.02	76.74	4.10	80.56	4.18
	30	61.42	3.75	65.24	3.89	69.05	4.03	71.81	4.08	76.68	4.15	80.49	4.24
	35	61.37	3.80	65.19	3.94	69.00	4.09	71.75	4.13	76.62	4.21	80.43	4.30
	40	61.33	3.86	65.14	4.00	68.95	4.14	71.70	4.19	76.56	4.27	80.37	4.36
	45	61.28	3.91	65.09	4.05	68.89	4.20	71.64	4.25	76.50	4.33	80.31	4.41
	50	61.23	3.96	65.04	4.10	68.84	4.25	71.59	4.30	76.45	4.38	80.25	4.47
	55	61.19	4.01	64.99	4.16	68.79	4.31	71.53	4.36	76.39	4.44	80.19	4.53
	60	61.14	4.06	64.94	4.21	68.73	4.37	71.48	4.42	76.33	4.50	80.13	4.59
	65	61.09	4.11	64.89	4.26	68.68	4.42	71.42	4.47	76.27	4.56	80.06	4.65
	70	61.05	4.17	64.84	4.32	68.63	4.48	71.37	4.53	76.21	4.61	80.00	4.71
	75	59.58	4.39	63.36	4.55	67.14	4.72	69.87	4.77	74.70	4.86	78.49	4.96
	80	58.11	4.62	61.88	4.78	65.65	4.96	68.38	5.02	73.20	5.11	76.97	5.21
	85	56.65	4.84	60.42	5.02	64.18	5.20	66.90	5.26	71.71	5.36	75.47	5.47
	90	55.20	5.07	58.95	5.25	62.70	5.44	65.42	5.50	70.21	5.61	73.97	5.72
	95	53.62	5.29	57.35	5.48	61.09	5.68	62.80	5.75	68.56	5.86	72.29	5.97
	100	52.31	5.52	56.05	5.72	59.78	5.93	61.99	5.99	67.25	6.11	70.99	6.23
	105	51.00	5.74	54.74	5.95	58.48	6.17	61.17	6.24	65.95	6.35	69.68	6.48
	110	49.70	5.96	53.43	6.18	57.17	6.41	59.87	6.48	64.64	6.60	68.38	6.74
	115	48.39	6.19	52.13	6.42	55.86	6.65	58.56	6.73	63.33	6.85	67.07	6.99
	118	47.61	6.32	51.35	6.56	55.08	6.79	57.78	6.87	62.55	7.00	66.29	7.14
	122	47.35	6.50	51.08	6.74	54.82	6.99	57.52	7.07	62.29	7.20	66.02	7.35
Mixed Indoor Units 78 (130%)	-4	61.21	3.37	65.01	3.49	68.81	3.62	71.56	3.66	76.41	3.73	80.21	3.81
	0	61.17	3.41	64.97	3.53	68.77	3.66	71.52	3.70	76.37	3.77	80.17	3.85
	5	61.12	3.46	64.92	3.59	68.72	3.72	71.46	3.76	76.31	3.83	80.10	3.91
	10	61.08	3.51	64.87	3.64	68.66	3.78	71.40	3.82	76.25	3.89	80.04	3.97
	14	61.03	3.57	64.82	3.70	68.61	3.83	71.35	3.88	76.19	3.95	79.98	4.03
	20	60.98	3.62	64.77	3.75	68.56	3.89	71.29	3.93	76.13	4.00	79.92	4.09
	25	60.94	3.67	64.72	3.80	68.51	3.94	71.24	3.99	76.08	4.06	79.86	4.14
	30	60.89	3.72	64.67	3.86	68.45	4.00	71.19	4.04	76.02	4.12	79.80	4.20
	35	60.84	3.77	64.62	3.91	68.40	4.05	71.13	4.10	75.96	4.17	79.74	4.26
	40	60.80	3.82	64.57	3.96	68.35	4.11	71.08	4.15	75.90	4.23	79.68	4.32
	45	60.75	3.87	64.52	4.01	68.30	4.16	71.02	4.21	75.84	4.29	79.62	4.37
	50	60.70	3.92	64.47	4.07	68.24	4.22	70.97	4.27	75.78	4.34	79.55	4.43
	55	60.66	3.98	64.43	4.12	68.19	4.27	70.91	4.32	75.73	4.40	79.49	4.49
	60	60.61	4.03	64.38	4.17	68.14	4.33	70.86	4.38	75.67	4.46	79.43	4.55
	65	60.57	4.08	64.33	4.23	68.09	4.38	70.80	4.43	75.61	4.52	79.37	4.61
	70	60.52	4.13	64.28	4.28	68.04	4.44	70.75	4.49	75.55	4.57	79.31	4.66
	75	59.06	4.35	62.81	4.51	66.56	4.68	69.27	4.73	74.06	4.82	77.81	4.92
	80	57.61	4.58	61.35	4.74	65.09	4.92	67.79	4.97	72.57	5.07	76.31	5.17
	85	56.16	4.80	59.89	4.97	63.62	5.15	66.32	5.21	71.09	5.31	74.82	5.42
	90	54.72	5.02	58.44	5.20	62.16	5.39	64.85	5.46	69.60	5.56	73.33	5.67
	95	53.15	5.24	56.86	5.43	60.56	5.63	62.26	5.70	67.96	5.81	71.67	5.92
	100	51.86	5.47	55.56	5.67	59.26	5.87	61.45	5.94	66.67	6.05	70.37	6.17
	105	50.56	5.69	54.27	5.90	57.97	6.11	60.64	6.18	65.38	6.30	69.08	6.43
	110	49.27	5.91	52.97	6.13	56.68	6.35	59.35	6.42	64.08	6.54	67.78	6.68
	115	47.98	6.13	51.68	6.36	55.38	6.59	58.06	6.67	62.79	6.79	66.49	6.93
	118	47.20	6.27	50.90	6.50	54.60	6.73	57.28	6.81	62.01	6.94	65.71	7.08
	122	46.94	6.45	50.64	6.68	54.35	6.93	57.02	7.01	61.75	7.14	65.45	7.28

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 252: LMU600HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 72 (120%)	-4	60.14	3.31	63.87	3.43	67.61	3.56	70.31	3.60	75.08	3.67	78.81	3.74
	0	60.11	3.35	63.84	3.47	67.57	3.60	70.27	3.64	75.04	3.71	78.77	3.78
	5	60.06	3.40	63.79	3.53	67.52	3.65	70.21	3.70	74.98	3.77	78.71	3.84
	10	60.01	3.45	63.74	3.58	67.47	3.71	70.16	3.75	74.92	3.82	78.65	3.90
	14	59.97	3.50	63.69	3.63	67.41	3.76	70.10	3.81	74.86	3.88	78.59	3.96
	20	59.92	3.55	63.64	3.68	67.36	3.82	70.05	3.86	74.81	3.93	78.53	4.01
	25	59.87	3.60	63.59	3.73	67.31	3.87	70.00	3.92	74.75	3.99	78.47	4.07
	30	59.83	3.65	63.54	3.79	67.26	3.93	69.94	3.97	74.69	4.04	78.41	4.13
	35	59.78	3.70	63.50	3.84	67.21	3.98	69.89	4.02	74.63	4.10	78.35	4.18
	40	59.74	3.75	63.45	3.89	67.16	4.03	69.84	4.08	74.58	4.16	78.29	4.24
	45	59.69	3.80	63.40	3.94	67.11	4.09	69.78	4.13	74.52	4.21	78.23	4.30
	50	59.65	3.85	63.35	4.00	67.05	4.14	69.73	4.19	74.46	4.27	78.17	4.35
	55	59.60	3.90	63.30	4.05	67.00	4.20	69.68	4.24	74.41	4.32	78.11	4.41
	60	59.55	3.96	63.25	4.10	66.95	4.25	69.62	4.30	74.35	4.38	78.05	4.47
	65	59.51	4.01	63.20	4.15	66.90	4.30	69.57	4.35	74.29	4.43	77.99	4.52
	70	59.46	4.06	63.16	4.20	66.85	4.36	69.52	4.41	74.23	4.49	77.93	4.58
	75	58.03	4.27	61.72	4.43	65.40	4.59	68.06	4.65	72.77	4.73	76.45	4.83
	80	56.60	4.49	60.28	4.66	63.95	4.83	66.60	4.88	71.30	4.97	74.97	5.07
	85	55.18	4.71	58.85	4.88	62.51	5.06	65.16	5.12	69.85	5.22	73.51	5.32
	90	53.76	4.93	57.42	5.11	61.08	5.30	63.72	5.36	68.39	5.46	72.05	5.57
	95	52.23	5.15	55.86	5.34	59.50	5.53	61.17	5.60	66.78	5.70	70.42	5.82
	100	50.95	5.37	54.59	5.56	58.23	5.77	60.38	5.83	65.51	5.94	69.15	6.06
	105	49.68	5.59	53.32	5.79	56.96	6.00	59.59	6.07	64.24	6.19	67.87	6.31
	110	48.41	5.81	52.05	6.02	55.69	6.24	58.31	6.31	62.96	6.43	66.60	6.56
	115	47.14	6.03	50.78	6.25	54.42	6.47	57.04	6.55	61.69	6.67	65.33	6.80
	118	46.38	6.16	50.01	6.38	53.65	6.61	56.28	6.69	60.93	6.82	64.57	6.95
	122	46.12	6.33	49.76	6.56	53.40	6.80	56.03	6.88	60.67	7.01	64.31	7.15
Mixed Indoor Units 66 (110%)	-4	59.07	3.25	62.74	3.37	66.41	3.49	69.06	3.53	73.75	3.60	77.42	3.67
	0	59.04	3.29	62.71	3.41	66.37	3.53	69.02	3.57	73.71	3.64	77.37	3.71
	5	58.99	3.34	62.66	3.46	66.32	3.59	68.97	3.63	73.65	3.70	77.31	3.77
	10	58.95	3.39	62.61	3.51	66.27	3.64	68.91	3.68	73.59	3.75	77.25	3.83
	14	58.90	3.44	62.56	3.56	66.22	3.69	68.86	3.74	73.53	3.81	77.19	3.88
	20	58.86	3.49	62.51	3.62	66.17	3.75	68.81	3.79	73.48	3.86	77.13	3.94
	25	58.81	3.54	62.46	3.67	66.12	3.80	68.75	3.84	73.42	3.92	77.07	4.00
	30	58.77	3.59	62.42	3.72	66.07	3.85	68.70	3.90	73.37	3.97	77.02	4.05
	35	58.72	3.64	62.37	3.77	66.02	3.91	68.65	3.95	73.31	4.03	76.96	4.11
	40	58.68	3.69	62.32	3.82	65.97	3.96	68.60	4.01	73.25	4.08	76.90	4.16
	45	58.63	3.74	62.27	3.87	65.91	4.01	68.54	4.06	73.20	4.14	76.84	4.22
	50	58.59	3.78	62.23	3.92	65.86	4.07	68.49	4.11	73.14	4.19	76.78	4.27
	55	58.54	3.83	62.18	3.97	65.81	4.12	68.44	4.17	73.09	4.24	76.72	4.33
	60	58.50	3.88	62.13	4.03	65.76	4.17	68.39	4.22	73.03	4.30	76.66	4.39
	65	58.45	3.93	62.08	4.08	65.71	4.23	68.33	4.27	72.97	4.35	76.60	4.44
	70	58.41	3.98	62.04	4.13	65.66	4.28	68.28	4.33	72.92	4.41	76.54	4.50
	75	57.00	4.20	60.62	4.35	64.24	4.51	66.85	4.56	71.48	4.65	75.09	4.74
	80	55.60	4.41	59.21	4.57	62.82	4.74	65.42	4.79	70.03	4.88	73.64	4.98
	85	54.20	4.63	57.80	4.80	61.40	4.97	64.01	5.03	68.61	5.12	72.21	5.23
	90	52.81	4.84	56.40	5.02	59.99	5.20	62.59	5.26	67.18	5.36	70.77	5.47
	95	51.30	5.06	54.87	5.24	58.45	5.43	60.09	5.50	65.59	5.60	69.17	5.71
	100	50.05	5.27	53.62	5.46	57.20	5.66	59.31	5.73	64.34	5.84	67.92	5.95
	105	48.80	5.49	52.37	5.69	55.95	5.89	58.53	5.96	63.10	6.07	66.67	6.20
	110	47.55	5.70	51.12	5.91	54.70	6.12	57.28	6.20	61.85	6.31	65.42	6.44
	115	46.30	5.92	49.88	6.13	53.45	6.36	56.03	6.43	60.60	6.55	64.17	6.68
	118	45.55	6.04	49.13	6.27	52.70	6.49	55.28	6.57	59.85	6.69	63.42	6.83
	122	45.30	6.22	48.88	6.44	52.45	6.68	55.03	6.76	59.60	6.88	63.17	7.02

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

Table 253: LMU600HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[°])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 60 (100%)	-4	58.01	3.19	61.61	3.31	65.21	3.43	67.81	3.47	72.41	3.53	76.02	3.60
	0	57.97	3.23	61.57	3.34	65.17	3.47	67.77	3.51	72.38	3.57	75.98	3.64
	5	57.93	3.28	61.52	3.40	65.12	3.52	67.72	3.56	72.32	3.63	75.91	3.70
	10	57.88	3.33	61.48	3.45	65.07	3.57	67.67	3.62	72.26	3.68	75.86	3.76
	14	57.84	3.38	61.43	3.50	65.02	3.63	67.62	3.67	72.21	3.74	75.80	3.81
	20	57.79	3.42	61.38	3.55	64.97	3.68	67.56	3.72	72.15	3.79	75.74	3.87
	25	57.75	3.47	61.34	3.60	64.92	3.73	67.51	3.77	72.10	3.84	75.68	3.92
	30	57.71	3.52	61.29	3.65	64.87	3.78	67.46	3.83	72.04	3.90	75.62	3.98
	35	57.66	3.57	61.24	3.70	64.82	3.83	67.41	3.88	71.99	3.95	75.57	4.03
	40	57.62	3.62	61.20	3.75	64.77	3.89	67.36	3.93	71.93	4.01	75.51	4.09
	45	57.57	3.67	61.15	3.80	64.72	3.94	67.31	3.98	71.87	4.06	75.45	4.14
	50	57.53	3.71	61.10	3.85	64.67	3.99	67.25	4.04	71.82	4.11	75.39	4.20
	55	57.48	3.76	61.05	3.90	64.62	4.04	67.20	4.09	71.76	4.17	75.33	4.25
	60	57.44	3.81	61.01	3.95	64.58	4.10	67.15	4.14	71.71	4.22	75.28	4.30
	65	57.40	3.86	60.96	4.00	64.53	4.15	67.10	4.19	71.65	4.27	75.22	4.36
	70	57.35	3.91	60.91	4.05	64.48	4.20	67.05	4.25	71.60	4.33	75.16	4.41
	75	55.97	4.12	59.53	4.27	63.08	4.43	65.64	4.48	70.18	4.56	73.74	4.65
	80	54.59	4.33	58.14	4.49	61.68	4.65	64.24	4.71	68.77	4.79	72.31	4.89
	85	53.22	4.54	56.76	4.71	60.30	4.88	62.85	4.94	67.37	5.03	70.90	5.13
	90	51.86	4.75	55.38	4.93	58.91	5.11	61.46	5.16	65.96	5.26	69.49	5.37
	95	50.37	4.96	53.88	5.14	57.39	5.33	59.00	5.39	64.41	5.49	67.92	5.61
	100	49.14	5.17	52.65	5.36	56.16	5.56	58.24	5.62	63.18	5.73	66.69	5.84
	105	47.92	5.38	51.43	5.58	54.94	5.79	57.47	5.85	61.96	5.96	65.46	6.08
	110	46.69	5.60	50.20	5.80	53.71	6.01	56.24	6.08	60.73	6.19	64.24	6.32
	115	45.47	5.81	48.97	6.02	52.48	6.24	55.02	6.31	59.50	6.43	63.01	6.56
	118	44.73	5.93	48.24	6.15	51.75	6.37	54.28	6.45	58.77	6.57	62.28	6.70
Mixed Indoor Units 54 (90%)	122	44.48	6.10	47.99	6.32	51.50	6.56	54.04	6.63	58.52	6.76	62.03	6.89
	-4	52.36	2.81	55.62	2.92	58.87	3.02	61.22	3.06	65.37	3.11	68.62	3.18
	0	52.34	2.84	55.59	2.95	58.84	3.05	61.18	3.09	65.34	3.15	68.59	3.21
	5	52.29	2.89	55.54	3.00	58.79	3.10	61.13	3.14	65.28	3.20	68.53	3.26
	10	52.25	2.93	55.50	3.04	58.74	3.15	61.09	3.19	65.23	3.25	68.48	3.31
	14	52.21	2.98	55.46	3.08	58.70	3.20	61.04	3.23	65.18	3.29	68.43	3.36
	20	52.17	3.02	55.41	3.13	58.65	3.24	60.99	3.28	65.13	3.34	68.37	3.41
	25	52.13	3.06	55.37	3.17	58.61	3.29	60.95	3.33	65.08	3.39	68.32	3.46
	30	52.09	3.10	55.33	3.22	58.56	3.33	60.90	3.37	65.03	3.44	68.27	3.50
	35	52.05	3.15	55.29	3.26	58.52	3.38	60.85	3.42	64.98	3.48	68.22	3.55
	40	52.01	3.19	55.24	3.31	58.47	3.43	60.81	3.47	64.94	3.53	68.17	3.60
	45	51.97	3.23	55.20	3.35	58.43	3.47	60.76	3.51	64.89	3.58	68.11	3.65
	50	51.93	3.27	55.16	3.39	58.38	3.52	60.71	3.56	64.84	3.63	68.06	3.70
	55	51.89	3.32	55.12	3.44	58.34	3.56	60.67	3.60	64.79	3.67	68.01	3.75
	60	51.85	3.36	55.07	3.48	58.30	3.61	60.62	3.65	64.74	3.72	67.96	3.79
	65	51.81	3.40	55.03	3.53	58.25	3.66	60.57	3.70	64.69	3.77	67.90	3.84
	70	51.77	3.45	54.99	3.57	58.21	3.70	60.53	3.74	64.64	3.81	67.85	3.89
	75	50.53	3.63	53.74	3.76	56.94	3.90	59.26	3.95	63.36	4.02	66.57	4.10
	80	49.28	3.82	52.48	3.96	55.68	4.10	57.99	4.15	62.08	4.23	65.28	4.31
	85	48.05	4.00	51.24	4.15	54.43	4.30	56.74	4.35	60.81	4.43	64.01	4.52
	90	46.81	4.19	50.00	4.34	53.18	4.50	55.48	4.55	59.55	4.64	62.73	4.73
	95	45.47	4.37	48.64	4.53	51.81	4.70	53.26	4.75	58.14	4.84	61.31	4.94
	100	44.37	4.56	47.53	4.73	50.70	4.90	52.57	4.96	57.04	5.05	60.21	5.15
	105	43.26	4.75	46.43	4.92	49.59	5.10	51.88	5.16	55.93	5.25	59.10	5.36
	110	42.15	4.93	45.32	5.11	48.49	5.30	50.77	5.36	54.82	5.46	57.99	5.57
	115	41.04	5.12	44.21	5.31	47.38	5.50	49.67	5.56	53.72	5.67	56.88	5.78
	118	40.38	5.23	43.55	5.42	46.72	5.62	49.00	5.68	53.05	5.79	56.22	5.91
	122	40.16	5.38	43.33	5.57	46.49	5.78	48.78	5.84	52.83	5.95	56.00	6.07

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 254: LMU600HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 48 (80%)	-4	46.59	2.43	49.48	2.52	52.38	2.62	54.47	2.65	58.16	2.70	61.06	2.75
	0	46.56	2.46	49.46	2.55	52.35	2.64	54.44	2.67	58.13	2.72	61.02	2.78
	5	46.53	2.50	49.41	2.59	52.30	2.69	54.39	2.72	58.08	2.77	60.97	2.82
	10	46.49	2.54	49.38	2.63	52.26	2.73	54.35	2.76	58.04	2.81	60.93	2.87
	14	46.45	2.58	49.34	2.67	52.22	2.77	54.31	2.80	57.99	2.85	60.88	2.91
	20	46.42	2.61	49.30	2.71	52.18	2.81	54.27	2.84	57.95	2.89	60.83	2.95
	25	46.38	2.65	49.26	2.75	52.14	2.85	54.23	2.88	57.91	2.93	60.79	2.99
	30	46.35	2.69	49.23	2.78	52.10	2.89	54.18	2.92	57.86	2.97	60.74	3.03
	35	46.31	2.72	49.19	2.82	52.06	2.93	54.14	2.96	57.82	3.01	60.69	3.08
	40	46.28	2.76	49.15	2.86	52.03	2.97	54.10	3.00	57.77	3.06	60.65	3.12
	45	46.24	2.80	49.11	2.90	51.99	3.01	54.06	3.04	57.73	3.10	60.60	3.16
	50	46.21	2.83	49.08	2.94	51.95	3.04	54.02	3.08	57.68	3.14	60.55	3.20
	55	46.17	2.87	49.04	2.98	51.91	3.08	53.98	3.12	57.64	3.18	60.51	3.24
	60	46.14	2.91	49.00	3.01	51.87	3.12	53.94	3.16	57.60	3.22	60.46	3.28
	65	46.10	2.95	48.96	3.05	51.83	3.16	53.89	3.20	57.55	3.26	60.41	3.33
	70	46.06	2.98	48.93	3.09	51.79	3.20	53.85	3.24	57.51	3.30	60.37	3.37
	75	44.96	3.14	47.81	3.26	50.66	3.38	52.72	3.42	56.37	3.48	59.22	3.55
	80	43.85	3.30	46.69	3.42	49.54	3.55	51.60	3.59	55.23	3.66	58.08	3.73
	85	42.75	3.46	45.59	3.59	48.43	3.72	50.48	3.77	54.11	3.84	56.95	3.91
	90	41.65	3.63	44.48	3.76	47.32	3.90	49.36	3.94	52.98	4.01	55.81	4.09
	95	40.46	3.79	43.28	3.92	46.09	4.07	47.39	4.11	51.73	4.19	54.55	4.28
	100	39.47	3.95	42.29	4.09	45.11	4.24	46.77	4.29	50.75	4.37	53.57	4.46
	105	38.49	4.11	41.31	4.26	44.12	4.41	46.16	4.46	49.76	4.55	52.58	4.64
	110	37.50	4.27	40.32	4.43	43.14	4.59	45.17	4.64	48.78	4.73	51.59	4.82
	115	36.52	4.43	39.34	4.59	42.15	4.76	44.19	4.81	47.79	4.90	50.61	5.00
	118	35.93	4.53	38.74	4.69	41.56	4.86	43.60	4.92	47.20	5.01	50.02	5.11
Mixed Indoor Units 42 (70%)	122	35.73	4.66	38.55	4.83	41.37	5.00	43.40	5.06	47.00	5.15	49.82	5.26
	-4	40.81	2.06	43.35	2.13	45.88	2.21	47.71	2.23	50.95	2.28	53.49	2.32
	0	40.79	2.08	43.32	2.15	45.86	2.23	47.69	2.26	50.92	2.30	53.46	2.35
	5	40.76	2.11	43.29	2.19	45.82	2.27	47.65	2.30	50.88	2.34	53.41	2.39
	10	40.73	2.14	43.26	2.22	45.79	2.30	47.61	2.33	50.84	2.37	53.37	2.42
	14	40.70	2.18	43.22	2.25	45.75	2.34	47.58	2.36	50.81	2.41	53.33	2.46
	20	40.66	2.21	43.19	2.29	45.72	2.37	47.54	2.40	50.77	2.44	53.29	2.49
	25	40.63	2.24	43.16	2.32	45.68	2.40	47.50	2.43	50.73	2.48	53.25	2.53
	30	40.60	2.27	43.12	2.35	45.65	2.44	47.47	2.47	50.69	2.51	53.21	2.56
	35	40.57	2.30	43.09	2.38	45.61	2.47	47.43	2.50	50.65	2.55	53.17	2.60
	40	40.54	2.33	43.06	2.42	45.58	2.50	47.39	2.53	50.61	2.58	53.13	2.63
	45	40.51	2.36	43.03	2.45	45.54	2.54	47.36	2.57	50.57	2.62	53.09	2.67
	50	40.48	2.39	42.99	2.48	45.51	2.57	47.32	2.60	50.53	2.65	53.05	2.70
	55	40.45	2.43	42.96	2.51	45.47	2.61	47.29	2.64	50.50	2.68	53.01	2.74
	60	40.42	2.46	42.93	2.55	45.44	2.64	47.25	2.67	50.46	2.72	52.97	2.77
	65	40.39	2.49	42.89	2.58	45.40	2.67	47.21	2.70	50.42	2.75	52.93	2.81
	70	40.35	2.52	42.86	2.61	45.37	2.71	47.18	2.74	50.38	2.79	52.88	2.84
	75	39.38	2.65	41.88	2.75	44.38	2.85	46.19	2.88	49.38	2.94	51.88	3.00
	80	38.41	2.79	40.91	2.89	43.40	3.00	45.20	3.03	48.39	3.09	50.88	3.15
	85	37.45	2.93	39.94	3.03	42.42	3.14	44.22	3.18	47.40	3.24	49.89	3.30
	90	36.49	3.06	38.97	3.17	41.45	3.29	43.24	3.33	46.41	3.39	48.89	3.46
	95	35.44	3.20	37.91	3.31	40.38	3.44	41.51	3.48	45.32	3.54	47.79	3.61
	100	34.58	3.33	37.05	3.46	39.52	3.58	40.98	3.62	44.46	3.69	46.92	3.77
	105	33.72	3.47	36.19	3.60	38.65	3.73	40.44	3.77	43.59	3.84	46.06	3.92
	110	32.85	3.61	35.32	3.74	37.79	3.87	39.57	3.92	42.73	3.99	45.20	4.07
	115	31.99	3.74	34.46	3.88	36.93	4.02	38.71	4.07	41.87	4.14	44.34	4.23
	118	31.47	3.82	33.94	3.96	36.41	4.11	38.19	4.15	41.35	4.23	43.82	4.32
	122	31.30	3.93	33.77	4.08	36.24	4.22	38.02	4.27	41.18	4.35	43.65	4.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and 67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these values can be different if the system is not running consistently.

Table 255: LMU600HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 36 (60%)	-4	35.04	1.68	37.21	1.74	39.39	1.80	40.96	1.82	43.74	1.86	45.92	1.90
	0	35.02	1.70	37.19	1.76	39.37	1.82	40.94	1.84	43.72	1.88	45.89	1.92
	5	34.99	1.72	37.16	1.79	39.34	1.85	40.91	1.87	43.68	1.91	45.86	1.95
	10	34.96	1.75	37.13	1.81	39.31	1.88	40.87	1.90	43.65	1.94	45.82	1.98
	14	34.94	1.77	37.11	1.84	39.28	1.91	40.84	1.93	43.62	1.97	45.79	2.00
	20	34.91	1.80	37.08	1.87	39.25	1.93	40.81	1.96	43.58	1.99	45.75	2.03
	25	34.88	1.83	37.05	1.89	39.22	1.96	40.78	1.98	43.55	2.02	45.72	2.06
	30	34.86	1.85	37.02	1.92	39.19	1.99	40.75	2.01	43.52	2.05	45.68	2.09
	35	34.83	1.88	36.99	1.95	39.16	2.02	40.72	2.04	43.48	2.08	45.65	2.12
	40	34.80	1.90	36.97	1.97	39.13	2.04	40.69	2.07	43.45	2.11	45.61	2.15
	45	34.78	1.93	36.94	2.00	39.10	2.07	40.66	2.10	43.42	2.13	45.58	2.18
	50	34.75	1.95	36.91	2.02	39.07	2.10	40.63	2.12	43.38	2.16	45.54	2.21
	55	34.72	1.98	36.88	2.05	39.04	2.13	40.59	2.15	43.35	2.19	45.51	2.23
	60	34.70	2.00	36.85	2.08	39.01	2.15	40.56	2.18	43.32	2.22	45.47	2.26
	65	34.67	2.03	36.82	2.10	38.98	2.18	40.53	2.21	43.28	2.25	45.44	2.29
	70	34.64	2.06	36.80	2.13	38.95	2.21	40.50	2.23	43.25	2.28	45.40	2.32
	75	33.81	2.17	35.96	2.25	38.10	2.33	39.65	2.35	42.39	2.40	44.54	2.45
	80	32.98	2.28	35.12	2.36	37.26	2.45	38.80	2.47	41.54	2.52	43.68	2.57
	85	32.15	2.39	34.29	2.48	36.42	2.57	37.96	2.60	40.69	2.64	42.83	2.70
	90	31.32	2.50	33.45	2.59	35.58	2.68	37.12	2.72	39.85	2.77	41.98	2.82
	95	30.43	2.61	32.55	2.71	34.67	2.80	35.64	2.84	38.91	2.89	41.03	2.95
	100	29.69	2.72	31.81	2.82	33.93	2.92	35.18	2.96	38.16	3.01	40.28	3.07
	105	28.95	2.83	31.06	2.94	33.18	3.04	34.72	3.08	37.42	3.13	39.54	3.20
	110	28.20	2.94	30.32	3.05	32.44	3.16	33.97	3.20	36.68	3.26	38.80	3.32
	115	27.46	3.05	29.58	3.16	31.70	3.28	33.23	3.32	35.94	3.38	38.06	3.45
	118	27.02	3.12	29.14	3.23	31.26	3.35	32.79	3.39	35.50	3.45	37.62	3.52
Mixed Indoor Units 30 (50%)	122	26.87	3.21	28.99	3.33	31.11	3.45	32.64	3.49	35.35	3.55	37.47	3.62
	-4	29.26	1.30	31.08	1.35	32.90	1.40	34.21	1.41	36.53	1.44	38.35	1.47
	0	29.25	1.31	31.06	1.36	32.88	1.41	34.19	1.43	36.51	1.45	38.33	1.48
	5	29.22	1.34	31.04	1.38	32.85	1.43	34.16	1.45	36.48	1.48	38.30	1.51
	10	29.20	1.36	31.01	1.40	32.83	1.46	34.14	1.47	36.45	1.50	38.27	1.53
	14	29.18	1.37	30.99	1.43	32.80	1.48	34.11	1.49	36.43	1.52	38.24	1.55
	20	29.16	1.39	30.97	1.45	32.78	1.50	34.08	1.52	36.40	1.54	38.21	1.58
	25	29.13	1.41	30.94	1.47	32.75	1.52	34.06	1.54	36.37	1.57	38.18	1.60
	30	29.11	1.43	30.92	1.49	32.73	1.54	34.03	1.56	36.34	1.59	38.15	1.62
	35	29.09	1.45	30.90	1.51	32.70	1.56	34.01	1.58	36.32	1.61	38.12	1.64
	40	29.07	1.47	30.87	1.53	32.68	1.58	33.98	1.60	36.29	1.63	38.09	1.66
	45	29.04	1.49	30.85	1.55	32.65	1.60	33.95	1.62	36.26	1.65	38.06	1.69
	50	29.02	1.51	30.82	1.57	32.63	1.63	33.93	1.64	36.23	1.68	38.03	1.71
	55	29.00	1.53	30.80	1.59	32.60	1.65	33.90	1.67	36.20	1.70	38.01	1.73
	60	28.98	1.55	30.78	1.61	32.58	1.67	33.88	1.69	36.18	1.72	37.98	1.75
	65	28.96	1.57	30.75	1.63	32.55	1.69	33.85	1.71	36.15	1.74	37.95	1.78
	70	28.93	1.59	30.73	1.65	32.53	1.71	33.82	1.73	36.12	1.76	37.92	1.80
	75	28.24	1.68	30.03	1.74	31.82	1.80	33.12	1.82	35.41	1.86	37.20	1.90
	80	27.54	1.76	29.33	1.83	31.12	1.90	32.41	1.92	34.69	1.95	36.48	1.99
	85	26.85	1.85	28.63	1.92	30.42	1.99	31.71	2.01	33.99	2.05	35.77	2.09
	90	26.16	1.94	27.94	2.01	29.72	2.08	31.00	2.10	33.28	2.14	35.06	2.19
	95	25.41	2.02	27.18	2.10	28.95	2.17	29.76	2.20	32.49	2.24	34.26	2.28
	100	24.79	2.11	26.56	2.18	28.33	2.26	29.38	2.29	31.87	2.33	33.64	2.38
	105	24.17	2.19	25.94	2.27	27.71	2.36	28.99	2.38	31.26	2.43	33.03	2.48
	110	23.56	2.28	25.33	2.36	27.10	2.45	28.37	2.48	30.64	2.52	32.41	2.57
	115	22.94	2.37	24.71	2.45	26.48	2.54	27.76	2.57	30.02	2.62	31.79	2.67
	118	22.57	2.42	24.34	2.51	26.11	2.60	27.38	2.63	29.65	2.68	31.42	2.73
	122	22.44	2.49	24.21	2.58	25.98	2.67	27.26	2.70	29.52	2.75	31.29	2.81

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

MULTI F MAX LMU600HV

Cooling Capacity Tables

MULTI F
MULTI F MAX

Table 256: LMU600HV Cooling Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp. (°F DB)	Indoor Air Temp. °F DB / °F WB											
		68 / 57		73 / 61		77 / 64		80 / 67		86 / 72		90 / 75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 24 (40%)	-4	23.49	0.92	24.95	0.96	26.40	0.99	27.46	1.00	29.32	1.02	30.78	1.04
	0	23.47	0.93	24.93	0.97	26.39	1.00	27.44	1.01	29.31	1.03	30.76	1.05
	5	23.46	0.95	24.91	0.98	26.37	1.02	27.42	1.03	29.28	1.05	30.74	1.07
	10	23.44	0.96	24.89	1.00	26.35	1.03	27.40	1.04	29.26	1.06	30.71	1.09
	14	23.42	0.97	24.87	1.01	26.33	1.05	27.38	1.06	29.24	1.08	30.69	1.10
	20	23.40	0.99	24.85	1.02	26.31	1.06	27.36	1.07	29.21	1.09	30.67	1.12
	25	23.38	1.00	24.84	1.04	26.29	1.08	27.34	1.09	29.19	1.11	30.64	1.13
	30	23.37	1.02	24.82	1.05	26.27	1.09	27.32	1.11	29.17	1.13	30.62	1.15
	35	23.35	1.03	24.80	1.07	26.25	1.11	27.30	1.12	29.15	1.14	30.60	1.16
	40	23.33	1.04	24.78	1.08	26.23	1.12	27.27	1.14	29.13	1.16	30.57	1.18
	45	23.31	1.06	24.76	1.10	26.21	1.14	27.25	1.15	29.10	1.17	30.55	1.20
	50	23.29	1.07	24.74	1.11	26.19	1.15	27.23	1.17	29.08	1.19	30.53	1.21
	55	23.28	1.09	24.72	1.13	26.17	1.17	27.21	1.18	29.06	1.20	30.50	1.23
	60	23.26	1.10	24.70	1.14	26.15	1.18	27.19	1.20	29.04	1.22	30.48	1.24
	65	23.24	1.11	24.68	1.16	26.13	1.20	27.17	1.21	29.01	1.23	30.46	1.26
	70	23.22	1.13	24.67	1.17	26.11	1.21	27.15	1.23	28.99	1.25	30.43	1.27
	75	22.66	1.19	24.10	1.23	25.54	1.28	26.58	1.29	28.42	1.32	29.86	1.34
	80	22.11	1.25	23.54	1.30	24.98	1.34	26.01	1.36	27.85	1.38	29.28	1.41
	85	21.55	1.31	22.98	1.36	24.41	1.41	25.45	1.43	27.28	1.45	28.71	1.48
	90	21.00	1.37	22.43	1.42	23.85	1.47	24.88	1.49	26.71	1.52	28.14	1.55
	95	20.40	1.43	21.82	1.49	23.24	1.54	23.89	1.56	26.08	1.59	27.50	1.62
	100	19.90	1.49	21.32	1.55	22.74	1.61	23.58	1.62	25.58	1.65	27.00	1.69
	105	19.40	1.56	20.82	1.61	22.24	1.67	23.27	1.69	25.09	1.72	26.51	1.76
	110	18.91	1.62	20.33	1.68	21.75	1.74	22.77	1.76	24.59	1.79	26.01	1.83
	115	18.41	1.68	19.83	1.74	21.25	1.80	22.28	1.82	24.09	1.86	25.51	1.89
	118	18.11	1.71	19.53	1.78	20.95	1.84	21.98	1.86	23.80	1.90	25.22	1.94
	122	18.01	1.76	19.43	1.83	20.85	1.89	21.88	1.92	23.70	1.95	25.12	1.99

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal cooling capacity rating obtained with air entering the indoor unit at 80°F dry bulb (DB) and
67°F wet bulb (WB), and outdoor ambient conditions of 95°F dry bulb (DB) and 75°F wet bulb (WB).

Cooling range can be extended from 14°F down to -4°F using the Low Ambient Wind Baffle Kit (sold
separately).

The shaded table columns and rows indicate reference data. When operating at this temperature, these
values can be different if the system is not running consistently.

HEATING CAPACITY DATA

Multi F LMU18CHV on page 262

Multi F LMU24CHV on page 268

Multi F LMU30CHV on page 288

Multi F LMU36CHV on page 330

Multi F MAX LMU480HV on page 400

Multi F MAX LMU540HV on page 410

Multi F MAX LMU600HV on page 421

MULTI F LMU18CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 257: LMU18CHV Heating Capacity Table — Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	-4.4	5.87	1.08	5.40	1.13	5.39	1.14	5.33	1.15	5.29	1.15	5.05	1.20
		0	-0.4	7.30	1.11	6.86	1.15	6.76	1.17	6.67	1.18	6.59	1.19	6.31	1.23
		5	4.5	9.01	1.15	8.59	1.19	8.39	1.21	8.25	1.23	8.14	1.24	7.81	1.28
		10	9	10.16	1.18	9.75	1.22	9.48	1.25	9.31	1.27	9.18	1.28	8.82	1.32
		17	15	11.42	1.22	11.02	1.26	10.67	1.30	10.48	1.32	10.33	1.34	9.93	1.37
		20	19	12.18	1.25	11.79	1.28	11.40	1.33	11.19	1.35	11.02	1.37	10.60	1.41
		25	23	13.46	1.30	13.06	1.33	12.61	1.39	12.37	1.41	12.18	1.44	11.72	1.47
		30	28	14.75	1.35	14.29	1.40	13.80	1.44	13.55	1.47	13.34	1.50	12.85	1.54
		35	32	16.04	1.41	15.53	1.46	15.00	1.50	14.73	1.53	14.51	1.56	13.99	1.60
		40	36	16.85	1.45	16.38	1.50	15.86	1.54	15.58	1.57	15.36	1.60	14.81	1.64
		45	41	17.87	1.50	17.45	1.55	16.93	1.60	16.65	1.63	16.43	1.65	15.83	1.70
		47	43	18.28	1.52	17.87	1.57	17.36	1.62	17.08	1.65	16.85	1.67	16.24	1.72
		50	46	18.34	1.51	17.97	1.56	17.52	1.60	17.27	1.63	17.07	1.65	16.49	1.69
		55	51	18.43	1.50	18.12	1.53	17.79	1.57	17.58	1.59	17.42	1.60	16.90	1.64
		60	56	18.52	1.48	18.27	1.51	18.05	1.54	17.90	1.55	17.77	1.56	17.32	1.58
		63	59	18.57	1.47	18.37	1.49	18.21	1.52	18.08	1.52	17.98	1.53	17.57	1.55
		68	64	18.62	1.46	18.46	1.48	18.37	1.50	18.27	1.50	18.20	1.50	17.82	1.52
	7 + 9	-4	-4.4	6.70	1.23	6.17	1.28	6.16	1.29	6.09	1.30	6.04	1.31	5.77	1.35
		0	-0.4	8.35	1.26	7.84	1.31	7.73	1.33	7.62	1.34	7.53	1.35	7.21	1.40
		5	4.5	10.30	1.30	9.82	1.35	9.58	1.37	9.43	1.39	9.31	1.40	8.93	1.45
		10	9	11.61	1.33	11.14	1.38	10.83	1.41	10.64	1.43	10.50	1.45	10.08	1.50
		17	15	13.05	1.38	12.60	1.43	12.20	1.47	11.98	1.49	11.80	1.51	11.35	1.56
		20	19	13.92	1.41	13.48	1.46	13.03	1.51	12.79	1.53	12.59	1.56	12.12	1.60
		25	23	15.38	1.47	14.93	1.51	14.41	1.57	14.13	1.60	13.92	1.63	13.39	1.67
		30	28	16.86	1.53	16.33	1.58	15.77	1.63	15.48	1.67	15.25	1.70	14.69	1.74
		35	32	18.33	1.60	17.74	1.65	17.14	1.70	16.83	1.74	16.58	1.77	15.99	1.81
		40	36	19.26	1.64	18.72	1.70	18.12	1.75	17.81	1.78	17.56	1.81	16.92	1.86
		45	41	20.43	1.70	19.94	1.76	19.35	1.81	19.03	1.85	18.77	1.87	18.09	1.93
		47	43	20.89	1.72	20.43	1.78	19.84	1.84	19.52	1.87	19.26	1.90	18.56	1.95
		50	46	20.96	1.71	20.53	1.76	20.03	1.82	19.74	1.84	19.50	1.87	18.84	1.92
		55	51	21.06	1.70	20.71	1.74	20.33	1.78	20.09	1.80	19.91	1.81	19.32	1.85
		60	56	21.16	1.68	20.89	1.71	20.63	1.74	20.45	1.75	20.31	1.76	19.79	1.79
		63	59	21.22	1.67	20.99	1.69	20.81	1.72	20.67	1.73	20.55	1.73	20.08	1.76
		68	64	21.28	1.66	21.10	1.68	20.99	1.70	20.88	1.70	20.80	1.70	20.36	1.72
	9 + 9	-4	-4.4	7.56	1.34	6.96	1.39	6.94	1.41	6.87	1.42	6.81	1.42	6.50	1.48
		0	-0.4	9.41	1.37	8.83	1.43	8.71	1.45	8.59	1.46	8.49	1.47	8.13	1.52
		5	4.5	11.61	1.42	11.06	1.47	10.80	1.50	10.63	1.51	10.49	1.53	10.07	1.58
		10	9	13.09	1.46	12.55	1.51	12.21	1.54	12.00	1.56	11.83	1.58	11.36	1.63
		17	15	14.71	1.51	14.20	1.56	13.75	1.60	13.50	1.63	13.30	1.65	12.79	1.70
		20	19	15.69	1.54	15.19	1.59	14.68	1.64	14.41	1.67	14.19	1.70	13.65	1.75
		25	23	17.34	1.60	16.82	1.65	16.24	1.71	15.93	1.75	15.69	1.77	15.09	1.82
		30	28	19.00	1.67	18.41	1.73	17.78	1.78	17.45	1.82	17.19	1.85	16.56	1.90
		35	32	20.66	1.74	20.00	1.80	19.32	1.85	18.97	1.89	18.69	1.93	18.02	1.97
		40	36	21.71	1.79	21.10	1.85	20.43	1.91	20.07	1.95	19.79	1.98	19.07	2.03
		45	41	23.02	1.86	22.47	1.92	21.81	1.98	21.45	2.01	21.16	2.04	20.39	2.10
		47	43	23.55	1.88	23.02	1.94	22.37	2.01	22.00	2.04	21.71	2.07	20.92	2.13
		50	46	23.62	1.87	23.14	1.93	22.57	1.98	22.24	2.01	21.98	2.03	21.24	2.09
		55	51	23.73	1.85	23.34	1.90	22.91	1.94	22.65	1.96	22.44	1.98	21.77	2.02
		60	56	23.85	1.83	23.54	1.87	23.25	1.90	23.05	1.91	22.89	1.92	22.31	1.95
		63	59	23.92	1.82	23.66	1.85	23.45	1.87	23.29	1.88	23.16	1.89	22.63	1.91
		68	64	23.99	1.81	23.78	1.83	23.66	1.85	23.54	1.86	23.44	1.86	22.95	1.88

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 258: LMU18CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 12	-4	-4.4	7.56	1.34	6.96	1.39	6.94	1.41	6.87	1.42	6.81	1.42	6.50	1.48
		0	-0.4	9.41	1.37	8.83	1.43	8.71	1.45	8.59	1.46	8.49	1.47	8.13	1.52
		5	4.5	11.61	1.42	11.06	1.47	10.80	1.50	10.63	1.51	10.49	1.53	10.07	1.58
		10	9	13.09	1.46	12.55	1.51	12.21	1.54	12.00	1.56	11.83	1.58	11.36	1.63
		17	15	14.71	1.51	14.20	1.56	13.75	1.60	13.50	1.63	13.30	1.65	12.79	1.70
		20	19	15.69	1.54	15.19	1.59	14.68	1.64	14.41	1.67	14.19	1.70	13.65	1.75
		25	23	17.34	1.60	16.82	1.65	16.24	1.71	15.93	1.75	15.69	1.77	15.09	1.82
		30	28	19.00	1.67	18.41	1.73	17.78	1.78	17.45	1.82	17.19	1.85	16.56	1.90
		35	32	20.66	1.74	20.00	1.80	19.32	1.85	18.97	1.89	18.69	1.93	18.02	1.97
		40	36	21.71	1.79	21.10	1.85	20.43	1.91	20.07	1.95	19.79	1.98	19.07	2.03
		45	41	23.02	1.86	22.47	1.92	21.81	1.98	21.45	2.01	21.16	2.04	20.39	2.10
		47	43	23.55	1.88	23.02	1.94	22.37	2.01	22.00	2.04	21.71	2.07	20.92	2.13
		50	46	23.62	1.87	23.14	1.93	22.57	1.98	22.24	2.01	21.98	2.03	21.24	2.09
		55	51	23.73	1.85	23.34	1.90	22.91	1.94	22.65	1.96	22.44	1.98	21.77	2.02
		60	56	23.85	1.83	23.54	1.87	23.25	1.90	23.05	1.91	22.89	1.92	22.31	1.95
		63	59	23.92	1.82	23.66	1.85	23.45	1.87	23.29	1.88	23.16	1.89	22.63	1.91
		68	64	23.99	1.81	23.78	1.83	23.66	1.85	23.54	1.86	23.44	1.86	22.95	1.88
	9 + 12	-4	-4.4	7.56	1.34	6.96	1.39	6.94	1.41	6.87	1.42	6.81	1.42	6.50	1.48
		0	-0.4	9.41	1.37	8.83	1.43	8.71	1.45	8.59	1.46	8.49	1.47	8.13	1.52
		5	4.5	11.61	1.42	11.06	1.47	10.80	1.50	10.63	1.51	10.49	1.53	10.07	1.58
		10	9	13.09	1.46	12.55	1.51	12.21	1.54	12.00	1.56	11.83	1.58	11.36	1.63
		17	15	14.71	1.51	14.20	1.56	13.75	1.60	13.50	1.63	13.30	1.65	12.79	1.70
		20	19	15.69	1.54	15.19	1.59	14.68	1.64	14.41	1.67	14.19	1.70	13.65	1.75
		25	23	17.34	1.60	16.82	1.65	16.24	1.71	15.93	1.75	15.69	1.77	15.09	1.82
		30	28	19.00	1.67	18.41	1.73	17.78	1.78	17.45	1.82	17.19	1.85	16.56	1.90
		35	32	20.66	1.74	20.00	1.80	19.32	1.85	18.97	1.89	18.69	1.93	18.02	1.97
		40	36	21.71	1.79	21.10	1.85	20.43	1.91	20.07	1.95	19.79	1.98	19.07	2.03
		45	41	23.02	1.86	22.47	1.92	21.81	1.98	21.45	2.01	21.16	2.04	20.39	2.10
		47	43	23.55	1.88	23.02	1.94	22.37	2.01	22.00	2.04	21.71	2.07	20.92	2.13
		50	46	23.62	1.87	23.14	1.93	22.57	1.98	22.24	2.01	21.98	2.03	21.24	2.09
		55	51	23.73	1.85	23.34	1.90	22.91	1.94	22.65	1.96	22.44	1.98	21.77	2.02
		60	56	23.85	1.83	23.54	1.87	23.25	1.90	23.05	1.91	22.89	1.92	22.31	1.95
		63	59	23.92	1.82	23.66	1.85	23.45	1.87	23.29	1.88	23.16	1.89	22.63	1.91
		68	64	23.99	1.81	23.78	1.83	23.66	1.85	23.54	1.86	23.44	1.86	22.95	1.88
	7 + 15	-4	-4.4	7.56	1.34	6.96	1.39	6.94	1.41	6.87	1.42	6.81	1.42	6.50	1.48
		0	-0.4	9.41	1.37	8.83	1.43	8.71	1.45	8.59	1.46	8.49	1.47	8.13	1.52
		5	4.5	11.61	1.42	11.06	1.47	10.80	1.50	10.63	1.51	10.49	1.53	10.07	1.58
		10	9	13.09	1.46	12.55	1.51	12.21	1.54	12.00	1.56	11.83	1.58	11.36	1.63
		17	15	14.71	1.51	14.20	1.56	13.75	1.60	13.50	1.63	13.30	1.65	12.79	1.70
		20	19	15.69	1.54	15.19	1.59	14.68	1.64	14.41	1.67	14.19	1.70	13.65	1.75
		25	23	17.34	1.60	16.82	1.65	16.24	1.71	15.93	1.75	15.69	1.77	15.09	1.82
		30	28	19.00	1.67	18.41	1.73	17.78	1.78	17.45	1.82	17.19	1.85	16.56	1.90
		35	32	20.66	1.74	20.00	1.80	19.32	1.85	18.97	1.89	18.69	1.93	18.02	1.97
		40	36	21.71	1.79	21.10	1.85	20.43	1.91	20.07	1.95	19.79	1.98	19.07	2.03
		45	41	23.02	1.86	22.47	1.92	21.81	1.98	21.45	2.01	21.16	2.04	20.39	2.10
		47	43	23.55	1.88	23.02	1.94	22.37	2.01	22.00	2.04	21.71	2.07	20.92	2.13

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 259: LMU18CHV Heating Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	-4.4	7.56	1.34	6.96	1.39	6.94	1.41	6.87	1.42	6.81	1.42	6.50	1.48
		0	-0.4	9.41	1.37	8.83	1.43	8.71	1.45	8.59	1.46	8.49	1.47	8.13	1.52
		5	4.5	11.61	1.42	11.06	1.47	10.80	1.50	10.63	1.51	10.49	1.53	10.07	1.58
		10	9	13.09	1.46	12.55	1.51	12.21	1.54	12.00	1.56	11.83	1.58	11.36	1.63
		17	15	14.71	1.51	14.20	1.56	13.75	1.60	13.50	1.63	13.30	1.65	12.79	1.70
		20	19	15.69	1.54	15.19	1.59	14.68	1.64	14.41	1.67	14.19	1.70	13.65	1.75
		25	23	17.34	1.60	16.82	1.65	16.24	1.71	15.93	1.75	15.69	1.77	15.09	1.82
		30	28	19.00	1.67	18.41	1.73	17.78	1.78	17.45	1.82	17.19	1.85	16.56	1.90
		35	32	20.66	1.74	20.00	1.80	19.32	1.85	18.97	1.89	18.69	1.93	18.02	1.97
		40	36	21.71	1.79	21.10	1.85	20.43	1.91	20.07	1.95	19.79	1.98	19.07	2.03
		45	41	23.02	1.86	22.47	1.92	21.81	1.98	21.45	2.01	21.16	2.04	20.39	2.10
		47	43	23.55	1.88	23.02	1.94	22.37	2.01	22.00	2.04	21.71	2.07	20.92	2.13
		50	46	23.62	1.87	23.14	1.93	22.57	1.98	22.24	2.01	21.98	2.03	21.24	2.09
		55	51	23.73	1.85	23.34	1.90	22.91	1.94	22.65	1.96	22.44	1.98	21.77	2.02
		60	56	23.85	1.83	23.54	1.87	23.25	1.90	23.05	1.91	22.89	1.92	22.31	1.95
		63	59	23.92	1.82	23.66	1.85	23.45	1.87	23.29	1.88	23.16	1.89	22.63	1.91
		68	64	23.99	1.81	23.78	1.83	23.66	1.85	23.54	1.86	23.44	1.86	22.95	1.88
	12 + 12	-4	-4.4	7.56	1.34	6.96	1.39	6.94	1.41	6.87	1.42	6.81	1.42	6.50	1.48
		0	-0.4	9.41	1.37	8.83	1.43	8.71	1.45	8.59	1.46	8.49	1.47	8.13	1.52
		5	4.5	11.61	1.42	11.06	1.47	10.80	1.50	10.63	1.51	10.49	1.53	10.07	1.58
		10	9	13.09	1.46	12.55	1.51	12.21	1.54	12.00	1.56	11.83	1.58	11.36	1.63
		17	15	14.71	1.51	14.20	1.56	13.75	1.60	13.50	1.63	13.30	1.65	12.79	1.70
		20	19	15.69	1.54	15.19	1.59	14.68	1.64	14.41	1.67	14.19	1.70	13.65	1.75
		25	23	17.34	1.60	16.82	1.65	16.24	1.71	15.93	1.75	15.69	1.77	15.09	1.82
		30	28	19.00	1.67	18.41	1.73	17.78	1.78	17.45	1.82	17.19	1.85	16.56	1.90
		35	32	20.66	1.74	20.00	1.80	19.32	1.85	18.97	1.89	18.69	1.93	18.02	1.97
		40	36	21.71	1.79	21.10	1.85	20.43	1.91	20.07	1.95	19.79	1.98	19.07	2.03
		45	41	23.02	1.86	22.47	1.92	21.81	1.98	21.45	2.01	21.16	2.04	20.39	2.10
		47	43	23.55	1.88	23.02	1.94	22.37	2.01	22.00	2.04	21.71	2.07	20.92	2.13
		50	46	23.62	1.87	23.14	1.93	22.57	1.98	22.24	2.01	21.98	2.03	21.24	2.09
		55	51	23.73	1.85	23.34	1.90	22.91	1.94	22.65	1.96	22.44	1.98	21.77	2.02
		60	56	23.85	1.83	23.54	1.87	23.25	1.90	23.05	1.91	22.89	1.92	22.31	1.95
		63	59	23.92	1.82	23.66	1.85	23.45	1.87	23.29	1.88	23.16	1.89	22.63	1.91
		68	64	23.99	1.81	23.78	1.83	23.66	1.85	23.54	1.86	23.44	1.86	22.95	1.88
Two (2) Ducted Indoor Units	9 + 9	-4	-4.4	8.85	1.31	8.23	1.37	8.16	1.38	8.06	1.39	7.98	1.40	7.63	1.45
		0	-0.4	10.23	1.35	9.64	1.40	9.48	1.42	9.34	1.43	9.23	1.44	8.84	1.49
		5	4.5	11.86	1.39	11.31	1.44	11.04	1.47	10.86	1.48	10.72	1.49	10.29	1.54
		10	9	12.96	1.42	12.44	1.47	12.09	1.51	11.88	1.53	11.71	1.54	11.25	1.59
		17	15	14.16	1.47	13.67	1.52	13.24	1.56	13.00	1.59	12.81	1.61	12.32	1.66
		20	19	14.89	1.50	14.42	1.55	13.94	1.60	13.68	1.63	13.47	1.66	12.96	1.70
		25	23	16.12	1.56	15.64	1.61	15.10	1.67	14.81	1.70	14.58	1.73	14.03	1.77
		30	28	17.35	1.63	16.82	1.68	16.24	1.73	15.94	1.77	15.70	1.80	15.13	1.84
		35	32	18.59	1.69	18.00	1.75	17.38	1.80	17.07	1.84	16.82	1.87	16.21	1.92
		40	36	19.54	1.74	18.99	1.80	18.38	1.85	18.06	1.89	17.81	1.92	17.16	1.97
		45	41	20.72	1.80	20.23	1.86	19.63	1.92	19.30	1.95	19.04	1.98	18.35	2.04
		47	43	21.19	1.83	20.72	1.89	20.13	1.95	19.80	1.98	19.54	2.01	18.83	2.07
		50	46	21.26	1.81	20.83	1.87	20.31	1.92	20.02	1.95	19.78	1.97	19.11	2.03
		55	51	21.36	1.80	21.01	1.84	20.62	1.88	20.38	1.90	20.19	1.92	19.59	1.96
		60	56	21.46	1.78	21.18	1.81	20.92	1.84	20.75	1.86	20.60	1.87	20.08	1.90
		63	59	21.53	1.76	21.29	1.79	21.11	1.82	20.96	1.83	20.85	1.84	20.36	1.86
		68	64	21.59	1.75	21.40	1.78	21.29	1.80	21.18	1.80	21.10	1.80	20.66	1.82

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 260: LMU18CHV Heating Capacity Table — Ducted, continued, and Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 12	-4	-4.4	8.85	1.31	8.23	1.37	8.16	1.38	8.06	1.39	7.98	1.40	7.63	1.45
		0	-0.4	10.23	1.35	9.64	1.40	9.48	1.42	9.34	1.43	9.23	1.44	8.84	1.49
		5	4.5	11.86	1.39	11.31	1.44	11.04	1.47	10.86	1.48	10.72	1.49	10.29	1.54
		10	9	12.96	1.42	12.44	1.47	12.09	1.51	11.88	1.53	11.71	1.54	11.25	1.59
		17	15	14.16	1.47	13.67	1.52	13.24	1.56	13.00	1.59	12.81	1.61	12.32	1.66
		20	19	14.89	1.50	14.42	1.55	13.94	1.60	13.68	1.63	13.47	1.66	12.96	1.70
		25	23	16.12	1.56	15.64	1.61	15.10	1.67	14.81	1.70	14.58	1.73	14.03	1.77
		30	28	17.35	1.63	16.82	1.68	16.24	1.73	15.94	1.77	15.70	1.80	15.13	1.84
		35	32	18.59	1.69	18.00	1.75	17.38	1.80	17.07	1.84	16.82	1.87	16.21	1.92
		40	36	19.54	1.74	18.99	1.80	18.38	1.85	18.06	1.89	17.81	1.92	17.16	1.97
		45	41	20.72	1.80	20.23	1.86	19.63	1.92	19.30	1.95	19.04	1.98	18.35	2.04
		47	43	21.19	1.83	20.72	1.89	20.13	1.95	19.80	1.98	19.54	2.01	18.83	2.07
		50	46	21.26	1.81	20.83	1.87	20.31	1.92	20.02	1.95	19.78	1.97	19.11	2.03
		55	51	21.36	1.80	21.01	1.84	20.62	1.88	20.38	1.90	20.19	1.92	19.59	1.96
		60	56	21.46	1.78	21.18	1.81	20.92	1.84	20.75	1.86	20.60	1.87	20.08	1.90
		63	59	21.53	1.76	21.29	1.79	21.11	1.82	20.96	1.83	20.85	1.84	20.36	1.86
	12 + 12	68	64	21.59	1.75	21.40	1.78	21.29	1.80	21.18	1.80	21.10	1.80	20.66	1.82
		-4	-4.4	8.85	1.31	8.23	1.37	8.16	1.38	8.06	1.39	7.98	1.40	7.63	1.45
		0	-0.4	10.23	1.35	9.64	1.40	9.48	1.42	9.34	1.43	9.23	1.44	8.84	1.49
		5	4.5	11.86	1.39	11.31	1.44	11.04	1.47	10.86	1.48	10.72	1.49	10.29	1.54
		10	9	12.96	1.42	12.44	1.47	12.09	1.51	11.88	1.53	11.71	1.54	11.25	1.59
		17	15	14.16	1.47	13.67	1.52	13.24	1.56	13.00	1.59	12.81	1.61	12.32	1.66
		20	19	14.89	1.50	14.42	1.55	13.94	1.60	13.68	1.63	13.47	1.66	12.96	1.70
		25	23	16.12	1.56	15.64	1.61	15.10	1.67	14.81	1.70	14.58	1.73	14.03	1.77
		30	28	17.35	1.63	16.82	1.68	16.24	1.73	15.94	1.77	15.70	1.80	15.13	1.84
		35	32	18.59	1.69	18.00	1.75	17.38	1.80	17.07	1.84	16.82	1.87	16.21	1.92
		40	36	19.54	1.74	18.99	1.80	18.38	1.85	18.06	1.89	17.81	1.92	17.16	1.97
		45	41	20.72	1.80	20.23	1.86	19.63	1.92	19.30	1.95	19.04	1.98	18.35	2.04
		47	43	21.19	1.83	20.72	1.89	20.13	1.95	19.80	1.98	19.54	2.01	18.83	2.07
		50	46	21.26	1.81	20.83	1.87	20.31	1.92	20.02	1.95	19.78	1.97	19.11	2.03
		55	51	21.36	1.80	21.01	1.84	20.62	1.88	20.38	1.90	20.19	1.92	19.59	1.96
		60	56	21.46	1.78	21.18	1.81	20.92	1.84	20.75	1.86	20.60	1.87	20.08	1.90
		63	59	21.53	1.76	21.29	1.79	21.11	1.82	20.96	1.83	20.85	1.84	20.36	1.86
		68	64	21.59	1.75	21.40	1.78	21.29	1.80	21.18	1.80	21.10	1.80	20.66	1.82
Two (2) Mixed Indoor Units	7 + 9	-4	-4.4	7.28	1.21	6.74	1.26	6.70	1.28	6.62	1.28	6.56	1.29	6.27	1.34
		0	-0.4	8.71	1.25	8.19	1.29	8.07	1.31	7.95	1.32	7.86	1.33	7.53	1.38
		5	4.5	10.41	1.28	9.92	1.33	9.69	1.36	9.53	1.37	9.41	1.38	9.03	1.43
		10	9	11.55	1.32	11.08	1.36	10.78	1.40	10.59	1.42	10.44	1.43	10.03	1.48
		17	15	12.81	1.36	12.36	1.41	11.97	1.45	11.75	1.47	11.58	1.49	11.14	1.54
		20	19	13.57	1.39	13.13	1.44	12.69	1.49	12.46	1.51	12.27	1.53	11.80	1.58
		25	23	14.84	1.45	14.40	1.49	13.90	1.55	13.63	1.58	13.42	1.60	12.92	1.64
		30	28	16.12	1.51	15.62	1.56	15.09	1.61	14.81	1.64	14.59	1.67	14.05	1.71
		35	32	17.41	1.57	16.85	1.63	16.28	1.67	15.99	1.71	15.75	1.74	15.18	1.78
		40	36	18.29	1.62	17.78	1.67	17.21	1.72	16.91	1.76	16.68	1.78	16.07	1.83
		45	41	19.40	1.67	18.94	1.73	18.38	1.78	18.08	1.82	17.83	1.84	17.18	1.90
		47	43	19.85	1.70	19.40	1.75	18.85	1.81	18.54	1.84	18.29	1.86	17.63	1.92
		50	46	19.90	1.69	19.50	1.74	19.02	1.79	18.74	1.81	18.52	1.84	17.90	1.88
		55	51	20.00	1.67	19.67	1.71	19.31	1.75	19.08	1.77	18.91	1.79	18.35	1.82
		60	56	20.10	1.65	19.84	1.68	19.59	1.71	19.43	1.73	19.29	1.74	18.80	1.76
		63	59	20.16	1.64	19.94	1.67	19.76	1.69	19.63	1.70	19.52	1.71	19.07	1.73
		68	64	20.22	1.63	20.04	1.65	19.94	1.67	19.84	1.67	19.75	1.68	19.34	1.69

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU18CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 261: LMU18CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 9	-4	-4.4	8.20	1.33	7.59	1.38	7.55	1.40	7.47	1.40	7.40	1.41	7.06	1.46
		0	-0.4	9.82	1.36	9.24	1.41	9.09	1.43	8.96	1.45	8.86	1.46	8.49	1.51
		5	4.5	11.74	1.40	11.19	1.45	10.92	1.48	10.75	1.50	10.60	1.51	10.18	1.56
		10	9	13.02	1.44	12.50	1.49	12.15	1.53	11.94	1.55	11.77	1.56	11.31	1.61
		17	15	14.44	1.49	13.93	1.54	13.49	1.58	13.25	1.61	13.05	1.63	12.55	1.68
		20	19	15.29	1.52	14.80	1.57	14.31	1.62	14.05	1.65	13.83	1.68	13.31	1.72
		25	23	16.73	1.58	16.23	1.63	15.67	1.69	15.37	1.72	15.13	1.75	14.56	1.80
		30	28	18.18	1.65	17.61	1.70	17.01	1.76	16.70	1.79	16.45	1.83	15.84	1.87
		35	32	19.62	1.72	19.00	1.78	18.35	1.82	18.02	1.87	17.76	1.90	17.12	1.95
		40	36	20.62	1.77	20.04	1.83	19.40	1.88	19.07	1.92	18.80	1.95	18.12	2.00
		45	41	21.87	1.83	21.35	1.89	20.72	1.95	20.38	1.98	20.10	2.01	19.37	2.07
		47	43	22.37	1.85	21.87	1.91	21.25	1.98	20.90	2.01	20.62	2.04	19.87	2.10
		50	46	22.44	1.84	21.99	1.90	21.44	1.95	21.13	1.98	20.88	2.00	20.18	2.06
		55	51	22.55	1.82	22.17	1.87	21.76	1.91	21.51	1.93	21.31	1.95	20.68	1.99
		60	56	22.66	1.80	22.36	1.84	22.09	1.87	21.90	1.89	21.75	1.90	21.19	1.93
		63	59	22.72	1.79	22.47	1.82	22.28	1.85	22.13	1.86	22.01	1.86	21.49	1.89
		68	64	22.79	1.78	22.59	1.80	22.48	1.82	22.36	1.83	22.27	1.83	21.80	1.85
	7 + 12	-4	-4.4	8.20	1.33	7.59	1.38	7.55	1.40	7.47	1.40	7.40	1.41	7.06	1.46
		0	-0.4	9.82	1.36	9.24	1.41	9.09	1.43	8.96	1.45	8.86	1.46	8.49	1.51
		5	4.5	11.74	1.40	11.19	1.45	10.92	1.48	10.75	1.50	10.60	1.51	10.18	1.56
		10	9	13.02	1.44	12.50	1.49	12.15	1.53	11.94	1.55	11.77	1.56	11.31	1.61
		17	15	14.44	1.49	13.93	1.54	13.49	1.58	13.25	1.61	13.05	1.63	12.55	1.68
		20	19	15.29	1.52	14.80	1.57	14.31	1.62	14.05	1.65	13.83	1.68	13.31	1.72
		25	23	16.73	1.58	16.23	1.63	15.67	1.69	15.37	1.72	15.13	1.75	14.56	1.80
		30	28	18.18	1.65	17.61	1.70	17.01	1.76	16.70	1.79	16.45	1.83	15.84	1.87
		35	32	19.62	1.72	19.00	1.78	18.35	1.82	18.02	1.87	17.76	1.90	17.12	1.95
		40	36	20.62	1.77	20.04	1.83	19.40	1.88	19.07	1.92	18.80	1.95	18.12	2.00
		45	41	21.87	1.83	21.35	1.89	20.72	1.95	20.38	1.98	20.10	2.01	19.37	2.07
		47	43	22.37	1.85	21.87	1.91	21.25	1.98	20.90	2.01	20.62	2.04	19.87	2.10
		50	46	22.44	1.84	21.99	1.90	21.44	1.95	21.13	1.98	20.88	2.00	20.18	2.06
		55	51	22.55	1.82	22.17	1.87	21.76	1.91	21.51	1.93	21.31	1.95	20.68	1.99
		60	56	22.66	1.80	22.36	1.84	22.09	1.87	21.90	1.89	21.75	1.90	21.19	1.93
		63	59	22.72	1.79	22.47	1.82	22.28	1.85	22.13	1.86	22.01	1.86	21.49	1.89
		68	64	22.79	1.78	22.59	1.80	22.48	1.82	22.36	1.83	22.27	1.83	21.80	1.85
	9 + 12	-4	-4.4	8.20	1.33	7.59	1.38	7.55	1.40	7.47	1.40	7.40	1.41	7.06	1.46
		0	-0.4	9.82	1.36	9.24	1.41	9.09	1.43	8.96	1.45	8.86	1.46	8.49	1.51
		5	4.5	11.74	1.40	11.19	1.45	10.92	1.48	10.75	1.50	10.60	1.51	10.18	1.56
		10	9	13.02	1.44	12.50	1.49	12.15	1.53	11.94	1.55	11.77	1.56	11.31	1.61
		17	15	14.44	1.49	13.93	1.54	13.49	1.58	13.25	1.61	13.05	1.63	12.55	1.68
		20	19	15.29	1.52	14.80	1.57	14.31	1.62	14.05	1.65	13.83	1.68	13.31	1.72
		25	23	16.73	1.58	16.23	1.63	15.67	1.69	15.37	1.72	15.13	1.75	14.56	1.80
		30	28	18.18	1.65	17.61	1.70	17.01	1.76	16.70	1.79	16.45	1.83	15.84	1.87
		35	32	19.62	1.72	19.00	1.78	18.35	1.82	18.02	1.87	17.76	1.90	17.12	1.95
		40	36	20.62	1.77	20.04	1.83	19.40	1.88	19.07	1.92	18.80	1.95	18.12	2.00
		45	41	21.87	1.83	21.35	1.89	20.72	1.95	20.38	1.98	20.10	2.01	19.37	2.07
		47	43	22.37	1.85	21.87	1.91	21.25	1.98	20.90	2.01	20.62	2.04	19.87	2.10
		50	46	22.44	1.84	21.99	1.90	21.44	1.95	21.13	1.98	20.88	2.00	20.18	2.06
		55	51	22.55	1.82	22.17	1.87	21.76	1.91	21.51	1.93	21.31	1.95	20.68	1.99
		60	56	22.66	1.80	22.36	1.84	22.09	1.87	21.90	1.89	21.75	1.90	21.19	1.93
		63	59	22.72	1.79	22.47	1.82	22.28	1.85	22.13	1.86	22.01	1.86	21.49	1.89
		68	64	22.79	1.78	22.59	1.80	22.48	1.82	22.36	1.83	22.27	1.83	21.80	1.85

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 262: LMU18CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 15	-4	-4.4	8.20	1.33	7.59	1.38	7.55	1.40	7.47	1.40	7.40	1.41	7.06	1.46
		0	-0.4	9.82	1.36	9.24	1.41	9.09	1.43	8.96	1.45	8.86	1.46	8.49	1.51
		5	4.5	11.74	1.40	11.19	1.45	10.92	1.48	10.75	1.50	10.60	1.51	10.18	1.56
		10	9	13.02	1.44	12.50	1.49	12.15	1.53	11.94	1.55	11.77	1.56	11.31	1.61
		17	15	14.44	1.49	13.93	1.54	13.49	1.58	13.25	1.61	13.05	1.63	12.55	1.68
		20	19	15.29	1.52	14.80	1.57	14.31	1.62	14.05	1.65	13.83	1.68	13.31	1.72
		25	23	16.73	1.58	16.23	1.63	15.67	1.69	15.37	1.72	15.13	1.75	14.56	1.80
		30	28	18.18	1.65	17.61	1.70	17.01	1.76	16.70	1.79	16.45	1.83	15.84	1.87
		35	32	19.62	1.72	19.00	1.78	18.35	1.82	18.02	1.87	17.76	1.90	17.12	1.95
		40	36	20.62	1.77	20.04	1.83	19.40	1.88	19.07	1.92	18.80	1.95	18.12	2.00
		45	41	21.87	1.83	21.35	1.89	20.72	1.95	20.38	1.98	20.10	2.01	19.37	2.07
		47	43	22.37	1.85	21.87	1.91	21.25	1.98	20.90	2.01	20.62	2.04	19.87	2.10
		50	46	22.44	1.84	21.99	1.90	21.44	1.95	21.13	1.98	20.88	2.00	20.18	2.06
		55	51	22.55	1.82	22.17	1.87	21.76	1.91	21.51	1.93	21.31	1.95	20.68	1.99
		60	56	22.66	1.80	22.36	1.84	22.09	1.87	21.90	1.89	21.75	1.90	21.19	1.93
		63	59	22.72	1.79	22.47	1.82	22.28	1.85	22.13	1.86	22.01	1.86	21.49	1.89
	12 + 12	68	64	22.79	1.78	22.59	1.80	22.48	1.82	22.36	1.83	22.27	1.83	21.80	1.85
		-4	-4.4	8.20	1.33	7.59	1.38	7.55	1.40	7.47	1.40	7.40	1.41	7.06	1.46
		0	-0.4	9.82	1.36	9.24	1.41	9.09	1.43	8.96	1.45	8.86	1.46	8.49	1.51
		5	4.5	11.74	1.40	11.19	1.45	10.92	1.48	10.75	1.50	10.60	1.51	10.18	1.56
		10	9	13.02	1.44	12.50	1.49	12.15	1.53	11.94	1.55	11.77	1.56	11.31	1.61
		17	15	14.44	1.49	13.93	1.54	13.49	1.58	13.25	1.61	13.05	1.63	12.55	1.68
		20	19	15.29	1.52	14.80	1.57	14.31	1.62	14.05	1.65	13.83	1.68	13.31	1.72
		25	23	16.73	1.58	16.23	1.63	15.67	1.69	15.37	1.72	15.13	1.75	14.56	1.80
		30	28	18.18	1.65	17.61	1.70	17.01	1.76	16.70	1.79	16.45	1.83	15.84	1.87
		35	32	19.62	1.72	19.00	1.78	18.35	1.82	18.02	1.87	17.76	1.90	17.12	1.95
		40	36	20.62	1.77	20.04	1.83	19.40	1.88	19.07	1.92	18.80	1.95	18.12	2.00
		45	41	21.87	1.83	21.35	1.89	20.72	1.95	20.38	1.98	20.10	2.01	19.37	2.07
		47	43	22.37	1.85	21.87	1.91	21.25	1.98	20.90	2.01	20.62	2.04	19.87	2.10
		50	46	22.44	1.84	21.99	1.90	21.44	1.95	21.13	1.98	20.88	2.00	20.18	2.06
		55	51	22.55	1.82	22.17	1.87	21.76	1.91	21.51	1.93	21.31	1.95	20.68	1.99
		60	56	22.66	1.80	22.36	1.84	22.09	1.87	21.90	1.89	21.75	1.90	21.19	1.93
		63	59	22.72	1.79	22.47	1.82	22.28	1.85	22.13	1.86	22.01	1.86	21.49	1.89
		68	64	22.79	1.78	22.59	1.80	22.48	1.82	22.36	1.83	22.27	1.83	21.80	1.85

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 263: LMU24CHV Heating Capacity Table — Non-Ducted Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	-4.4	4.94	1.20	4.53	1.25	4.53	1.27	4.49	1.27	4.45	1.28	4.24	1.33
		0	-0.4	6.28	1.21	5.89	1.26	5.81	1.28	5.73	1.29	5.67	1.30	5.43	1.35
		5	4.5	7.89	1.22	7.51	1.27	7.34	1.30	7.22	1.31	7.12	1.32	6.84	1.37
		10	9	8.96	1.24	8.59	1.28	8.35	1.31	8.21	1.33	8.10	1.34	7.78	1.38
		17	15	10.14	1.25	9.78	1.29	9.48	1.33	9.30	1.35	9.17	1.37	8.81	1.41
		20	19	10.85	1.26	10.51	1.30	10.16	1.34	9.97	1.37	9.82	1.39	9.44	1.43
		25	23	12.05	1.28	11.69	1.32	11.28	1.37	11.07	1.39	10.90	1.42	10.49	1.45
		30	28	13.25	1.31	12.84	1.35	12.40	1.39	12.17	1.42	11.99	1.45	11.55	1.48
		35	32	14.46	1.33	14.00	1.38	13.52	1.41	13.28	1.45	13.08	1.47	12.61	1.51
		40	36	15.20	1.37	14.77	1.42	14.30	1.46	14.05	1.49	13.85	1.51	13.35	1.55
		45	41	16.12	1.42	15.73	1.47	15.27	1.51	15.01	1.54	14.81	1.56	14.27	1.61
		47	43	16.48	1.44	16.12	1.49	15.66	1.53	15.40	1.56	15.20	1.58	14.64	1.63
		50	46	16.53	1.43	16.20	1.47	15.80	1.51	15.57	1.54	15.39	1.56	14.87	1.60
		55	51	16.61	1.41	16.34	1.45	16.04	1.48	15.85	1.50	15.71	1.51	15.24	1.55
		60	56	16.69	1.40	16.48	1.43	16.27	1.45	16.14	1.46	16.02	1.47	15.61	1.49
		63	59	16.74	1.39	16.56	1.41	16.42	1.43	16.30	1.44	16.22	1.45	15.84	1.46
		68	64	16.79	1.38	16.64	1.40	16.56	1.42	16.48	1.42	16.41	1.42	16.07	1.43
	7 + 9	-4	-4.4	5.64	1.25	5.18	1.30	5.18	1.31	5.13	1.32	5.08	1.33	4.85	1.38
		0	-0.4	7.18	1.26	6.74	1.31	6.64	1.33	6.55	1.34	6.48	1.35	6.20	1.40
		5	4.5	9.01	1.27	8.58	1.32	8.38	1.34	8.25	1.36	8.14	1.37	7.81	1.42
		10	9	10.24	1.28	9.82	1.33	9.55	1.36	9.38	1.38	9.25	1.39	8.89	1.44
		17	15	11.58	1.30	11.18	1.34	10.83	1.38	10.63	1.40	10.48	1.42	10.07	1.46
		20	19	12.40	1.31	12.01	1.35	11.61	1.39	11.39	1.42	11.22	1.44	10.79	1.48
		25	23	13.77	1.33	13.36	1.37	12.90	1.42	12.65	1.45	12.46	1.47	11.99	1.51
		30	28	15.15	1.36	14.68	1.40	14.17	1.44	13.91	1.48	13.71	1.50	13.20	1.54
		35	32	16.52	1.38	16.00	1.43	15.45	1.47	15.18	1.50	14.95	1.53	14.41	1.57
		40	36	17.37	1.42	16.88	1.47	16.34	1.51	16.06	1.55	15.83	1.57	15.26	1.61
		45	41	18.42	1.47	17.98	1.52	17.45	1.57	17.16	1.60	16.93	1.62	16.31	1.67
		47	43	18.84	1.49	18.42	1.54	17.89	1.59	17.60	1.62	17.37	1.64	16.73	1.69
		50	46	18.89	1.48	18.51	1.53	18.06	1.57	17.79	1.60	17.58	1.62	16.99	1.66
		55	51	18.99	1.47	18.67	1.50	18.33	1.54	18.12	1.56	17.95	1.57	17.42	1.61
		60	56	19.08	1.45	18.83	1.48	18.60	1.51	18.44	1.52	18.31	1.53	17.84	1.55
		63	59	19.13	1.44	18.93	1.47	18.76	1.49	18.63	1.50	18.53	1.50	18.10	1.52
		68	64	19.19	1.43	19.02	1.45	18.93	1.47	18.83	1.47	18.75	1.48	18.36	1.49
	9 + 9	-4	-4.4	6.35	1.32	5.83	1.37	5.83	1.39	5.77	1.40	5.72	1.40	5.46	1.46
		0	-0.4	8.08	1.33	7.58	1.38	7.47	1.40	7.37	1.41	7.29	1.42	6.98	1.48
		5	4.5	10.14	1.34	9.66	1.39	9.43	1.42	9.28	1.44	9.16	1.45	8.79	1.50
		10	9	11.52	1.35	11.05	1.40	10.74	1.44	10.56	1.46	10.41	1.47	10.00	1.52
		17	15	13.03	1.37	12.58	1.41	12.18	1.46	11.96	1.48	11.79	1.50	11.33	1.55
		20	19	13.95	1.38	13.51	1.42	13.06	1.47	12.81	1.50	12.62	1.52	12.14	1.56
		25	23	15.49	1.40	15.03	1.44	14.51	1.50	14.23	1.53	14.01	1.55	13.49	1.59
		30	28	17.04	1.43	16.51	1.48	15.95	1.52	15.65	1.56	15.42	1.58	14.85	1.62
		35	32	18.59	1.46	18.00	1.51	17.38	1.55	17.07	1.59	16.82	1.62	16.21	1.65
		40	36	19.54	1.50	18.99	1.55	18.38	1.60	18.06	1.63	17.81	1.66	17.16	1.70
		45	41	20.72	1.56	20.23	1.61	19.63	1.66	19.30	1.69	19.04	1.71	18.35	1.76
		47	43	21.19	1.58	20.72	1.63	20.13	1.68	19.80	1.71	19.54	1.73	18.83	1.79
		50	46	21.26	1.57	20.83	1.61	20.31	1.66	20.02	1.69	19.78	1.71	19.11	1.75
		55	51	21.36	1.55	21.01	1.59	20.62	1.63	20.38	1.64	20.19	1.66	19.59	1.70
		60	56	21.46	1.53	21.18	1.56	20.92	1.59	20.75	1.60	20.60	1.61	20.08	1.64
		63	59	21.53	1.52	21.29	1.55	21.11	1.57	20.96	1.58	20.85	1.59	20.36	1.60
		68	64	21.59	1.51	21.40	1.53	21.29	1.55	21.18	1.56	21.10	1.56	20.66	1.57

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 264: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 12	-4	-4.4	6.70	1.36	6.15	1.41	6.15	1.43	6.09	1.44	6.04	1.45	5.76	1.50
		0	-0.4	8.53	1.37	8.00	1.42	7.89	1.44	7.78	1.46	7.70	1.47	7.37	1.52
		5	4.5	10.70	1.38	10.19	1.43	9.95	1.46	9.80	1.48	9.67	1.49	9.28	1.54
		10	9	12.16	1.39	11.66	1.44	11.34	1.48	11.14	1.50	10.99	1.51	10.56	1.56
		17	15	13.76	1.41	13.28	1.46	12.86	1.50	12.63	1.53	12.44	1.55	11.96	1.59
		20	19	14.73	1.42	14.26	1.46	13.78	1.52	13.53	1.54	13.32	1.57	12.82	1.61
		25	23	16.35	1.44	15.87	1.49	15.31	1.54	15.02	1.57	14.79	1.60	14.24	1.64
		30	28	17.99	1.47	17.43	1.52	16.83	1.57	16.52	1.60	16.28	1.63	15.68	1.67
		35	32	19.62	1.50	19.00	1.56	18.35	1.60	18.02	1.63	17.76	1.66	17.12	1.70
		40	36	20.62	1.55	20.04	1.60	19.40	1.64	19.07	1.68	18.80	1.71	18.12	1.75
		45	41	21.87	1.60	21.35	1.65	20.72	1.71	20.38	1.74	20.10	1.76	19.37	1.81
		47	43	22.37	1.62	21.87	1.68	21.25	1.73	20.90	1.76	20.62	1.78	19.87	1.84
		50	46	22.44	1.61	21.99	1.66	21.44	1.71	21.13	1.73	20.88	1.76	20.18	1.80
		55	51	22.55	1.60	22.17	1.64	21.76	1.67	21.51	1.69	21.31	1.71	20.68	1.74
		60	56	22.66	1.58	22.36	1.61	22.09	1.64	21.90	1.65	21.75	1.66	21.19	1.69
		63	59	22.72	1.57	22.47	1.59	22.28	1.62	22.13	1.63	22.01	1.63	21.49	1.65
		68	64	22.79	1.56	22.59	1.58	22.48	1.60	22.36	1.60	22.27	1.60	21.80	1.62
	9 + 12	-4	-4.4	7.40	1.46	6.80	1.51	6.80	1.53	6.73	1.54	6.67	1.55	6.36	1.61
		0	-0.4	9.43	1.47	8.84	1.52	8.72	1.55	8.60	1.56	8.51	1.57	8.14	1.63
		5	4.5	11.83	1.48	11.27	1.54	11.00	1.57	10.83	1.59	10.69	1.60	10.25	1.66
		10	9	13.44	1.50	12.89	1.55	12.53	1.59	12.32	1.61	12.14	1.63	11.67	1.68
		17	15	15.20	1.51	14.68	1.56	14.21	1.61	13.96	1.64	13.75	1.66	13.22	1.71
		20	19	16.28	1.53	15.76	1.57	15.23	1.63	14.95	1.66	14.72	1.68	14.16	1.73
		25	23	18.07	1.55	17.54	1.60	16.93	1.66	16.61	1.69	16.35	1.72	15.73	1.76
		30	28	19.88	1.58	19.26	1.63	18.60	1.68	18.26	1.72	17.99	1.75	17.33	1.80
		35	32	21.69	1.61	21.00	1.67	20.28	1.71	19.92	1.75	19.63	1.79	18.92	1.83
		40	36	22.79	1.66	22.15	1.72	21.45	1.77	21.07	1.80	20.78	1.83	20.02	1.88
		45	41	24.17	1.72	23.60	1.78	22.90	1.83	22.52	1.87	22.22	1.89	21.41	1.95
		47	43	24.73	1.74	24.17	1.80	23.48	1.86	23.10	1.89	22.79	1.92	21.96	1.97
		50	46	24.80	1.73	24.30	1.78	23.70	1.84	23.35	1.86	23.08	1.89	22.30	1.94
		55	51	24.92	1.71	24.51	1.76	24.05	1.80	23.78	1.82	23.56	1.83	22.86	1.87
		60	56	25.04	1.70	24.72	1.73	24.41	1.76	24.20	1.77	24.04	1.78	23.42	1.81
		63	59	25.11	1.68	24.84	1.71	24.63	1.74	24.46	1.75	24.32	1.75	23.76	1.77
		68	64	25.19	1.67	24.97	1.69	24.84	1.71	24.71	1.72	24.61	1.72	24.10	1.74
	7 + 15	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 265: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
	12 + 12	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
	7 + 18	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 266: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 18	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
	12 + 15	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
	12 + 18	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 267: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 15	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
	7 + 24	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
	9 + 24	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 268: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 18	-4	-4.4	7.69	1.50	7.07	1.55	7.06	1.57	6.99	1.59	6.93	1.59	6.61	1.65
		0	-0.4	9.79	1.51	9.19	1.56	9.06	1.59	8.94	1.60	8.84	1.62	8.46	1.67
		5	4.5	12.29	1.52	11.71	1.58	11.43	1.61	11.25	1.63	11.10	1.64	10.65	1.70
		10	9	13.96	1.54	13.39	1.59	13.02	1.63	12.80	1.65	12.62	1.67	12.12	1.72
		17	15	15.80	1.55	15.25	1.60	14.77	1.65	14.50	1.68	14.29	1.70	13.74	1.75
		20	19	16.91	1.57	16.37	1.61	15.83	1.67	15.53	1.70	15.30	1.73	14.72	1.77
		25	23	18.78	1.59	18.22	1.64	17.59	1.70	17.25	1.73	16.99	1.76	16.35	1.81
		30	28	20.65	1.62	20.02	1.68	19.33	1.73	18.97	1.77	18.69	1.80	18.00	1.84
		35	32	22.53	1.66	21.82	1.71	21.07	1.76	20.69	1.80	20.39	1.83	19.65	1.88
		40	36	23.68	1.70	23.02	1.76	22.28	1.81	21.90	1.85	21.59	1.88	20.81	1.93
		45	41	25.12	1.76	24.52	1.82	23.79	1.88	23.40	1.91	23.08	1.94	22.24	2.00
		47	43	25.69	1.79	25.12	1.85	24.40	1.91	24.00	1.94	23.68	1.97	22.82	2.03
		50	46	25.77	1.78	25.25	1.83	24.62	1.88	24.26	1.91	23.98	1.93	23.17	1.99
		55	51	25.89	1.76	25.46	1.80	24.99	1.85	24.71	1.87	24.48	1.88	23.75	1.92
		60	56	26.02	1.74	25.68	1.77	25.36	1.81	25.15	1.82	24.97	1.83	24.33	1.86
		63	59	26.09	1.73	25.81	1.76	25.59	1.78	25.41	1.79	25.27	1.80	24.68	1.82
		68	64	26.17	1.72	25.94	1.74	25.81	1.76	25.68	1.76	25.57	1.77	25.04	1.78
Three (3) Non-Ducted Indoor Units	7 + 7 + 7	-4	-4.4	7.40	1.37	6.80	1.43	6.80	1.44	6.73	1.45	6.67	1.46	6.36	1.52
		0	-0.4	9.43	1.38	8.84	1.44	8.72	1.46	8.60	1.47	8.51	1.48	8.14	1.54
		5	4.5	11.83	1.40	11.27	1.45	11.00	1.48	10.83	1.49	10.69	1.51	10.25	1.56
		10	9	13.44	1.41	12.89	1.46	12.53	1.49	12.32	1.52	12.14	1.53	11.67	1.58
		17	15	15.20	1.43	14.68	1.47	14.21	1.52	13.96	1.54	13.75	1.56	13.22	1.61
		20	19	16.28	1.44	15.76	1.48	15.23	1.53	14.95	1.56	14.72	1.58	14.16	1.63
		25	23	18.07	1.46	17.54	1.50	16.93	1.56	16.61	1.59	16.35	1.62	15.73	1.66
		30	28	19.88	1.49	19.26	1.54	18.60	1.59	18.26	1.62	17.99	1.65	17.33	1.69
		35	32	21.69	1.52	21.00	1.57	20.28	1.61	19.92	1.65	19.63	1.68	18.92	1.72
		40	36	22.79	1.56	22.15	1.62	21.45	1.66	21.07	1.70	20.78	1.73	20.02	1.77
		45	41	24.17	1.62	23.60	1.67	22.90	1.73	22.52	1.76	22.22	1.78	21.41	1.83
		47	43	24.73	1.64	24.17	1.70	23.48	1.75	23.10	1.78	22.79	1.80	21.96	1.86
		50	46	24.80	1.63	24.30	1.68	23.70	1.73	23.35	1.75	23.08	1.78	22.30	1.82
		55	51	24.92	1.61	24.51	1.65	24.05	1.69	23.78	1.71	23.56	1.73	22.86	1.76
		60	56	25.04	1.60	24.72	1.63	24.41	1.66	24.20	1.67	24.04	1.68	23.42	1.71
		63	59	25.11	1.59	24.84	1.61	24.63	1.64	24.46	1.64	24.32	1.65	23.76	1.67
		68	64	25.19	1.58	24.97	1.60	24.84	1.61	24.71	1.62	24.61	1.62	24.10	1.64
	7 + 7 + 9	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 269: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 9	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	7 + 7 + 12	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	9 + 9 + 9	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 270: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 12	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	7 + 7 + 15	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	9 + 9 + 12	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 271: LMU24CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 15	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	7 + 12 + 12	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	7 + 7 + 18	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 272: LMU24CHV Heating Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 15	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
	9 + 12 + 12	-4	-4.4	7.69	1.39	7.07	1.44	7.06	1.46	6.99	1.47	6.93	1.48	6.61	1.53
		0	-0.4	9.79	1.40	9.19	1.45	9.06	1.48	8.94	1.49	8.84	1.50	8.46	1.55
		5	4.5	12.29	1.41	11.71	1.46	11.43	1.49	11.25	1.51	11.10	1.53	10.65	1.58
		10	9	13.96	1.43	13.39	1.47	13.02	1.51	12.80	1.53	12.62	1.55	12.12	1.60
		17	15	15.80	1.44	15.25	1.49	14.77	1.53	14.50	1.56	14.29	1.58	13.74	1.63
		20	19	16.91	1.45	16.37	1.50	15.83	1.55	15.53	1.58	15.30	1.60	14.72	1.65
		25	23	18.78	1.48	18.22	1.52	17.59	1.58	17.25	1.61	16.99	1.63	16.35	1.68
		30	28	20.65	1.51	20.02	1.56	19.33	1.60	18.97	1.64	18.69	1.67	18.00	1.71
		35	32	22.53	1.54	21.82	1.59	21.07	1.63	20.69	1.67	20.39	1.70	19.65	1.74
		40	36	23.68	1.58	23.02	1.64	22.28	1.68	21.90	1.72	21.59	1.75	20.81	1.79
		45	41	25.12	1.64	24.52	1.69	23.79	1.74	23.40	1.78	23.08	1.80	22.24	1.85
		47	43	25.69	1.66	25.12	1.71	24.40	1.77	24.00	1.80	23.68	1.82	22.82	1.88
		50	46	25.77	1.65	25.25	1.70	24.62	1.75	24.26	1.77	23.98	1.80	23.17	1.84
		55	51	25.89	1.63	25.46	1.67	24.99	1.71	24.71	1.73	24.48	1.75	23.75	1.78
		60	56	26.02	1.61	25.68	1.65	25.36	1.68	25.15	1.69	24.97	1.70	24.33	1.72
		63	59	26.09	1.60	25.81	1.63	25.59	1.65	25.41	1.66	25.27	1.67	24.68	1.69
		68	64	26.17	1.59	25.94	1.61	25.81	1.63	25.68	1.64	25.57	1.64	25.04	1.65
Two (2) Ducted Indoor Units	9 + 9	-4	-4.4	6.76	1.38	6.24	1.44	6.22	1.46	6.15	1.47	6.09	1.47	5.82	1.53
		0	-0.4	8.27	1.40	7.77	1.45	7.65	1.47	7.55	1.49	7.46	1.50	7.14	1.55
		5	4.5	10.06	1.41	9.59	1.46	9.36	1.49	9.21	1.51	9.09	1.53	8.72	1.58
		10	9	11.26	1.43	10.80	1.48	10.50	1.51	10.32	1.53	10.18	1.55	9.78	1.60
		17	15	12.58	1.45	12.14	1.49	11.76	1.54	11.55	1.57	11.38	1.59	10.94	1.63
		20	19	13.38	1.46	12.96	1.51	12.52	1.56	12.29	1.59	12.10	1.61	11.65	1.65
		25	23	14.72	1.49	14.29	1.53	13.79	1.59	13.53	1.62	13.32	1.65	12.82	1.69
		30	28	16.07	1.52	15.58	1.57	15.04	1.62	14.77	1.65	14.54	1.68	14.01	1.73
		35	32	17.43	1.55	16.87	1.61	16.30	1.65	16.00	1.69	15.77	1.72	15.20	1.76
		40	36	18.31	1.60	17.80	1.65	17.23	1.70	16.93	1.74	16.69	1.77	16.09	1.81
		45	41	19.42	1.66	18.96	1.71	18.40	1.76	18.10	1.80	17.85	1.82	17.20	1.87
		47	43	19.87	1.68	19.42	1.73	18.87	1.79	18.56	1.82	18.31	1.84	17.65	1.90
		50	46	19.93	1.67	19.52	1.72	19.04	1.77	18.76	1.79	18.54	1.82	17.92	1.86
		55	51	20.02	1.65	19.69	1.69	19.33	1.73	19.11	1.75	18.93	1.77	18.37	1.80
		60	56	20.12	1.63	19.86	1.66	19.61	1.69	19.45	1.71	19.31	1.72	18.82	1.74
		63	59	20.18	1.62	19.96	1.65	19.79	1.67	19.65	1.68	19.54	1.69	19.09	1.71
		68	64	20.24	1.61	20.06	1.63	19.96	1.65	19.86	1.66	19.78	1.66	19.36	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 273: LMU24CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 12	-4	-4.4	7.89	1.53	7.28	1.59	7.25	1.61	7.17	1.62	7.11	1.63	6.79	1.69
		0	-0.4	9.65	1.54	9.07	1.60	8.93	1.63	8.81	1.64	8.71	1.65	8.34	1.71
		5	4.5	11.74	1.56	11.19	1.62	10.92	1.65	10.75	1.67	10.61	1.68	10.18	1.74
		10	9	13.14	1.58	12.61	1.63	12.26	1.67	12.05	1.70	11.88	1.71	11.41	1.77
		17	15	14.68	1.60	14.17	1.65	13.73	1.70	13.48	1.73	13.28	1.75	12.77	1.80
		20	19	15.62	1.61	15.12	1.66	14.62	1.72	14.34	1.75	14.13	1.78	13.59	1.83
		25	23	17.18	1.64	16.67	1.69	16.09	1.75	15.79	1.79	15.54	1.82	14.96	1.87
		30	28	18.76	1.68	18.18	1.73	17.55	1.79	17.23	1.83	16.97	1.86	16.35	1.91
		35	32	20.34	1.72	19.69	1.78	19.02	1.82	18.68	1.87	18.40	1.90	17.74	1.95
		40	36	21.37	1.77	20.77	1.83	20.11	1.88	19.76	1.92	19.48	1.95	18.78	2.00
		45	41	22.67	1.83	22.13	1.89	21.47	1.95	21.12	1.98	20.83	2.01	20.08	2.07
		47	43	23.19	1.85	22.67	1.91	22.02	1.98	21.66	2.01	21.37	2.04	20.59	2.10
		50	46	23.25	1.84	22.78	1.90	22.22	1.95	21.90	1.98	21.64	2.00	20.91	2.06
		55	51	23.37	1.82	22.98	1.87	22.56	1.91	22.30	1.93	22.09	1.95	21.44	1.99
		60	56	23.48	1.80	23.17	1.84	22.89	1.87	22.69	1.89	22.54	1.90	21.96	1.93
		63	59	23.55	1.79	23.29	1.82	23.09	1.85	22.93	1.86	22.81	1.86	22.28	1.89
		68	64	23.62	1.78	23.41	1.80	23.29	1.82	23.17	1.83	23.08	1.83	22.60	1.85
	12 + 12	-4	-4.4	8.16	1.57	7.53	1.64	7.50	1.66	7.42	1.67	7.35	1.68	7.02	1.74
		0	-0.4	9.98	1.59	9.38	1.65	9.24	1.68	9.11	1.69	9.01	1.70	8.62	1.76
		5	4.5	12.14	1.61	11.57	1.66	11.30	1.70	11.12	1.72	10.97	1.74	10.53	1.79
		10	9	13.59	1.62	13.04	1.68	12.68	1.72	12.46	1.75	12.29	1.76	11.80	1.82
		17	15	15.18	1.65	14.66	1.70	14.19	1.75	13.94	1.78	13.73	1.80	13.20	1.86
		20	19	16.15	1.66	15.64	1.71	15.11	1.77	14.83	1.80	14.61	1.83	14.05	1.88
		25	23	17.77	1.69	17.24	1.74	16.64	1.81	16.33	1.84	16.08	1.87	15.47	1.92
		30	28	19.40	1.73	18.80	1.79	18.15	1.84	17.82	1.88	17.55	1.91	16.91	1.96
		35	32	21.03	1.77	20.36	1.83	19.67	1.88	19.31	1.92	19.03	1.96	18.34	2.00
		40	36	22.10	1.82	21.48	1.88	20.80	1.93	20.44	1.98	20.15	2.01	19.42	2.06
		45	41	23.44	1.88	22.88	1.95	22.21	2.01	21.84	2.04	21.54	2.07	20.76	2.13
		47	43	23.98	1.91	23.44	1.97	22.77	2.03	22.40	2.07	22.10	2.10	21.30	2.16
		50	46	24.05	1.90	23.56	1.95	22.98	2.01	22.65	2.04	22.38	2.06	21.62	2.12
		55	51	24.17	1.88	23.76	1.92	23.33	1.97	23.06	1.99	22.84	2.01	22.17	2.05
		60	56	24.28	1.86	23.97	1.89	23.67	1.93	23.47	1.94	23.31	1.95	22.71	1.98
		63	59	24.35	1.84	24.09	1.87	23.88	1.90	23.72	1.91	23.59	1.92	23.04	1.94
		68	64	24.42	1.83	24.21	1.86	24.09	1.88	23.97	1.88	23.87	1.89	23.37	1.90
	9 + 18	-4	-4.4	8.16	1.57	7.53	1.64	7.50	1.66	7.42	1.67	7.35	1.68	7.02	1.74
		0	-0.4	9.98	1.59	9.38	1.65	9.24	1.68	9.11	1.69	9.01	1.70	8.62	1.76
		5	4.5	12.14	1.61	11.57	1.66	11.30	1.70	11.12	1.72	10.97	1.74	10.53	1.79
		10	9	13.59	1.62	13.04	1.68	12.68	1.72	12.46	1.75	12.29	1.76	11.80	1.82
		17	15	15.18	1.65	14.66	1.70	14.19	1.75	13.94	1.78	13.73	1.80	13.20	1.86
		20	19	16.15	1.66	15.64	1.71	15.11	1.77	14.83	1.80	14.61	1.83	14.05	1.88
		25	23	17.77	1.69	17.24	1.74	16.64	1.81	16.33	1.84	16.08	1.87	15.47	1.92
		30	28	19.40	1.73	18.80	1.79	18.15	1.84	17.82	1.88	17.55	1.91	16.91	1.96
		35	32	21.03	1.77	20.36	1.83	19.67	1.88	19.31	1.92	19.03	1.96	18.34	2.00
		40	36	22.10	1.82	21.48	1.88	20.80	1.93	20.44	1.98	20.15	2.01	19.42	2.06
		45	41	23.44	1.88	22.88	1.95	22.21	2.01	21.84	2.04	21.54	2.07	20.76	2.13
		47	43	23.98	1.91	23.44	1.97	22.77	2.03	22.40	2.07	22.10	2.10	21.30	2.16
		50	46	24.05	1.90	23.56	1.95	22.98	2.01	22.65	2.04	22.38	2.06	21.62	2.12
		55	51	24.17	1.88	23.76	1.92	23.33	1.97	23.06	1.99	22.84	2.01	22.17	2.05
		60	56	24.28	1.86	23.97	1.89	23.67	1.93	23.47	1.94	23.31	1.95	22.71	1.98
		63	59	24.35	1.84	24.09	1.87	23.88	1.90	23.72	1.91	23.59	1.92	23.04	1.94
		68	64	24.42	1.83	24.21	1.86	24.09	1.88	23.97	1.88	23.87	1.89	23.37	1.90

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 274: LMU24CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 18	-4	-4.4	8.16	1.57	7.53	1.64	7.50	1.66	7.42	1.67	7.35	1.68	7.02	1.74
		0	-0.4	9.98	1.59	9.38	1.65	9.24	1.68	9.11	1.69	9.01	1.70	8.62	1.76
		5	4.5	12.14	1.61	11.57	1.66	11.30	1.70	11.12	1.72	10.97	1.74	10.53	1.79
		10	9	13.59	1.62	13.04	1.68	12.68	1.72	12.46	1.75	12.29	1.76	11.80	1.82
		17	15	15.18	1.65	14.66	1.70	14.19	1.75	13.94	1.78	13.73	1.80	13.20	1.86
		20	19	16.15	1.66	15.64	1.71	15.11	1.77	14.83	1.80	14.61	1.83	14.05	1.88
		25	23	17.77	1.69	17.24	1.74	16.64	1.81	16.33	1.84	16.08	1.87	15.47	1.92
		30	28	19.40	1.73	18.80	1.79	18.15	1.84	17.82	1.88	17.55	1.91	16.91	1.96
		35	32	21.03	1.77	20.36	1.83	19.67	1.88	19.31	1.92	19.03	1.96	18.34	2.00
		40	36	22.10	1.82	21.48	1.88	20.80	1.93	20.44	1.98	20.15	2.01	19.42	2.06
		45	41	23.44	1.88	22.88	1.95	22.21	2.01	21.84	2.04	21.54	2.07	20.76	2.13
		47	43	23.98	1.91	23.44	1.97	22.77	2.03	22.40	2.07	22.10	2.10	21.30	2.16
		50	46	24.05	1.90	23.56	1.95	22.98	2.01	22.65	2.04	22.38	2.06	21.62	2.12
		55	51	24.17	1.88	23.76	1.92	23.33	1.97	23.06	1.99	22.84	2.01	22.17	2.05
		60	56	24.28	1.86	23.97	1.89	23.67	1.93	23.47	1.94	23.31	1.95	22.71	1.98
		63	59	24.35	1.84	24.09	1.87	23.88	1.90	23.72	1.91	23.59	1.92	23.04	1.94
		68	64	24.42	1.83	24.21	1.86	24.09	1.88	23.97	1.88	23.87	1.89	23.37	1.90
Three (3) Ducted Indoor Units	9 + 9 + 9	-4	-4.4	8.16	1.46	7.53	1.52	7.50	1.54	7.42	1.55	7.35	1.56	7.02	1.61
		0	-0.4	9.98	1.47	9.38	1.53	9.24	1.55	9.11	1.57	9.01	1.58	8.62	1.64
		5	4.5	12.14	1.49	11.57	1.54	11.30	1.58	11.12	1.59	10.97	1.61	10.53	1.66
		10	9	13.59	1.51	13.04	1.56	12.68	1.60	12.46	1.62	12.29	1.64	11.80	1.69
		17	15	15.18	1.53	14.66	1.58	14.19	1.62	13.94	1.65	13.73	1.67	13.20	1.72
		20	19	16.15	1.54	15.64	1.59	15.11	1.64	14.83	1.67	14.61	1.70	14.05	1.74
		25	23	17.77	1.57	17.24	1.61	16.64	1.68	16.33	1.71	16.08	1.74	15.47	1.78
		30	28	19.40	1.60	18.80	1.66	18.15	1.71	17.82	1.75	17.55	1.78	16.91	1.82
		35	32	21.03	1.64	20.36	1.70	19.67	1.74	19.31	1.78	19.03	1.81	18.34	1.86
		40	36	22.10	1.69	21.48	1.75	20.80	1.79	20.44	1.83	20.15	1.86	19.42	1.91
		45	41	23.44	1.75	22.88	1.81	22.21	1.86	21.84	1.89	21.54	1.92	20.76	1.98
		47	43	23.98	1.77	23.44	1.83	22.77	1.89	22.40	1.92	22.10	1.95	21.30	2.00
		50	46	24.05	1.76	23.56	1.81	22.98	1.86	22.65	1.89	22.38	1.92	21.62	1.97
		55	51	24.17	1.74	23.76	1.78	23.33	1.83	23.06	1.85	22.84	1.86	22.17	1.90
		60	56	24.28	1.72	23.97	1.76	23.67	1.79	23.47	1.80	23.31	1.81	22.71	1.84
		63	59	24.35	1.71	24.09	1.74	23.88	1.76	23.72	1.77	23.59	1.78	23.04	1.80
		68	64	24.42	1.70	24.21	1.72	24.09	1.74	23.97	1.75	23.87	1.75	23.37	1.76
	9 + 9 + 12	-4	-4.4	8.16	1.46	7.53	1.52	7.50	1.54	7.42	1.55	7.35	1.56	7.02	1.61
		0	-0.4	9.98	1.47	9.38	1.53	9.24	1.55	9.11	1.57	9.01	1.58	8.62	1.64
		5	4.5	12.14	1.49	11.57	1.54	11.30	1.58	11.12	1.59	10.97	1.61	10.53	1.66
		10	9	13.59	1.51	13.04	1.56	12.68	1.60	12.46	1.62	12.29	1.64	11.80	1.69
		17	15	15.18	1.53	14.66	1.58	14.19	1.62	13.94	1.65	13.73	1.67	13.20	1.72
		20	19	16.15	1.54	15.64	1.59	15.11	1.64	14.83	1.67	14.61	1.70	14.05	1.74
		25	23	17.77	1.57	17.24	1.61	16.64	1.68	16.33	1.71	16.08	1.74	15.47	1.78
		30	28	19.40	1.60	18.80	1.66	18.15	1.71	17.82	1.75	17.55	1.78	16.91	1.82
		35	32	21.03	1.64	20.36	1.70	19.67	1.74	19.31	1.78	19.03	1.81	18.34	1.86
		40	36	22.10	1.69	21.48	1.75	20.80	1.79	20.44	1.83	20.15	1.86	19.42	1.91
		45	41	23.44	1.75	22.88	1.81	22.21	1.86	21.84	1.89	21.54	1.92	20.76	1.98
		47	43	23.98	1.77	23.44	1.83	22.77	1.89	22.40	1.92	22.10	1.95	21.30	2.00
		50	46	24.05	1.76	23.56	1.81	22.98	1.86	22.65	1.89	22.38	1.92	21.62	1.97
		55	51	24.17	1.74	23.76	1.78	23.33	1.83	23.06	1.85	22.84	1.86	22.17	1.90
		60	56	24.28	1.72	23.97	1.76	23.67	1.79	23.47	1.80	23.31	1.81	22.71	1.84
		63	59	24.35	1.71	24.09	1.74	23.88	1.76	23.72	1.77	23.59	1.78	23.04	1.80
		68	64	24.42	1.70	24.21	1.72	24.09	1.74	23.97	1.75	23.87	1.75	23.37	1.76

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 275: LMU24CHV Heating Capacity Table — Ducted, continued, and Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 12 + 12	-4	-4.4	8.16	1.46	7.53	1.52	7.50	1.54	7.42	1.55	7.35	1.56	7.02	1.61
		0	-0.4	9.98	1.47	9.38	1.53	9.24	1.55	9.11	1.57	9.01	1.58	8.62	1.64
		5	4.5	12.14	1.49	11.57	1.54	11.30	1.58	11.12	1.59	10.97	1.61	10.53	1.66
		10	9	13.59	1.51	13.04	1.56	12.68	1.60	12.46	1.62	12.29	1.64	11.80	1.69
		17	15	15.18	1.53	14.66	1.58	14.19	1.62	13.94	1.65	13.73	1.67	13.20	1.72
		20	19	16.15	1.54	15.64	1.59	15.11	1.64	14.83	1.67	14.61	1.70	14.05	1.74
		25	23	17.77	1.57	17.24	1.61	16.64	1.68	16.33	1.71	16.08	1.74	15.47	1.78
		30	28	19.40	1.60	18.80	1.66	18.15	1.71	17.82	1.75	17.55	1.78	16.91	1.82
		35	32	21.03	1.64	20.36	1.70	19.67	1.74	19.31	1.78	19.03	1.81	18.34	1.86
		40	36	22.10	1.69	21.48	1.75	20.80	1.79	20.44	1.83	20.15	1.86	19.42	1.91
		45	41	23.44	1.75	22.88	1.81	22.21	1.86	21.84	1.89	21.54	1.92	20.76	1.98
		47	43	23.98	1.77	23.44	1.83	22.77	1.89	22.40	1.92	22.10	1.95	21.30	2.00
		50	46	24.05	1.76	23.56	1.81	22.98	1.86	22.65	1.89	22.38	1.92	21.62	1.97
		55	51	24.17	1.74	23.76	1.78	23.33	1.83	23.06	1.85	22.84	1.86	22.17	1.90
		60	56	24.28	1.72	23.97	1.76	23.67	1.79	23.47	1.80	23.31	1.81	22.71	1.84
		63	59	24.35	1.71	24.09	1.74	23.88	1.76	23.72	1.77	23.59	1.78	23.04	1.80
		68	64	24.42	1.70	24.21	1.72	24.09	1.74	23.97	1.75	23.87	1.75	23.37	1.76
Two (2) Mixed Indoor Units	7 + 9	-4	-4.4	5.83	1.28	5.36	1.33	5.35	1.35	5.30	1.35	5.25	1.36	5.01	1.41
		0	-0.4	7.27	1.29	6.82	1.34	6.72	1.36	6.63	1.37	6.56	1.38	6.28	1.43
		5	4.5	8.98	1.30	8.55	1.35	8.35	1.38	8.22	1.39	8.11	1.41	7.78	1.45
		10	9	10.12	1.32	9.71	1.36	9.44	1.40	9.28	1.41	9.15	1.43	8.79	1.48
		17	15	11.39	1.33	10.99	1.38	10.64	1.42	10.45	1.44	10.30	1.46	9.90	1.50
		20	19	12.15	1.34	11.76	1.39	11.37	1.43	11.16	1.46	10.99	1.48	10.57	1.52
		25	23	13.43	1.37	13.03	1.41	12.58	1.46	12.34	1.49	12.15	1.51	11.69	1.55
		30	28	14.72	1.40	14.26	1.44	13.77	1.49	13.52	1.52	13.32	1.55	12.83	1.58
		35	32	16.01	1.43	15.50	1.48	14.97	1.51	14.70	1.55	14.49	1.58	13.96	1.62
		40	36	16.82	1.47	16.35	1.52	15.83	1.56	15.56	1.59	15.34	1.62	14.78	1.66
		45	41	17.84	1.52	17.42	1.57	16.90	1.62	16.62	1.65	16.40	1.67	15.80	1.72
		47	43	18.25	1.54	17.84	1.59	17.33	1.64	17.05	1.67	16.82	1.69	16.21	1.74
		50	46	18.30	1.53	17.94	1.58	17.49	1.62	17.24	1.65	17.04	1.67	16.46	1.71
		55	51	18.39	1.51	18.09	1.55	17.75	1.59	17.55	1.61	17.39	1.62	16.87	1.66
		60	56	18.48	1.50	18.24	1.53	18.02	1.55	17.86	1.57	17.74	1.58	17.29	1.60
		63	59	18.54	1.49	18.33	1.51	18.18	1.53	18.05	1.54	17.95	1.55	17.54	1.57
		68	64	18.59	1.48	18.43	1.50	18.34	1.52	18.24	1.52	18.17	1.52	17.79	1.53
	9 + 9	-4	-4.4	6.55	1.35	6.03	1.41	6.02	1.43	5.96	1.44	5.90	1.44	5.64	1.50
		0	-0.4	8.17	1.37	7.67	1.42	7.56	1.44	7.46	1.45	7.38	1.47	7.06	1.52
		5	4.5	10.10	1.38	9.62	1.43	9.40	1.46	9.24	1.48	9.12	1.49	8.75	1.54
		10	9	11.39	1.39	10.93	1.44	10.62	1.48	10.44	1.50	10.29	1.52	9.89	1.56
		17	15	12.81	1.41	12.36	1.46	11.97	1.50	11.76	1.53	11.58	1.55	11.14	1.59
		20	19	13.67	1.42	13.23	1.47	12.79	1.52	12.55	1.55	12.36	1.57	11.89	1.61
		25	23	15.11	1.45	14.66	1.49	14.15	1.55	13.88	1.58	13.67	1.60	13.15	1.65
		30	28	16.56	1.48	16.04	1.53	15.49	1.58	15.21	1.61	14.98	1.64	14.43	1.68
		35	32	18.01	1.51	17.43	1.56	16.84	1.61	16.54	1.64	16.30	1.67	15.71	1.71
		40	36	18.93	1.55	18.39	1.61	17.81	1.65	17.50	1.69	17.25	1.72	16.63	1.76
		45	41	20.07	1.61	19.59	1.66	19.02	1.72	18.70	1.75	18.45	1.77	17.78	1.82
		47	43	20.53	1.63	20.07	1.69	19.50	1.74	19.18	1.77	18.93	1.79	18.24	1.85
		50	46	20.59	1.62	20.18	1.67	19.68	1.72	19.39	1.74	19.16	1.77	18.52	1.81
		55	51	20.69	1.60	20.35	1.64	19.97	1.68	19.74	1.70	19.56	1.72	18.98	1.75
		60	56	20.79	1.59	20.52	1.62	20.27	1.65	20.10	1.66	19.96	1.67	19.45	1.70
		63	59	20.85	1.58	20.63	1.60	20.45	1.63	20.31	1.63	20.20	1.64	19.73	1.66
		68	64	20.91	1.57	20.73	1.59	20.63	1.61	20.52	1.61	20.44	1.61	20.01	1.63

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 276: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 12	-4	-4.4	6.92	1.39	6.37	1.45	6.36	1.47	6.29	1.48	6.23	1.48	5.95	1.54
		0	-0.4	8.63	1.41	8.10	1.46	7.99	1.48	7.88	1.50	7.79	1.51	7.46	1.56
		5	4.5	10.66	1.42	10.16	1.47	9.92	1.50	9.76	1.52	9.63	1.53	9.24	1.58
		10	9	12.02	1.43	11.54	1.48	11.22	1.52	11.02	1.54	10.87	1.56	10.44	1.61
		17	15	13.52	1.45	13.05	1.50	12.64	1.55	12.41	1.57	12.23	1.59	11.76	1.64
		20	19	14.43	1.47	13.97	1.51	13.50	1.56	13.25	1.59	13.05	1.61	12.56	1.66
		25	23	15.95	1.49	15.48	1.53	14.94	1.59	14.66	1.62	14.43	1.65	13.89	1.69
		30	28	17.48	1.52	16.94	1.57	16.36	1.62	16.06	1.66	15.82	1.68	15.24	1.73
		35	32	19.01	1.55	18.41	1.61	17.78	1.65	17.46	1.69	17.20	1.72	16.58	1.76
		40	36	19.98	1.60	19.42	1.65	18.80	1.70	18.47	1.74	18.21	1.77	17.55	1.81
		45	41	21.19	1.66	20.69	1.71	20.08	1.76	19.74	1.80	19.48	1.82	18.77	1.87
		47	43	21.68	1.68	21.19	1.73	20.59	1.79	20.25	1.82	19.98	1.84	19.25	1.90
		50	46	21.74	1.67	21.30	1.72	20.77	1.77	20.47	1.79	20.23	1.82	19.55	1.86
		55	51	21.85	1.65	21.48	1.69	21.09	1.73	20.84	1.75	20.65	1.77	20.04	1.80
		60	56	21.95	1.63	21.67	1.66	21.40	1.69	21.22	1.71	21.07	1.72	20.53	1.74
		63	59	22.02	1.62	21.78	1.65	21.59	1.67	21.44	1.68	21.32	1.69	20.83	1.71
		68	64	22.08	1.61	21.89	1.63	21.78	1.65	21.67	1.66	21.58	1.66	21.13	1.67
	9 + 12	-4	-4.4	7.65	1.49	7.04	1.55	7.03	1.57	6.95	1.58	6.89	1.59	6.58	1.65
		0	-0.4	9.54	1.51	8.95	1.56	8.83	1.59	8.70	1.60	8.61	1.61	8.24	1.67
		5	4.5	11.78	1.52	11.23	1.58	10.96	1.61	10.79	1.63	10.65	1.64	10.22	1.70
		10	9	13.29	1.54	12.75	1.59	12.39	1.63	12.18	1.65	12.01	1.67	11.54	1.72
		17	15	14.94	1.56	14.42	1.61	13.97	1.66	13.72	1.68	13.51	1.71	12.99	1.76
		20	19	15.95	1.57	15.44	1.62	14.92	1.67	14.65	1.70	14.43	1.73	13.88	1.78
		25	23	17.63	1.60	17.10	1.64	16.51	1.71	16.20	1.74	15.95	1.77	15.35	1.81
		30	28	19.32	1.63	18.72	1.68	18.08	1.74	17.75	1.77	17.48	1.81	16.84	1.85
		35	32	21.01	1.66	20.34	1.72	19.65	1.77	19.30	1.81	19.01	1.84	18.33	1.89
		40	36	22.08	1.71	21.46	1.77	20.78	1.82	20.42	1.86	20.13	1.89	19.40	1.94
		45	41	23.42	1.77	22.86	1.83	22.19	1.89	21.82	1.92	21.52	1.95	20.74	2.01
		47	43	23.96	1.80	23.42	1.86	22.75	1.92	22.38	1.95	22.08	1.98	21.28	2.04
		50	46	24.03	1.79	23.54	1.84	22.96	1.89	22.63	1.92	22.36	1.94	21.61	2.00
		55	51	24.14	1.77	23.74	1.81	23.31	1.85	23.04	1.88	22.82	1.89	22.15	1.93
		60	56	24.26	1.75	23.95	1.78	23.65	1.82	23.45	1.83	23.29	1.84	22.69	1.87
		63	59	24.33	1.74	24.07	1.77	23.86	1.79	23.70	1.80	23.56	1.81	23.02	1.83
		68	64	24.40	1.73	24.19	1.75	24.07	1.77	23.94	1.77	23.85	1.78	23.35	1.79
	9 + 15	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 277: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 12	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84
	7 + 18	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84
	9 + 18	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 278: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	12 + 15	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84
	12 + 18	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84
	15 + 18	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 279: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 24*	-4	-4.4	7.94	1.53	7.32	1.59	7.30	1.61	7.22	1.62	7.16	1.63	6.83	1.69
		0	-0.4	9.91	1.54	9.30	1.60	9.17	1.63	9.04	1.64	8.94	1.66	8.56	1.71
		5	4.5	12.24	1.56	11.66	1.62	11.39	1.65	11.21	1.67	11.06	1.69	10.61	1.74
		10	9	13.81	1.58	13.25	1.63	12.88	1.67	12.66	1.69	12.48	1.71	11.99	1.77
		17	15	15.53	1.60	14.99	1.65	14.51	1.70	14.25	1.73	14.04	1.75	13.50	1.80
		20	19	16.57	1.61	16.04	1.66	15.50	1.72	15.22	1.75	14.99	1.77	14.42	1.82
		25	23	18.31	1.64	17.77	1.69	17.15	1.75	16.83	1.78	16.57	1.81	15.94	1.86
		30	28	20.07	1.67	19.45	1.73	18.78	1.78	18.44	1.82	18.16	1.85	17.49	1.90
		35	32	21.83	1.71	21.13	1.77	20.41	1.81	20.05	1.86	19.75	1.89	19.04	1.94
		40	36	22.94	1.76	22.30	1.82	21.59	1.87	21.21	1.91	20.91	1.94	20.15	1.99
		45	41	24.33	1.82	23.75	1.88	23.05	1.94	22.67	1.97	22.36	2.00	21.55	2.06
		47	43	24.89	1.84	24.33	1.91	23.64	1.97	23.25	2.00	22.94	2.03	22.11	2.09
		50	46	24.96	1.83	24.46	1.89	23.85	1.94	23.51	1.97	23.23	1.99	22.45	2.05
		55	51	25.08	1.81	24.67	1.86	24.21	1.90	23.93	1.92	23.71	1.94	23.01	1.98
		60	56	25.20	1.79	24.88	1.83	24.57	1.86	24.36	1.88	24.19	1.89	23.57	1.92
		63	59	25.28	1.78	25.00	1.81	24.79	1.84	24.62	1.85	24.48	1.85	23.91	1.88
		68	64	25.35	1.77	25.13	1.79	25.00	1.81	24.88	1.82	24.77	1.82	24.25	1.84
Three (3) Mixed Indoor Units	7 + 7 + 9	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	7 + 9 + 9	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 280: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 12	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	9 + 9 + 9	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	7 + 9 + 12	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU24CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 281: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 12	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	7 + 9 + 15	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	7 + 12 + 12	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 282: LMU24CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 18	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	9 + 9 + 15	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71
	9 + 12 + 12	-4	-4.4	7.94	1.42	7.32	1.48	7.30	1.50	7.22	1.51	7.16	1.52	6.83	1.57
		0	-0.4	9.91	1.44	9.30	1.49	9.17	1.51	9.04	1.53	8.94	1.54	8.56	1.59
		5	4.5	12.24	1.45	11.66	1.50	11.39	1.54	11.21	1.55	11.06	1.57	10.61	1.62
		10	9	13.81	1.47	13.25	1.52	12.88	1.55	12.66	1.58	12.48	1.59	11.99	1.64
		17	15	15.53	1.48	14.99	1.53	14.51	1.58	14.25	1.61	14.04	1.63	13.50	1.67
		20	19	16.57	1.50	16.04	1.54	15.50	1.60	15.22	1.63	14.99	1.65	14.42	1.70
		25	23	18.31	1.52	17.77	1.57	17.15	1.63	16.83	1.66	16.57	1.69	15.94	1.73
		30	28	20.07	1.56	19.45	1.61	18.78	1.66	18.44	1.69	18.16	1.72	17.49	1.77
		35	32	21.83	1.59	21.13	1.64	20.41	1.69	20.05	1.73	19.75	1.76	19.04	1.80
		40	36	22.94	1.63	22.30	1.69	21.59	1.74	21.21	1.77	20.91	1.80	20.15	1.85
		45	41	24.33	1.69	23.75	1.75	23.05	1.80	22.67	1.84	22.36	1.86	21.55	1.92
		47	43	24.89	1.72	24.33	1.77	23.64	1.83	23.25	1.86	22.94	1.89	22.11	1.94
		50	46	24.96	1.70	24.46	1.76	23.85	1.81	23.51	1.83	23.23	1.86	22.45	1.91
		55	51	25.08	1.69	24.67	1.73	24.21	1.77	23.93	1.79	23.71	1.81	23.01	1.84
		60	56	25.20	1.67	24.88	1.70	24.57	1.73	24.36	1.74	24.19	1.76	23.57	1.78
		63	59	25.28	1.66	25.00	1.68	24.79	1.71	24.62	1.72	24.48	1.73	23.91	1.75
		68	64	25.35	1.65	25.13	1.67	25.00	1.69	24.88	1.69	24.77	1.70	24.25	1.71

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 283: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	-4.4	5.25	1.09	4.83	1.13	4.82	1.15	4.77	1.15	4.73	1.16	4.51	1.20
		0	-0.4	6.55	1.10	6.15	1.15	6.06	1.17	5.98	1.18	5.91	1.18	5.66	1.23
		5	4.5	8.10	1.12	7.72	1.16	7.53	1.19	7.41	1.20	7.32	1.21	7.02	1.25
		10	9	9.14	1.14	8.77	1.18	8.52	1.21	8.37	1.23	8.26	1.24	7.93	1.28
		17	15	10.28	1.16	9.92	1.20	9.61	1.24	9.43	1.26	9.29	1.27	8.94	1.31
		20	19	10.97	1.18	10.62	1.21	10.26	1.25	10.07	1.28	9.92	1.30	9.54	1.33
		25	23	12.13	1.20	11.77	1.24	11.36	1.29	11.14	1.31	10.97	1.33	10.56	1.37
		30	28	13.29	1.24	12.88	1.28	12.44	1.32	12.21	1.35	12.03	1.37	11.59	1.41
		35	32	14.46	1.27	14.00	1.32	13.52	1.35	13.28	1.38	13.08	1.41	12.61	1.44
		40	36	15.20	1.31	14.77	1.35	14.30	1.39	14.05	1.42	13.85	1.45	13.35	1.48
		45	41	16.12	1.36	15.73	1.40	15.27	1.44	15.01	1.47	14.81	1.49	14.27	1.53
		47	43	16.48	1.37	16.12	1.42	15.66	1.46	15.40	1.49	15.20	1.51	14.64	1.56
		50	46	16.53	1.37	16.20	1.41	15.80	1.45	15.57	1.47	15.39	1.49	14.87	1.53
		55	51	16.61	1.35	16.34	1.38	16.04	1.42	15.85	1.43	15.71	1.45	15.24	1.48
		60	56	16.69	1.34	16.48	1.36	16.27	1.39	16.14	1.40	16.02	1.41	15.61	1.43
		63	59	16.74	1.33	16.56	1.35	16.42	1.37	16.30	1.38	16.22	1.38	15.84	1.40
		68	64	16.79	1.32	16.64	1.34	16.56	1.35	16.48	1.36	16.41	1.36	16.07	1.37
	7 + 9	-4	-4.4	6.00	1.21	5.52	1.25	5.51	1.27	5.45	1.28	5.40	1.29	5.16	1.33
		0	-0.4	7.49	1.22	7.03	1.27	6.93	1.29	6.83	1.30	6.76	1.31	6.47	1.36
		5	4.5	9.26	1.24	8.82	1.29	8.61	1.32	8.47	1.33	8.36	1.34	8.02	1.39
		10	9	10.44	1.26	10.02	1.31	9.74	1.34	9.57	1.36	9.44	1.37	9.07	1.41
		17	15	11.74	1.29	11.34	1.33	10.98	1.37	10.78	1.39	10.62	1.41	10.21	1.45
		20	19	12.53	1.30	12.14	1.34	11.73	1.39	11.51	1.41	11.34	1.44	10.91	1.48
		25	23	13.86	1.33	13.45	1.37	12.98	1.42	12.73	1.45	12.54	1.48	12.07	1.52
		30	28	15.19	1.37	14.72	1.42	14.22	1.46	13.95	1.49	13.75	1.52	13.24	1.56
		35	32	16.52	1.41	16.00	1.46	15.45	1.50	15.18	1.53	14.95	1.56	14.41	1.60
		40	36	17.37	1.45	16.88	1.50	16.34	1.54	16.06	1.57	15.83	1.60	15.26	1.64
		45	41	18.42	1.50	17.98	1.55	17.45	1.60	17.16	1.63	16.93	1.65	16.31	1.70
		47	43	18.84	1.52	18.42	1.57	17.89	1.62	17.60	1.65	17.37	1.67	16.73	1.72
		50	46	18.89	1.51	18.51	1.56	18.06	1.60	17.79	1.63	17.58	1.65	16.99	1.69
		55	51	18.99	1.50	18.67	1.53	18.33	1.57	18.12	1.59	17.95	1.60	17.42	1.64
		60	56	19.08	1.48	18.83	1.51	18.60	1.54	18.44	1.55	18.31	1.56	17.84	1.58
		63	59	19.13	1.47	18.93	1.49	18.76	1.52	18.63	1.52	18.53	1.53	18.10	1.55
		68	64	19.19	1.46	19.02	1.48	18.93	1.50	18.83	1.50	18.75	1.50	18.36	1.52
	9 + 9	-4	-4.4	6.75	1.33	6.21	1.38	6.20	1.40	6.13	1.41	6.08	1.42	5.80	1.47
		0	-0.4	8.42	1.35	7.91	1.40	7.79	1.42	7.69	1.44	7.60	1.45	7.28	1.50
		5	4.5	10.41	1.37	9.92	1.42	9.69	1.45	9.53	1.47	9.41	1.48	9.03	1.53
		10	9	11.75	1.39	11.27	1.44	10.96	1.48	10.77	1.50	10.62	1.51	10.20	1.56
		17	15	13.21	1.42	12.75	1.46	12.35	1.51	12.13	1.53	11.95	1.56	11.49	1.60
		20	19	14.10	1.44	13.65	1.48	13.20	1.53	12.95	1.56	12.76	1.58	12.27	1.63
		25	23	15.59	1.47	15.13	1.51	14.60	1.57	14.33	1.60	14.10	1.63	13.57	1.67
		30	28	17.09	1.51	16.56	1.56	15.99	1.61	15.70	1.65	15.46	1.67	14.90	1.72
		35	32	18.59	1.55	18.00	1.61	17.38	1.65	17.07	1.69	16.82	1.72	16.21	1.76
		40	36	19.54	1.60	18.99	1.65	18.38	1.70	18.06	1.74	17.81	1.77	17.16	1.81
		45	41	20.72	1.66	20.23	1.71	19.63	1.76	19.30	1.80	19.04	1.82	18.35	1.87
		47	43	21.19	1.68	20.72	1.73	20.13	1.79	19.80	1.82	19.54	1.84	18.83	1.90
		50	46	21.26	1.67	20.83	1.72	20.31	1.77	20.02	1.79	19.78	1.82	19.11	1.86
		55	51	21.36	1.65	21.01	1.69	20.62	1.73	20.38	1.75	20.19	1.77	19.59	1.80
		60	56	21.46	1.63	21.18	1.66	20.92	1.69	20.75	1.71	20.60	1.72	20.08	1.74
		63	59	21.53	1.62	21.29	1.65	21.11	1.67	20.96	1.68	20.85	1.69	20.36	1.71
		68	64	21.59	1.61	21.40	1.63	21.29	1.65	21.18	1.66	21.10	1.66	20.66	1.67

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 284: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 12	-4	-4.4	7.12	1.39	6.56	1.44	6.54	1.46	6.47	1.47	6.42	1.48	6.12	1.54
		0	-0.4	8.89	1.41	8.35	1.46	8.23	1.49	8.11	1.50	8.02	1.51	7.68	1.56
		5	4.5	10.99	1.43	10.47	1.48	10.23	1.51	10.06	1.53	9.93	1.55	9.53	1.60
		10	9	12.40	1.45	11.90	1.50	11.56	1.54	11.37	1.56	11.21	1.58	10.77	1.63
		17	15	13.95	1.48	13.46	1.53	13.04	1.58	12.80	1.60	12.61	1.62	12.13	1.67
		20	19	14.88	1.50	14.41	1.55	13.93	1.60	13.67	1.63	13.46	1.65	12.95	1.70
		25	23	16.46	1.54	15.97	1.58	15.41	1.64	15.12	1.67	14.89	1.70	14.33	1.75
		30	28	18.04	1.58	17.48	1.63	16.88	1.68	16.57	1.72	16.32	1.75	15.72	1.79
		35	32	19.62	1.62	19.00	1.68	18.35	1.72	18.02	1.76	17.76	1.80	17.12	1.84
		40	36	20.62	1.67	20.04	1.73	19.40	1.78	19.07	1.81	18.80	1.84	18.12	1.89
		45	41	21.87	1.73	21.35	1.79	20.72	1.84	20.38	1.88	20.10	1.90	19.37	1.96
		47	43	22.37	1.75	21.87	1.81	21.25	1.87	20.90	1.90	20.62	1.93	19.87	1.98
		50	46	22.44	1.74	21.99	1.79	21.44	1.85	21.13	1.87	20.88	1.90	20.18	1.95
		55	51	22.55	1.72	22.17	1.77	21.76	1.81	21.51	1.83	21.31	1.84	20.68	1.88
		60	56	22.66	1.70	22.36	1.74	22.09	1.77	21.90	1.78	21.75	1.79	21.19	1.82
		63	59	22.72	1.69	22.47	1.72	22.28	1.75	22.13	1.76	22.01	1.76	21.49	1.78
		68	64	22.79	1.68	22.59	1.70	22.48	1.72	22.36	1.73	22.27	1.73	21.80	1.75
	9 + 12	-4	-4.4	7.87	1.50	7.25	1.56	7.23	1.58	7.15	1.59	7.09	1.60	6.77	1.66
		0	-0.4	9.82	1.52	9.22	1.58	9.09	1.60	8.97	1.62	8.87	1.63	8.49	1.69
		5	4.5	12.15	1.54	11.57	1.60	11.30	1.63	11.12	1.65	10.97	1.67	10.53	1.72
		10	9	13.70	1.57	13.15	1.62	12.78	1.66	12.56	1.69	12.39	1.70	11.90	1.76
		17	15	15.41	1.60	14.88	1.65	14.41	1.70	14.15	1.73	13.94	1.75	13.40	1.80
		20	19	16.45	1.62	15.93	1.67	15.40	1.73	15.11	1.76	14.88	1.78	14.32	1.83
		25	23	18.19	1.66	17.65	1.71	17.04	1.77	16.71	1.81	16.45	1.83	15.84	1.88
		30	28	19.94	1.70	19.32	1.76	18.66	1.81	18.32	1.85	18.04	1.89	17.38	1.93
		35	32	21.69	1.75	21.00	1.81	20.28	1.86	19.92	1.90	19.63	1.94	18.92	1.98
		40	36	22.79	1.80	22.15	1.86	21.45	1.92	21.07	1.96	20.78	1.99	20.02	2.04
		45	41	24.17	1.86	23.60	1.93	22.90	1.99	22.52	2.02	22.22	2.05	21.41	2.11
		47	43	24.73	1.89	24.17	1.95	23.48	2.02	23.10	2.05	22.79	2.08	21.96	2.14
		50	46	24.80	1.88	24.30	1.93	23.70	1.99	23.35	2.02	23.08	2.04	22.30	2.10
		55	51	24.92	1.86	24.51	1.90	24.05	1.95	23.78	1.97	23.56	1.99	22.86	2.03
		60	56	25.04	1.84	24.72	1.87	24.41	1.91	24.20	1.92	24.04	1.93	23.42	1.96
		63	59	25.11	1.83	24.84	1.86	24.63	1.88	24.46	1.89	24.32	1.90	23.76	1.92
		68	64	25.19	1.81	24.97	1.84	24.84	1.86	24.71	1.86	24.61	1.87	24.10	1.88
	7 + 15	-4	-4.4	8.24	1.55	7.59	1.61	7.58	1.63	7.49	1.64	7.43	1.65	7.09	1.71
		0	-0.4	10.29	1.57	9.66	1.63	9.52	1.66	9.39	1.67	9.29	1.68	8.89	1.74
		5	4.5	12.73	1.60	12.13	1.66	11.84	1.69	11.65	1.71	11.50	1.72	11.03	1.78
		10	9	14.36	1.62	13.77	1.68	13.39	1.72	13.16	1.74	12.98	1.76	12.47	1.82
		17	15	16.15	1.65	15.59	1.71	15.10	1.76	14.82	1.79	14.60	1.81	14.04	1.86
		20	19	17.24	1.67	16.69	1.73	16.13	1.78	15.83	1.82	15.59	1.84	15.00	1.90
		25	23	19.05	1.71	18.49	1.76	17.85	1.83	17.51	1.87	17.24	1.90	16.59	1.95
		30	28	20.89	1.76	20.24	1.82	19.55	1.88	19.19	1.92	18.90	1.95	18.21	2.00
		35	32	22.72	1.81	22.00	1.87	21.25	1.92	20.87	1.97	20.56	2.00	19.82	2.05
		40	36	23.88	1.86	23.21	1.93	22.47	1.98	22.08	2.02	21.77	2.06	20.98	2.11
		45	41	25.33	1.93	24.72	1.99	23.99	2.05	23.59	2.09	23.28	2.12	22.43	2.18
		47	43	25.90	1.95	25.33	2.02	24.60	2.08	24.20	2.12	23.88	2.15	23.01	2.21
		50	46	25.98	1.94	25.46	2.00	24.83	2.06	24.47	2.09	24.18	2.11	23.36	2.17
		55	51	26.11	1.92	25.67	1.97	25.20	2.02	24.91	2.04	24.68	2.06	23.95	2.10
		60	56	26.23	1.90	25.89	1.94	25.57	1.97	25.36	1.99	25.18	2.00	24.54	2.03
		63	59	26.31	1.89	26.02	1.92	25.80	1.95	25.62	1.96	25.48	1.97	24.89	1.99
		68	64	26.39	1.88	26.15	1.90	26.02	1.92	25.89	1.93	25.78	1.93	25.25	1.95

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 285: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	-4.4	8.99	1.65	8.28	1.71	8.26	1.73	8.18	1.74	8.10	1.75	7.74	1.82
		0	-0.4	11.23	1.67	10.54	1.73	10.39	1.76	10.25	1.78	10.13	1.79	9.70	1.85
		5	4.5	13.88	1.70	13.23	1.76	12.92	1.79	12.71	1.81	12.54	1.83	12.04	1.89
		10	9	15.66	1.72	15.03	1.78	14.61	1.82	14.36	1.85	14.16	1.87	13.60	1.93
		17	15	17.62	1.75	17.00	1.81	16.47	1.87	16.17	1.90	15.93	1.92	15.32	1.98
		20	19	18.80	1.78	18.20	1.83	17.60	1.89	17.27	1.93	17.01	1.96	16.36	2.01
		25	23	20.79	1.82	20.17	1.87	19.47	1.94	19.10	1.98	18.81	2.01	18.10	2.07
		30	28	22.79	1.87	22.08	1.93	21.32	1.99	20.93	2.04	20.62	2.07	19.86	2.12
		35	32	24.79	1.92	24.00	1.99	23.18	2.04	22.76	2.09	22.43	2.13	21.62	2.18
		40	36	26.05	1.98	25.32	2.05	24.51	2.10	24.09	2.15	23.75	2.18	22.89	2.24
		45	41	27.63	2.05	26.97	2.12	26.17	2.18	25.74	2.22	25.39	2.25	24.47	2.32
		47	43	28.26	2.07	27.63	2.14	26.84	2.21	26.40	2.25	26.05	2.28	25.10	2.35
		50	46	28.34	2.06	27.77	2.12	27.08	2.18	26.69	2.22	26.38	2.24	25.49	2.30
		55	51	28.48	2.04	28.01	2.09	27.49	2.14	27.18	2.16	26.92	2.18	26.13	2.23
		60	56	28.62	2.02	28.25	2.06	27.90	2.09	27.66	2.11	27.47	2.12	26.77	2.16
		63	59	28.70	2.01	28.39	2.04	28.14	2.07	27.95	2.08	27.80	2.09	27.15	2.11
		68	64	28.79	1.99	28.53	2.02	28.39	2.04	28.25	2.05	28.13	2.05	27.54	2.07
	12 + 12	-4	-4.4	8.99	1.65	8.28	1.71	8.26	1.73	8.18	1.74	8.10	1.75	7.74	1.82
		0	-0.4	11.23	1.67	10.54	1.73	10.39	1.76	10.25	1.78	10.13	1.79	9.70	1.85
		5	4.5	13.88	1.70	13.23	1.76	12.92	1.79	12.71	1.81	12.54	1.83	12.04	1.89
		10	9	15.66	1.72	15.03	1.78	14.61	1.82	14.36	1.85	14.16	1.87	13.60	1.93
		17	15	17.62	1.75	17.00	1.81	16.47	1.87	16.17	1.90	15.93	1.92	15.32	1.98
		20	19	18.80	1.78	18.20	1.83	17.60	1.89	17.27	1.93	17.01	1.96	16.36	2.01
		25	23	20.79	1.82	20.17	1.87	19.47	1.94	19.10	1.98	18.81	2.01	18.10	2.07
		30	28	22.79	1.87	22.08	1.93	21.32	1.99	20.93	2.04	20.62	2.07	19.86	2.12
		35	32	24.79	1.92	24.00	1.99	23.18	2.04	22.76	2.09	22.43	2.13	21.62	2.18
		40	36	26.05	1.98	25.32	2.05	24.51	2.10	24.09	2.15	23.75	2.18	22.89	2.24
		45	41	27.63	2.05	26.97	2.12	26.17	2.18	25.74	2.22	25.39	2.25	24.47	2.32
		47	43	28.26	2.07	27.63	2.14	26.84	2.21	26.40	2.25	26.05	2.28	25.10	2.35
		50	46	28.34	2.06	27.77	2.12	27.08	2.18	26.69	2.22	26.38	2.24	25.49	2.30
		55	51	28.48	2.04	28.01	2.09	27.49	2.14	27.18	2.16	26.92	2.18	26.13	2.23
		60	56	28.62	2.02	28.25	2.06	27.90	2.09	27.66	2.11	27.47	2.12	26.77	2.16
		63	59	28.70	2.01	28.39	2.04	28.14	2.07	27.95	2.08	27.80	2.09	27.15	2.11
		68	64	28.79	1.99	28.53	2.02	28.39	2.04	28.25	2.05	28.13	2.05	27.54	2.07
	7 + 18	-4	-4.4	9.37	1.70	8.63	1.76	8.61	1.79	8.52	1.80	8.44	1.81	8.06	1.87
		0	-0.4	11.70	1.72	10.98	1.79	10.82	1.81	10.67	1.83	10.55	1.84	10.10	1.91
		5	4.5	14.46	1.75	13.78	1.81	13.45	1.85	13.24	1.87	13.07	1.89	12.54	1.95
		10	9	16.31	1.77	15.65	1.84	15.22	1.88	14.96	1.91	14.75	1.93	14.17	1.99
		17	15	18.35	1.81	17.71	1.87	17.15	1.92	16.84	1.96	16.60	1.98	15.96	2.04
		20	19	19.59	1.83	18.96	1.89	18.33	1.95	17.99	1.99	17.72	2.02	17.04	2.07
		25	23	21.65	1.88	21.01	1.93	20.28	2.00	19.90	2.04	19.59	2.08	18.85	2.13
		30	28	23.74	1.93	23.00	1.99	22.21	2.05	21.80	2.10	21.48	2.13	20.69	2.19
		35	32	25.82	1.98	25.00	2.05	24.15	2.10	23.71	2.15	23.36	2.19	22.52	2.25
		40	36	27.13	2.04	26.37	2.11	25.53	2.17	25.09	2.21	24.74	2.25	23.84	2.31
		45	41	28.78	2.11	28.09	2.18	27.26	2.25	26.81	2.29	26.45	2.32	25.49	2.39
		47	43	29.44	2.14	28.78	2.21	27.96	2.28	27.50	2.32	27.13	2.35	26.15	2.42
		50	46	29.52	2.13	28.93	2.19	28.21	2.25	27.80	2.29	27.48	2.31	26.55	2.38
		55	51	29.67	2.10	29.18	2.16	28.64	2.21	28.31	2.23	28.04	2.25	27.22	2.30
		60	56	29.81	2.08	29.42	2.12	29.06	2.16	28.81	2.18	28.61	2.19	27.88	2.22
		63	59	29.90	2.07	29.57	2.10	29.32	2.13	29.12	2.14	28.96	2.15	28.28	2.18
		68	64	29.98	2.05	29.72	2.08	29.57	2.10	29.42	2.11	29.30	2.11	28.69	2.13

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 286: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 18	-4	-4.4	10.12	1.81	9.32	1.88	9.30	1.90	9.20	1.91	9.12	1.92	8.70	2.00
		0	-0.4	12.63	1.83	11.86	1.90	11.69	1.93	11.53	1.95	11.40	1.96	10.91	2.03
		5	4.5	15.62	1.86	14.88	1.93	14.53	1.97	14.30	1.99	14.11	2.01	13.54	2.08
		10	9	17.62	1.89	16.90	1.95	16.43	2.00	16.15	2.03	15.93	2.05	15.30	2.12
		17	15	19.82	1.93	19.13	1.99	18.53	2.05	18.19	2.08	17.92	2.11	17.23	2.17
		20	19	21.15	1.95	20.48	2.01	19.79	2.08	19.43	2.12	19.13	2.15	18.41	2.21
		25	23	23.38	2.00	22.69	2.06	21.90	2.13	21.49	2.18	21.16	2.21	20.36	2.27
		30	28	25.64	2.05	24.84	2.12	23.99	2.19	23.55	2.23	23.20	2.27	22.34	2.33
		35	32	27.88	2.11	27.00	2.18	26.08	2.24	25.61	2.29	25.23	2.33	24.32	2.39
		40	36	29.31	2.17	28.48	2.25	27.57	2.31	27.10	2.36	26.71	2.40	25.75	2.46
		45	41	31.08	2.25	30.34	2.32	29.44	2.39	28.96	2.44	28.57	2.47	27.53	2.54
		47	43	31.79	2.28	31.08	2.35	30.19	2.43	29.70	2.47	29.31	2.50	28.24	2.58
		50	46	31.89	2.26	31.24	2.33	30.47	2.40	30.03	2.43	29.67	2.46	28.67	2.53
		55	51	32.04	2.24	31.51	2.29	30.93	2.35	30.57	2.38	30.29	2.40	29.39	2.45
		60	56	32.20	2.22	31.78	2.26	31.39	2.30	31.12	2.32	30.90	2.33	30.11	2.37
		63	59	32.29	2.20	31.94	2.24	31.66	2.27	31.45	2.28	31.27	2.29	30.55	2.32
		68	64	32.38	2.19	32.10	2.21	31.94	2.24	31.78	2.25	31.64	2.25	30.98	2.27
	12 + 15	-4	-4.4	10.12	1.81	9.32	1.88	9.30	1.90	9.20	1.91	9.12	1.92	8.70	2.00
		0	-0.4	12.63	1.83	11.86	1.90	11.69	1.93	11.53	1.95	11.40	1.96	10.91	2.03
		5	4.5	15.62	1.86	14.88	1.93	14.53	1.97	14.30	1.99	14.11	2.01	13.54	2.08
		10	9	17.62	1.89	16.90	1.95	16.43	2.00	16.15	2.03	15.93	2.05	15.30	2.12
		17	15	19.82	1.93	19.13	1.99	18.53	2.05	18.19	2.08	17.92	2.11	17.23	2.17
		20	19	21.15	1.95	20.48	2.01	19.79	2.08	19.43	2.12	19.13	2.15	18.41	2.21
		25	23	23.38	2.00	22.69	2.06	21.90	2.13	21.49	2.18	21.16	2.21	20.36	2.27
		30	28	25.64	2.05	24.84	2.12	23.99	2.19	23.55	2.23	23.20	2.27	22.34	2.33
		35	32	27.88	2.11	27.00	2.18	26.08	2.24	25.61	2.29	25.23	2.33	24.32	2.39
		40	36	29.31	2.17	28.48	2.25	27.57	2.31	27.10	2.36	26.71	2.40	25.75	2.46
		45	41	31.08	2.25	30.34	2.32	29.44	2.39	28.96	2.44	28.57	2.47	27.53	2.54
		47	43	31.79	2.28	31.08	2.35	30.19	2.43	29.70	2.47	29.31	2.50	28.24	2.58
		50	46	31.89	2.26	31.24	2.33	30.47	2.40	30.03	2.43	29.67	2.46	28.67	2.53
		55	51	32.04	2.24	31.51	2.29	30.93	2.35	30.57	2.38	30.29	2.40	29.39	2.45
		60	56	32.20	2.22	31.78	2.26	31.39	2.30	31.12	2.32	30.90	2.33	30.11	2.37
		63	59	32.29	2.20	31.94	2.24	31.66	2.27	31.45	2.28	31.27	2.29	30.55	2.32
		68	64	32.38	2.19	32.10	2.21	31.94	2.24	31.78	2.25	31.64	2.25	30.98	2.27
	12 + 18	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 287: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 15	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45
	7 + 24	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45
	9 + 24	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 288: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 18	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45
	18 + 18	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45
	12 + 24	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 289: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 24	-4	-4.4	10.90	1.95	10.04	2.03	10.02	2.06	9.91	2.07	9.82	2.08	9.38	2.16
		0	-0.4	13.61	1.98	12.78	2.05	12.59	2.09	12.42	2.11	12.28	2.12	11.76	2.20
		5	4.5	16.83	2.01	16.03	2.08	15.66	2.13	15.40	2.15	15.20	2.17	14.59	2.24
		10	9	18.98	2.04	18.21	2.11	17.71	2.17	17.40	2.20	17.16	2.22	16.48	2.29
		17	15	21.35	2.08	20.61	2.15	19.96	2.21	19.60	2.25	19.31	2.28	18.57	2.35
		20	19	22.79	2.11	22.06	2.17	21.33	2.25	20.93	2.29	20.62	2.32	19.83	2.39
		25	23	25.20	2.16	24.45	2.22	23.60	2.31	23.15	2.35	22.79	2.39	21.94	2.45
		30	28	27.62	2.22	26.77	2.29	25.85	2.36	25.37	2.42	24.99	2.46	24.07	2.52
		35	32	30.04	2.28	29.09	2.36	28.10	2.42	27.59	2.48	27.19	2.52	26.20	2.58
		40	36	31.57	2.35	30.69	2.43	29.71	2.50	29.19	2.55	28.78	2.59	27.74	2.66
		45	41	33.49	2.43	32.69	2.51	31.73	2.59	31.20	2.64	30.78	2.67	29.66	2.75
		47	43	34.25	2.46	33.49	2.54	32.53	2.62	32.00	2.67	31.57	2.71	30.43	2.79
		50	46	34.35	2.45	33.66	2.52	32.83	2.59	32.35	2.63	31.97	2.66	30.89	2.73
		55	51	34.52	2.42	33.95	2.48	33.32	2.54	32.94	2.57	32.63	2.59	31.67	2.65
		60	56	34.69	2.39	34.24	2.44	33.82	2.49	33.53	2.50	33.30	2.52	32.44	2.56
		63	59	34.79	2.38	34.41	2.42	34.11	2.45	33.88	2.47	33.69	2.48	32.91	2.51
		68	64	34.89	2.36	34.59	2.39	34.41	2.42	34.24	2.43	34.10	2.43	33.38	2.45
Three (3) Non-Ducted Indoor Units	7 + 7 + 7	-4	-4.4	7.87	1.46	7.25	1.52	7.23	1.54	7.15	1.55	7.09	1.56	6.77	1.62
		0	-0.4	9.82	1.48	9.22	1.54	9.09	1.56	8.97	1.58	8.87	1.59	8.49	1.65
		5	4.5	12.15	1.51	11.57	1.56	11.30	1.59	11.12	1.61	10.97	1.63	10.53	1.68
		10	9	13.70	1.53	13.15	1.58	12.78	1.62	12.56	1.64	12.39	1.66	11.90	1.71
		17	15	15.41	1.56	14.88	1.61	14.41	1.66	14.15	1.69	13.94	1.71	13.40	1.76
		20	19	16.45	1.58	15.93	1.63	15.40	1.68	15.11	1.71	14.88	1.74	14.32	1.79
		25	23	18.19	1.62	17.65	1.66	17.04	1.73	16.71	1.76	16.45	1.79	15.84	1.84
		30	28	19.94	1.66	19.32	1.72	18.66	1.77	18.32	1.81	18.04	1.84	17.38	1.89
		35	32	21.69	1.71	21.00	1.77	20.28	1.81	19.92	1.86	19.63	1.89	18.92	1.94
		40	36	22.79	1.76	22.15	1.82	21.45	1.87	21.07	1.91	20.78	1.94	20.02	1.99
		45	41	24.17	1.82	23.60	1.88	22.90	1.94	22.52	1.97	22.22	2.00	21.41	2.06
		47	43	24.73	1.84	24.17	1.91	23.48	1.97	23.10	2.00	22.79	2.03	21.96	2.09
		50	46	24.80	1.83	24.30	1.89	23.70	1.94	23.35	1.97	23.08	1.99	22.30	2.05
		55	51	24.92	1.81	24.51	1.86	24.05	1.90	23.78	1.92	23.56	1.94	22.86	1.98
		60	56	25.04	1.79	24.72	1.83	24.41	1.86	24.20	1.88	24.04	1.89	23.42	1.92
		63	59	25.11	1.78	24.84	1.81	24.63	1.84	24.46	1.85	24.32	1.85	23.76	1.88
		68	64	25.19	1.77	24.97	1.79	24.84	1.81	24.71	1.82	24.61	1.82	24.10	1.84
	7 + 7 + 9	-4	-4.4	8.62	1.57	7.94	1.63	7.92	1.65	7.84	1.66	7.77	1.67	7.41	1.73
		0	-0.4	10.76	1.59	10.10	1.65	9.96	1.67	9.82	1.69	9.71	1.70	9.30	1.76
		5	4.5	13.30	1.61	12.68	1.67	12.38	1.71	12.18	1.73	12.02	1.74	11.53	1.80
		10	9	15.01	1.64	14.40	1.69	14.00	1.74	13.76	1.76	13.57	1.78	13.03	1.83
		17	15	16.88	1.67	16.30	1.72	15.78	1.78	15.50	1.80	15.27	1.83	14.68	1.88
		20	19	18.02	1.69	17.44	1.74	16.86	1.80	16.55	1.84	16.30	1.86	15.68	1.91
		25	23	19.92	1.73	19.33	1.78	18.66	1.85	18.30	1.89	18.02	1.92	17.34	1.97
		30	28	21.84	1.78	21.16	1.84	20.43	1.89	20.06	1.94	19.76	1.97	19.03	2.02
		35	32	23.75	1.83	23.00	1.89	22.21	1.94	21.81	1.99	21.50	2.02	20.72	2.07
		40	36	24.96	1.88	24.26	1.95	23.49	2.00	23.08	2.04	22.76	2.08	21.93	2.13
		45	41	26.48	1.95	25.84	2.01	25.08	2.07	24.67	2.11	24.33	2.14	23.45	2.20
		47	43	27.08	1.97	26.48	2.04	25.72	2.10	25.30	2.14	24.96	2.17	24.06	2.23
		50	46	27.16	1.96	26.61	2.02	25.95	2.08	25.58	2.11	25.28	2.13	24.42	2.19
		55	51	27.29	1.94	26.84	1.99	26.35	2.04	26.04	2.06	25.80	2.08	25.04	2.12
		60	56	27.43	1.92	27.07	1.96	26.74	1.99	26.51	2.01	26.32	2.02	25.65	2.05
		63	59	27.51	1.91	27.21	1.94	26.97	1.97	26.79	1.98	26.64	1.98	26.02	2.01
		68	64	27.59	1.89	27.34	1.92	27.21	1.94	27.07	1.95	26.96	1.95	26.39	1.97

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 290: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 9	-4	-4.4	9.37	1.68	8.63	1.74	8.61	1.76	8.52	1.77	8.44	1.78	8.06	1.85
		0	-0.4	11.70	1.70	10.98	1.76	10.82	1.79	10.67	1.81	10.55	1.82	10.10	1.88
		5	4.5	14.46	1.73	13.78	1.79	13.45	1.83	13.24	1.85	13.07	1.86	12.54	1.93
		10	9	16.31	1.75	15.65	1.81	15.22	1.86	14.96	1.88	14.75	1.90	14.17	1.96
		17	15	18.35	1.79	17.71	1.84	17.15	1.90	16.84	1.93	16.60	1.96	15.96	2.01
		20	19	19.59	1.81	18.96	1.86	18.33	1.93	17.99	1.96	17.72	1.99	17.04	2.05
		25	23	21.65	1.85	21.01	1.91	20.28	1.98	19.90	2.02	19.59	2.05	18.85	2.10
		30	28	23.74	1.90	23.00	1.97	22.21	2.03	21.80	2.07	21.48	2.11	20.69	2.16
		35	32	25.82	1.95	25.00	2.02	24.15	2.08	23.71	2.13	23.36	2.16	22.52	2.22
		40	36	27.13	2.01	26.37	2.08	25.53	2.14	25.09	2.19	24.74	2.22	23.84	2.28
		45	41	28.78	2.08	28.09	2.15	27.26	2.22	26.81	2.26	26.45	2.29	25.49	2.36
		47	43	29.44	2.11	28.78	2.18	27.96	2.25	27.50	2.29	27.13	2.32	26.15	2.39
		50	46	29.52	2.10	28.93	2.16	28.21	2.22	27.80	2.26	27.48	2.28	26.55	2.35
		55	51	29.67	2.08	29.18	2.13	28.64	2.18	28.31	2.20	28.04	2.22	27.22	2.27
		60	56	29.81	2.05	29.42	2.09	29.06	2.13	28.81	2.15	28.61	2.16	27.88	2.19
		63	59	29.90	2.04	29.57	2.07	29.32	2.10	29.12	2.12	28.96	2.12	28.28	2.15
		68	64	29.98	2.03	29.72	2.05	29.57	2.08	29.42	2.08	29.30	2.09	28.69	2.10
	7 + 7 + 12	-4	-4.4	9.74	1.70	8.97	1.76	8.95	1.79	8.86	1.80	8.78	1.81	8.38	1.87
		0	-0.4	12.16	1.72	11.42	1.79	11.26	1.81	11.10	1.83	10.98	1.84	10.51	1.91
		5	4.5	15.04	1.75	14.33	1.81	13.99	1.85	13.77	1.87	13.59	1.89	13.04	1.95
		10	9	16.97	1.77	16.28	1.84	15.82	1.88	15.55	1.91	15.34	1.93	14.73	1.99
		17	15	19.08	1.81	18.42	1.87	17.84	1.92	17.52	1.96	17.26	1.98	16.60	2.04
		20	19	20.37	1.83	19.72	1.89	19.06	1.95	18.71	1.99	18.42	2.02	17.72	2.07
		25	23	22.52	1.88	21.85	1.93	21.09	2.00	20.69	2.04	20.37	2.08	19.61	2.13
		30	28	24.69	1.93	23.92	1.99	23.10	2.05	22.68	2.10	22.34	2.13	21.52	2.19
		35	32	26.85	1.98	26.00	2.05	25.11	2.10	24.66	2.15	24.30	2.19	23.42	2.25
		40	36	28.22	2.04	27.43	2.11	26.55	2.17	26.09	2.21	25.72	2.25	24.79	2.31
		45	41	29.93	2.11	29.22	2.18	28.35	2.25	27.88	2.29	27.51	2.32	26.51	2.39
		47	43	30.61	2.14	29.93	2.21	29.08	2.28	28.60	2.32	28.22	2.35	27.19	2.42
		50	46	30.70	2.13	30.08	2.19	29.34	2.25	28.92	2.29	28.58	2.31	27.61	2.38
		55	51	30.85	2.10	30.34	2.16	29.78	2.21	29.44	2.23	29.17	2.25	28.30	2.30
		60	56	31.00	2.08	30.60	2.12	30.22	2.16	29.97	2.18	29.76	2.19	29.00	2.22
		63	59	31.09	2.07	30.75	2.10	30.49	2.13	30.28	2.14	30.11	2.15	29.41	2.18
		68	64	31.18	2.05	30.91	2.08	30.76	2.10	30.60	2.11	30.47	2.11	29.84	2.13
	9 + 9 + 9	-4	-4.4	10.12	1.73	9.32	1.79	9.30	1.82	9.20	1.83	9.12	1.84	8.70	1.91
		0	-0.4	12.63	1.75	11.86	1.82	11.69	1.85	11.53	1.86	11.40	1.88	10.91	1.94
		5	4.5	15.62	1.78	14.88	1.84	14.53	1.88	14.30	1.90	14.11	1.92	13.54	1.98
		10	9	17.62	1.81	16.90	1.87	16.43	1.91	16.15	1.94	15.93	1.96	15.30	2.02
		17	15	19.82	1.84	19.13	1.90	18.53	1.96	18.19	1.99	17.92	2.02	17.23	2.08
		20	19	21.15	1.86	20.48	1.92	19.79	1.99	19.43	2.02	19.13	2.05	18.41	2.11
		25	23	23.38	1.91	22.69	1.96	21.90	2.04	21.49	2.08	21.16	2.11	20.36	2.17
		30	28	25.64	1.96	24.84	2.03	23.99	2.09	23.55	2.13	23.20	2.17	22.34	2.23
		35	32	27.88	2.01	27.00	2.09	26.08	2.14	25.61	2.19	25.23	2.23	24.32	2.28
		40	36	29.31	2.07	28.48	2.15	27.57	2.21	27.10	2.25	26.71	2.29	25.75	2.35
		45	41	31.08	2.15	30.34	2.22	29.44	2.29	28.96	2.33	28.57	2.36	27.53	2.43
		47	43	31.79	2.18	31.08	2.25	30.19	2.32	29.70	2.36	29.31	2.39	28.24	2.46
		50	46	31.89	2.16	31.24	2.23	30.47	2.29	30.03	2.33	29.67	2.35	28.67	2.42
		55	51	32.04	2.14	31.51	2.19	30.93	2.24	30.57	2.27	30.29	2.29	29.39	2.34
		60	56	32.20	2.12	31.78	2.16	31.39	2.20	31.12	2.21	30.90	2.23	30.11	2.26
		63	59	32.29	2.10	31.94	2.14	31.66	2.17	31.45	2.18	31.27	2.19	30.55	2.21
		68	64	32.38	2.09	32.10	2.12	31.94	2.14	31.78	2.15	31.64	2.15	30.98	2.17

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 291: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued..

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 12	-4	-4.4	10.49	1.76	9.66	1.83	9.64	1.86	9.54	1.87	9.46	1.88	9.02	1.95
		0	-0.4	13.10	1.79	12.30	1.85	12.12	1.88	11.96	1.90	11.82	1.92	11.32	1.98
		5	4.5	16.20	1.82	15.43	1.88	15.07	1.92	14.83	1.94	14.63	1.96	14.04	2.03
		10	9	18.27	1.84	17.53	1.91	17.04	1.95	16.75	1.98	16.52	2.00	15.87	2.07
		17	15	20.55	1.88	19.84	1.94	19.21	2.00	18.87	2.03	18.59	2.06	17.87	2.12
		20	19	21.94	1.90	21.24	1.96	20.53	2.03	20.15	2.07	19.84	2.10	19.09	2.15
		25	23	24.25	1.95	23.53	2.01	22.71	2.08	22.28	2.12	21.94	2.16	21.11	2.21
		30	28	26.58	2.00	25.76	2.07	24.88	2.13	24.42	2.18	24.06	2.22	23.17	2.27
		35	32	28.92	2.06	28.00	2.13	27.04	2.19	26.56	2.24	26.17	2.28	25.22	2.33
		40	36	30.39	2.12	29.54	2.19	28.60	2.25	28.10	2.30	27.70	2.34	26.70	2.40
		45	41	32.23	2.19	31.46	2.27	30.54	2.34	30.03	2.38	29.62	2.41	28.55	2.48
		47	43	32.97	2.22	32.23	2.30	31.31	2.37	30.80	2.41	30.39	2.44	29.29	2.52
		50	46	33.07	2.21	32.40	2.27	31.60	2.34	31.14	2.38	30.77	2.40	29.73	2.47
		55	51	33.23	2.18	32.68	2.24	32.07	2.29	31.70	2.32	31.41	2.34	30.48	2.39
		60	56	33.39	2.16	32.95	2.20	32.55	2.24	32.27	2.26	32.05	2.27	31.23	2.31
		63	59	33.49	2.15	33.12	2.18	32.83	2.21	32.61	2.23	32.43	2.24	31.68	2.26
		68	64	33.58	2.13	33.29	2.16	33.12	2.19	32.95	2.19	32.82	2.20	32.13	2.22
	7 + 7 + 15	-4	-4.4	10.87	1.79	10.01	1.86	9.99	1.89	9.88	1.90	9.79	1.91	9.35	1.98
		0	-0.4	13.57	1.82	12.74	1.89	12.56	1.92	12.38	1.93	12.24	1.95	11.72	2.02
		5	4.5	16.78	1.85	15.98	1.91	15.61	1.95	15.36	1.98	15.16	1.99	14.54	2.06
		10	9	18.92	1.87	18.16	1.94	17.65	1.99	17.35	2.01	17.11	2.04	16.43	2.10
		17	15	21.29	1.91	20.55	1.97	19.90	2.03	19.54	2.07	19.25	2.09	18.51	2.15
		20	19	22.72	1.93	22.00	1.99	21.26	2.06	20.87	2.10	20.55	2.13	19.77	2.19
		25	23	25.12	1.98	24.37	2.04	23.52	2.12	23.08	2.16	22.72	2.19	21.87	2.25
		30	28	27.53	2.04	26.68	2.10	25.77	2.17	25.29	2.22	24.91	2.25	24.00	2.31
		35	32	29.95	2.09	29.00	2.17	28.01	2.22	27.51	2.27	27.10	2.32	26.12	2.37
		40	36	31.48	2.15	30.59	2.23	29.62	2.29	29.10	2.34	28.69	2.38	27.65	2.44
		45	41	33.38	2.23	32.59	2.30	31.63	2.37	31.10	2.42	30.68	2.45	29.57	2.52
		47	43	34.15	2.26	33.38	2.33	32.43	2.41	31.90	2.45	31.48	2.48	30.33	2.56
		50	46	34.25	2.24	33.56	2.31	32.73	2.38	32.25	2.41	31.87	2.44	30.80	2.51
		55	51	34.41	2.22	33.84	2.28	33.22	2.33	32.84	2.36	32.53	2.38	31.57	2.43
		60	56	34.58	2.20	34.13	2.24	33.71	2.28	33.42	2.30	33.19	2.31	32.34	2.35
		63	59	34.68	2.18	34.30	2.22	34.01	2.25	33.77	2.26	33.59	2.27	32.81	2.30
		68	64	34.78	2.17	34.48	2.20	34.31	2.22	34.13	2.23	33.99	2.23	33.28	2.25
	9 + 9 + 12	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 292: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 12 + 12	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 7 + 18	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 293: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	9 + 12 + 12	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 9 + 18	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 294: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 12 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	9 + 9 + 18	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	9 + 12 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 295: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 12 + 12	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 12 + 18	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 15 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 296: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 24	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	9 + 12 + 18	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	9 + 15 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 297: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 12 + 15	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 9 + 24	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31
	7 + 15 + 18	-4	-4.4	10.90	1.84	10.04	1.91	10.02	1.93	9.91	1.95	9.82	1.96	9.38	2.03
		0	-0.4	13.61	1.86	12.78	1.93	12.59	1.96	12.42	1.98	12.28	1.99	11.76	2.07
		5	4.5	16.83	1.89	16.03	1.96	15.66	2.00	15.40	2.02	15.20	2.04	14.59	2.11
		10	9	18.98	1.92	18.21	1.99	17.71	2.04	17.40	2.06	17.16	2.09	16.48	2.15
		17	15	21.35	1.96	20.61	2.02	19.96	2.08	19.60	2.12	19.31	2.14	18.57	2.21
		20	19	22.79	1.98	22.06	2.04	21.33	2.11	20.93	2.15	20.62	2.18	19.83	2.24
		25	23	25.20	2.03	24.45	2.09	23.60	2.17	23.15	2.21	22.79	2.25	21.94	2.31
		30	28	27.62	2.09	26.77	2.15	25.85	2.22	25.37	2.27	24.99	2.31	24.07	2.37
		35	32	30.04	2.14	29.09	2.22	28.10	2.28	27.59	2.33	27.19	2.37	26.20	2.43
		40	36	31.57	2.20	30.69	2.28	29.71	2.35	29.19	2.40	28.78	2.43	27.74	2.50
		45	41	33.49	2.28	32.69	2.36	31.73	2.43	31.20	2.48	30.78	2.51	29.66	2.59
		47	43	34.25	2.31	33.49	2.39	32.53	2.47	32.00	2.51	31.57	2.54	30.43	2.62
		50	46	34.35	2.30	33.66	2.37	32.83	2.44	32.35	2.47	31.97	2.50	30.89	2.57
		55	51	34.52	2.28	33.95	2.33	33.32	2.39	32.94	2.41	32.63	2.44	31.67	2.49
		60	56	34.69	2.25	34.24	2.29	33.82	2.34	33.53	2.35	33.30	2.37	32.44	2.41
		63	59	34.79	2.24	34.41	2.27	34.11	2.31	33.88	2.32	33.69	2.33	32.91	2.36
		68	64	34.89	2.22	34.59	2.25	34.41	2.28	34.24	2.28	34.10	2.29	33.38	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 298: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 7	-4	-4.4	10.49	1.77	9.66	1.84	9.64	1.86	9.54	1.88	9.46	1.89	9.02	1.96
		0	-0.4	13.10	1.79	12.30	1.86	12.12	1.89	11.96	1.91	11.82	1.92	11.32	1.99
		5	4.5	16.20	1.82	15.43	1.89	15.07	1.93	14.83	1.95	14.63	1.97	14.04	2.03
		10	9	18.27	1.85	17.53	1.91	17.04	1.96	16.75	1.99	16.52	2.01	15.87	2.07
		17	15	20.55	1.89	19.84	1.95	19.21	2.01	18.87	2.04	18.59	2.07	17.87	2.13
		20	19	21.94	1.91	21.24	1.97	20.53	2.04	20.15	2.08	19.84	2.11	19.09	2.16
		25	23	24.25	1.96	23.53	2.01	22.71	2.09	22.28	2.13	21.94	2.17	21.11	2.22
		30	28	26.58	2.01	25.76	2.08	24.88	2.14	24.42	2.19	24.06	2.23	23.17	2.28
		35	32	28.92	2.07	28.00	2.14	27.04	2.19	26.56	2.25	26.17	2.29	25.22	2.34
		40	36	30.39	2.13	29.54	2.20	28.60	2.26	28.10	2.31	27.70	2.35	26.70	2.41
		45	41	32.23	2.20	31.46	2.28	30.54	2.35	30.03	2.39	29.62	2.42	28.55	2.49
		47	43	32.97	2.23	32.23	2.31	31.31	2.38	30.80	2.42	30.39	2.45	29.29	2.53
		50	46	33.07	2.22	32.40	2.28	31.60	2.35	31.14	2.39	30.77	2.41	29.73	2.48
		55	51	33.23	2.19	32.68	2.25	32.07	2.30	31.70	2.33	31.41	2.35	30.48	2.40
		60	56	33.39	2.17	32.95	2.21	32.55	2.25	32.27	2.27	32.05	2.28	31.23	2.32
		63	59	33.49	2.16	33.12	2.19	32.83	2.22	32.61	2.24	32.43	2.24	31.68	2.27
		68	64	33.58	2.14	33.29	2.17	33.12	2.20	32.95	2.20	32.82	2.21	32.13	2.22
	7 + 7 + 7 + 9	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 7 + 9 + 9	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 299: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 12	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 9 + 9 + 9	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 7 + 9 + 12	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 300: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 15	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	9 + 9 + 9 + 9	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 9 + 9 + 12	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 301: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 9 + 15	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 7 + 12 + 12	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 7 + 7 + 18	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 302: LMU30CHV Heating Capacity Table —Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 9 + 12	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 9 + 9 + 15	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29
	7 + 9 + 12 + 12	-4	-4.4	10.90	1.82	10.04	1.89	10.02	1.92	9.91	1.93	9.82	1.94	9.38	2.01
		0	-0.4	13.61	1.85	12.78	1.92	12.59	1.95	12.42	1.96	12.28	1.98	11.76	2.05
		5	4.5	16.83	1.88	16.03	1.94	15.66	1.99	15.40	2.01	15.20	2.03	14.59	2.09
		10	9	18.98	1.90	18.21	1.97	17.71	2.02	17.40	2.05	17.16	2.07	16.48	2.13
		17	15	21.35	1.94	20.61	2.00	19.96	2.07	19.60	2.10	19.31	2.13	18.57	2.19
		20	19	22.79	1.97	22.06	2.03	21.33	2.10	20.93	2.14	20.62	2.17	19.83	2.23
		25	23	25.20	2.01	24.45	2.07	23.60	2.15	23.15	2.19	22.79	2.23	21.94	2.29
		30	28	27.62	2.07	26.77	2.14	25.85	2.20	25.37	2.25	24.99	2.29	24.07	2.35
		35	32	30.04	2.13	29.09	2.20	28.10	2.26	27.59	2.31	27.19	2.35	26.20	2.41
		40	36	31.57	2.19	30.69	2.26	29.71	2.33	29.19	2.38	28.78	2.42	27.74	2.48
		45	41	33.49	2.26	32.69	2.34	31.73	2.41	31.20	2.46	30.78	2.49	29.66	2.57
		47	43	34.25	2.30	33.49	2.37	32.53	2.45	32.00	2.49	31.57	2.52	30.43	2.60
		50	46	34.35	2.28	33.66	2.35	32.83	2.42	32.35	2.45	31.97	2.48	30.89	2.55
		55	51	34.52	2.26	33.95	2.31	33.32	2.37	32.94	2.40	32.63	2.42	31.67	2.47
		60	56	34.69	2.23	34.24	2.28	33.82	2.32	33.53	2.34	33.30	2.35	32.44	2.39
		63	59	34.79	2.22	34.41	2.25	34.11	2.29	33.88	2.30	33.69	2.31	32.91	2.34
		68	64	34.89	2.20	34.59	2.23	34.41	2.26	34.24	2.26	34.10	2.27	33.38	2.29

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 303: LMU30CHV Heating Capacity Table —Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 9	-4	-4.4	4.63	1.36	4.20	1.41	4.23	1.43	4.20	1.44	4.17	1.44	3.97	1.50
		0	-0.4	6.42	1.39	6.00	1.44	5.93	1.47	5.85	1.48	5.79	1.49	5.54	1.54
		5	4.5	8.54	1.43	8.13	1.48	7.94	1.51	7.82	1.53	7.72	1.54	7.40	1.60
		10	9	9.96	1.47	9.56	1.52	9.29	1.56	9.13	1.58	9.01	1.59	8.65	1.64
		17	15	11.53	1.52	11.13	1.57	10.78	1.61	10.58	1.64	10.43	1.66	10.03	1.71
		20	19	12.48	1.55	12.08	1.60	11.68	1.65	11.46	1.68	11.29	1.71	10.86	1.75
		25	23	14.06	1.61	13.65	1.66	13.17	1.72	12.92	1.75	12.72	1.78	12.24	1.83
		30	28	15.66	1.68	15.18	1.73	14.65	1.78	14.39	1.82	14.17	1.85	13.65	1.90
		35	32	17.26	1.74	16.71	1.80	16.14	1.85	15.85	1.89	15.62	1.93	15.05	1.97
		40	36	18.14	1.79	17.63	1.85	17.06	1.91	16.77	1.95	16.53	1.98	15.93	2.03
		45	41	19.23	1.86	18.78	1.92	18.22	1.98	17.92	2.01	17.68	2.04	17.04	2.10
		47	43	19.67	1.88	19.23	1.94	18.69	2.01	18.38	2.04	18.14	2.07	17.48	2.13
		50	46	19.73	1.87	19.33	1.93	18.86	1.98	18.58	2.01	18.36	2.03	17.74	2.09
		55	51	19.83	1.85	19.50	1.90	19.14	1.94	18.92	1.96	18.74	1.98	18.19	2.02
		60	56	19.92	1.83	19.67	1.87	19.42	1.90	19.26	1.91	19.12	1.92	18.64	1.95
		63	59	19.98	1.82	19.76	1.85	19.59	1.87	19.46	1.88	19.35	1.89	18.90	1.91
		68	64	20.04	1.81	19.86	1.83	19.77	1.85	19.66	1.86	19.58	1.86	19.17	1.88
	9 + 12	-4	-4.4	5.40	1.53	4.90	1.59	4.94	1.61	4.90	1.62	4.86	1.63	4.63	1.69
		0	-0.4	7.49	1.57	7.00	1.63	6.92	1.65	6.83	1.67	6.75	1.68	6.46	1.74
		5	4.5	9.96	1.61	9.48	1.67	9.27	1.71	9.12	1.73	9.00	1.74	8.64	1.80
		10	9	11.62	1.65	11.15	1.71	10.84	1.75	10.66	1.78	10.51	1.80	10.09	1.85
		17	15	13.45	1.71	12.98	1.76	12.57	1.82	12.34	1.85	12.16	1.87	11.69	1.93
		20	19	14.55	1.75	14.09	1.80	13.62	1.86	13.37	1.90	13.17	1.92	12.67	1.98
		25	23	16.40	1.81	15.92	1.87	15.36	1.94	15.07	1.98	14.84	2.01	14.28	2.06
		30	28	18.27	1.89	17.70	1.95	17.09	2.01	16.78	2.06	16.53	2.09	15.92	2.14
		35	32	20.13	1.96	19.49	2.03	18.82	2.09	18.49	2.13	18.22	2.17	17.56	2.23
		40	36	21.16	2.02	20.56	2.09	19.91	2.15	19.56	2.19	19.28	2.23	18.59	2.29
		45	41	22.44	2.09	21.90	2.16	21.26	2.23	20.90	2.27	20.62	2.30	19.87	2.37
		47	43	22.95	2.12	22.44	2.19	21.80	2.26	21.44	2.30	21.16	2.33	20.39	2.40
		50	46	23.02	2.11	22.55	2.17	21.99	2.23	21.68	2.27	21.42	2.29	20.70	2.36
		55	51	23.13	2.09	22.75	2.14	22.33	2.19	22.07	2.21	21.86	2.23	21.22	2.28
		60	56	23.24	2.06	22.94	2.10	22.66	2.14	22.46	2.16	22.31	2.17	21.74	2.20
		63	59	23.31	2.05	23.06	2.08	22.86	2.11	22.70	2.12	22.57	2.13	22.05	2.16
		68	64	23.38	2.04	23.17	2.06	23.06	2.09	22.94	2.09	22.84	2.10	22.37	2.11
	12 + 12	-4	-4.4	6.17	1.68	5.61	1.74	5.64	1.76	5.60	1.77	5.56	1.78	5.29	1.85
		0	-0.4	8.56	1.72	8.00	1.78	7.90	1.81	7.80	1.83	7.72	1.84	7.38	1.90
		5	4.5	11.39	1.77	10.84	1.83	10.59	1.87	10.42	1.89	10.29	1.91	9.87	1.97
		10	9	13.28	1.81	12.74	1.88	12.39	1.92	12.18	1.95	12.01	1.97	11.53	2.03
		17	15	15.37	1.87	14.83	1.93	14.37	1.99	14.11	2.03	13.90	2.05	13.36	2.11
		20	19	16.63	1.91	16.10	1.97	15.56	2.04	15.28	2.08	15.04	2.11	14.47	2.17
		25	23	18.75	1.99	18.19	2.05	17.56	2.12	17.23	2.17	16.96	2.20	16.32	2.26
		30	28	20.87	2.07	20.23	2.14	19.53	2.20	19.18	2.25	18.89	2.29	18.19	2.35
		35	32	23.00	2.15	22.27	2.23	21.51	2.29	21.12	2.34	20.82	2.38	20.06	2.44
		40	36	24.17	2.21	23.50	2.29	22.75	2.36	22.35	2.40	22.04	2.44	21.24	2.51
		45	41	25.64	2.29	25.03	2.37	24.29	2.44	23.89	2.49	23.56	2.52	22.71	2.60
		47	43	26.23	2.32	25.64	2.40	24.91	2.48	24.50	2.52	24.17	2.55	23.30	2.63
		50	46	26.30	2.31	25.77	2.38	25.13	2.45	24.77	2.48	24.48	2.51	23.65	2.58
		55	51	26.43	2.28	25.99	2.34	25.51	2.40	25.22	2.42	24.99	2.45	24.25	2.50
		60	56	26.56	2.26	26.21	2.30	25.89	2.35	25.67	2.36	25.49	2.38	24.84	2.41
		63	59	26.64	2.25	26.35	2.28	26.12	2.32	25.94	2.33	25.80	2.34	25.20	2.37
		68	64	26.71	2.23	26.48	2.26	26.35	2.29	26.21	2.29	26.10	2.30	25.56	2.32

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 304: LMU30CHV Heating Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 18	-4	-4.4	6.95	1.84	6.31	1.92	6.35	1.94	6.30	1.95	6.25	1.96	5.96	2.03
		0	-0.4	9.63	1.89	9.00	1.96	8.89	1.99	8.78	2.01	8.69	2.02	8.31	2.09
		5	4.5	12.81	1.94	12.20	2.01	11.92	2.05	11.73	2.08	11.58	2.10	11.11	2.17
		10	9	14.95	1.99	14.34	2.06	13.94	2.11	13.70	2.14	13.51	2.17	12.98	2.23
		17	15	17.29	2.06	16.69	2.13	16.17	2.19	15.87	2.23	15.64	2.26	15.04	2.32
		20	19	18.72	2.10	18.12	2.17	17.52	2.24	17.19	2.28	16.93	2.32	16.29	2.38
		25	23	21.09	2.18	20.47	2.25	19.76	2.33	19.38	2.38	19.08	2.42	18.37	2.48
		30	28	23.49	2.27	22.76	2.35	21.98	2.42	21.58	2.48	21.26	2.52	20.47	2.58
		35	32	25.88	2.36	25.06	2.45	24.21	2.51	23.77	2.57	23.42	2.62	22.58	2.68
		40	36	27.20	2.43	26.44	2.52	25.60	2.59	25.15	2.64	24.80	2.69	23.90	2.76
		45	41	28.85	2.52	28.16	2.60	27.33	2.68	26.88	2.73	26.52	2.77	25.55	2.85
		47	43	29.51	2.55	28.85	2.64	28.03	2.72	27.57	2.77	27.20	2.81	26.21	2.89
		50	46	29.60	2.54	29.00	2.61	28.28	2.69	27.87	2.73	27.55	2.76	26.62	2.84
		55	51	29.74	2.51	29.25	2.57	28.71	2.63	28.38	2.66	28.12	2.69	27.28	2.75
		60	56	29.89	2.48	29.50	2.53	29.14	2.58	28.89	2.60	28.69	2.61	27.95	2.65
		63	59	29.97	2.47	29.65	2.51	29.39	2.55	29.19	2.56	29.03	2.57	28.35	2.60
		68	64	30.06	2.45	29.80	2.48	29.65	2.51	29.50	2.52	29.38	2.53	28.76	2.55
	12 + 18	-4	-4.4	7.48	1.99	6.79	2.07	6.84	2.09	6.78	2.11	6.74	2.12	6.42	2.20
		0	-0.4	10.37	2.04	9.69	2.12	9.58	2.15	9.46	2.17	9.36	2.18	8.95	2.26
		5	4.5	13.80	2.10	13.14	2.17	12.84	2.22	12.63	2.24	12.47	2.26	11.96	2.34
		10	9	16.10	2.15	15.44	2.22	15.02	2.28	14.76	2.31	14.55	2.34	13.98	2.41
		17	15	18.63	2.22	17.98	2.29	17.42	2.37	17.10	2.40	16.85	2.44	16.20	2.51
		20	19	20.16	2.27	19.52	2.34	18.87	2.42	18.52	2.47	18.24	2.50	17.54	2.57
		25	23	22.72	2.36	22.05	2.43	21.28	2.52	20.88	2.57	20.56	2.61	19.79	2.68
		30	28	25.31	2.46	24.52	2.54	23.68	2.61	23.25	2.67	22.90	2.72	22.06	2.79
		35	32	27.88	2.55	27.00	2.64	26.08	2.71	25.61	2.77	25.23	2.83	24.32	2.89
		40	36	29.31	2.63	28.48	2.72	27.57	2.79	27.10	2.85	26.71	2.90	25.75	2.98
		45	41	31.08	2.72	30.34	2.81	29.44	2.90	28.96	2.95	28.57	2.99	27.53	3.08
		47	43	31.79	2.76	31.08	2.85	30.19	2.94	29.70	2.99	29.31	3.03	28.24	3.12
		50	46	31.89	2.74	31.24	2.82	30.47	2.90	30.03	2.95	29.67	2.98	28.67	3.06
		55	51	32.04	2.71	31.51	2.78	30.93	2.84	30.57	2.88	30.29	2.90	29.39	2.96
		60	56	32.20	2.68	31.78	2.73	31.39	2.78	31.12	2.80	30.90	2.82	30.11	2.87
		63	59	32.29	2.66	31.94	2.71	31.66	2.75	31.45	2.76	31.27	2.77	30.55	2.81
	18 + 18	68	64	32.38	2.65	32.10	2.68	31.94	2.71	31.78	2.72	31.64	2.73	30.98	2.75
		-4	-4.4	8.31	1.99	7.55	2.07	7.60	2.09	7.54	2.11	7.48	2.12	7.13	2.20
		0	-0.4	11.52	2.04	10.77	2.12	10.65	2.15	10.51	2.17	10.40	2.18	9.94	2.26
		5	4.5	15.34	2.10	14.60	2.17	14.26	2.22	14.04	2.24	13.86	2.26	13.29	2.34
		10	9	17.89	2.15	17.16	2.22	16.69	2.28	16.40	2.31	16.17	2.34	15.53	2.41
		17	15	20.70	2.22	19.98	2.29	19.35	2.37	19.00	2.40	18.72	2.44	18.00	2.51
		20	19	22.40	2.27	21.69	2.34	20.96	2.42	20.58	2.47	20.26	2.50	19.49	2.57
		25	23	25.25	2.36	24.50	2.43	23.65	2.52	23.20	2.57	22.84	2.61	21.98	2.68
		30	28	28.12	2.46	27.25	2.54	26.31	2.61	25.83	2.67	25.44	2.72	24.51	2.79
		35	32	30.98	2.55	30.00	2.64	28.97	2.71	28.45	2.77	28.04	2.83	27.02	2.89
		40	36	32.56	2.63	31.65	2.72	30.64	2.79	30.11	2.85	29.68	2.90	28.61	2.98
		45	41	34.53	2.72	33.71	2.81	32.72	2.90	32.17	2.95	31.74	2.99	30.59	3.08
		47	43	35.32	2.76	34.53	2.85	33.55	2.94	33.00	2.99	32.56	3.03	31.38	3.12
		50	46	35.43	2.74	34.71	2.82	33.85	2.90	33.36	2.95	32.97	2.98	31.86	3.06
		55	51	35.60	2.71	35.01	2.78	34.36	2.84	33.97	2.88	33.65	2.90	32.66	2.96
		60	56	35.77	2.68	35.31	2.73	34.87	2.78	34.58	2.80	34.34	2.82	33.46	2.87
		63	59	35.88	2.66	35.49	2.71	35.18	2.75	34.94	2.76	34.75	2.77	33.94	2.81
		68	64	35.98	2.65	35.67	2.68	35.49	2.71	35.31	2.72	35.16	2.73	34.43	2.75

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 305: LMU30CHV Heating Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 9 + 9	-4	-4.4	6.95	1.76	6.31	1.83	6.35	1.85	6.30	1.86	6.25	1.87	5.96	1.94
		0	-0.4	9.63	1.80	9.00	1.87	8.89	1.90	8.78	1.91	8.69	1.93	8.31	2.00
		5	4.5	12.81	1.85	12.20	1.92	11.92	1.96	11.73	1.98	11.58	2.00	11.11	2.06
		10	9	14.95	1.90	14.34	1.96	13.94	2.01	13.70	2.04	13.51	2.06	12.98	2.13
		17	15	17.29	1.96	16.69	2.03	16.17	2.09	15.87	2.12	15.64	2.15	15.04	2.21
		20	19	18.72	2.01	18.12	2.07	17.52	2.14	17.19	2.18	16.93	2.21	16.29	2.27
		25	23	21.09	2.08	20.47	2.14	19.76	2.22	19.38	2.27	19.08	2.30	18.37	2.37
		30	28	23.49	2.17	22.76	2.24	21.98	2.31	21.58	2.36	21.26	2.40	20.47	2.46
		35	32	25.88	2.25	25.06	2.33	24.21	2.39	23.77	2.45	23.42	2.49	22.58	2.56
		40	36	27.20	2.32	26.44	2.40	25.60	2.47	25.15	2.52	24.80	2.56	23.90	2.63
		45	41	28.85	2.40	28.16	2.48	27.33	2.56	26.88	2.61	26.52	2.64	25.55	2.72
		47	43	29.51	2.43	28.85	2.51	28.03	2.60	27.57	2.64	27.20	2.68	26.21	2.76
		50	46	29.60	2.42	29.00	2.49	28.28	2.56	27.87	2.60	27.55	2.63	26.62	2.70
		55	51	29.74	2.39	29.25	2.45	28.71	2.51	28.38	2.54	28.12	2.56	27.28	2.62
		60	56	29.89	2.37	29.50	2.41	29.14	2.46	28.89	2.48	28.69	2.49	27.95	2.53
		63	59	29.97	2.35	29.65	2.39	29.39	2.43	29.19	2.44	29.03	2.45	28.35	2.48
		68	64	30.06	2.34	29.80	2.37	29.65	2.39	29.50	2.40	29.38	2.41	28.76	2.43
	9 + 9 + 12	-4	-4.4	7.48	1.87	6.79	1.95	6.84	1.97	6.78	1.98	6.74	1.99	6.42	2.06
		0	-0.4	10.37	1.92	9.69	1.99	9.58	2.02	9.46	2.04	9.36	2.05	8.95	2.12
		5	4.5	13.80	1.97	13.14	2.04	12.84	2.08	12.63	2.11	12.47	2.13	11.96	2.20
		10	9	16.10	2.02	15.44	2.09	15.02	2.14	14.76	2.17	14.55	2.20	13.98	2.27
		17	15	18.63	2.09	17.98	2.16	17.42	2.22	17.10	2.26	16.85	2.29	16.20	2.36
		20	19	20.16	2.13	19.52	2.20	18.87	2.28	18.52	2.32	18.24	2.35	17.54	2.42
		25	23	22.72	2.22	22.05	2.28	21.28	2.37	20.88	2.41	20.56	2.45	19.79	2.52
		30	28	25.31	2.31	24.52	2.38	23.68	2.46	23.25	2.51	22.90	2.55	22.06	2.62
		35	32	27.88	2.40	27.00	2.48	26.08	2.55	25.61	2.61	25.23	2.66	24.32	2.72
		40	36	29.31	2.47	28.48	2.55	27.57	2.63	27.10	2.68	26.71	2.73	25.75	2.80
		45	41	31.08	2.56	30.34	2.64	29.44	2.72	28.96	2.77	28.57	2.81	27.53	2.89
		47	43	31.79	2.59	31.08	2.68	30.19	2.76	29.70	2.81	29.31	2.85	28.24	2.93
		50	46	31.89	2.57	31.24	2.65	30.47	2.73	30.03	2.77	29.67	2.80	28.67	2.88
		55	51	32.04	2.55	31.51	2.61	30.93	2.67	30.57	2.70	30.29	2.73	29.39	2.79
		60	56	32.20	2.52	31.78	2.57	31.39	2.62	31.12	2.64	30.90	2.65	30.11	2.69
		63	59	32.29	2.50	31.94	2.54	31.66	2.58	31.45	2.60	31.27	2.61	30.55	2.64
		68	64	32.38	2.49	32.10	2.52	31.94	2.55	31.78	2.56	31.64	2.56	30.98	2.58
	9 + 12 + 12	-4	-4.4	8.31	1.87	7.55	1.95	7.60	1.97	7.54	1.98	7.48	1.99	7.13	2.06
		0	-0.4	11.52	1.92	10.77	1.99	10.65	2.02	10.51	2.04	10.40	2.05	9.94	2.12
		5	4.5	15.34	1.97	14.60	2.04	14.26	2.08	14.04	2.11	13.86	2.13	13.29	2.20
		10	9	17.89	2.02	17.16	2.09	16.69	2.14	16.40	2.17	16.17	2.20	15.53	2.27
		17	15	20.70	2.09	19.98	2.16	19.35	2.22	19.00	2.26	18.72	2.29	18.00	2.36
		20	19	22.40	2.13	21.69	2.20	20.96	2.28	20.58	2.32	20.26	2.35	19.49	2.42
		25	23	25.25	2.22	24.50	2.28	23.65	2.37	23.20	2.41	22.84	2.45	21.98	2.52
		30	28	28.12	2.31	27.25	2.38	26.31	2.46	25.83	2.51	25.44	2.55	24.51	2.62
		35	32	30.98	2.40	30.00	2.48	28.97	2.55	28.45	2.61	28.04	2.66	27.02	2.72
		40	36	32.56	2.47	31.65	2.55	30.64	2.63	30.11	2.68	29.68	2.73	28.61	2.80
		45	41	34.53	2.56	33.71	2.64	32.72	2.72	32.17	2.77	31.74	2.81	30.59	2.89
		47	43	35.32	2.59	34.53	2.68	33.55	2.76	33.00	2.81	32.56	2.85	31.38	2.93
		50	46	35.43	2.57	34.71	2.65	33.85	2.73	33.36	2.77	32.97	2.80	31.86	2.88
		55	51	35.60	2.55	35.01	2.61	34.36	2.67	33.97	2.70	33.65	2.73	32.66	2.79
		60	56	35.77	2.52	35.31	2.57	34.87	2.62	34.58	2.64	34.34	2.65	33.46	2.69
		63	59	35.88	2.50	35.49	2.54	35.18	2.58	34.94	2.60	34.75	2.61	33.94	2.64
		68	64	35.98	2.49	35.67	2.52	35.49	2.55	35.31	2.56	35.16	2.56	34.43	2.58

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 306: LMU30CHV Heating Capacity Table —Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 9 + 18	-4	-4.4	8.31	1.87	7.55	1.95	7.60	1.97	7.54	1.98	7.48	1.99	7.13	2.06
		0	-0.4	11.52	1.92	10.77	1.99	10.65	2.02	10.51	2.04	10.40	2.05	9.94	2.12
		5	4.5	15.34	1.97	14.60	2.04	14.26	2.08	14.04	2.11	13.86	2.13	13.29	2.20
		10	9	17.89	2.02	17.16	2.09	16.69	2.14	16.40	2.17	16.17	2.20	15.53	2.27
		17	15	20.70	2.09	19.98	2.16	19.35	2.22	19.00	2.26	18.72	2.29	18.00	2.36
		20	19	22.40	2.13	21.69	2.20	20.96	2.28	20.58	2.32	20.26	2.35	19.49	2.42
		25	23	25.25	2.22	24.50	2.28	23.65	2.37	23.20	2.41	22.84	2.45	21.98	2.52
		30	28	28.12	2.31	27.25	2.38	26.31	2.46	25.83	2.51	25.44	2.55	24.51	2.62
		35	32	30.98	2.40	30.00	2.48	28.97	2.55	28.45	2.61	28.04	2.66	27.02	2.72
		40	36	32.56	2.47	31.65	2.55	30.64	2.63	30.11	2.68	29.68	2.73	28.61	2.80
		45	41	34.53	2.56	33.71	2.64	32.72	2.72	32.17	2.77	31.74	2.81	30.59	2.89
		47	43	35.32	2.59	34.53	2.68	33.55	2.76	33.00	2.81	32.56	2.85	31.38	2.93
		50	46	35.43	2.57	34.71	2.65	33.85	2.73	33.36	2.77	32.97	2.80	31.86	2.88
		55	51	35.60	2.55	35.01	2.61	34.36	2.67	33.97	2.70	33.65	2.73	32.66	2.79
		60	56	35.77	2.52	35.31	2.57	34.87	2.62	34.58	2.64	34.34	2.65	33.46	2.69
		63	59	35.88	2.50	35.49	2.54	35.18	2.58	34.94	2.60	34.75	2.61	33.94	2.64
		68	64	35.98	2.49	35.67	2.52	35.49	2.55	35.31	2.56	35.16	2.56	34.43	2.58
	12 + 12 + 12	-4	-4.4	8.31	1.87	7.55	1.95	7.60	1.97	7.54	1.98	7.48	1.99	7.13	2.06
		0	-0.4	11.52	1.92	10.77	1.99	10.65	2.02	10.51	2.04	10.40	2.05	9.94	2.12
		5	4.5	15.34	1.97	14.60	2.04	14.26	2.08	14.04	2.11	13.86	2.13	13.29	2.20
		10	9	17.89	2.02	17.16	2.09	16.69	2.14	16.40	2.17	16.17	2.20	15.53	2.27
		17	15	20.70	2.09	19.98	2.16	19.35	2.22	19.00	2.26	18.72	2.29	18.00	2.36
		20	19	22.40	2.13	21.69	2.20	20.96	2.28	20.58	2.32	20.26	2.35	19.49	2.42
		25	23	25.25	2.22	24.50	2.28	23.65	2.37	23.20	2.41	22.84	2.45	21.98	2.52
		30	28	28.12	2.31	27.25	2.38	26.31	2.46	25.83	2.51	25.44	2.55	24.51	2.62
		35	32	30.98	2.40	30.00	2.48	28.97	2.55	28.45	2.61	28.04	2.66	27.02	2.72
		40	36	32.56	2.47	31.65	2.55	30.64	2.63	30.11	2.68	29.68	2.73	28.61	2.80
		45	41	34.53	2.56	33.71	2.64	32.72	2.72	32.17	2.77	31.74	2.81	30.59	2.89
		47	43	35.32	2.59	34.53	2.68	33.55	2.76	33.00	2.81	32.56	2.85	31.38	2.93
		50	46	35.43	2.57	34.71	2.65	33.85	2.73	33.36	2.77	32.97	2.80	31.86	2.88
		55	51	35.60	2.55	35.01	2.61	34.36	2.67	33.97	2.70	33.65	2.73	32.66	2.79
		60	56	35.77	2.52	35.31	2.57	34.87	2.62	34.58	2.64	34.34	2.65	33.46	2.69
		63	59	35.88	2.50	35.49	2.54	35.18	2.58	34.94	2.60	34.75	2.61	33.94	2.64
		68	64	35.98	2.49	35.67	2.52	35.49	2.55	35.31	2.56	35.16	2.56	34.43	2.58
	9 + 12 + 18	-4	-4.4	8.31	1.87	7.55	1.95	7.60	1.97	7.54	1.98	7.48	1.99	7.13	2.06
		0	-0.4	11.52	1.92	10.77	1.99	10.65	2.02	10.51	2.04	10.40	2.05	9.94	2.12
		5	4.5	15.34	1.97	14.60	2.04	14.26	2.08	14.04	2.11	13.86	2.13	13.29	2.20
		10	9	17.89	2.02	17.16	2.09	16.69	2.14	16.40	2.17	16.17	2.20	15.53	2.27
		17	15	20.70	2.09	19.98	2.16	19.35	2.22	19.00	2.26	18.72	2.29	18.00	2.36
		20	19	22.40	2.13	21.69	2.20	20.96	2.28	20.58	2.32	20.26	2.35	19.49	2.42
		25	23	25.25	2.22	24.50	2.28	23.65	2.37	23.20	2.41	22.84	2.45	21.98	2.52
		30	28	28.12	2.31	27.25	2.38	26.31	2.46	25.83	2.51	25.44	2.55	24.51	2.62
		35	32	30.98	2.40	30.00	2.48	28.97	2.55	28.45	2.61	28.04	2.66	27.02	2.72
		40	36	32.56	2.47	31.65	2.55	30.64	2.63	30.11	2.68	29.68	2.73	28.61	2.80
		45	41	34.53	2.56	33.71	2.64	32.72	2.72	32.17	2.77	31.74	2.81	30.59	2.89
		47	43	35.32	2.59	34.53	2.68	33.55	2.76	33.00	2.81	32.56	2.85	31.38	2.93
		50	46	35.43	2.57	34.71	2.65	33.85	2.73	33.36	2.77	32.97	2.80	31.86	2.88
		55	51	35.60	2.55	35.01	2.61	34.36	2.67	33.97	2.70	33.65	2.73	32.66	2.79
		60	56	35.77	2.52	35.31	2.57	34.87	2.62	34.58	2.64	34.34	2.65	33.46	2.69
		63	59	35.88	2.50	35.49	2.54	35.18	2.58	34.94	2.60	34.75	2.61	33.94	2.64
		68	64	35.98	2.49	35.67	2.52	35.49	2.55	35.31	2.56	35.16	2.56	34.43	2.58

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 307: LMU30CHV Heating Capacity Table —Ducted, continued / Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 9 + 9	-4	-4.4	8.31	1.86	7.55	1.93	7.60	1.95	7.54	1.96	7.48	1.97	7.13	2.05
		0	-0.4	11.52	1.90	10.77	1.97	10.65	2.01	10.51	2.02	10.40	2.04	9.94	2.11
		5	4.5	15.34	1.96	14.60	2.03	14.26	2.07	14.04	2.09	13.86	2.11	13.29	2.18
		10	9	17.89	2.01	17.16	2.08	16.69	2.13	16.40	2.16	16.17	2.18	15.53	2.25
		17	15	20.70	2.07	19.98	2.14	19.35	2.21	19.00	2.24	18.72	2.27	18.00	2.34
		20	19	22.40	2.12	21.69	2.18	20.96	2.26	20.58	2.30	20.26	2.33	19.49	2.40
		25	23	25.25	2.20	24.50	2.26	23.65	2.35	23.20	2.40	22.84	2.44	21.98	2.50
		30	28	28.12	2.29	27.25	2.37	26.31	2.44	25.83	2.49	25.44	2.54	24.51	2.60
		35	32	30.98	2.38	30.00	2.47	28.97	2.53	28.45	2.59	28.04	2.64	27.02	2.70
		40	36	32.56	2.45	31.65	2.54	30.64	2.61	30.11	2.66	29.68	2.71	28.61	2.78
		45	41	34.53	2.54	33.71	2.62	32.72	2.70	32.17	2.75	31.74	2.79	30.59	2.87
		47	43	35.32	2.57	34.53	2.66	33.55	2.74	33.00	2.79	32.56	2.83	31.38	2.91
		50	46	35.43	2.56	34.71	2.63	33.85	2.71	33.36	2.75	32.97	2.78	31.86	2.86
		55	51	35.60	2.53	35.01	2.59	34.36	2.65	33.97	2.68	33.65	2.71	32.66	2.77
		60	56	35.77	2.50	35.31	2.55	34.87	2.60	34.58	2.62	34.34	2.63	33.46	2.67
		63	59	35.88	2.49	35.49	2.53	35.18	2.56	34.94	2.58	34.75	2.59	33.94	2.62
		68	64	35.98	2.47	35.67	2.50	35.49	2.53	35.31	2.54	35.16	2.54	34.43	2.56
	9 + 9 + 9 + 12	-4	-4.4	8.31	1.86	7.55	1.93	7.60	1.95	7.54	1.96	7.48	1.97	7.13	2.05
		0	-0.4	11.52	1.90	10.77	1.97	10.65	2.01	10.51	2.02	10.40	2.04	9.94	2.11
		5	4.5	15.34	1.96	14.60	2.03	14.26	2.07	14.04	2.09	13.86	2.11	13.29	2.18
		10	9	17.89	2.01	17.16	2.08	16.69	2.13	16.40	2.16	16.17	2.18	15.53	2.25
		17	15	20.70	2.07	19.98	2.14	19.35	2.21	19.00	2.24	18.72	2.27	18.00	2.34
		20	19	22.40	2.12	21.69	2.18	20.96	2.26	20.58	2.30	20.26	2.33	19.49	2.40
		25	23	25.25	2.20	24.50	2.26	23.65	2.35	23.20	2.40	22.84	2.44	21.98	2.50
		30	28	28.12	2.29	27.25	2.37	26.31	2.44	25.83	2.49	25.44	2.54	24.51	2.60
		35	32	30.98	2.38	30.00	2.47	28.97	2.53	28.45	2.59	28.04	2.64	27.02	2.70
		40	36	32.56	2.45	31.65	2.54	30.64	2.61	30.11	2.66	29.68	2.71	28.61	2.78
		45	41	34.53	2.54	33.71	2.62	32.72	2.70	32.17	2.75	31.74	2.79	30.59	2.87
		47	43	35.32	2.57	34.53	2.66	33.55	2.74	33.00	2.79	32.56	2.83	31.38	2.91
		50	46	35.43	2.56	34.71	2.63	33.85	2.71	33.36	2.75	32.97	2.78	31.86	2.86
		55	51	35.60	2.53	35.01	2.59	34.36	2.65	33.97	2.68	33.65	2.71	32.66	2.77
		60	56	35.77	2.50	35.31	2.55	34.87	2.60	34.58	2.62	34.34	2.63	33.46	2.67
		63	59	35.88	2.49	35.49	2.53	35.18	2.56	34.94	2.58	34.75	2.59	33.94	2.62
		68	64	35.98	2.47	35.67	2.50	35.49	2.53	35.31	2.54	35.16	2.54	34.43	2.56
Two (2) Mixed Indoor Units	7 + 9	-4	-4.4	5.02	1.22	4.59	1.27	4.60	1.28	4.56	1.29	4.52	1.29	4.31	1.34
		0	-0.4	6.56	1.24	6.15	1.29	6.07	1.31	5.99	1.32	5.92	1.33	5.67	1.38
		5	4.5	8.40	1.27	8.00	1.31	7.81	1.34	7.69	1.36	7.59	1.37	7.28	1.42
		10	9	9.63	1.30	9.24	1.34	8.98	1.37	8.83	1.39	8.70	1.41	8.36	1.45
		17	15	10.98	1.33	10.60	1.37	10.26	1.41	10.08	1.44	9.93	1.46	9.55	1.50
		20	19	11.80	1.35	11.42	1.39	11.04	1.44	10.84	1.47	10.67	1.49	10.27	1.53
		25	23	13.17	1.40	12.78	1.44	12.34	1.49	12.10	1.52	11.92	1.55	11.47	1.59
		30	28	14.55	1.44	14.10	1.49	13.62	1.54	13.37	1.57	13.17	1.60	12.68	1.64
		35	32	15.93	1.49	15.43	1.55	14.90	1.59	14.63	1.62	14.42	1.65	13.90	1.69
		40	36	16.74	1.54	16.27	1.59	15.76	1.64	15.48	1.67	15.26	1.70	14.71	1.74
		45	41	17.76	1.59	17.33	1.65	16.82	1.70	16.54	1.73	16.32	1.75	15.73	1.80
		47	43	18.17	1.61	17.76	1.67	17.25	1.72	16.97	1.75	16.74	1.77	16.14	1.83
		50	46	18.22	1.60	17.85	1.65	17.41	1.70	17.16	1.72	16.96	1.75	16.38	1.79
		55	51	18.31	1.59	18.00	1.63	17.67	1.66	17.47	1.68	17.31	1.70	16.79	1.73
		60	56	18.40	1.57	18.16	1.60	17.93	1.63	17.78	1.64	17.66	1.65	17.21	1.68
		63	59	18.45	1.56	18.25	1.58	18.09	1.61	17.97	1.62	17.87	1.62	17.45	1.64
		68	64	18.50	1.55	18.34	1.57	18.25	1.59	18.16	1.59	18.08	1.60	17.70	1.61

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 308: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 9	-4	-4.4	5.64	1.34	5.17	1.40	5.18	1.41	5.12	1.42	5.08	1.43	4.85	1.48
		0	-0.4	7.38	1.37	6.92	1.42	6.83	1.44	6.73	1.46	6.66	1.47	6.37	1.52
		5	4.5	9.45	1.40	9.00	1.45	8.79	1.48	8.65	1.50	8.53	1.51	8.19	1.56
		10	9	10.83	1.43	10.39	1.48	10.10	1.51	9.93	1.54	9.79	1.55	9.40	1.60
		17	15	12.35	1.47	11.92	1.51	11.55	1.56	11.34	1.59	11.17	1.61	10.74	1.65
		20	19	13.27	1.49	12.85	1.54	12.42	1.59	12.19	1.62	12.01	1.64	11.55	1.69
		25	23	14.82	1.54	14.38	1.58	13.88	1.64	13.61	1.68	13.40	1.70	12.90	1.75
		30	28	16.37	1.59	15.86	1.65	15.32	1.70	15.04	1.73	14.81	1.76	14.27	1.81
		35	32	17.92	1.65	17.35	1.71	16.76	1.75	16.46	1.79	16.22	1.82	15.63	1.87
		40	36	18.84	1.70	18.31	1.75	17.72	1.80	17.42	1.84	17.17	1.87	16.55	1.92
		45	41	19.98	1.76	19.50	1.81	18.93	1.87	18.61	1.90	18.36	1.93	17.69	1.99
		47	43	20.43	1.78	19.98	1.84	19.41	1.90	19.09	1.93	18.84	1.96	18.15	2.01
		50	46	20.49	1.77	20.08	1.82	19.58	1.87	19.30	1.90	19.07	1.92	18.43	1.98
		55	51	20.59	1.75	20.25	1.79	19.88	1.84	19.65	1.86	19.47	1.87	18.89	1.91
		60	56	20.69	1.73	20.43	1.76	20.17	1.80	20.00	1.81	19.86	1.82	19.36	1.85
		63	59	20.75	1.72	20.53	1.75	20.35	1.77	20.21	1.78	20.10	1.79	19.63	1.81
		68	64	20.81	1.71	20.63	1.73	20.53	1.75	20.42	1.76	20.34	1.76	19.92	1.77
	7 + 12	-4	-4.4	5.96	1.40	5.45	1.45	5.46	1.47	5.41	1.48	5.37	1.49	5.12	1.54
		0	-0.4	7.79	1.42	7.30	1.48	7.20	1.50	7.11	1.52	7.03	1.53	6.73	1.58
		5	4.5	9.97	1.46	9.50	1.51	9.28	1.54	9.13	1.56	9.01	1.57	8.64	1.63
		10	9	11.43	1.49	10.97	1.54	10.66	1.58	10.48	1.60	10.33	1.62	9.93	1.67
		17	15	13.04	1.53	12.58	1.58	12.19	1.63	11.97	1.65	11.79	1.67	11.34	1.72
		20	19	14.01	1.55	13.56	1.60	13.11	1.66	12.87	1.69	12.67	1.71	12.19	1.76
		25	23	15.64	1.60	15.17	1.65	14.65	1.71	14.37	1.75	14.15	1.77	13.62	1.82
		30	28	17.28	1.66	16.74	1.71	16.17	1.77	15.87	1.81	15.63	1.84	15.06	1.88
		35	32	18.92	1.72	18.32	1.78	17.69	1.82	17.37	1.87	17.12	1.90	16.50	1.95
		40	36	19.88	1.77	19.32	1.83	18.71	1.88	18.38	1.92	18.12	1.95	17.47	2.00
		45	41	21.09	1.83	20.58	1.89	19.98	1.95	19.65	1.98	19.38	2.01	18.68	2.07
		47	43	21.57	1.85	21.09	1.91	20.48	1.98	20.15	2.01	19.88	2.04	19.16	2.10
		50	46	21.63	1.84	21.20	1.90	20.67	1.95	20.37	1.98	20.13	2.00	19.45	2.06
		55	51	21.74	1.82	21.38	1.87	20.98	1.91	20.74	1.93	20.55	1.95	19.94	1.99
		60	56	21.84	1.80	21.56	1.84	21.29	1.87	21.11	1.89	20.97	1.90	20.43	1.93
		63	59	21.91	1.79	21.67	1.82	21.48	1.85	21.33	1.86	21.22	1.86	20.72	1.89
		68	64	21.97	1.78	21.78	1.80	21.67	1.82	21.56	1.83	21.47	1.83	21.02	1.85
	9 + 12	-4	-4.4	6.58	1.52	6.03	1.58	6.04	1.59	5.98	1.61	5.93	1.61	5.65	1.67
		0	-0.4	8.61	1.54	8.07	1.60	7.96	1.63	7.86	1.64	7.77	1.65	7.44	1.71
		5	4.5	11.02	1.58	10.49	1.64	10.25	1.67	10.09	1.69	9.96	1.71	9.55	1.76
		10	9	12.63	1.61	12.12	1.67	11.78	1.71	11.58	1.73	11.42	1.75	10.97	1.81
		17	15	14.41	1.66	13.91	1.71	13.47	1.76	13.22	1.79	13.03	1.82	12.53	1.87
		20	19	15.48	1.69	14.99	1.74	14.49	1.80	14.22	1.83	14.01	1.86	13.47	1.91
		25	23	17.28	1.74	16.77	1.79	16.19	1.86	15.88	1.89	15.64	1.92	15.05	1.98
		30	28	19.10	1.80	18.51	1.86	17.87	1.92	17.54	1.96	17.28	1.99	16.64	2.04
		35	32	20.91	1.86	20.24	1.93	19.55	1.98	19.20	2.02	18.92	2.06	18.24	2.11
		40	36	21.97	1.92	21.36	1.98	20.68	2.04	20.32	2.08	20.03	2.11	19.31	2.17
		45	41	23.31	1.98	22.75	2.05	22.08	2.11	21.71	2.15	21.42	2.18	20.64	2.25
		47	43	23.84	2.01	23.31	2.08	22.64	2.14	22.27	2.18	21.97	2.21	21.17	2.28
		50	46	23.91	2.00	23.43	2.06	22.85	2.12	22.52	2.15	22.25	2.17	21.50	2.23
		55	51	24.03	1.98	23.63	2.03	23.19	2.07	22.92	2.10	22.71	2.12	22.04	2.16
		60	56	24.14	1.96	23.83	1.99	23.53	2.03	23.33	2.04	23.17	2.06	22.58	2.09
		63	59	24.21	1.94	23.95	1.97	23.74	2.00	23.58	2.01	23.45	2.02	22.90	2.05
		68	64	24.28	1.93	24.07	1.95	23.95	1.98	23.83	1.98	23.73	1.99	23.23	2.00

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 309: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 15	-4	-4.4	7.52	1.66	6.89	1.72	6.90	1.74	6.83	1.75	6.78	1.76	6.46	1.83
		0	-0.4	9.84	1.69	9.22	1.75	9.10	1.78	8.98	1.79	8.88	1.81	8.50	1.87
		5	4.5	12.59	1.73	11.99	1.79	11.71	1.83	11.53	1.85	11.38	1.86	10.92	1.92
		10	9	14.44	1.76	13.85	1.82	13.47	1.87	13.23	1.89	13.05	1.91	12.54	1.97
		17	15	16.47	1.81	15.89	1.87	15.39	1.92	15.11	1.96	14.89	1.98	14.32	2.04
		20	19	17.69	1.84	17.13	1.90	16.56	1.96	16.25	2.00	16.01	2.03	15.40	2.08
		25	23	19.75	1.90	19.17	1.95	18.50	2.03	18.15	2.07	17.87	2.10	17.20	2.16
		30	28	21.82	1.97	21.15	2.03	20.42	2.09	20.05	2.14	19.75	2.18	19.02	2.23
		35	32	23.89	2.03	23.13	2.10	22.35	2.16	21.94	2.21	21.62	2.25	20.84	2.30
		40	36	25.11	2.09	24.41	2.16	23.63	2.22	23.22	2.27	22.89	2.31	22.06	2.37
		45	41	26.63	2.16	26.00	2.24	25.23	2.31	24.81	2.35	24.48	2.38	23.59	2.45
		47	43	27.24	2.19	26.63	2.27	25.87	2.34	25.45	2.38	25.11	2.41	24.20	2.48
		50	46	27.32	2.18	26.77	2.25	26.11	2.31	25.73	2.35	25.43	2.37	24.57	2.44
		55	51	27.46	2.16	27.00	2.21	26.50	2.26	26.20	2.29	25.95	2.31	25.19	2.36
		60	56	27.59	2.13	27.23	2.18	26.90	2.22	26.67	2.23	26.48	2.25	25.80	2.28
		63	59	27.67	2.12	27.37	2.15	27.13	2.19	26.95	2.20	26.80	2.21	26.17	2.23
		68	64	27.75	2.11	27.51	2.13	27.37	2.16	27.23	2.16	27.12	2.17	26.55	2.19
	12 + 12	-4	-4.4	7.52	1.66	6.89	1.72	6.90	1.74	6.83	1.75	6.78	1.76	6.46	1.83
		0	-0.4	9.84	1.69	9.22	1.75	9.10	1.78	8.98	1.79	8.88	1.81	8.50	1.87
		5	4.5	12.59	1.73	11.99	1.79	11.71	1.83	11.53	1.85	11.38	1.86	10.92	1.92
		10	9	14.44	1.76	13.85	1.82	13.47	1.87	13.23	1.89	13.05	1.91	12.54	1.97
		17	15	16.47	1.81	15.89	1.87	15.39	1.92	15.11	1.96	14.89	1.98	14.32	2.04
		20	19	17.69	1.84	17.13	1.90	16.56	1.96	16.25	2.00	16.01	2.03	15.40	2.08
		25	23	19.75	1.90	19.17	1.95	18.50	2.03	18.15	2.07	17.87	2.10	17.20	2.16
		30	28	21.82	1.97	21.15	2.03	20.42	2.09	20.05	2.14	19.75	2.18	19.02	2.23
		35	32	23.89	2.03	23.13	2.10	22.35	2.16	21.94	2.21	21.62	2.25	20.84	2.30
		40	36	25.11	2.09	24.41	2.16	23.63	2.22	23.22	2.27	22.89	2.31	22.06	2.37
		45	41	26.63	2.16	26.00	2.24	25.23	2.31	24.81	2.35	24.48	2.38	23.59	2.45
		47	43	27.24	2.19	26.63	2.27	25.87	2.34	25.45	2.38	25.11	2.41	24.20	2.48
		50	46	27.32	2.18	26.77	2.25	26.11	2.31	25.73	2.35	25.43	2.37	24.57	2.44
		55	51	27.46	2.16	27.00	2.21	26.50	2.26	26.20	2.29	25.95	2.31	25.19	2.36
		60	56	27.59	2.13	27.23	2.18	26.90	2.22	26.67	2.23	26.48	2.25	25.80	2.28
		63	59	27.67	2.12	27.37	2.15	27.13	2.19	26.95	2.20	26.80	2.21	26.17	2.23
		68	64	27.75	2.11	27.51	2.13	27.37	2.16	27.23	2.16	27.12	2.17	26.55	2.19
	7 + 18	-4	-4.4	7.84	1.71	7.17	1.78	7.19	1.80	7.12	1.81	7.06	1.82	6.73	1.89
		0	-0.4	10.25	1.74	9.60	1.81	9.48	1.84	9.35	1.85	9.25	1.87	8.85	1.93
		5	4.5	13.12	1.78	12.49	1.85	12.20	1.89	12.01	1.91	11.85	1.93	11.37	1.99
		10	9	15.04	1.82	14.43	1.88	14.03	1.93	13.79	1.96	13.59	1.98	13.06	2.04
		17	15	17.15	1.87	16.55	1.93	16.03	1.99	15.74	2.02	15.51	2.05	14.91	2.11
		20	19	18.43	1.90	17.84	1.96	17.25	2.03	16.93	2.07	16.67	2.10	16.04	2.15
		25	23	20.57	1.96	19.96	2.02	19.27	2.10	18.91	2.14	18.61	2.17	17.91	2.23
		30	28	22.73	2.03	22.03	2.10	21.27	2.16	20.88	2.21	20.57	2.25	19.81	2.30
		35	32	24.89	2.10	24.10	2.17	23.28	2.23	22.86	2.28	22.52	2.32	21.71	2.38
		40	36	26.16	2.16	25.42	2.24	24.61	2.30	24.19	2.35	23.84	2.39	22.98	2.45
		45	41	27.74	2.24	27.08	2.31	26.28	2.38	25.85	2.43	25.50	2.46	24.57	2.53
		47	43	28.38	2.27	27.74	2.34	26.95	2.42	26.51	2.46	26.16	2.49	25.21	2.57
		50	46	28.46	2.25	27.89	2.32	27.20	2.39	26.80	2.42	26.49	2.45	25.59	2.52
		55	51	28.60	2.23	28.13	2.29	27.61	2.34	27.29	2.37	27.04	2.39	26.24	2.44
		60	56	28.74	2.21	28.36	2.25	28.02	2.29	27.78	2.31	27.58	2.32	26.88	2.36
		63	59	28.82	2.19	28.51	2.23	28.26	2.26	28.07	2.27	27.91	2.28	27.26	2.31
		68	64	28.91	2.18	28.65	2.21	28.51	2.23	28.36	2.24	28.25	2.24	27.66	2.26

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 310: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 18	-4	-4.4	8.46	1.82	7.75	1.89	7.76	1.92	7.68	1.93	7.62	1.94	7.27	2.01
		0	-0.4	11.07	1.86	10.37	1.93	10.24	1.96	10.10	1.98	9.99	1.99	9.56	2.06
		5	4.5	14.17	1.90	13.49	1.97	13.18	2.01	12.97	2.03	12.80	2.05	12.28	2.12
		10	9	16.24	1.94	15.58	2.01	15.15	2.06	14.89	2.08	14.68	2.11	14.10	2.17
		17	15	18.52	1.99	17.88	2.05	17.32	2.12	17.00	2.15	16.75	2.18	16.11	2.25
		20	19	19.91	2.03	19.27	2.09	18.63	2.16	18.28	2.20	18.01	2.23	17.32	2.29
		25	23	22.22	2.09	21.56	2.15	20.81	2.23	20.42	2.28	20.10	2.31	19.35	2.37
		30	28	24.55	2.16	23.79	2.23	22.97	2.30	22.55	2.35	22.21	2.39	21.40	2.45
		35	32	26.88	2.24	26.02	2.32	25.14	2.38	24.69	2.43	24.32	2.48	23.45	2.54
		40	36	28.25	2.30	27.46	2.38	26.58	2.45	26.12	2.50	25.75	2.54	24.82	2.61
		45	41	29.96	2.38	29.25	2.46	28.38	2.54	27.91	2.59	27.54	2.62	26.54	2.70
		47	43	30.65	2.42	29.96	2.50	29.11	2.58	28.63	2.62	28.25	2.66	27.22	2.74
		50	46	30.74	2.40	30.12	2.47	29.37	2.54	28.95	2.58	28.60	2.61	27.64	2.68
		55	51	30.89	2.38	30.37	2.43	29.81	2.49	29.47	2.52	29.20	2.54	28.33	2.60
		60	56	31.04	2.35	30.63	2.40	30.26	2.44	30.00	2.46	29.79	2.47	29.03	2.51
		63	59	31.13	2.33	30.79	2.37	30.52	2.41	30.31	2.42	30.15	2.43	29.44	2.46
		68	64	31.22	2.32	30.94	2.35	30.79	2.38	30.63	2.38	30.50	2.39	29.87	2.41
	12 + 15	-4	-4.4	8.46	1.82	7.75	1.89	7.76	1.92	7.68	1.93	7.62	1.94	7.27	2.01
		0	-0.4	11.07	1.86	10.37	1.93	10.24	1.96	10.10	1.98	9.99	1.99	9.56	2.06
		5	4.5	14.17	1.90	13.49	1.97	13.18	2.01	12.97	2.03	12.80	2.05	12.28	2.12
		10	9	16.24	1.94	15.58	2.01	15.15	2.06	14.89	2.08	14.68	2.11	14.10	2.17
		17	15	18.52	1.99	17.88	2.05	17.32	2.12	17.00	2.15	16.75	2.18	16.11	2.25
		20	19	19.91	2.03	19.27	2.09	18.63	2.16	18.28	2.20	18.01	2.23	17.32	2.29
		25	23	22.22	2.09	21.56	2.15	20.81	2.23	20.42	2.28	20.10	2.31	19.35	2.37
		30	28	24.55	2.16	23.79	2.23	22.97	2.30	22.55	2.35	22.21	2.39	21.40	2.45
		35	32	26.88	2.24	26.02	2.32	25.14	2.38	24.69	2.43	24.32	2.48	23.45	2.54
		40	36	28.25	2.30	27.46	2.38	26.58	2.45	26.12	2.50	25.75	2.54	24.82	2.61
		45	41	29.96	2.38	29.25	2.46	28.38	2.54	27.91	2.59	27.54	2.62	26.54	2.70
		47	43	30.65	2.42	29.96	2.50	29.11	2.58	28.63	2.62	28.25	2.66	27.22	2.74
		50	46	30.74	2.40	30.12	2.47	29.37	2.54	28.95	2.58	28.60	2.61	27.64	2.68
		55	51	30.89	2.38	30.37	2.43	29.81	2.49	29.47	2.52	29.20	2.54	28.33	2.60
		60	56	31.04	2.35	30.63	2.40	30.26	2.44	30.00	2.46	29.79	2.47	29.03	2.51
		63	59	31.13	2.33	30.79	2.37	30.52	2.41	30.31	2.42	30.15	2.43	29.44	2.46
		68	64	31.22	2.32	30.94	2.35	30.79	2.38	30.63	2.38	30.50	2.39	29.87	2.41
	12 + 18	-4	-4.4	9.12	1.97	8.35	2.05	8.36	2.07	8.28	2.08	8.21	2.09	7.83	2.17
		0	-0.4	11.93	2.01	11.18	2.08	11.03	2.12	10.88	2.13	10.76	2.15	10.30	2.22
		5	4.5	15.27	2.05	14.54	2.13	14.20	2.17	13.97	2.19	13.79	2.21	13.23	2.29
		10	9	17.50	2.09	16.79	2.17	16.32	2.22	16.04	2.25	15.82	2.28	15.20	2.35
		17	15	19.96	2.15	19.27	2.22	18.66	2.29	18.32	2.33	18.05	2.36	17.36	2.43
		20	19	21.45	2.19	20.77	2.26	20.07	2.33	19.70	2.38	19.40	2.41	18.66	2.48
		25	23	23.94	2.26	23.23	2.32	22.42	2.41	22.00	2.46	21.66	2.50	20.85	2.56
		30	28	26.45	2.34	25.64	2.41	24.75	2.49	24.30	2.54	23.94	2.59	23.06	2.65
		35	32	28.96	2.42	28.04	2.50	27.09	2.57	26.60	2.63	26.21	2.67	25.26	2.74
		40	36	30.44	2.49	29.58	2.57	28.64	2.64	28.15	2.70	27.75	2.74	26.74	2.82
		45	41	32.28	2.57	31.51	2.66	30.59	2.74	30.08	2.79	29.67	2.83	28.59	2.92
		47	43	33.02	2.61	32.28	2.70	31.36	2.78	30.85	2.83	30.44	2.87	29.33	2.95
		50	46	33.12	2.59	32.45	2.67	31.65	2.75	31.19	2.79	30.82	2.82	29.78	2.90
		55	51	33.28	2.57	32.73	2.63	32.13	2.69	31.76	2.72	31.46	2.75	30.53	2.81
		60	56	33.44	2.54	33.01	2.59	32.60	2.63	32.32	2.65	32.10	2.67	31.28	2.71
		63	59	33.54	2.52	33.17	2.56	32.89	2.60	32.66	2.61	32.48	2.62	31.73	2.66
		68	64	33.64	2.51	33.34	2.54	33.18	2.57	33.01	2.57	32.87	2.58	32.18	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 311: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 24	-4	-4.4	9.29	1.97	8.50	2.05	8.52	2.07	8.44	2.08	8.37	2.09	7.98	2.17
		0	-0.4	12.15	2.01	11.39	2.08	11.24	2.12	11.09	2.13	10.97	2.15	10.49	2.22
		5	4.5	15.55	2.05	14.81	2.13	14.47	2.17	14.24	2.19	14.05	2.21	13.48	2.29
		10	9	17.83	2.09	17.10	2.17	16.63	2.22	16.34	2.25	16.12	2.28	15.48	2.35
		17	15	20.33	2.15	19.63	2.22	19.01	2.29	18.66	2.33	18.39	2.36	17.68	2.43
		20	19	21.85	2.19	21.16	2.26	20.45	2.33	20.07	2.38	19.77	2.41	19.02	2.48
		25	23	24.39	2.26	23.67	2.32	22.85	2.41	22.41	2.46	22.07	2.50	21.24	2.56
		30	28	26.95	2.34	26.12	2.41	25.22	2.49	24.76	2.54	24.39	2.59	23.49	2.65
		35	32	29.51	2.42	28.57	2.50	27.60	2.57	27.10	2.63	26.70	2.67	25.74	2.74
		40	36	31.01	2.49	30.14	2.57	29.18	2.64	28.67	2.70	28.27	2.74	27.25	2.82
		45	41	32.89	2.57	32.11	2.66	31.16	2.74	30.64	2.79	30.23	2.83	29.13	2.92
		47	43	33.64	2.61	32.89	2.70	31.95	2.78	31.43	2.83	31.01	2.87	29.88	2.95
		50	46	33.74	2.59	33.06	2.67	32.24	2.75	31.78	2.79	31.40	2.82	30.34	2.90
		55	51	33.91	2.57	33.35	2.63	32.73	2.69	32.35	2.72	32.05	2.75	31.10	2.81
		60	56	34.07	2.54	33.63	2.59	33.21	2.63	32.93	2.65	32.70	2.67	31.87	2.71
		63	59	34.17	2.52	33.80	2.56	33.51	2.60	33.28	2.61	33.09	2.62	32.32	2.66
		68	64	34.27	2.51	33.97	2.54	33.80	2.57	33.63	2.57	33.49	2.58	32.79	2.60
	9 + 24*	-4	-4.4	9.61	1.97	8.79	2.05	8.81	2.07	8.72	2.08	8.65	2.09	8.25	2.17
		0	-0.4	12.57	2.01	11.77	2.08	11.62	2.12	11.46	2.13	11.34	2.15	10.85	2.22
		5	4.5	16.08	2.05	15.32	2.13	14.96	2.17	14.72	2.19	14.53	2.21	13.94	2.29
		10	9	18.44	2.09	17.69	2.17	17.20	2.22	16.90	2.25	16.67	2.28	16.01	2.35
		17	15	21.03	2.15	20.30	2.22	19.66	2.29	19.30	2.33	19.02	2.36	18.28	2.43
		20	19	22.60	2.19	21.88	2.26	21.15	2.33	20.75	2.38	20.44	2.41	19.66	2.48
		25	23	25.22	2.26	24.48	2.32	23.62	2.41	23.18	2.46	22.82	2.50	21.96	2.56
		30	28	27.87	2.34	27.01	2.41	26.08	2.49	25.60	2.54	25.22	2.59	24.29	2.65
		35	32	30.51	2.42	29.54	2.50	28.54	2.57	28.02	2.63	27.61	2.67	26.61	2.74
		40	36	32.07	2.49	31.17	2.57	30.17	2.64	29.65	2.70	29.23	2.74	28.17	2.82
		45	41	34.01	2.57	33.20	2.66	32.22	2.74	31.69	2.79	31.26	2.83	30.12	2.92
		47	43	34.79	2.61	34.01	2.70	33.04	2.78	32.50	2.83	32.07	2.87	30.90	2.95
		50	46	34.89	2.59	34.19	2.67	33.34	2.75	32.86	2.79	32.47	2.82	31.38	2.90
		55	51	35.06	2.57	34.48	2.63	33.84	2.69	33.45	2.72	33.14	2.75	32.16	2.81
		60	56	35.23	2.54	34.77	2.59	34.35	2.63	34.05	2.65	33.82	2.67	32.95	2.71
		63	59	35.33	2.52	34.95	2.56	34.65	2.60	34.41	2.61	34.22	2.62	33.42	2.66
		68	64	35.44	2.51	35.13	2.54	34.95	2.57	34.77	2.57	34.63	2.58	33.90	2.60
	15 + 18	-4	-4.4	9.61	1.97	8.79	2.05	8.81	2.07	8.72	2.08	8.65	2.09	8.25	2.17
		0	-0.4	12.57	2.01	11.77	2.08	11.62	2.12	11.46	2.13	11.34	2.15	10.85	2.22
		5	4.5	16.08	2.05	15.32	2.13	14.96	2.17	14.72	2.19	14.53	2.21	13.94	2.29
		10	9	18.44	2.09	17.69	2.17	17.20	2.22	16.90	2.25	16.67	2.28	16.01	2.35
		17	15	21.03	2.15	20.30	2.22	19.66	2.29	19.30	2.33	19.02	2.36	18.28	2.43
		20	19	22.60	2.19	21.88	2.26	21.15	2.33	20.75	2.38	20.44	2.41	19.66	2.48
		25	23	25.22	2.26	24.48	2.32	23.62	2.41	23.18	2.46	22.82	2.50	21.96	2.56
		30	28	27.87	2.34	27.01	2.41	26.08	2.49	25.60	2.54	25.22	2.59	24.29	2.65
		35	32	30.51	2.42	29.54	2.50	28.54	2.57	28.02	2.63	27.61	2.67	26.61	2.74
		40	36	32.07	2.49	31.17	2.57	30.17	2.64	29.65	2.70	29.23	2.74	28.17	2.82
		45	41	34.01	2.57	33.20	2.66	32.22	2.74	31.69	2.79	31.26	2.83	30.12	2.92
		47	43	34.79	2.61	34.01	2.70	33.04	2.78	32.50	2.83	32.07	2.87	30.90	2.95
		50	46	34.89	2.59	34.19	2.67	33.34	2.75	32.86	2.79	32.47	2.82	31.38	2.90
		55	51	35.06	2.57	34.48	2.63	33.84	2.69	33.45	2.72	33.14	2.75	32.16	2.81
		60	56	35.23	2.54	34.77	2.59	34.35	2.63	34.05	2.65	33.82	2.67	32.95	2.71
		63	59	35.33	2.52	34.95	2.56	34.65	2.60	34.41	2.61	34.22	2.62	33.42	2.66
		68	64	35.44	2.51	35.13	2.54	34.95	2.57	34.77	2.57	34.63	2.58	33.90	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

* The indoor unit must be non-ducted type.

Table 312: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	18 + 18	-4	-4.4	9.61	1.97	8.79	2.05	8.81	2.07	8.72	2.08	8.65	2.09	8.25	2.17
		0	-0.4	12.57	2.01	11.77	2.08	11.62	2.12	11.46	2.13	11.34	2.15	10.85	2.22
		5	4.5	16.08	2.05	15.32	2.13	14.96	2.17	14.72	2.19	14.53	2.21	13.94	2.29
		10	9	18.44	2.09	17.69	2.17	17.20	2.22	16.90	2.25	16.67	2.28	16.01	2.35
		17	15	21.03	2.15	20.30	2.22	19.66	2.29	19.30	2.33	19.02	2.36	18.28	2.43
		20	19	22.60	2.19	21.88	2.26	21.15	2.33	20.75	2.38	20.44	2.41	19.66	2.48
		25	23	25.22	2.26	24.48	2.32	23.62	2.41	23.18	2.46	22.82	2.50	21.96	2.56
		30	28	27.87	2.34	27.01	2.41	26.08	2.49	25.60	2.54	25.22	2.59	24.29	2.65
		35	32	30.51	2.42	29.54	2.50	28.54	2.57	28.02	2.63	27.61	2.67	26.61	2.74
		40	36	32.07	2.49	31.17	2.57	30.17	2.64	29.65	2.70	29.23	2.74	28.17	2.82
		45	41	34.01	2.57	33.20	2.66	32.22	2.74	31.69	2.79	31.26	2.83	30.12	2.92
		47	43	34.79	2.61	34.01	2.70	33.04	2.78	32.50	2.83	32.07	2.87	30.90	2.95
		50	46	34.89	2.59	34.19	2.67	33.34	2.75	32.86	2.79	32.47	2.82	31.38	2.90
		55	51	35.06	2.57	34.48	2.63	33.84	2.69	33.45	2.72	33.14	2.75	32.16	2.81
		60	56	35.23	2.54	34.77	2.59	34.35	2.63	34.05	2.65	33.82	2.67	32.95	2.71
		63	59	35.33	2.52	34.95	2.56	34.65	2.60	34.41	2.61	34.22	2.62	33.42	2.66
		68	64	35.44	2.51	35.13	2.54	34.95	2.57	34.77	2.57	34.63	2.58	33.90	2.60
	12 + 24*	-4	-4.4	9.61	1.97	8.79	2.05	8.81	2.07	8.72	2.08	8.65	2.09	8.25	2.17
		0	-0.4	12.57	2.01	11.77	2.08	11.62	2.12	11.46	2.13	11.34	2.15	10.85	2.22
		5	4.5	16.08	2.05	15.32	2.13	14.96	2.17	14.72	2.19	14.53	2.21	13.94	2.29
		10	9	18.44	2.09	17.69	2.17	17.20	2.22	16.90	2.25	16.67	2.28	16.01	2.35
		17	15	21.03	2.15	20.30	2.22	19.66	2.29	19.30	2.33	19.02	2.36	18.28	2.43
		20	19	22.60	2.19	21.88	2.26	21.15	2.33	20.75	2.38	20.44	2.41	19.66	2.48
		25	23	25.22	2.26	24.48	2.32	23.62	2.41	23.18	2.46	22.82	2.50	21.96	2.56
		30	28	27.87	2.34	27.01	2.41	26.08	2.49	25.60	2.54	25.22	2.59	24.29	2.65
		35	32	30.51	2.42	29.54	2.50	28.54	2.57	28.02	2.63	27.61	2.67	26.61	2.74
		40	36	32.07	2.49	31.17	2.57	30.17	2.64	29.65	2.70	29.23	2.74	28.17	2.82
		45	41	34.01	2.57	33.20	2.66	32.22	2.74	31.69	2.79	31.26	2.83	30.12	2.92
		47	43	34.79	2.61	34.01	2.70	33.04	2.78	32.50	2.83	32.07	2.87	30.90	2.95
		50	46	34.89	2.59	34.19	2.67	33.34	2.75	32.86	2.79	32.47	2.82	31.38	2.90
		55	51	35.06	2.57	34.48	2.63	33.84	2.69	33.45	2.72	33.14	2.75	32.16	2.81
		60	56	35.23	2.54	34.77	2.59	34.35	2.63	34.05	2.65	33.82	2.67	32.95	2.71
		63	59	35.33	2.52	34.95	2.56	34.65	2.60	34.41	2.61	34.22	2.62	33.42	2.66
		68	64	35.44	2.51	35.13	2.54	34.95	2.57	34.77	2.57	34.63	2.58	33.90	2.60
	15 + 24*	-4	-4.4	9.61	1.97	8.79	2.05	8.81	2.07	8.72	2.08	8.65	2.09	8.25	2.17
		0	-0.4	12.57	2.01	11.77	2.08	11.62	2.12	11.46	2.13	11.34	2.15	10.85	2.22
		5	4.5	16.08	2.05	15.32	2.13	14.96	2.17	14.72	2.19	14.53	2.21	13.94	2.29
		10	9	18.44	2.09	17.69	2.17	17.20	2.22	16.90	2.25	16.67	2.28	16.01	2.35
		17	15	21.03	2.15	20.30	2.22	19.66	2.29	19.30	2.33	19.02	2.36	18.28	2.43
		20	19	22.60	2.19	21.88	2.26	21.15	2.33	20.75	2.38	20.44	2.41	19.66	2.48
		25	23	25.22	2.26	24.48	2.32	23.62	2.41	23.18	2.46	22.82	2.50	21.96	2.56
		30	28	27.87	2.34	27.01	2.41	26.08	2.49	25.60	2.54	25.22	2.59	24.29	2.65
		35	32	30.51	2.42	29.54	2.50	28.54	2.57	28.02	2.63	27.61	2.67	26.61	2.74
		40	36	32.07	2.49	31.17	2.57	30.17	2.64	29.65	2.70	29.23	2.74	28.17	2.82
		45	41	34.01	2.57	33.20	2.66	32.22	2.74	31.69	2.79	31.26	2.83	30.12	2.92
		47	43	34.79	2.61	34.01	2.70	33.04	2.78	32.50	2.83	32.07	2.87	30.90	2.95
		50	46	34.89	2.59	34.19	2.67	33.34	2.75	32.86	2.79	32.47	2.82	31.38	2.90
		55	51	35.06	2.57	34.48	2.63	33.84	2.69	33.45	2.72	33.14	2.75	32.16	2.81
		60	56	35.23	2.54	34.77	2.59	34.35	2.63	34.05	2.65	33.82	2.67	32.95	2.71
		63	59	35.33	2.52	34.95	2.56	34.65	2.60	34.41	2.61	34.22	2.62	33.42	2.66
		68	64	35.44	2.51	35.13	2.54	34.95	2.57	34.77	2.57	34.63	2.58	33.90	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

* The indoor unit must be non-ducted type.

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 313: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 7 + 9	-4	-4.4	7.21	1.58	6.60	1.64	6.61	1.66	6.55	1.67	6.49	1.68	6.19	1.74
		0	-0.4	9.43	1.61	8.84	1.67	8.72	1.70	8.60	1.71	8.51	1.72	8.14	1.78
		5	4.5	12.07	1.65	11.49	1.71	11.23	1.74	11.05	1.76	10.90	1.78	10.46	1.84
		10	9	13.84	1.68	13.27	1.74	12.90	1.78	12.68	1.81	12.51	1.83	12.01	1.88
		17	15	15.78	1.73	15.23	1.78	14.75	1.84	14.48	1.87	14.27	1.89	13.72	1.95
		20	19	16.96	1.76	16.42	1.81	15.87	1.87	15.57	1.91	15.34	1.93	14.76	1.99
		25	23	18.93	1.81	18.37	1.86	17.73	1.93	17.39	1.97	17.12	2.00	16.48	2.06
		30	28	20.91	1.87	20.27	1.94	19.57	2.00	19.21	2.04	18.92	2.07	18.23	2.13
		35	32	22.90	1.94	22.17	2.01	21.41	2.06	21.03	2.11	20.72	2.15	19.97	2.20
		40	36	24.07	1.99	23.39	2.06	22.64	2.12	22.25	2.17	21.94	2.20	21.14	2.26
		45	41	25.52	2.06	24.91	2.13	24.18	2.20	23.78	2.24	23.46	2.27	22.61	2.34
		47	43	26.11	2.09	25.52	2.16	24.80	2.23	24.39	2.27	24.07	2.30	23.19	2.37
		50	46	26.18	2.08	25.66	2.14	25.02	2.20	24.66	2.24	24.37	2.26	23.55	2.33
		55	51	26.31	2.06	25.88	2.11	25.40	2.16	25.11	2.18	24.87	2.20	24.14	2.25
		60	56	26.44	2.04	26.10	2.08	25.78	2.11	25.55	2.13	25.38	2.14	24.73	2.18
		63	59	26.52	2.02	26.23	2.06	26.00	2.09	25.82	2.10	25.68	2.11	25.08	2.13
		68	64	26.59	2.01	26.36	2.04	26.23	2.06	26.09	2.06	25.99	2.07	25.44	2.09
	7 + 9 + 9	-4	-4.4	7.84	1.68	7.17	1.75	7.19	1.77	7.12	1.78	7.06	1.79	6.73	1.86
		0	-0.4	10.25	1.72	9.60	1.78	9.48	1.81	9.35	1.82	9.25	1.84	8.85	1.90
		5	4.5	13.12	1.75	12.49	1.82	12.20	1.86	12.01	1.88	11.85	1.89	11.37	1.96
		10	9	15.04	1.79	14.43	1.85	14.03	1.90	13.79	1.93	13.59	1.95	13.06	2.01
		17	15	17.15	1.84	16.55	1.90	16.03	1.96	15.74	1.99	15.51	2.02	14.91	2.07
		20	19	18.43	1.87	17.84	1.93	17.25	1.99	16.93	2.03	16.67	2.06	16.04	2.12
		25	23	20.57	1.93	19.96	1.99	19.27	2.06	18.91	2.10	18.61	2.14	17.91	2.19
		30	28	22.73	2.00	22.03	2.06	21.27	2.13	20.88	2.17	20.57	2.21	19.81	2.27
		35	32	24.89	2.07	24.10	2.14	23.28	2.19	22.86	2.25	22.52	2.29	21.71	2.34
		40	36	26.16	2.13	25.42	2.20	24.61	2.26	24.19	2.31	23.84	2.35	22.98	2.41
		45	41	27.74	2.20	27.08	2.28	26.28	2.35	25.85	2.39	25.50	2.42	24.57	2.49
		47	43	28.38	2.23	27.74	2.31	26.95	2.38	26.51	2.42	26.16	2.45	25.21	2.53
		50	46	28.46	2.22	27.89	2.28	27.20	2.35	26.80	2.39	26.49	2.41	25.59	2.48
		55	51	28.60	2.19	28.13	2.25	27.61	2.30	27.29	2.33	27.04	2.35	26.24	2.40
		60	56	28.74	2.17	28.36	2.21	28.02	2.25	27.78	2.27	27.58	2.28	26.88	2.32
		63	59	28.82	2.16	28.51	2.19	28.26	2.22	28.07	2.24	27.91	2.24	27.26	2.27
		68	64	28.91	2.14	28.65	2.17	28.51	2.20	28.36	2.20	28.25	2.21	27.66	2.22
	7 + 7 + 12	-4	-4.4	8.15	1.71	7.46	1.78	7.47	1.80	7.40	1.81	7.34	1.82	7.00	1.89
		0	-0.4	10.66	1.74	9.99	1.81	9.86	1.84	9.73	1.85	9.62	1.87	9.21	1.93
		5	4.5	13.64	1.78	12.99	1.85	12.69	1.89	12.49	1.91	12.33	1.93	11.83	1.99
		10	9	15.64	1.82	15.00	1.88	14.59	1.93	14.34	1.96	14.14	1.98	13.58	2.04
		17	15	17.84	1.87	17.22	1.93	16.67	1.99	16.37	2.02	16.13	2.05	15.51	2.11
		20	19	19.17	1.90	18.56	1.96	17.94	2.03	17.61	2.07	17.34	2.10	16.68	2.15
		25	23	21.40	1.96	20.76	2.02	20.04	2.10	19.66	2.14	19.36	2.17	18.63	2.23
		30	28	23.64	2.03	22.91	2.10	22.12	2.16	21.72	2.21	21.39	2.25	20.61	2.30
		35	32	25.88	2.10	25.06	2.17	24.21	2.23	23.77	2.28	23.42	2.32	22.58	2.38
		40	36	27.20	2.16	26.44	2.24	25.60	2.30	25.15	2.35	24.80	2.39	23.90	2.45
		45	41	28.85	2.24	28.16	2.31	27.33	2.38	26.88	2.43	26.52	2.46	25.55	2.53
		47	43	29.51	2.27	28.85	2.34	28.03	2.42	27.57	2.46	27.20	2.49	26.21	2.57
		50	46	29.60	2.25	29.00	2.32	28.28	2.39	27.87	2.42	27.55	2.45	26.62	2.52
		55	51	29.74	2.23	29.25	2.29	28.71	2.34	28.38	2.37	28.12	2.39	27.28	2.44
		60	56	29.89	2.21	29.50	2.25	29.14	2.29	28.89	2.31	28.69	2.32	27.95	2.36
		63	59	29.97	2.19	29.65	2.23	29.39	2.26	29.19	2.27	29.03	2.28	28.35	2.31
		68	64	30.06	2.18	29.80	2.21	29.65	2.23	29.50	2.24	29.38	2.24	28.76	2.26

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 314: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 9	-4	-4.4	8.46	1.74	7.75	1.81	7.76	1.83	7.68	1.84	7.62	1.85	7.27	1.92
		0	-0.4	11.07	1.77	10.37	1.84	10.24	1.87	10.10	1.88	9.99	1.90	9.56	1.97
		5	4.5	14.17	1.81	13.49	1.88	13.18	1.92	12.97	1.94	12.80	1.96	12.28	2.02
		10	9	16.24	1.85	15.58	1.91	15.15	1.96	14.89	1.99	14.68	2.01	14.10	2.07
		17	15	18.52	1.90	17.88	1.96	17.32	2.02	17.00	2.05	16.75	2.08	16.11	2.14
		20	19	19.91	1.93	19.27	1.99	18.63	2.06	18.28	2.10	18.01	2.13	17.32	2.19
		25	23	22.22	1.99	21.56	2.05	20.81	2.13	20.42	2.17	20.10	2.21	19.35	2.27
		30	28	24.55	2.06	23.79	2.13	22.97	2.20	22.55	2.25	22.21	2.29	21.40	2.34
		35	32	26.88	2.13	26.02	2.21	25.14	2.27	24.69	2.32	24.32	2.36	23.45	2.42
		40	36	28.25	2.20	27.46	2.27	26.58	2.34	26.12	2.39	25.75	2.42	24.82	2.49
		45	41	29.96	2.27	29.25	2.35	28.38	2.42	27.91	2.47	27.54	2.50	26.54	2.58
		47	43	30.65	2.31	29.96	2.38	29.11	2.46	28.63	2.50	28.25	2.53	27.22	2.61
		50	46	30.74	2.29	30.12	2.36	29.37	2.43	28.95	2.46	28.60	2.49	27.64	2.56
		55	51	30.89	2.27	30.37	2.32	29.81	2.38	29.47	2.40	29.20	2.43	28.33	2.48
		60	56	31.04	2.24	30.63	2.29	30.26	2.33	30.00	2.35	29.79	2.36	29.03	2.40
		63	59	31.13	2.23	30.79	2.26	30.52	2.30	30.31	2.31	30.15	2.32	29.44	2.35
		68	64	31.22	2.21	30.94	2.24	30.79	2.27	30.63	2.27	30.50	2.28	29.87	2.30
	7 + 9 + 12	-4	-4.4	8.78	1.77	8.03	1.84	8.05	1.87	7.97	1.88	7.91	1.89	7.54	1.96
		0	-0.4	11.48	1.81	10.76	1.88	10.62	1.91	10.47	1.92	10.36	1.94	9.91	2.00
		5	4.5	14.69	1.85	13.99	1.92	13.67	1.96	13.45	1.98	13.27	2.00	12.74	2.06
		10	9	16.84	1.89	16.16	1.95	15.71	2.00	15.44	2.03	15.22	2.05	14.62	2.11
		17	15	19.21	1.94	18.54	2.00	17.96	2.06	17.63	2.10	17.37	2.12	16.70	2.19
		20	19	20.64	1.97	19.98	2.03	19.32	2.10	18.96	2.14	18.67	2.17	17.96	2.23
		25	23	23.04	2.03	22.36	2.09	21.58	2.17	21.17	2.22	20.85	2.25	20.06	2.31
		30	28	25.46	2.11	24.67	2.17	23.82	2.24	23.39	2.29	23.04	2.33	22.19	2.39
		35	32	27.88	2.18	26.99	2.25	26.07	2.31	25.60	2.37	25.23	2.41	24.31	2.47
		40	36	29.30	2.24	28.47	2.32	27.56	2.38	27.09	2.43	26.71	2.47	25.74	2.54
		45	41	31.07	2.32	30.33	2.40	29.44	2.47	28.95	2.52	28.56	2.55	27.52	2.63
		47	43	31.78	2.35	31.07	2.43	30.18	2.51	29.69	2.55	29.30	2.58	28.23	2.66
		50	46	31.87	2.34	31.23	2.41	30.46	2.48	30.02	2.51	29.66	2.54	28.66	2.61
		55	51	32.03	2.31	31.50	2.37	30.92	2.43	30.56	2.45	30.28	2.47	29.38	2.53
		60	56	32.19	2.29	31.77	2.33	31.38	2.37	31.11	2.39	30.89	2.41	30.10	2.44
		63	59	32.28	2.27	31.93	2.31	31.65	2.34	31.43	2.36	31.26	2.36	30.53	2.39
		68	64	32.37	2.26	32.09	2.29	31.93	2.31	31.77	2.32	31.63	2.32	30.97	2.34
	9 + 9 + 12	-4	-4.4	9.12	1.85	8.35	1.92	8.36	1.95	8.28	1.96	8.21	1.97	7.83	2.04
		0	-0.4	11.93	1.89	11.18	1.96	11.03	1.99	10.88	2.01	10.76	2.02	10.30	2.09
		5	4.5	15.27	1.93	14.54	2.00	14.20	2.04	13.97	2.06	13.79	2.08	13.23	2.15
		10	9	17.50	1.97	16.79	2.04	16.32	2.09	16.04	2.12	15.82	2.14	15.20	2.21
		17	15	19.96	2.02	19.27	2.09	18.66	2.15	18.32	2.19	18.05	2.22	17.36	2.28
		20	19	21.45	2.06	20.77	2.12	20.07	2.19	19.70	2.23	19.40	2.27	18.66	2.33
		25	23	23.94	2.12	23.23	2.18	22.42	2.27	22.00	2.31	21.66	2.35	20.85	2.41
		30	28	26.45	2.20	25.64	2.27	24.75	2.34	24.30	2.39	23.94	2.43	23.06	2.49
		35	32	28.96	2.27	28.04	2.35	27.09	2.41	26.60	2.47	26.21	2.51	25.26	2.57
		40	36	30.44	2.34	29.58	2.42	28.64	2.49	28.15	2.54	27.75	2.58	26.74	2.65
		45	41	32.28	2.42	31.51	2.50	30.59	2.58	30.08	2.63	29.67	2.66	28.59	2.74
		47	43	33.02	2.45	32.28	2.53	31.36	2.61	30.85	2.66	30.44	2.70	29.33	2.78
		50	46	33.12	2.44	32.45	2.51	31.65	2.58	31.19	2.62	30.82	2.65	29.78	2.72
		55	51	33.28	2.41	32.73	2.47	32.13	2.53	31.76	2.56	31.46	2.58	30.53	2.64
		60	56	33.44	2.39	33.01	2.43	32.60	2.48	32.32	2.50	32.10	2.51	31.28	2.55
		63	59	33.54	2.37	33.17	2.41	32.89	2.44	32.66	2.46	32.48	2.47	31.73	2.50
		68	64	33.64	2.36	33.34	2.39	33.18	2.41	33.01	2.42	32.87	2.42	32.18	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 315: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 15	-4	-4.4	9.29	1.85	8.50	1.92	8.52	1.95	8.44	1.96	8.37	1.97	7.98	2.04
		0	-0.4	12.15	1.89	11.39	1.96	11.24	1.99	11.09	2.01	10.97	2.02	10.49	2.09
		5	4.5	15.55	1.93	14.81	2.00	14.47	2.04	14.24	2.06	14.05	2.08	13.48	2.15
		10	9	17.83	1.97	17.10	2.04	16.63	2.09	16.34	2.12	16.12	2.14	15.48	2.21
		17	15	20.33	2.02	19.63	2.09	19.01	2.15	18.66	2.19	18.39	2.22	17.68	2.28
		20	19	21.85	2.06	21.16	2.12	20.45	2.19	20.07	2.23	19.77	2.27	19.02	2.33
		25	23	24.39	2.12	23.67	2.18	22.85	2.27	22.41	2.31	22.07	2.35	21.24	2.41
		30	28	26.95	2.20	26.12	2.27	25.22	2.34	24.76	2.39	24.39	2.43	23.49	2.49
		35	32	29.51	2.27	28.57	2.35	27.60	2.41	27.10	2.47	26.70	2.51	25.74	2.57
		40	36	31.01	2.34	30.14	2.42	29.18	2.49	28.67	2.54	28.27	2.58	27.25	2.65
		45	41	32.89	2.42	32.11	2.50	31.16	2.58	30.64	2.63	30.23	2.66	29.13	2.74
		47	43	33.64	2.45	32.89	2.53	31.95	2.61	31.43	2.66	31.01	2.70	29.88	2.78
		50	46	33.74	2.44	33.06	2.51	32.24	2.58	31.78	2.62	31.40	2.65	30.34	2.72
		55	51	33.91	2.41	33.35	2.47	32.73	2.53	32.35	2.56	32.05	2.58	31.10	2.64
		60	56	34.07	2.39	33.63	2.43	33.21	2.48	32.93	2.50	32.70	2.51	31.87	2.55
		63	59	34.17	2.37	33.80	2.41	33.51	2.44	33.28	2.46	33.09	2.47	32.32	2.50
		68	64	34.27	2.36	33.97	2.39	33.80	2.41	33.63	2.42	33.49	2.42	32.79	2.44
	7 + 12 + 12	-4	-4.4	9.29	1.85	8.50	1.92	8.52	1.95	8.44	1.96	8.37	1.97	7.98	2.04
		0	-0.4	12.15	1.89	11.39	1.96	11.24	1.99	11.09	2.01	10.97	2.02	10.49	2.09
		5	4.5	15.55	1.93	14.81	2.00	14.47	2.04	14.24	2.06	14.05	2.08	13.48	2.15
		10	9	17.83	1.97	17.10	2.04	16.63	2.09	16.34	2.12	16.12	2.14	15.48	2.21
		17	15	20.33	2.02	19.63	2.09	19.01	2.15	18.66	2.19	18.39	2.22	17.68	2.28
		20	19	21.85	2.06	21.16	2.12	20.45	2.19	20.07	2.23	19.77	2.27	19.02	2.33
		25	23	24.39	2.12	23.67	2.18	22.85	2.27	22.41	2.31	22.07	2.35	21.24	2.41
		30	28	26.95	2.20	26.12	2.27	25.22	2.34	24.76	2.39	24.39	2.43	23.49	2.49
		35	32	29.51	2.27	28.57	2.35	27.60	2.41	27.10	2.47	26.70	2.51	25.74	2.57
		40	36	31.01	2.34	30.14	2.42	29.18	2.49	28.67	2.54	28.27	2.58	27.25	2.65
		45	41	32.89	2.42	32.11	2.50	31.16	2.58	30.64	2.63	30.23	2.66	29.13	2.74
		47	43	33.64	2.45	32.89	2.53	31.95	2.61	31.43	2.66	31.01	2.70	29.88	2.78
		50	46	33.74	2.44	33.06	2.51	32.24	2.58	31.78	2.62	31.40	2.65	30.34	2.72
		55	51	33.91	2.41	33.35	2.47	32.73	2.53	32.35	2.56	32.05	2.58	31.10	2.64
		60	56	34.07	2.39	33.63	2.43	33.21	2.48	32.93	2.50	32.70	2.51	31.87	2.55
		63	59	34.17	2.37	33.80	2.41	33.51	2.44	33.28	2.46	33.09	2.47	32.32	2.50
		68	64	34.27	2.36	33.97	2.39	33.80	2.41	33.63	2.42	33.49	2.42	32.79	2.44
	7 + 7 + 18	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 316: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 15	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	9 + 12 + 12	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	7 + 9 + 18	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 317: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 15	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	9 + 9 + 18	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	9 + 12 + 15	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 318: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 12 + 12	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	7 + 12 + 18	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	7 + 7 + 24*	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

* The indoor unit must be non-ducted type.

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 319: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 18	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	9 + 15 + 15	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	12 + 12 + 15	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 320: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 24*	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
	7 + 15 + 18	-4	-4.4	9.61	1.85	8.79	1.92	8.81	1.95	8.72	1.96	8.65	1.97	8.25	2.04
		0	-0.4	12.57	1.89	11.77	1.96	11.62	1.99	11.46	2.01	11.34	2.02	10.85	2.09
		5	4.5	16.08	1.93	15.32	2.00	14.96	2.04	14.72	2.06	14.53	2.08	13.94	2.15
		10	9	18.44	1.97	17.69	2.04	17.20	2.09	16.90	2.12	16.67	2.14	16.01	2.21
		17	15	21.03	2.02	20.30	2.09	19.66	2.15	19.30	2.19	19.02	2.22	18.28	2.28
		20	19	22.60	2.06	21.88	2.12	21.15	2.19	20.75	2.23	20.44	2.27	19.66	2.33
		25	23	25.22	2.12	24.48	2.18	23.62	2.27	23.18	2.31	22.82	2.35	21.96	2.41
		30	28	27.87	2.20	27.01	2.27	26.08	2.34	25.60	2.39	25.22	2.43	24.29	2.49
		35	32	30.51	2.27	29.54	2.35	28.54	2.41	28.02	2.47	27.61	2.51	26.61	2.57
		40	36	32.07	2.34	31.17	2.42	30.17	2.49	29.65	2.54	29.23	2.58	28.17	2.65
		45	41	34.01	2.42	33.20	2.50	32.22	2.58	31.69	2.63	31.26	2.66	30.12	2.74
		47	43	34.79	2.45	34.01	2.53	33.04	2.61	32.50	2.66	32.07	2.70	30.90	2.78
		50	46	34.89	2.44	34.19	2.51	33.34	2.58	32.86	2.62	32.47	2.65	31.38	2.72
		55	51	35.06	2.41	34.48	2.47	33.84	2.53	33.45	2.56	33.14	2.58	32.16	2.64
		60	56	35.23	2.39	34.77	2.43	34.35	2.48	34.05	2.50	33.82	2.51	32.95	2.55
		63	59	35.33	2.37	34.95	2.41	34.65	2.44	34.41	2.46	34.22	2.47	33.42	2.50
		68	64	35.44	2.36	35.13	2.39	34.95	2.41	34.77	2.42	34.63	2.42	33.90	2.44
Four (4) Mixed Indoor Units	7 + 7 + 7 + 9	-4	-4.4	9.12	1.84	8.35	1.91	8.36	1.93	8.28	1.94	8.21	1.95	7.83	2.03
		0	-0.4	11.93	1.87	11.18	1.94	11.03	1.97	10.88	1.99	10.76	2.00	10.30	2.08
		5	4.5	15.27	1.91	14.54	1.98	14.20	2.02	13.97	2.05	13.79	2.07	13.23	2.13
		10	9	17.50	1.95	16.79	2.02	16.32	2.07	16.04	2.10	15.82	2.12	15.20	2.19
		17	15	19.96	2.01	19.27	2.07	18.66	2.13	18.32	2.17	18.05	2.20	17.36	2.26
		20	19	21.45	2.04	20.77	2.10	20.07	2.18	19.70	2.22	19.40	2.25	18.66	2.31
		25	23	23.94	2.11	23.23	2.17	22.42	2.25	22.00	2.29	21.66	2.33	20.85	2.39
		30	28	26.45	2.18	25.64	2.25	24.75	2.32	24.30	2.37	23.94	2.41	23.06	2.47
		35	32	28.96	2.25	28.04	2.33	27.09	2.39	26.60	2.45	26.21	2.49	25.26	2.56
		40	36	30.44	2.32	29.58	2.40	28.64	2.47	28.15	2.52	27.75	2.56	26.74	2.63
		45	41	32.28	2.40	31.51	2.48	30.59	2.56	30.08	2.61	29.67	2.64	28.59	2.72
		47	43	33.02	2.43	32.28	2.51	31.36	2.60	30.85	2.64	30.44	2.68	29.33	2.76
		50	46	33.12	2.42	32.45	2.49	31.65	2.56	31.19	2.60	30.82	2.63	29.78	2.70
		55	51	33.28	2.39	32.73	2.45	32.13	2.51	31.76	2.54	31.46	2.56	30.53	2.62
		60	56	33.44	2.37	33.01	2.41	32.60	2.46	32.32	2.48	32.10	2.49	31.28	2.53
		63	59	33.54	2.35	33.17	2.39	32.89	2.43	32.66	2.44	32.48	2.45	31.73	2.48
		68	64	33.64	2.34	33.34	2.37	33.18	2.39	33.01	2.40	32.87	2.41	32.18	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

* The indoor unit must be non-ducted type.

MULTI F LMU30CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 321: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 9	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 7 + 7 + 12	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 9 + 9 + 9	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 322: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 12	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	9 + 9 + 9 + 9	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 9 + 9 + 12	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 323: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 9 + 15	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 7 + 12 + 12	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 7 + 7 + 18	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 324: LMU30CHV Heating Capacity Table —Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 9 + 12	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 9 + 9 + 15	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43
	7 + 9 + 12 + 12	-4	-4.4	9.61	1.84	8.79	1.91	8.81	1.93	8.72	1.94	8.65	1.95	8.25	2.03
		0	-0.4	12.57	1.87	11.77	1.94	11.62	1.97	11.46	1.99	11.34	2.00	10.85	2.08
		5	4.5	16.08	1.91	15.32	1.98	14.96	2.02	14.72	2.05	14.53	2.07	13.94	2.13
		10	9	18.44	1.95	17.69	2.02	17.20	2.07	16.90	2.10	16.67	2.12	16.01	2.19
		17	15	21.03	2.01	20.30	2.07	19.66	2.13	19.30	2.17	19.02	2.20	18.28	2.26
		20	19	22.60	2.04	21.88	2.10	21.15	2.18	20.75	2.22	20.44	2.25	19.66	2.31
		25	23	25.22	2.11	24.48	2.17	23.62	2.25	23.18	2.29	22.82	2.33	21.96	2.39
		30	28	27.87	2.18	27.01	2.25	26.08	2.32	25.60	2.37	25.22	2.41	24.29	2.47
		35	32	30.51	2.25	29.54	2.33	28.54	2.39	28.02	2.45	27.61	2.49	26.61	2.56
		40	36	32.07	2.32	31.17	2.40	30.17	2.47	29.65	2.52	29.23	2.56	28.17	2.63
		45	41	34.01	2.40	33.20	2.48	32.22	2.56	31.69	2.61	31.26	2.64	30.12	2.72
		47	43	34.79	2.43	34.01	2.51	33.04	2.60	32.50	2.64	32.07	2.68	30.90	2.76
		50	46	34.89	2.42	34.19	2.49	33.34	2.56	32.86	2.60	32.47	2.63	31.38	2.70
		55	51	35.06	2.39	34.48	2.45	33.84	2.51	33.45	2.54	33.14	2.56	32.16	2.62
		60	56	35.23	2.37	34.77	2.41	34.35	2.46	34.05	2.48	33.82	2.49	32.95	2.53
		63	59	35.33	2.35	34.95	2.39	34.65	2.43	34.41	2.44	34.22	2.45	33.42	2.48
		68	64	35.44	2.34	35.13	2.37	34.95	2.39	34.77	2.40	34.63	2.41	33.90	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 325: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 7	-4	-4.4	5.25	1.11	4.87	1.15	4.82	1.17	4.77	1.17	4.73	1.18	4.51	1.22
		0	-0.4	6.55	1.13	6.15	1.17	6.06	1.19	5.98	1.20	5.91	1.21	5.66	1.25
		5	4.5	8.10	1.16	7.72	1.20	7.53	1.22	7.41	1.24	7.32	1.25	7.02	1.29
		10	9	9.14	1.18	8.77	1.22	8.52	1.25	8.37	1.27	8.26	1.29	7.93	1.33
		17	15	10.28	1.22	9.92	1.26	9.61	1.29	9.43	1.32	9.29	1.33	8.94	1.37
		20	19	10.97	1.24	10.62	1.28	10.26	1.32	10.07	1.35	9.92	1.37	9.54	1.40
		25	23	12.13	1.28	11.77	1.32	11.36	1.37	11.14	1.40	10.97	1.42	10.56	1.45
		30	28	13.29	1.33	12.88	1.37	12.44	1.41	12.21	1.44	12.03	1.47	11.59	1.51
		35	32	14.46	1.37	14.00	1.42	13.52	1.46	13.28	1.49	13.08	1.52	12.61	1.56
		40	36	15.20	1.41	14.77	1.46	14.30	1.50	14.05	1.54	13.85	1.56	13.35	1.60
		45	41	16.12	1.46	15.73	1.51	15.27	1.56	15.01	1.59	14.81	1.61	14.27	1.66
		47	43	16.48	1.48	16.12	1.53	15.66	1.58	15.40	1.61	15.20	1.63	14.64	1.68
		50	46	16.53	1.48	16.20	1.52	15.80	1.56	15.57	1.59	15.39	1.61	14.87	1.65
		55	51	16.61	1.46	16.34	1.50	16.04	1.53	15.85	1.55	15.71	1.56	15.24	1.60
		60	56	16.69	1.44	16.48	1.47	16.27	1.50	16.14	1.51	16.02	1.52	15.61	1.54
		63	59	16.74	1.43	16.56	1.46	16.42	1.48	16.30	1.49	16.22	1.49	15.84	1.51
		68	64	16.79	1.43	16.64	1.44	16.56	1.46	16.48	1.46	16.41	1.47	16.07	1.48
	7 + 9	-4	-4.4	6.00	1.22	5.56	1.27	5.51	1.29	5.45	1.30	5.40	1.30	5.16	1.35
		0	-0.4	7.49	1.25	7.03	1.30	6.93	1.32	6.83	1.33	6.76	1.34	6.47	1.39
		5	4.5	9.26	1.28	8.82	1.33	8.61	1.35	8.47	1.37	8.36	1.38	8.02	1.43
		10	9	10.44	1.31	10.02	1.35	9.74	1.39	9.57	1.41	9.44	1.42	9.07	1.47
		17	15	11.74	1.35	11.34	1.39	10.98	1.43	10.78	1.46	10.62	1.47	10.21	1.52
		20	19	12.53	1.37	12.14	1.41	11.73	1.46	11.51	1.49	11.34	1.51	10.91	1.55
		25	23	13.86	1.42	13.45	1.46	12.98	1.51	12.73	1.54	12.54	1.57	12.07	1.61
		30	28	15.19	1.47	14.72	1.52	14.22	1.56	13.95	1.60	13.75	1.62	13.24	1.67
		35	32	16.52	1.52	16.00	1.57	15.45	1.61	15.18	1.65	14.95	1.68	14.41	1.72
		40	36	17.37	1.56	16.88	1.62	16.34	1.66	16.06	1.70	15.83	1.73	15.26	1.77
		45	41	18.42	1.62	17.98	1.67	17.45	1.73	17.16	1.76	16.93	1.78	16.31	1.83
		47	43	18.84	1.64	18.42	1.70	17.89	1.75	17.60	1.78	17.37	1.80	16.73	1.86
		50	46	18.89	1.63	18.51	1.68	18.06	1.73	17.79	1.75	17.58	1.78	16.99	1.82
		55	51	18.99	1.61	18.67	1.65	18.33	1.69	18.12	1.71	17.95	1.73	17.42	1.76
		60	56	19.08	1.60	18.83	1.63	18.60	1.66	18.44	1.67	18.31	1.68	17.84	1.71
		63	59	19.13	1.59	18.93	1.61	18.76	1.64	18.63	1.64	18.53	1.65	18.10	1.67
		68	64	19.19	1.58	19.02	1.60	18.93	1.61	18.83	1.62	18.75	1.62	18.36	1.64
	9 + 9	-4	-4.4	6.75	1.36	6.26	1.41	6.20	1.43	6.13	1.43	6.08	1.44	5.80	1.50
		0	-0.4	8.42	1.38	7.91	1.44	7.79	1.46	7.69	1.47	7.60	1.48	7.28	1.53
		5	4.5	10.41	1.42	9.92	1.47	9.69	1.50	9.53	1.52	9.41	1.53	9.03	1.58
		10	9	11.75	1.45	11.27	1.50	10.96	1.54	10.77	1.56	10.62	1.57	10.20	1.62
		17	15	13.21	1.49	12.75	1.54	12.35	1.58	12.13	1.61	11.95	1.63	11.49	1.68
		20	19	14.10	1.52	13.65	1.56	13.20	1.62	12.95	1.65	12.76	1.67	12.27	1.72
		25	23	15.59	1.57	15.13	1.61	14.60	1.67	14.33	1.71	14.10	1.73	13.57	1.78
		30	28	17.09	1.62	16.56	1.68	15.99	1.73	15.70	1.77	15.46	1.80	14.90	1.84
		35	32	18.59	1.68	18.00	1.74	17.38	1.79	17.07	1.83	16.82	1.86	16.21	1.91
		40	36	19.54	1.73	18.99	1.79	18.38	1.84	18.06	1.88	17.81	1.91	17.16	1.96
		45	41	20.72	1.79	20.23	1.85	19.63	1.91	19.30	1.94	19.04	1.97	18.35	2.03
		47	43	21.19	1.82	20.72	1.88	20.13	1.94	19.80	1.97	19.54	2.00	18.83	2.06
		50	46	21.26	1.81	20.83	1.86	20.31	1.91	20.02	1.94	19.78	1.96	19.11	2.02
		55	51	21.36	1.79	21.01	1.83	20.62	1.87	20.38	1.89	20.19	1.91	19.59	1.95
		60	56	21.46	1.77	21.18	1.80	20.92	1.83	20.75	1.85	20.60	1.86	20.08	1.89
		63	59	21.53	1.76	21.29	1.78	21.11	1.81	20.96	1.82	20.85	1.83	20.36	1.85
		68	64	21.59	1.74	21.40	1.77	21.29	1.79	21.18	1.79	21.10	1.80	20.66	1.81

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 326: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	7 + 12	-4	-4.4	7.12	1.41	6.61	1.47	6.54	1.48	6.47	1.49	6.42	1.50	6.12	1.56
		0	-0.4	8.89	1.44	8.35	1.49	8.23	1.52	8.11	1.53	8.02	1.54	7.68	1.60
		5	4.5	10.99	1.47	10.47	1.53	10.23	1.56	10.06	1.58	9.93	1.59	9.53	1.64
		10	9	12.40	1.51	11.90	1.56	11.56	1.60	11.37	1.62	11.21	1.64	10.77	1.69
		17	15	13.95	1.55	13.46	1.60	13.04	1.65	12.80	1.68	12.61	1.70	12.13	1.75
		20	19	14.88	1.58	14.41	1.63	13.93	1.68	13.67	1.71	13.46	1.74	12.95	1.79
		25	23	16.46	1.63	15.97	1.68	15.41	1.74	15.12	1.78	14.89	1.80	14.33	1.85
		30	28	18.04	1.69	17.48	1.75	16.88	1.80	16.57	1.84	16.32	1.87	15.72	1.92
		35	32	19.62	1.75	19.00	1.81	18.35	1.86	18.02	1.90	17.76	1.94	17.12	1.98
		40	36	20.62	1.80	20.04	1.86	19.40	1.92	19.07	1.96	18.80	1.99	18.12	2.04
		45	41	21.87	1.86	21.35	1.93	20.72	1.99	20.38	2.02	20.10	2.05	19.37	2.11
		47	43	22.37	1.89	21.87	1.95	21.25	2.02	20.90	2.05	20.62	2.08	19.87	2.14
		50	46	22.44	1.88	21.99	1.93	21.44	1.99	21.13	2.02	20.88	2.04	20.18	2.10
		55	51	22.55	1.86	22.17	1.90	21.76	1.95	21.51	1.97	21.31	1.99	20.68	2.03
		60	56	22.66	1.84	22.36	1.87	22.09	1.91	21.90	1.92	21.75	1.93	21.19	1.96
		63	59	22.72	1.83	22.47	1.86	22.28	1.88	22.13	1.89	22.01	1.90	21.49	1.92
		68	64	22.79	1.81	22.59	1.84	22.48	1.86	22.36	1.86	22.27	1.87	21.80	1.88
	9 + 12	-4	-4.4	7.87	1.53	7.30	1.59	7.23	1.61	7.15	1.62	7.09	1.62	6.77	1.69
		0	-0.4	9.82	1.56	9.22	1.62	9.09	1.64	8.97	1.66	8.87	1.67	8.49	1.73
		5	4.5	12.15	1.60	11.57	1.65	11.30	1.69	11.12	1.71	10.97	1.72	10.53	1.78
		10	9	13.70	1.63	13.15	1.69	12.78	1.73	12.56	1.75	12.39	1.77	11.90	1.83
		17	15	15.41	1.68	14.88	1.73	14.41	1.79	14.15	1.81	13.94	1.84	13.40	1.89
		20	19	16.45	1.71	15.93	1.76	15.40	1.82	15.11	1.86	14.88	1.88	14.32	1.93
		25	23	18.19	1.77	17.65	1.82	17.04	1.89	16.71	1.92	16.45	1.95	15.84	2.01
		30	28	19.94	1.83	19.32	1.89	18.66	1.95	18.32	1.99	18.04	2.03	17.38	2.08
		35	32	21.69	1.89	21.00	1.96	20.28	2.01	19.92	2.06	19.63	2.10	18.92	2.15
		40	36	22.79	1.95	22.15	2.02	21.45	2.07	21.07	2.12	20.78	2.15	20.02	2.21
		45	41	24.17	2.02	23.60	2.09	22.90	2.15	22.52	2.19	22.22	2.22	21.41	2.29
		47	43	24.73	2.05	24.17	2.11	23.48	2.18	23.10	2.22	22.79	2.25	21.96	2.32
		50	46	24.80	2.03	24.30	2.10	23.70	2.16	23.35	2.19	23.08	2.21	22.30	2.27
		55	51	24.92	2.01	24.51	2.06	24.05	2.11	23.78	2.14	23.56	2.15	22.86	2.20
		60	56	25.04	1.99	24.72	2.03	24.41	2.07	24.20	2.08	24.04	2.09	23.42	2.13
		63	59	25.11	1.98	24.84	2.01	24.63	2.04	24.46	2.05	24.32	2.06	23.76	2.08
		68	64	25.19	1.97	24.97	1.99	24.84	2.01	24.71	2.02	24.61	2.02	24.10	2.04
	7 + 15	-4	-4.4	8.24	1.58	7.65	1.64	7.58	1.66	7.49	1.67	7.43	1.68	7.09	1.74
		0	-0.4	10.29	1.61	9.66	1.67	9.52	1.70	9.39	1.71	9.29	1.72	8.89	1.78
		5	4.5	12.73	1.65	12.13	1.71	11.84	1.74	11.65	1.76	11.50	1.78	11.03	1.84
		10	9	14.36	1.68	13.77	1.74	13.39	1.78	13.16	1.81	12.98	1.83	12.47	1.89
		17	15	16.15	1.73	15.59	1.79	15.10	1.84	14.82	1.87	14.60	1.90	14.04	1.95
		20	19	17.24	1.76	16.69	1.82	16.13	1.88	15.83	1.91	15.59	1.94	15.00	2.00
		25	23	19.05	1.82	18.49	1.87	17.85	1.95	17.51	1.98	17.24	2.02	16.59	2.07
		30	28	20.89	1.89	20.24	1.95	19.55	2.01	19.19	2.05	18.90	2.09	18.21	2.14
		35	32	22.72	1.95	22.00	2.02	21.25	2.08	20.87	2.13	20.56	2.16	19.82	2.22
		40	36	23.88	2.01	23.21	2.08	22.47	2.14	22.08	2.19	21.77	2.22	20.98	2.28
		45	41	25.33	2.08	24.72	2.15	23.99	2.22	23.59	2.26	23.28	2.29	22.43	2.36
		47	43	25.90	2.11	25.33	2.18	24.60	2.25	24.20	2.29	23.88	2.32	23.01	2.39
		50	46	25.98	2.10	25.46	2.16	24.83	2.22	24.47	2.26	24.18	2.28	23.36	2.35
		55	51	26.11	2.08	25.67	2.13	25.20	2.18	24.91	2.20	24.68	2.22	23.95	2.27
		60	56	26.23	2.05	25.89	2.09	25.57	2.13	25.36	2.15	25.18	2.16	24.54	2.19
		63	59	26.31	2.04	26.02	2.07	25.80	2.10	25.62	2.12	25.48	2.12	24.89	2.15
		68	64	26.39	2.03	26.15	2.05	26.02	2.08	25.89	2.08	25.78	2.09	25.25	2.10

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 327: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 15	-4	-4.4	8.99	1.67	8.35	1.74	8.26	1.76	8.18	1.77	8.10	1.78	7.74	1.85
		0	-0.4	11.23	1.71	10.54	1.77	10.39	1.80	10.25	1.81	10.13	1.83	9.70	1.89
		5	4.5	13.88	1.75	13.23	1.81	12.92	1.85	12.71	1.87	12.54	1.89	12.04	1.95
		10	9	15.66	1.79	15.03	1.85	14.61	1.89	14.36	1.92	14.16	1.94	13.60	2.00
		17	15	17.62	1.84	17.00	1.90	16.47	1.95	16.17	1.99	15.93	2.01	15.32	2.07
		20	19	18.80	1.87	18.20	1.93	17.60	1.99	17.27	2.03	17.01	2.06	16.36	2.12
		25	23	20.79	1.93	20.17	1.99	19.47	2.06	19.10	2.11	18.81	2.14	18.10	2.20
		30	28	22.79	2.00	22.08	2.07	21.32	2.13	20.93	2.18	20.62	2.22	19.86	2.27
		35	32	24.79	2.07	24.00	2.15	23.18	2.20	22.76	2.26	22.43	2.30	21.62	2.35
		40	36	26.05	2.13	25.32	2.21	24.51	2.27	24.09	2.32	23.75	2.36	22.89	2.42
		45	41	27.63	2.21	26.97	2.28	26.17	2.36	25.74	2.40	25.39	2.43	24.47	2.50
		47	43	28.26	2.24	27.63	2.31	26.84	2.39	26.40	2.43	26.05	2.46	25.10	2.54
		50	46	28.34	2.23	27.77	2.29	27.08	2.36	26.69	2.40	26.38	2.42	25.49	2.49
		55	51	28.48	2.20	28.01	2.26	27.49	2.31	27.18	2.34	26.92	2.36	26.13	2.41
		60	56	28.62	2.18	28.25	2.22	27.90	2.26	27.66	2.28	27.47	2.29	26.77	2.33
		63	59	28.70	2.17	28.39	2.20	28.14	2.23	27.95	2.24	27.80	2.25	27.15	2.28
		68	64	28.79	2.15	28.53	2.18	28.39	2.20	28.25	2.21	28.13	2.22	27.54	2.23
	12 + 12	-4	-4.4	8.99	1.67	8.35	1.74	8.26	1.76	8.18	1.77	8.10	1.78	7.74	1.85
		0	-0.4	11.23	1.71	10.54	1.77	10.39	1.80	10.25	1.81	10.13	1.83	9.70	1.89
		5	4.5	13.88	1.75	13.23	1.81	12.92	1.85	12.71	1.87	12.54	1.89	12.04	1.95
		10	9	15.66	1.79	15.03	1.85	14.61	1.89	14.36	1.92	14.16	1.94	13.60	2.00
		17	15	17.62	1.84	17.00	1.90	16.47	1.95	16.17	1.99	15.93	2.01	15.32	2.07
		20	19	18.80	1.87	18.20	1.93	17.60	1.99	17.27	2.03	17.01	2.06	16.36	2.12
		25	23	20.79	1.93	20.17	1.99	19.47	2.06	19.10	2.11	18.81	2.14	18.10	2.20
		30	28	22.79	2.00	22.08	2.07	21.32	2.13	20.93	2.18	20.62	2.22	19.86	2.27
		35	32	24.79	2.07	24.00	2.15	23.18	2.20	22.76	2.26	22.43	2.30	21.62	2.35
		40	36	26.05	2.13	25.32	2.21	24.51	2.27	24.09	2.32	23.75	2.36	22.89	2.42
		45	41	27.63	2.21	26.97	2.28	26.17	2.36	25.74	2.40	25.39	2.43	24.47	2.50
		47	43	28.26	2.24	27.63	2.31	26.84	2.39	26.40	2.43	26.05	2.46	25.10	2.54
		50	46	28.34	2.23	27.77	2.29	27.08	2.36	26.69	2.40	26.38	2.42	25.49	2.49
		55	51	28.48	2.20	28.01	2.26	27.49	2.31	27.18	2.34	26.92	2.36	26.13	2.41
		60	56	28.62	2.18	28.25	2.22	27.90	2.26	27.66	2.28	27.47	2.29	26.77	2.33
		63	59	28.70	2.17	28.39	2.20	28.14	2.23	27.95	2.24	27.80	2.25	27.15	2.28
		68	64	28.79	2.15	28.53	2.18	28.39	2.20	28.25	2.21	28.13	2.22	27.54	2.23
	7 + 18	-4	-4.4	9.37	1.73	8.69	1.80	8.61	1.82	8.52	1.83	8.44	1.84	8.06	1.91
		0	-0.4	11.70	1.76	10.98	1.83	10.82	1.86	10.67	1.87	10.55	1.89	10.10	1.95
		5	4.5	14.46	1.80	13.78	1.87	13.45	1.91	13.24	1.93	13.07	1.95	12.54	2.01
		10	9	16.31	1.84	15.65	1.91	15.22	1.96	14.96	1.98	14.75	2.00	14.17	2.07
		17	15	18.35	1.90	17.71	1.96	17.15	2.02	16.84	2.05	16.60	2.08	15.96	2.14
		20	19	19.59	1.93	18.96	1.99	18.33	2.06	17.99	2.10	17.72	2.13	17.04	2.19
		25	23	21.65	2.00	21.01	2.05	20.28	2.13	19.90	2.18	19.59	2.21	18.85	2.27
		30	28	23.74	2.07	23.00	2.14	22.21	2.20	21.80	2.25	21.48	2.29	20.69	2.35
		35	32	25.82	2.14	25.00	2.22	24.15	2.28	23.71	2.33	23.36	2.37	22.52	2.43
		40	36	27.13	2.20	26.37	2.28	25.53	2.35	25.09	2.40	24.74	2.43	23.84	2.50
		45	41	28.78	2.28	28.09	2.36	27.26	2.43	26.81	2.48	26.45	2.51	25.49	2.59
		47	43	29.44	2.31	28.78	2.39	27.96	2.47	27.50	2.51	27.13	2.54	26.15	2.62
		50	46	29.52	2.30	28.93	2.37	28.21	2.44	27.80	2.47	27.48	2.50	26.55	2.57
		55	51	29.67	2.28	29.18	2.33	28.64	2.39	28.31	2.41	28.04	2.44	27.22	2.49
		60	56	29.81	2.25	29.42	2.29	29.06	2.34	28.81	2.35	28.61	2.37	27.88	2.41
		63	59	29.90	2.24	29.57	2.27	29.32	2.31	29.12	2.32	28.96	2.33	28.28	2.36
		68	64	29.98	2.22	29.72	2.25	29.57	2.28	29.42	2.28	29.30	2.29	28.69	2.31

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 328: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	9 + 18	-4	-4.4	10.12	1.84	9.39	1.91	9.30	1.93	9.20	1.94	9.12	1.95	8.70	2.03
		0	-0.4	12.63	1.87	11.86	1.95	11.69	1.98	11.53	1.99	11.40	2.01	10.91	2.08
		5	4.5	15.62	1.92	14.88	1.99	14.53	2.03	14.30	2.05	14.11	2.07	13.54	2.14
		10	9	17.62	1.96	16.90	2.03	16.43	2.08	16.15	2.11	15.93	2.13	15.30	2.20
		17	15	19.82	2.02	19.13	2.08	18.53	2.15	18.19	2.18	17.92	2.21	17.23	2.28
		20	19	21.15	2.06	20.48	2.12	19.79	2.19	19.43	2.23	19.13	2.26	18.41	2.33
		25	23	23.38	2.12	22.69	2.19	21.90	2.27	21.49	2.31	21.16	2.35	20.36	2.41
		30	28	25.64	2.20	24.84	2.27	23.99	2.34	23.55	2.40	23.20	2.44	22.34	2.50
		35	32	27.88	2.28	27.00	2.36	26.08	2.42	25.61	2.48	25.23	2.52	24.32	2.58
		40	36	29.31	2.35	28.48	2.43	27.57	2.50	27.10	2.55	26.71	2.59	25.75	2.66
		45	41	31.08	2.43	30.34	2.51	29.44	2.59	28.96	2.64	28.57	2.67	27.53	2.75
		47	43	31.79	2.46	31.08	2.54	30.19	2.62	29.70	2.67	29.31	2.71	28.24	2.79
		50	46	31.89	2.45	31.24	2.52	30.47	2.59	30.03	2.63	29.67	2.66	28.67	2.73
		55	51	32.04	2.42	31.51	2.48	30.93	2.54	30.57	2.57	30.29	2.59	29.39	2.65
		60	56	32.20	2.39	31.78	2.44	31.39	2.49	31.12	2.50	30.90	2.52	30.11	2.56
		63	59	32.29	2.38	31.94	2.42	31.66	2.45	31.45	2.47	31.27	2.48	30.55	2.51
		68	64	32.38	2.36	32.10	2.39	31.94	2.42	31.78	2.43	31.64	2.43	30.98	2.45
	12 + 15	-4	-4.4	10.12	1.84	9.39	1.91	9.30	1.93	9.20	1.94	9.12	1.95	8.70	2.03
		0	-0.4	12.63	1.87	11.86	1.95	11.69	1.98	11.53	1.99	11.40	2.01	10.91	2.08
		5	4.5	15.62	1.92	14.88	1.99	14.53	2.03	14.30	2.05	14.11	2.07	13.54	2.14
		10	9	17.62	1.96	16.90	2.03	16.43	2.08	16.15	2.11	15.93	2.13	15.30	2.20
		17	15	19.82	2.02	19.13	2.08	18.53	2.15	18.19	2.18	17.92	2.21	17.23	2.28
		20	19	21.15	2.06	20.48	2.12	19.79	2.19	19.43	2.23	19.13	2.26	18.41	2.33
		25	23	23.38	2.12	22.69	2.19	21.90	2.27	21.49	2.31	21.16	2.35	20.36	2.41
		30	28	25.64	2.20	24.84	2.27	23.99	2.34	23.55	2.40	23.20	2.44	22.34	2.50
		35	32	27.88	2.28	27.00	2.36	26.08	2.42	25.61	2.48	25.23	2.52	24.32	2.58
		40	36	29.31	2.35	28.48	2.43	27.57	2.50	27.10	2.55	26.71	2.59	25.75	2.66
		45	41	31.08	2.43	30.34	2.51	29.44	2.59	28.96	2.64	28.57	2.67	27.53	2.75
		47	43	31.79	2.46	31.08	2.54	30.19	2.62	29.70	2.67	29.31	2.71	28.24	2.79
		50	46	31.89	2.45	31.24	2.52	30.47	2.59	30.03	2.63	29.67	2.66	28.67	2.73
		55	51	32.04	2.42	31.51	2.48	30.93	2.54	30.57	2.57	30.29	2.59	29.39	2.65
		60	56	32.20	2.39	31.78	2.44	31.39	2.49	31.12	2.50	30.90	2.52	30.11	2.56
		63	59	32.29	2.38	31.94	2.42	31.66	2.45	31.45	2.47	31.27	2.48	30.55	2.51
		68	64	32.38	2.36	32.10	2.39	31.94	2.42	31.78	2.43	31.64	2.43	30.98	2.45
	12 + 18	-4	-4.4	11.13	1.98	10.43	2.06	10.29	2.08	10.15	2.10	10.04	2.11	9.61	2.19
		0	-0.4	13.81	2.02	12.97	2.10	12.78	2.13	12.61	2.15	12.46	2.16	11.94	2.24
		5	4.5	17.08	2.07	16.27	2.15	15.89	2.19	15.63	2.22	15.43	2.24	14.81	2.31
		10	9	19.26	2.12	18.48	2.19	17.98	2.24	17.66	2.27	17.42	2.30	16.73	2.37
		17	15	21.67	2.18	20.92	2.25	20.26	2.32	19.89	2.35	19.60	2.39	18.85	2.45
		20	19	23.13	2.22	22.39	2.28	21.65	2.36	21.24	2.41	20.93	2.44	20.13	2.51
		25	23	25.58	2.29	24.82	2.36	23.95	2.45	23.50	2.50	23.13	2.54	22.27	2.60
		30	28	27.92	2.37	27.05	2.45	26.12	2.53	25.64	2.58	25.26	2.63	24.33	2.69
		35	32	30.98	2.46	30.00	2.55	28.97	2.61	28.45	2.67	28.04	2.72	27.02	2.79
		40	36	32.56	2.53	31.65	2.62	30.64	2.69	30.11	2.75	29.68	2.79	28.61	2.87
		45	41	34.53	2.62	33.71	2.71	32.72	2.79	32.17	2.84	31.74	2.88	30.59	2.97
		47	43	35.32	2.66	34.53	2.74	33.55	2.83	33.00	2.88	32.56	2.92	31.38	3.01
		50	46	35.43	2.64	34.71	2.72	33.85	2.80	33.36	2.84	32.97	2.87	31.86	2.95
		55	51	35.60	2.61	35.01	2.68	34.36	2.74	33.97	2.77	33.65	2.80	32.66	2.85
		60	56	35.77	2.58	35.31	2.63	34.87	2.68	34.58	2.70	34.34	2.72	33.46	2.76
		63	59	35.88	2.57	35.49	2.61	35.18	2.65	34.94	2.66	34.75	2.67	33.94	2.70
		68	64	35.98	2.55	35.67	2.58	35.49	2.61	35.31	2.62	35.16	2.63	34.43	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 329: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 15	-4	-4.4	11.13	1.98	10.43	2.06	10.29	2.08	10.15	2.10	10.04	2.11	9.61	2.19
		0	-0.4	13.81	2.02	12.97	2.10	12.78	2.13	12.61	2.15	12.46	2.16	11.94	2.24
		5	4.5	17.08	2.07	16.27	2.15	15.89	2.19	15.63	2.22	15.43	2.24	14.81	2.31
		10	9	19.26	2.12	18.48	2.19	17.98	2.24	17.66	2.27	17.42	2.30	16.73	2.37
		17	15	21.67	2.18	20.92	2.25	20.26	2.32	19.89	2.35	19.60	2.39	18.85	2.45
		20	19	23.13	2.22	22.39	2.28	21.65	2.36	21.24	2.41	20.93	2.44	20.13	2.51
		25	23	25.58	2.29	24.82	2.36	23.95	2.45	23.50	2.50	23.13	2.54	22.27	2.60
		30	28	27.92	2.37	27.05	2.45	26.12	2.53	25.64	2.58	25.26	2.63	24.33	2.69
		35	32	30.98	2.46	30.00	2.55	28.97	2.61	28.45	2.67	28.04	2.72	27.02	2.79
		40	36	32.56	2.53	31.65	2.62	30.64	2.69	30.11	2.75	29.68	2.79	28.61	2.87
		45	41	34.53	2.62	33.71	2.71	32.72	2.79	32.17	2.84	31.74	2.88	30.59	2.97
		47	43	35.32	2.66	34.53	2.74	33.55	2.83	33.00	2.88	32.56	2.92	31.38	3.01
		50	46	35.43	2.64	34.71	2.72	33.85	2.80	33.36	2.84	32.97	2.87	31.86	2.95
		55	51	35.60	2.61	35.01	2.68	34.36	2.74	33.97	2.77	33.65	2.80	32.66	2.85
		60	56	35.77	2.58	35.31	2.63	34.87	2.68	34.58	2.70	34.34	2.72	33.46	2.76
		63	59	35.88	2.57	35.49	2.61	35.18	2.65	34.94	2.66	34.75	2.67	33.94	2.70
		68	64	35.98	2.55	35.67	2.58	35.49	2.61	35.31	2.62	35.16	2.63	34.43	2.65
	7 + 24	-4	-4.4	11.50	2.02	10.78	2.10	10.64	2.13	10.49	2.14	10.38	2.15	9.93	2.23
		0	-0.4	13.82	2.06	12.98	2.14	12.79	2.18	12.61	2.20	12.47	2.21	11.94	2.29
		5	4.5	17.09	2.11	16.28	2.19	15.90	2.24	15.64	2.26	15.44	2.28	14.82	2.36
		10	9	19.27	2.16	18.49	2.23	17.98	2.29	17.67	2.32	17.43	2.35	16.74	2.42
		17	15	21.68	2.22	20.93	2.29	20.27	2.36	19.90	2.40	19.61	2.44	18.86	2.51
		20	19	23.14	2.26	22.40	2.33	21.66	2.41	21.25	2.46	20.94	2.49	20.14	2.56
		25	23	25.67	2.34	24.91	2.41	24.05	2.50	23.59	2.55	23.23	2.59	22.35	2.66
		30	28	28.85	2.42	27.95	2.50	26.99	2.58	26.50	2.64	26.10	2.68	25.14	2.75
		35	32	32.02	2.51	31.00	2.60	29.94	2.67	29.40	2.73	28.97	2.78	27.92	2.85
		40	36	33.65	2.58	32.70	2.67	31.66	2.75	31.11	2.81	30.67	2.85	29.56	2.93
		45	41	35.69	2.67	34.83	2.76	33.81	2.85	33.25	2.90	32.80	2.94	31.61	3.03
		47	43	36.50	2.71	35.69	2.80	34.67	2.89	34.10	2.94	33.65	2.98	32.42	3.07
		50	46	36.61	2.69	35.87	2.77	34.98	2.85	34.48	2.90	34.07	2.93	32.92	3.01
		55	51	36.79	2.67	36.18	2.73	35.51	2.80	35.10	2.83	34.78	2.85	33.75	2.91
		60	56	36.97	2.64	36.49	2.69	36.04	2.74	35.73	2.76	35.48	2.77	34.57	2.82
		63	59	37.07	2.62	36.67	2.66	36.35	2.70	36.10	2.72	35.90	2.73	35.07	2.76
		68	64	37.18	2.60	36.85	2.64	36.67	2.67	36.48	2.67	36.33	2.68	35.57	2.70
	9 + 24	-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.11	2.16	16.29	2.24	15.92	2.29	15.65	2.32	15.45	2.34	14.83	2.41
		10	9	19.29	2.21	18.51	2.29	18.00	2.35	17.69	2.38	17.44	2.40	16.75	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
		55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
		63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 330: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 18	-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.11	2.16	16.29	2.24	15.92	2.29	15.65	2.32	15.45	2.34	14.83	2.41
		10	9	19.29	2.21	18.51	2.29	18.00	2.35	17.69	2.38	17.44	2.40	16.75	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
		55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
	18 + 18	63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77
		-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.13	2.16	16.32	2.24	15.94	2.29	15.68	2.32	15.47	2.34	14.85	2.41
		10	9	19.32	2.21	18.54	2.29	18.03	2.35	17.71	2.38	17.47	2.40	16.78	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
	12 + 24	55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
		63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77
		-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.13	2.16	16.32	2.24	15.94	2.29	15.68	2.32	15.47	2.34	14.85	2.41
		10	9	19.32	2.21	18.54	2.29	18.03	2.35	17.71	2.38	17.47	2.40	16.78	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
		55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
		63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 331: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Non-Ducted Indoor Units	15 + 24	-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.16	2.16	16.34	2.24	15.97	2.29	15.70	2.32	15.50	2.34	14.87	2.41
		10	9	19.35	2.21	18.57	2.29	18.06	2.35	17.74	2.38	17.49	2.40	16.80	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
		55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
	18 + 24	63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77
		-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.16	2.16	16.34	2.24	15.97	2.29	15.70	2.32	15.50	2.34	14.87	2.41
		10	9	19.35	2.21	18.57	2.29	18.06	2.35	17.74	2.38	17.49	2.40	16.80	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
	24 + 24	55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
		63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77
		-4	-4.4	12.14	2.07	11.38	2.15	11.23	2.18	11.08	2.19	10.95	2.20	10.48	2.29
		0	-0.4	14.13	2.11	13.37	2.19	13.11	2.23	12.92	2.25	12.76	2.26	12.23	2.34
		5	4.5	17.16	2.16	16.34	2.24	15.97	2.29	15.70	2.32	15.50	2.34	14.87	2.41
		10	9	19.35	2.21	18.57	2.29	18.06	2.35	17.74	2.38	17.49	2.40	16.80	2.48
		17	15	21.79	2.28	21.03	2.35	20.37	2.42	20.00	2.46	19.71	2.49	18.95	2.57
		20	19	23.78	2.32	23.02	2.39	22.25	2.47	21.84	2.52	21.51	2.55	20.69	2.62
		25	23	27.11	2.39	26.30	2.46	25.39	2.56	24.91	2.61	24.52	2.65	23.60	2.72
		30	28	30.45	2.48	29.51	2.56	28.50	2.64	27.97	2.70	27.56	2.75	26.54	2.82
		35	32	33.80	2.57	32.72	2.66	31.61	2.73	31.04	2.79	30.59	2.84	29.48	2.91
		40	36	35.52	2.64	34.52	2.74	33.42	2.81	32.84	2.87	32.38	2.92	31.21	3.00
		45	41	37.67	2.74	36.77	2.83	35.69	2.92	35.10	2.97	34.62	3.01	33.37	3.10
		47	43	38.54	2.78	37.67	2.87	36.60	2.96	36.00	3.01	35.52	3.05	34.23	3.14
		50	46	38.65	2.76	37.87	2.84	36.93	2.92	36.40	2.97	35.97	3.00	34.75	3.08
		55	51	38.84	2.73	38.19	2.80	37.49	2.86	37.06	2.90	36.71	2.92	35.63	2.98
		60	56	39.03	2.70	38.52	2.75	38.04	2.80	37.72	2.82	37.46	2.84	36.50	2.88
		63	59	39.14	2.68	38.71	2.73	38.38	2.77	38.12	2.78	37.91	2.79	37.02	2.82
		68	64	39.25	2.66	38.91	2.70	38.71	2.73	38.52	2.74	38.36	2.74	37.56	2.77

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 332: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 7	-4	-4.4	7.87	1.49	7.30	1.55	7.23	1.56	7.15	1.57	7.09	1.58	6.77	1.64
		0	-0.4	9.82	1.52	9.22	1.57	9.09	1.60	8.97	1.61	8.87	1.62	8.49	1.68
		5	4.5	12.15	1.55	11.57	1.61	11.30	1.64	11.12	1.66	10.97	1.68	10.53	1.73
		10	9	13.70	1.59	13.15	1.64	12.78	1.68	12.56	1.71	12.39	1.72	11.90	1.78
		17	15	15.41	1.63	14.88	1.68	14.41	1.74	14.15	1.77	13.94	1.79	13.40	1.84
		20	19	16.45	1.66	15.93	1.71	15.40	1.77	15.11	1.81	14.88	1.83	14.32	1.88
		25	23	18.19	1.72	17.65	1.77	17.04	1.83	16.71	1.87	16.45	1.90	15.84	1.95
		30	28	19.94	1.78	19.32	1.84	18.66	1.90	18.32	1.94	18.04	1.97	17.38	2.02
		35	32	21.69	1.84	21.00	1.91	20.28	1.96	19.92	2.00	19.63	2.04	18.92	2.09
		40	36	22.79	1.90	22.15	1.96	21.45	2.02	21.07	2.06	20.78	2.09	20.02	2.15
		45	41	24.17	1.96	23.60	2.03	22.90	2.09	22.52	2.13	22.22	2.16	21.41	2.23
		47	43	24.73	1.99	24.17	2.06	23.48	2.12	23.10	2.16	22.79	2.19	21.96	2.26
		50	46	24.80	1.98	24.30	2.04	23.70	2.10	23.35	2.13	23.08	2.15	22.30	2.21
		55	51	24.92	1.96	24.51	2.01	24.05	2.05	23.78	2.08	23.56	2.10	22.86	2.14
		60	56	25.04	1.94	24.72	1.97	24.41	2.01	24.20	2.03	24.04	2.04	23.42	2.07
		63	59	25.11	1.92	24.84	1.96	24.63	1.99	24.46	2.00	24.32	2.00	23.76	2.03
		68	64	25.19	1.91	24.97	1.94	24.84	1.96	24.71	1.96	24.61	1.97	24.10	1.99
	7 + 7 + 9	-4	-4.4	8.62	1.59	8.00	1.65	7.92	1.67	7.84	1.68	7.77	1.69	7.41	1.75
		0	-0.4	10.76	1.62	10.10	1.68	9.96	1.71	9.82	1.72	9.71	1.74	9.30	1.80
		5	4.5	13.30	1.66	12.68	1.72	12.38	1.76	12.18	1.78	12.02	1.79	11.53	1.85
		10	9	15.01	1.70	14.40	1.76	14.00	1.80	13.76	1.82	13.57	1.84	13.03	1.90
		17	15	16.88	1.75	16.30	1.80	15.78	1.86	15.50	1.89	15.27	1.91	14.68	1.97
		20	19	18.02	1.78	17.44	1.83	16.86	1.90	16.55	1.93	16.30	1.96	15.68	2.01
		25	23	19.92	1.84	19.33	1.89	18.66	1.96	18.30	2.00	18.02	2.03	17.34	2.09
		30	28	21.84	1.90	21.16	1.97	20.43	2.03	20.06	2.07	19.76	2.11	19.03	2.16
		35	32	23.75	1.97	23.00	2.04	22.21	2.09	21.81	2.14	21.50	2.18	20.72	2.24
		40	36	24.96	2.03	24.26	2.10	23.49	2.16	23.08	2.20	22.76	2.24	21.93	2.30
		45	41	26.48	2.10	25.84	2.17	25.08	2.24	24.67	2.28	24.33	2.31	23.45	2.38
		47	43	27.08	2.13	26.48	2.20	25.72	2.27	25.30	2.31	24.96	2.34	24.06	2.41
		50	46	27.16	2.12	26.61	2.18	25.95	2.24	25.58	2.28	25.28	2.30	24.42	2.37
		55	51	27.29	2.09	26.84	2.15	26.35	2.20	26.04	2.22	25.80	2.24	25.04	2.29
		60	56	27.43	2.07	27.07	2.11	26.74	2.15	26.51	2.17	26.32	2.18	25.65	2.21
		63	59	27.51	2.06	27.21	2.09	26.97	2.12	26.79	2.13	26.64	2.14	26.02	2.17
		68	64	27.59	2.05	27.34	2.07	27.21	2.10	27.07	2.10	26.96	2.11	26.39	2.12
	7 + 9 + 9	-4	-4.4	9.37	1.70	8.69	1.77	8.61	1.79	8.52	1.80	8.44	1.81	8.06	1.88
		0	-0.4	11.70	1.73	10.98	1.80	10.82	1.83	10.67	1.84	10.55	1.86	10.10	1.92
		5	4.5	14.46	1.78	13.78	1.84	13.45	1.88	13.24	1.90	13.07	1.92	12.54	1.98
		10	9	16.31	1.82	15.65	1.88	15.22	1.92	14.96	1.95	14.75	1.97	14.17	2.03
		17	15	18.35	1.87	17.71	1.93	17.15	1.99	16.84	2.02	16.60	2.05	15.96	2.11
		20	19	19.59	1.90	18.96	1.96	18.33	2.03	17.99	2.06	17.72	2.09	17.04	2.15
		25	23	21.65	1.96	21.01	2.02	20.28	2.10	19.90	2.14	19.59	2.17	18.85	2.23
		30	28	23.74	2.04	23.00	2.10	22.21	2.17	21.80	2.22	21.48	2.25	20.69	2.31
		35	32	25.82	2.11	25.00	2.18	24.15	2.24	23.71	2.29	23.36	2.33	22.52	2.39
		40	36	27.13	2.17	26.37	2.25	25.53	2.31	25.09	2.36	24.74	2.40	23.84	2.46
		45	41	28.78	2.25	28.09	2.32	27.26	2.39	26.81	2.44	26.45	2.47	25.49	2.54
		47	43	29.44	2.28	28.78	2.35	27.96	2.43	27.50	2.47	27.13	2.50	26.15	2.58
		50	46	29.52	2.26	28.93	2.33	28.21	2.40	27.80	2.43	27.48	2.46	26.55	2.53
		55	51	29.67	2.24	29.18	2.29	28.64	2.35	28.31	2.38	28.04	2.40	27.22	2.45
		60	56	29.81	2.22	29.42	2.26	29.06	2.30	28.81	2.32	28.61	2.33	27.88	2.37
		63	59	29.90	2.20	29.57	2.24	29.32	2.27	29.12	2.28	28.96	2.29	28.28	2.32
		68	64	29.98	2.19	29.72	2.21	29.57	2.24	29.42	2.25	29.30	2.25	28.69	2.27

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 333: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 12	-4	-4.4	9.74	1.73	9.04	1.80	8.95	1.82	8.86	1.83	8.78	1.84	8.38	1.91
		0	-0.4	12.16	1.76	11.42	1.83	11.26	1.86	11.10	1.87	10.98	1.89	10.51	1.95
		5	4.5	15.04	1.80	14.33	1.87	13.99	1.91	13.77	1.93	13.59	1.95	13.04	2.01
		10	9	16.97	1.84	16.28	1.91	15.82	1.96	15.55	1.98	15.34	2.00	14.73	2.07
		17	15	19.08	1.90	18.42	1.96	17.84	2.02	17.52	2.05	17.26	2.08	16.60	2.14
		20	19	20.37	1.93	19.72	1.99	19.06	2.06	18.71	2.10	18.42	2.13	17.72	2.19
		25	23	22.52	2.00	21.85	2.05	21.09	2.13	20.69	2.18	20.37	2.21	19.61	2.27
		30	28	24.69	2.07	23.92	2.14	23.10	2.20	22.68	2.25	22.34	2.29	21.52	2.35
		35	32	26.85	2.14	26.00	2.22	25.11	2.28	24.66	2.33	24.30	2.37	23.42	2.43
		40	36	28.22	2.20	27.43	2.28	26.55	2.35	26.09	2.40	25.72	2.43	24.79	2.50
		45	41	29.93	2.28	29.22	2.36	28.35	2.43	27.88	2.48	27.51	2.51	26.51	2.59
		47	43	30.61	2.31	29.93	2.39	29.08	2.47	28.60	2.51	28.22	2.54	27.19	2.62
		50	46	30.70	2.30	30.08	2.37	29.34	2.44	28.92	2.47	28.58	2.50	27.61	2.57
		55	51	30.85	2.28	30.34	2.33	29.78	2.39	29.44	2.41	29.17	2.44	28.30	2.49
		60	56	31.00	2.25	30.60	2.29	30.22	2.34	29.97	2.35	29.76	2.37	29.00	2.41
		63	59	31.09	2.24	30.75	2.27	30.49	2.31	30.28	2.32	30.11	2.33	29.41	2.36
		68	64	31.18	2.22	30.91	2.25	30.76	2.28	30.60	2.28	30.47	2.29	29.84	2.31
	9 + 9 + 9	-4	-4.4	10.12	1.75	9.39	1.82	9.30	1.85	9.20	1.86	9.12	1.87	8.70	1.94
		0	-0.4	12.63	1.79	11.86	1.86	11.69	1.89	11.53	1.90	11.40	1.92	10.91	1.99
		5	4.5	15.62	1.83	14.88	1.90	14.53	1.94	14.30	1.96	14.11	1.98	13.54	2.05
		10	9	17.62	1.87	16.90	1.94	16.43	1.99	16.15	2.01	15.93	2.04	15.30	2.10
		17	15	19.82	1.93	19.13	1.99	18.53	2.05	18.19	2.08	17.92	2.11	17.23	2.17
		20	19	21.15	1.96	20.48	2.02	19.79	2.09	19.43	2.13	19.13	2.16	18.41	2.22
		25	23	23.38	2.03	22.69	2.09	21.90	2.17	21.49	2.21	21.16	2.24	20.36	2.30
		30	28	25.64	2.10	24.84	2.17	23.99	2.24	23.55	2.29	23.20	2.33	22.34	2.39
		35	32	27.88	2.18	27.00	2.25	26.08	2.31	25.61	2.37	25.23	2.41	24.32	2.47
		40	36	29.31	2.24	28.48	2.32	27.57	2.38	27.10	2.43	26.71	2.47	25.75	2.54
		45	41	31.08	2.32	30.34	2.40	29.44	2.47	28.96	2.52	28.57	2.55	27.53	2.63
		47	43	31.79	2.35	31.08	2.43	30.19	2.51	29.70	2.55	29.31	2.58	28.24	2.66
		50	46	31.89	2.34	31.24	2.41	30.47	2.48	30.03	2.51	29.67	2.54	28.67	2.61
		55	51	32.04	2.31	31.51	2.37	30.93	2.43	30.57	2.45	30.29	2.47	29.39	2.53
		60	56	32.20	2.29	31.78	2.33	31.39	2.37	31.12	2.39	30.90	2.41	30.11	2.44
		63	59	32.29	2.27	31.94	2.31	31.66	2.34	31.45	2.36	31.27	2.36	30.55	2.39
		68	64	32.38	2.26	32.10	2.29	31.94	2.31	31.78	2.32	31.64	2.32	30.98	2.34
	7 + 9 + 12	-4	-4.4	10.49	1.79	9.74	1.86	9.64	1.88	9.54	1.89	9.46	1.90	9.02	1.97
		0	-0.4	13.10	1.82	12.30	1.89	12.12	1.92	11.96	1.94	11.82	1.95	11.32	2.02
		5	4.5	16.20	1.87	15.43	1.94	15.07	1.98	14.83	2.00	14.63	2.02	14.04	2.09
		10	9	18.27	1.91	17.53	1.98	17.04	2.03	16.75	2.05	16.52	2.08	15.87	2.14
		17	15	20.55	1.97	19.84	2.03	19.21	2.09	18.87	2.13	18.59	2.15	17.87	2.22
		20	19	21.94	2.00	21.24	2.06	20.53	2.13	20.15	2.17	19.84	2.21	19.09	2.27
		25	23	24.25	2.07	23.53	2.13	22.71	2.21	22.28	2.25	21.94	2.29	21.11	2.35
		30	28	26.58	2.14	25.76	2.21	24.88	2.28	24.42	2.33	24.06	2.37	23.17	2.43
		35	32	28.92	2.22	28.00	2.30	27.04	2.36	26.56	2.41	26.17	2.46	25.22	2.52
		40	36	30.39	2.28	29.54	2.36	28.60	2.43	28.10	2.48	27.70	2.52	26.70	2.59
		45	41	32.23	2.37	31.46	2.44	30.54	2.52	30.03	2.57	29.62	2.60	28.55	2.68
		47	43	32.97	2.40	32.23	2.48	31.31	2.56	30.80	2.60	30.39	2.64	29.29	2.71
		50	46	33.07	2.38	32.40	2.45	31.60	2.52	31.14	2.56	30.77	2.59	29.73	2.66
		55	51	33.23	2.36	32.68	2.42	32.07	2.47	31.70	2.50	31.41	2.52	30.48	2.58
		60	56	33.39	2.33	32.95	2.38	32.55	2.42	32.27	2.44	32.05	2.45	31.23	2.49
		63	59	33.49	2.32	33.12	2.35	32.83	2.39	32.61	2.40	32.43	2.41	31.68	2.44
		68	64	33.58	2.30	33.29	2.33	33.12	2.36	32.95	2.36	32.82	2.37	32.13	2.39

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 334: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 7 + 15	-4	-4.4	10.87	1.82	10.08	1.90	9.99	1.92	9.88	1.93	9.79	1.94	9.35	2.01
		0	-0.4	13.57	1.86	12.74	1.93	12.56	1.96	12.38	1.98	12.24	1.99	11.72	2.06
		5	4.5	16.78	1.91	15.98	1.97	15.61	2.02	15.36	2.04	15.16	2.06	14.54	2.13
		10	9	18.92	1.95	18.16	2.01	17.65	2.06	17.35	2.09	17.11	2.12	16.43	2.18
		17	15	21.29	2.00	20.55	2.07	19.90	2.13	19.54	2.17	19.25	2.19	18.51	2.26
		20	19	22.72	2.04	22.00	2.10	21.26	2.17	20.87	2.22	20.55	2.25	19.77	2.31
		25	23	25.12	2.11	24.37	2.17	23.52	2.25	23.08	2.30	22.72	2.33	21.87	2.39
		30	28	27.53	2.19	26.68	2.26	25.77	2.33	25.29	2.38	24.91	2.42	24.00	2.48
		35	32	29.95	2.26	29.00	2.34	28.01	2.40	27.51	2.46	27.10	2.50	26.12	2.56
		40	36	31.48	2.33	30.59	2.41	29.62	2.48	29.10	2.53	28.69	2.57	27.65	2.64
		45	41	33.38	2.41	32.59	2.49	31.63	2.57	31.10	2.62	30.68	2.65	29.57	2.73
		47	43	34.15	2.44	33.38	2.52	32.43	2.61	31.90	2.65	31.48	2.69	30.33	2.77
		50	46	34.25	2.43	33.56	2.50	32.73	2.57	32.25	2.61	31.87	2.64	30.80	2.71
		55	51	34.41	2.40	33.84	2.46	33.22	2.52	32.84	2.55	32.53	2.57	31.57	2.63
		60	56	34.58	2.38	34.13	2.42	33.71	2.47	33.42	2.49	33.19	2.50	32.34	2.54
		63	59	34.68	2.36	34.30	2.40	34.01	2.44	33.77	2.45	33.59	2.46	32.81	2.49
		68	64	34.78	2.35	34.48	2.38	34.31	2.40	34.13	2.41	33.99	2.42	33.28	2.44
	9 + 9 + 12	-4	-4.4	11.13	1.86	10.43	1.94	10.29	1.96	10.15	1.97	10.04	1.98	9.61	2.06
		0	-0.4	13.81	1.90	12.97	1.97	12.78	2.01	12.61	2.02	12.46	2.04	11.94	2.11
		5	4.5	17.08	1.95	16.27	2.02	15.89	2.06	15.63	2.08	15.43	2.10	14.81	2.17
		10	9	19.26	1.99	18.48	2.06	17.98	2.11	17.66	2.14	17.42	2.16	16.73	2.23
		17	15	21.67	2.05	20.92	2.11	20.26	2.18	19.89	2.22	19.60	2.24	18.85	2.31
		20	19	23.13	2.09	22.39	2.15	21.65	2.22	21.24	2.27	20.93	2.30	20.13	2.36
		25	23	25.58	2.16	24.82	2.22	23.95	2.30	23.50	2.35	23.13	2.39	22.27	2.45
		30	28	27.92	2.23	27.05	2.31	26.12	2.38	25.64	2.43	25.26	2.47	24.33	2.54
		35	32	30.98	2.31	30.00	2.40	28.97	2.46	28.45	2.51	28.04	2.56	27.02	2.62
		40	36	32.56	2.38	31.65	2.46	30.64	2.53	30.11	2.59	29.68	2.63	28.61	2.70
		45	41	34.53	2.47	33.71	2.55	32.72	2.63	32.17	2.67	31.74	2.71	30.59	2.79
		47	43	35.32	2.50	34.53	2.58	33.55	2.66	33.00	2.71	32.56	2.75	31.38	2.83
		50	46	35.43	2.48	34.71	2.56	33.85	2.63	33.36	2.67	32.97	2.70	31.86	2.78
		55	51	35.60	2.46	35.01	2.52	34.36	2.58	33.97	2.61	33.65	2.63	32.66	2.69
		60	56	35.77	2.43	35.31	2.48	34.87	2.52	34.58	2.54	34.34	2.56	33.46	2.60
		63	59	35.88	2.41	35.49	2.45	35.18	2.49	34.94	2.50	34.75	2.51	33.94	2.54
		68	64	35.98	2.40	35.67	2.43	35.49	2.46	35.31	2.47	35.16	2.47	34.43	2.49
	7 + 9 + 15	-4	-4.4	11.50	1.91	10.78	1.98	10.64	2.00	10.49	2.02	10.38	2.03	9.93	2.10
		0	-0.4	13.82	1.94	12.98	2.02	12.79	2.05	12.61	2.07	12.47	2.08	11.94	2.16
		5	4.5	17.09	1.99	16.28	2.06	15.90	2.11	15.64	2.13	15.44	2.15	14.82	2.22
		10	9	19.27	2.04	18.49	2.11	17.98	2.16	17.67	2.19	17.43	2.21	16.74	2.28
		17	15	21.68	2.09	20.93	2.16	20.27	2.23	19.90	2.26	19.61	2.29	18.86	2.36
		20	19	23.14	2.13	22.40	2.20	21.66	2.27	21.25	2.32	20.94	2.35	20.14	2.41
		25	23	25.67	2.20	24.91	2.27	24.05	2.35	23.59	2.40	23.23	2.44	22.35	2.50
		30	28	28.85	2.28	27.95	2.36	26.99	2.43	26.50	2.49	26.10	2.53	25.14	2.59
		35	32	32.02	2.36	31.00	2.45	29.94	2.51	29.40	2.57	28.97	2.62	27.92	2.68
		40	36	33.65	2.43	32.70	2.52	31.66	2.59	31.11	2.64	30.67	2.69	29.56	2.76
		45	41	35.69	2.52	34.83	2.60	33.81	2.68	33.25	2.73	32.80	2.77	31.61	2.85
		47	43	36.50	2.55	35.69	2.64	34.67	2.72	34.10	2.77	33.65	2.81	32.42	2.89
		50	46	36.61	2.54	35.87	2.61	34.98	2.69	34.48	2.73	34.07	2.76	32.92	2.84
		55	51	36.79	2.51	36.18	2.57	35.51	2.63	35.10	2.66	34.78	2.69	33.75	2.75
		60	56	36.97	2.48	36.49	2.53	36.04	2.58	35.73	2.60	35.48	2.61	34.57	2.65
		63	59	37.07	2.47	36.67	2.51	36.35	2.55	36.10	2.56	35.90	2.57	35.07	2.60
		68	64	37.18	2.45	36.85	2.48	36.67	2.51	36.48	2.52	36.33	2.53	35.57	2.55

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 335: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 12 + 12	-4	-4.4	11.50	1.91	10.78	1.98	10.64	2.00	10.49	2.02	10.38	2.03	9.93	2.10
		0	-0.4	13.82	1.94	12.98	2.02	12.79	2.05	12.61	2.07	12.47	2.08	11.94	2.16
		5	4.5	17.09	1.99	16.28	2.06	15.90	2.11	15.64	2.13	15.44	2.15	14.82	2.22
		10	9	19.27	2.04	18.49	2.11	17.98	2.16	17.67	2.19	17.43	2.21	16.74	2.28
		17	15	21.68	2.09	20.93	2.16	20.27	2.23	19.90	2.26	19.61	2.29	18.86	2.36
		20	19	23.14	2.13	22.40	2.20	21.66	2.27	21.25	2.32	20.94	2.35	20.14	2.41
		25	23	25.67	2.20	24.91	2.27	24.05	2.35	23.59	2.40	23.23	2.44	22.35	2.50
		30	28	28.85	2.28	27.95	2.36	26.99	2.43	26.50	2.49	26.10	2.53	25.14	2.59
		35	32	32.02	2.36	31.00	2.45	29.94	2.51	29.40	2.57	28.97	2.62	27.92	2.68
		40	36	33.65	2.43	32.70	2.52	31.66	2.59	31.11	2.64	30.67	2.69	29.56	2.76
		45	41	35.69	2.52	34.83	2.60	33.81	2.68	33.25	2.73	32.80	2.77	31.61	2.85
		47	43	36.50	2.55	35.69	2.64	34.67	2.72	34.10	2.77	33.65	2.81	32.42	2.89
		50	46	36.61	2.54	35.87	2.61	34.98	2.69	34.48	2.73	34.07	2.76	32.92	2.84
		55	51	36.79	2.51	36.18	2.57	35.51	2.63	35.10	2.66	34.78	2.69	33.75	2.75
		60	56	36.97	2.48	36.49	2.53	36.04	2.58	35.73	2.60	35.48	2.61	34.57	2.65
		63	59	37.07	2.47	36.67	2.51	36.35	2.55	36.10	2.56	35.90	2.57	35.07	2.60
		68	64	37.18	2.45	36.85	2.48	36.67	2.51	36.48	2.52	36.33	2.53	35.57	2.55
	7 + 7 + 18	-4	-4.4	11.87	1.95	11.13	2.02	10.98	2.05	10.83	2.06	10.71	2.07	10.25	2.15
		0	-0.4	13.82	1.99	13.07	2.06	12.82	2.09	12.63	2.11	12.47	2.13	11.96	2.20
		5	4.5	17.10	2.03	16.29	2.11	15.91	2.15	15.65	2.18	15.44	2.20	14.82	2.27
		10	9	19.28	2.08	18.50	2.15	17.99	2.21	17.68	2.24	17.43	2.26	16.74	2.33
		17	15	21.69	2.14	20.94	2.21	20.28	2.28	19.91	2.31	19.62	2.34	18.87	2.41
		20	19	23.25	2.18	22.51	2.25	21.76	2.32	21.35	2.37	21.03	2.40	20.23	2.47
		25	23	26.50	2.25	25.72	2.32	24.82	2.40	24.35	2.45	23.98	2.49	23.08	2.56
		30	28	29.78	2.33	28.85	2.41	27.86	2.48	27.35	2.54	26.94	2.58	25.95	2.65
		35	32	33.05	2.42	32.00	2.50	30.91	2.57	30.35	2.63	29.91	2.67	28.83	2.74
		40	36	34.73	2.49	33.76	2.57	32.68	2.64	32.11	2.70	31.66	2.74	30.51	2.82
		45	41	36.84	2.57	35.96	2.66	34.90	2.74	34.32	2.79	33.85	2.83	32.62	2.92
		47	43	37.68	2.61	36.84	2.70	35.78	2.78	35.20	2.83	34.73	2.87	33.47	2.95
		50	46	37.79	2.59	37.03	2.67	36.11	2.75	35.59	2.79	35.17	2.82	33.98	2.90
		55	51	37.97	2.57	37.34	2.63	36.66	2.69	36.23	2.72	35.90	2.75	34.84	2.81
		60	56	38.16	2.54	37.66	2.59	37.20	2.63	36.88	2.65	36.63	2.67	35.69	2.71
		63	59	38.27	2.52	37.85	2.56	37.53	2.60	37.27	2.61	37.06	2.62	36.20	2.66
		68	64	38.38	2.51	38.04	2.54	37.85	2.57	37.66	2.57	37.51	2.58	36.72	2.60
	9 + 9 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.11	2.03	16.29	2.11	15.92	2.15	15.65	2.18	15.45	2.20	14.83	2.27
		10	9	19.29	2.08	18.51	2.15	18.00	2.21	17.69	2.24	17.44	2.26	16.75	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 336: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 12 + 12	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.11	2.03	16.29	2.11	15.92	2.15	15.65	2.18	15.45	2.20	14.83	2.27
		10	9	19.29	2.08	18.51	2.15	18.00	2.21	17.69	2.24	17.44	2.26	16.75	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	7 + 9 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.12	2.03	16.30	2.11	15.93	2.15	15.66	2.18	15.46	2.20	14.84	2.27
		10	9	19.30	2.08	18.52	2.15	18.01	2.21	17.70	2.24	17.45	2.26	16.76	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	7 + 12 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.12	2.03	16.30	2.11	15.93	2.15	15.66	2.18	15.46	2.20	14.84	2.27
		10	9	19.30	2.08	18.52	2.15	18.01	2.21	17.70	2.24	17.45	2.26	16.76	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 337: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 9 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.13	2.03	16.32	2.11	15.94	2.15	15.68	2.18	15.47	2.20	14.85	2.27
		10	9	19.32	2.08	18.54	2.15	18.03	2.21	17.71	2.24	17.47	2.26	16.78	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	9 + 12 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.13	2.03	16.32	2.11	15.94	2.15	15.68	2.18	15.47	2.20	14.85	2.27
		10	9	19.32	2.08	18.54	2.15	18.03	2.21	17.71	2.24	17.47	2.26	16.78	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	12 + 12 + 12	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.13	2.03	16.32	2.11	15.94	2.15	15.68	2.18	15.47	2.20	14.85	2.27
		10	9	19.32	2.08	18.54	2.15	18.03	2.21	17.71	2.24	17.47	2.26	16.78	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 338: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 12 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.14	2.03	16.33	2.11	15.95	2.15	15.68	2.18	15.48	2.20	14.86	2.27
		10	9	19.33	2.08	18.55	2.15	18.04	2.21	17.72	2.24	17.48	2.26	16.78	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	7 + 15 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.14	2.03	16.33	2.11	15.95	2.15	15.68	2.18	15.48	2.20	14.86	2.27
		10	9	19.33	2.08	18.55	2.15	18.04	2.21	17.72	2.24	17.48	2.26	16.78	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	7 + 7 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.15	2.03	16.33	2.11	15.96	2.15	15.69	2.18	15.49	2.20	14.87	2.27
		10	9	19.34	2.08	18.56	2.15	18.05	2.21	17.73	2.24	17.49	2.26	16.79	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 339: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 12 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.16	2.03	16.34	2.11	15.97	2.15	15.70	2.18	15.50	2.20	14.87	2.27
		10	9	19.35	2.08	18.57	2.15	18.06	2.21	17.74	2.24	17.49	2.26	16.80	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	9 + 15 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.16	2.03	16.34	2.11	15.97	2.15	15.70	2.18	15.50	2.20	14.87	2.27
		10	9	19.35	2.08	18.57	2.15	18.06	2.21	17.74	2.24	17.49	2.26	16.80	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	12 + 12 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.16	2.03	16.34	2.11	15.97	2.15	15.70	2.18	15.50	2.20	14.87	2.27
		10	9	19.35	2.08	18.57	2.15	18.06	2.21	17.74	2.24	17.49	2.26	16.80	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 340: LMU36CHV Heating Capacity Table —Non-Ducted Indoor Unit, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 9 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	7 + 15 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	9 + 9 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 341: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 15 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	12 + 12 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	12 + 15 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 342: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 12 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	7 + 18 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	9 + 12 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 343: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	9 + 18 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	12 + 15 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	15 + 15 + 15	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 344: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	7 + 15 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	9 + 15 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	12 + 12 + 24	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 345: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Non-Ducted Indoor Units	12 + 18 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
	15 + 15 + 18	-4	-4.4	12.14	1.95	11.38	2.02	11.23	2.05	11.08	2.06	10.95	2.07	10.48	2.15
		0	-0.4	14.13	1.99	13.37	2.06	13.11	2.09	12.92	2.11	12.76	2.13	12.23	2.20
		5	4.5	17.17	2.03	16.35	2.11	15.97	2.15	15.71	2.18	15.50	2.20	14.88	2.27
		10	9	19.36	2.08	18.57	2.15	18.06	2.21	17.75	2.24	17.50	2.26	16.81	2.33
		17	15	21.79	2.14	21.03	2.21	20.37	2.28	20.00	2.31	19.71	2.34	18.95	2.41
		20	19	23.78	2.18	23.02	2.25	22.25	2.32	21.84	2.37	21.51	2.40	20.69	2.47
		25	23	27.11	2.25	26.30	2.32	25.39	2.40	24.91	2.45	24.52	2.49	23.60	2.56
		30	28	30.45	2.33	29.51	2.41	28.50	2.48	27.97	2.54	27.56	2.58	26.54	2.65
		35	32	33.80	2.42	32.72	2.50	31.61	2.57	31.04	2.63	30.59	2.67	29.48	2.74
		40	36	35.52	2.49	34.52	2.57	33.42	2.64	32.84	2.70	32.38	2.74	31.21	2.82
		45	41	37.67	2.57	36.77	2.66	35.69	2.74	35.10	2.79	34.62	2.83	33.37	2.92
		47	43	38.54	2.61	37.67	2.70	36.60	2.78	36.00	2.83	35.52	2.87	34.23	2.95
		50	46	38.65	2.59	37.87	2.67	36.93	2.75	36.40	2.79	35.97	2.82	34.75	2.90
		55	51	38.84	2.57	38.19	2.63	37.49	2.69	37.06	2.72	36.71	2.75	35.63	2.81
		60	56	39.03	2.54	38.52	2.59	38.04	2.63	37.72	2.65	37.46	2.67	36.50	2.71
		63	59	39.14	2.52	38.71	2.56	38.38	2.60	38.12	2.61	37.91	2.62	37.02	2.66
		68	64	39.25	2.51	38.91	2.54	38.71	2.57	38.52	2.57	38.36	2.58	37.56	2.60
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 7	-4	-4.4	10.49	1.80	9.74	1.87	9.64	1.89	9.54	1.90	9.46	1.91	9.02	1.98
		0	-0.4	13.10	1.83	12.30	1.90	12.12	1.93	11.96	1.95	11.82	1.96	11.32	2.03
		5	4.5	16.20	1.88	15.43	1.94	15.07	1.99	14.83	2.01	14.63	2.03	14.04	2.09
		10	9	18.27	1.92	17.53	1.98	17.04	2.03	16.75	2.06	16.52	2.08	15.87	2.15
		17	15	20.55	1.97	19.84	2.04	19.21	2.10	18.87	2.13	18.59	2.16	17.87	2.22
		20	19	21.94	2.01	21.24	2.07	20.53	2.14	20.15	2.18	19.84	2.21	19.09	2.27
		25	23	24.25	2.08	23.53	2.14	22.71	2.22	22.28	2.26	21.94	2.30	21.11	2.36
		30	28	26.58	2.15	25.76	2.22	24.88	2.29	24.42	2.34	24.06	2.38	23.17	2.44
		35	32	28.92	2.23	28.00	2.31	27.04	2.37	26.56	2.42	26.17	2.47	25.22	2.53
		40	36	30.39	2.29	29.54	2.37	28.60	2.44	28.10	2.49	27.70	2.53	26.70	2.60
		45	41	32.23	2.37	31.46	2.45	30.54	2.53	30.03	2.58	29.62	2.61	28.55	2.69
		47	43	32.97	2.41	32.23	2.49	31.31	2.57	30.80	2.61	30.39	2.65	29.29	2.72
		50	46	33.07	2.39	32.40	2.46	31.60	2.53	31.14	2.57	30.77	2.60	29.73	2.67
		55	51	33.23	2.37	32.68	2.42	32.07	2.48	31.70	2.51	31.41	2.53	30.48	2.59
		60	56	33.39	2.34	32.95	2.39	32.55	2.43	32.27	2.45	32.05	2.46	31.23	2.50
		63	59	33.49	2.33	33.12	2.36	32.83	2.40	32.61	2.41	32.43	2.42	31.68	2.45
		68	64	33.58	2.31	33.29	2.34	33.12	2.37	32.95	2.37	32.82	2.38	32.13	2.40

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 346: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 7 + 9	-4	-4.4	11.13	1.85	10.43	1.92	10.29	1.95	10.15	1.96	10.04	1.97	9.61	2.04
		0	-0.4	13.81	1.89	12.97	1.96	12.78	1.99	12.61	2.01	12.46	2.02	11.94	2.09
		5	4.5	17.08	1.93	16.27	2.00	15.89	2.05	15.63	2.07	15.43	2.09	14.81	2.16
		10	9	19.26	1.98	18.48	2.04	17.98	2.10	17.66	2.12	17.42	2.15	16.73	2.22
		17	15	21.67	2.03	20.92	2.10	20.26	2.16	19.89	2.20	19.60	2.23	18.85	2.29
		20	19	23.13	2.07	22.39	2.13	21.65	2.21	21.24	2.25	20.93	2.28	20.13	2.34
		25	23	25.58	2.14	24.82	2.20	23.95	2.29	23.50	2.33	23.13	2.37	22.27	2.43
		30	28	27.92	2.22	27.05	2.29	26.12	2.36	25.64	2.41	25.26	2.46	24.33	2.52
		35	32	30.98	2.30	30.00	2.38	28.97	2.44	28.45	2.50	28.04	2.54	27.02	2.60
		40	36	32.56	2.36	31.65	2.45	30.64	2.51	30.11	2.57	29.68	2.61	28.61	2.68
		45	41	34.53	2.45	33.71	2.53	32.72	2.61	32.17	2.65	31.74	2.69	30.59	2.77
		47	43	35.32	2.48	34.53	2.56	33.55	2.64	33.00	2.69	32.56	2.73	31.38	2.81
		50	46	35.43	2.46	34.71	2.54	33.85	2.61	33.36	2.65	32.97	2.68	31.86	2.76
		55	51	35.60	2.44	35.01	2.50	34.36	2.56	33.97	2.59	33.65	2.61	32.66	2.67
		60	56	35.77	2.41	35.31	2.46	34.87	2.50	34.58	2.52	34.34	2.54	33.46	2.58
		63	59	35.88	2.40	35.49	2.44	35.18	2.47	34.94	2.48	34.75	2.49	33.94	2.52
		68	64	35.98	2.38	35.67	2.41	35.49	2.44	35.31	2.45	35.16	2.45	34.43	2.47
	7 + 7 + 9 + 9	-4	-4.4	11.87	1.88	11.13	1.96	10.98	1.98	10.83	2.00	10.71	2.01	10.25	2.08
		0	-0.4	13.82	1.92	13.07	2.00	12.82	2.03	12.63	2.05	12.47	2.06	11.96	2.13
		5	4.5	17.10	1.97	16.29	2.04	15.91	2.08	15.65	2.11	15.44	2.13	14.82	2.20
		10	9	19.28	2.01	18.50	2.08	17.99	2.14	17.68	2.16	17.43	2.19	16.74	2.26
		17	15	21.69	2.07	20.94	2.14	20.28	2.20	19.91	2.24	19.62	2.27	18.87	2.34
		20	19	23.25	2.11	22.51	2.17	21.76	2.25	21.35	2.29	21.03	2.32	20.23	2.39
		25	23	26.50	2.18	25.72	2.24	24.82	2.33	24.35	2.37	23.98	2.41	23.08	2.48
		30	28	29.78	2.26	28.85	2.33	27.86	2.41	27.35	2.46	26.94	2.50	25.95	2.56
		35	32	33.05	2.34	32.00	2.42	30.91	2.48	30.35	2.54	29.91	2.59	28.83	2.65
		40	36	34.73	2.41	33.76	2.49	32.68	2.56	32.11	2.61	31.66	2.66	30.51	2.73
		45	41	36.84	2.49	35.96	2.58	34.90	2.66	34.32	2.70	33.85	2.74	32.62	2.82
		47	43	37.68	2.53	36.84	2.61	35.78	2.69	35.20	2.74	34.73	2.78	33.47	2.86
		50	46	37.79	2.51	37.03	2.59	36.11	2.66	35.59	2.70	35.17	2.73	33.98	2.81
		55	51	37.97	2.48	37.34	2.55	36.66	2.61	36.23	2.64	35.90	2.66	34.84	2.72
		60	56	38.16	2.46	37.66	2.51	37.20	2.55	36.88	2.57	36.63	2.59	35.69	2.63
		63	59	38.27	2.44	37.85	2.48	37.53	2.52	37.27	2.53	37.06	2.54	36.20	2.57
		68	64	38.38	2.43	38.04	2.46	37.85	2.49	37.66	2.49	37.51	2.50	36.72	2.52
	7 + 7 + 7 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.11	1.97	16.29	2.04	15.92	2.08	15.65	2.11	15.45	2.13	14.83	2.20
		10	9	19.29	2.01	18.51	2.08	18.00	2.14	17.69	2.16	17.44	2.19	16.75	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 347: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 9 + 9	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.12	1.97	16.30	2.04	15.93	2.08	15.66	2.11	15.46	2.13	14.84	2.20
		10	9	19.30	2.01	18.52	2.08	18.01	2.14	17.70	2.16	17.45	2.19	16.76	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 7 + 9 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.12	1.97	16.31	2.04	15.93	2.08	15.67	2.11	15.47	2.13	14.85	2.20
		10	9	19.31	2.01	18.53	2.08	18.02	2.14	17.70	2.16	17.46	2.19	16.77	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 7 + 7 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.13	1.97	16.32	2.04	15.94	2.08	15.68	2.11	15.47	2.13	14.85	2.20
		10	9	19.32	2.01	18.54	2.08	18.03	2.14	17.71	2.16	17.47	2.19	16.78	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 348: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 9 + 9	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.13	1.97	16.32	2.04	15.94	2.08	15.68	2.11	15.47	2.13	14.85	2.20
		10	9	19.32	2.01	18.54	2.08	18.03	2.14	17.71	2.16	17.47	2.19	16.78	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
	7 + 9 + 9 + 12	63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.14	1.97	16.33	2.04	15.95	2.08	15.68	2.11	15.48	2.13	14.86	2.20
		10	9	19.33	2.01	18.55	2.08	18.04	2.14	17.72	2.16	17.48	2.19	16.78	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
	7 + 7 + 9 + 15	55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.15	1.97	16.33	2.04	15.96	2.08	15.69	2.11	15.49	2.13	14.87	2.20
		10	9	19.34	2.01	18.56	2.08	18.05	2.14	17.73	2.16	17.49	2.19	16.79	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 349: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 12 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.15	1.97	16.33	2.04	15.96	2.08	15.69	2.11	15.49	2.13	14.87	2.20
		10	9	19.34	2.01	18.56	2.08	18.05	2.14	17.73	2.16	17.49	2.19	16.79	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 7 + 7 + 18	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.16	1.97	16.34	2.04	15.97	2.08	15.70	2.11	15.50	2.13	14.87	2.20
		10	9	19.35	2.01	18.57	2.08	18.06	2.14	17.74	2.16	17.49	2.19	16.80	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	9 + 9 + 9 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.16	1.97	16.34	2.04	15.97	2.08	15.70	2.11	15.50	2.13	14.87	2.20
		10	9	19.35	2.01	18.57	2.08	18.06	2.14	17.74	2.16	17.49	2.19	16.80	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 350: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 9 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
	7 + 9 + 12 + 12	63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
	7 + 7 + 9 + 18	55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 351: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 12 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	9 + 9 + 9 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	9 + 9 + 12 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 352: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 9 + 18	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
	7 + 9 + 12 + 15	63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
	7 + 12 + 12 + 12	55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 353: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 12 + 18	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 7 + 15 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 7 + 7 + 24	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 354: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 9 + 18	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	9 + 9 + 12 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	9 + 12 + 12 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 355: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 9 + 12 + 18	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 9 + 15 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	7 + 12 + 12 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 356: LMU36CHV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	7 + 7 + 9 + 24	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
	7 + 7 + 15 + 18	63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
	9 + 9 + 12 + 18	55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
		-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 357: LMU36CHV Heating Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Non-Ducted Indoor Units	9 + 9 + 15 + 15	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
	12 + 12 + 12 + 12	-4	-4.4	12.14	1.88	11.38	1.96	11.23	1.98	11.08	2.00	10.95	2.01	10.48	2.08
		0	-0.4	14.13	1.92	13.37	2.00	13.11	2.03	12.92	2.05	12.76	2.06	12.23	2.13
		5	4.5	17.17	1.97	16.35	2.04	15.97	2.08	15.71	2.11	15.50	2.13	14.88	2.20
		10	9	19.36	2.01	18.57	2.08	18.06	2.14	17.75	2.16	17.50	2.19	16.81	2.26
		17	15	21.79	2.07	21.03	2.14	20.37	2.20	20.00	2.24	19.71	2.27	18.95	2.34
		20	19	23.78	2.11	23.02	2.17	22.25	2.25	21.84	2.29	21.51	2.32	20.69	2.39
		25	23	27.11	2.18	26.30	2.24	25.39	2.33	24.91	2.37	24.52	2.41	23.60	2.48
		30	28	30.45	2.26	29.51	2.33	28.50	2.41	27.97	2.46	27.56	2.50	26.54	2.56
		35	32	33.80	2.34	32.72	2.42	31.61	2.48	31.04	2.54	30.59	2.59	29.48	2.65
		40	36	35.52	2.41	34.52	2.49	33.42	2.56	32.84	2.61	32.38	2.66	31.21	2.73
		45	41	37.67	2.49	36.77	2.58	35.69	2.66	35.10	2.70	34.62	2.74	33.37	2.82
		47	43	38.54	2.53	37.67	2.61	36.60	2.69	36.00	2.74	35.52	2.78	34.23	2.86
		50	46	38.65	2.51	37.87	2.59	36.93	2.66	36.40	2.70	35.97	2.73	34.75	2.81
		55	51	38.84	2.48	38.19	2.55	37.49	2.61	37.06	2.64	36.71	2.66	35.63	2.72
		60	56	39.03	2.46	38.52	2.51	38.04	2.55	37.72	2.57	37.46	2.59	36.50	2.63
		63	59	39.14	2.44	38.71	2.48	38.38	2.52	38.12	2.53	37.91	2.54	37.02	2.57
		68	64	39.25	2.43	38.91	2.46	38.71	2.49	38.52	2.49	38.36	2.50	37.56	2.52
Two (2) Ducted Indoor Units	9 + 9	-4	-4.4	6.97	1.48	6.55	1.54	6.45	1.56	6.36	1.57	6.29	1.58	6.02	1.64
		0	-0.4	7.94	1.51	7.52	1.56	7.37	1.59	7.26	1.60	7.17	1.61	6.87	1.67
		5	4.5	9.13	1.53	8.72	1.59	8.50	1.62	8.36	1.64	8.25	1.65	7.92	1.71
		10	9	10.23	1.55	9.82	1.61	9.54	1.65	9.38	1.67	9.24	1.69	8.88	1.74
		17	15	11.68	1.59	11.28	1.64	10.92	1.69	10.73	1.72	10.57	1.74	10.16	1.79
		20	19	12.66	1.61	12.25	1.66	11.84	1.71	11.62	1.75	11.45	1.77	11.01	1.82
		25	23	14.28	1.65	13.86	1.70	13.38	1.76	13.12	1.79	12.92	1.82	12.44	1.87
		30	28	15.92	1.69	15.43	1.75	14.90	1.80	14.62	1.84	14.41	1.88	13.88	1.92
		35	32	17.56	1.74	17.00	1.80	16.42	1.85	16.12	1.89	15.89	1.93	15.31	1.97
		40	36	18.45	1.79	17.93	1.85	17.36	1.91	17.06	1.95	16.82	1.98	16.21	2.03
		45	41	19.57	1.86	19.10	1.92	18.54	1.98	18.23	2.01	17.99	2.04	17.33	2.10
		47	43	20.02	1.88	19.57	1.94	19.01	2.01	18.70	2.04	18.45	2.07	17.78	2.13
		50	46	20.08	1.87	19.67	1.93	19.18	1.98	18.91	2.01	18.68	2.03	18.05	2.09
		55	51	20.17	1.85	19.84	1.90	19.47	1.94	19.25	1.96	19.07	1.98	18.51	2.02
		60	56	20.27	1.83	20.01	1.87	19.76	1.90	19.59	1.91	19.46	1.92	18.96	1.95
		63	59	20.33	1.82	20.11	1.85	19.94	1.87	19.80	1.88	19.69	1.89	19.23	1.91
		68	64	20.39	1.81	20.21	1.83	20.11	1.85	20.01	1.86	19.92	1.86	19.51	1.88

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 358: LMU36CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	9 + 12	-4	-4.4	8.13	1.67	7.64	1.74	7.53	1.76	7.42	1.77	7.34	1.78	7.03	1.85
		0	-0.4	9.27	1.70	8.78	1.76	8.60	1.79	8.47	1.81	8.37	1.82	8.02	1.88
		5	4.5	10.66	1.73	10.17	1.79	9.92	1.83	9.76	1.85	9.63	1.86	9.24	1.93
		10	9	11.93	1.75	11.45	1.81	11.13	1.86	10.94	1.88	10.79	1.90	10.36	1.96
		17	15	13.63	1.79	13.16	1.85	12.74	1.90	12.51	1.93	12.33	1.96	11.86	2.02
		20	19	14.77	1.81	14.30	1.87	13.82	1.93	13.56	1.97	13.36	2.00	12.85	2.05
		25	23	16.67	1.86	16.17	1.91	15.61	1.98	15.31	2.02	15.08	2.06	14.51	2.11
		30	28	18.58	1.91	18.00	1.97	17.38	2.03	17.06	2.08	16.81	2.11	16.19	2.17
		35	32	20.49	1.96	19.83	2.03	19.16	2.09	18.81	2.13	18.54	2.17	17.87	2.23
		40	36	21.53	2.02	20.93	2.09	20.26	2.15	19.91	2.19	19.63	2.23	18.92	2.29
		45	41	22.83	2.09	22.29	2.16	21.63	2.23	21.27	2.27	20.99	2.30	20.22	2.37
		47	43	23.36	2.12	22.83	2.19	22.18	2.26	21.82	2.30	21.53	2.33	20.75	2.40
		50	46	23.43	2.11	22.95	2.17	22.38	2.23	22.06	2.27	21.80	2.29	21.06	2.36
		55	51	23.54	2.09	23.15	2.14	22.72	2.19	22.46	2.21	22.25	2.23	21.59	2.28
		60	56	23.65	2.06	23.35	2.10	23.06	2.14	22.86	2.16	22.70	2.17	22.12	2.20
		63	59	23.72	2.05	23.46	2.08	23.26	2.11	23.10	2.12	22.97	2.13	22.44	2.16
		68	64	23.79	2.04	23.58	2.06	23.47	2.09	23.35	2.09	23.25	2.10	22.76	2.11
	12 + 12	-4	-4.4	9.29	1.83	8.73	1.90	8.60	1.92	8.48	1.93	8.38	1.94	8.03	2.02
		0	-0.4	10.59	1.85	10.03	1.92	9.83	1.95	9.68	1.97	9.56	1.98	9.17	2.05
		5	4.5	12.17	1.88	11.62	1.95	11.33	1.99	11.15	2.02	11.00	2.03	10.56	2.10
		10	9	13.63	1.91	13.08	1.98	12.72	2.03	12.50	2.06	12.32	2.08	11.84	2.14
		17	15	15.58	1.95	15.04	2.01	14.56	2.08	14.30	2.11	14.09	2.14	13.55	2.20
		20	19	16.87	1.98	16.34	2.04	15.79	2.11	15.50	2.15	15.26	2.18	14.68	2.24
		25	23	19.04	2.03	18.48	2.09	17.83	2.16	17.50	2.21	17.23	2.24	16.58	2.30
		30	28	21.22	2.08	20.57	2.15	19.86	2.22	19.50	2.27	19.20	2.31	18.50	2.37
		35	32	23.41	2.14	22.66	2.22	21.89	2.28	21.50	2.33	21.18	2.37	20.42	2.43
		40	36	24.60	2.20	23.91	2.28	23.15	2.35	22.74	2.40	22.42	2.43	21.61	2.50
		45	41	26.09	2.28	25.47	2.36	24.72	2.43	24.31	2.48	23.98	2.51	23.11	2.59
		47	43	26.69	2.31	26.09	2.39	25.34	2.47	24.93	2.51	24.60	2.54	23.70	2.62
		50	46	26.76	2.30	26.22	2.37	25.58	2.44	25.20	2.47	24.91	2.50	24.07	2.57
		55	51	26.89	2.28	26.45	2.33	25.96	2.39	25.66	2.41	25.42	2.44	24.67	2.49
		60	56	27.03	2.25	26.67	2.29	26.35	2.34	26.12	2.35	25.94	2.37	25.28	2.41
		63	59	27.10	2.24	26.81	2.27	26.58	2.31	26.39	2.32	26.25	2.33	25.64	2.36
		68	64	27.18	2.22	26.94	2.25	26.81	2.28	26.67	2.28	26.56	2.29	26.01	2.31
	9 + 18	-4	-4.4	10.45	2.01	9.82	2.09	9.68	2.11	9.54	2.13	9.43	2.14	9.03	2.22
		0	-0.4	11.91	2.04	11.28	2.11	11.06	2.15	10.89	2.17	10.76	2.18	10.31	2.26
		5	4.5	13.70	2.07	13.08	2.15	12.75	2.19	12.54	2.22	12.38	2.24	11.88	2.31
		10	9	15.34	2.10	14.72	2.18	14.31	2.23	14.06	2.26	13.87	2.29	13.32	2.36
		17	15	17.53	2.15	16.92	2.21	16.38	2.28	16.09	2.32	15.85	2.35	15.24	2.42
		20	19	18.99	2.17	18.38	2.24	17.77	2.32	17.44	2.36	17.17	2.40	16.52	2.46
		25	23	21.42	2.23	20.79	2.29	20.07	2.38	19.69	2.43	19.38	2.47	18.65	2.53
		30	28	23.88	2.29	23.14	2.37	22.35	2.44	21.94	2.49	21.61	2.54	20.81	2.60
		35	32	26.34	2.36	25.50	2.44	24.63	2.50	24.19	2.56	23.83	2.61	22.97	2.67
		40	36	27.68	2.42	26.90	2.51	26.04	2.58	25.59	2.63	25.23	2.68	24.32	2.75
		45	41	29.35	2.51	28.65	2.59	27.81	2.68	27.35	2.72	26.98	2.76	26.00	2.84
		47	43	30.03	2.54	29.35	2.63	28.52	2.71	28.05	2.76	27.68	2.80	26.67	2.88
		50	46	30.11	2.53	29.51	2.60	28.78	2.68	28.36	2.72	28.03	2.75	27.08	2.83
		55	51	30.26	2.50	29.76	2.56	29.21	2.62	28.87	2.65	28.61	2.68	27.76	2.74
		60	56	30.41	2.48	30.01	2.52	29.64	2.57	29.39	2.59	29.19	2.60	28.44	2.64
		63	59	30.50	2.46	30.16	2.50	29.90	2.54	29.70	2.55	29.53	2.56	28.85	2.59
		68	64	30.58	2.44	30.32	2.47	30.17	2.50	30.01	2.51	29.89	2.52	29.26	2.54

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 359: LMU369HV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 18	-4	-4.4	11.62	2.17	10.91	2.25	10.75	2.28	10.60	2.30	10.48	2.31	10.04	2.39
		0	-0.4	13.24	2.20	12.54	2.28	12.29	2.32	12.10	2.34	11.95	2.36	11.46	2.44
		5	4.5	15.22	2.24	14.53	2.32	14.17	2.37	13.94	2.39	13.75	2.41	13.20	2.49
		10	9	17.05	2.27	16.36	2.35	15.90	2.41	15.63	2.44	15.41	2.47	14.80	2.55
		17	15	19.48	2.32	18.80	2.39	18.21	2.47	17.88	2.51	17.61	2.54	16.94	2.61
		20	19	21.10	2.35	20.42	2.42	19.74	2.50	19.38	2.55	19.08	2.59	18.36	2.66
		25	23	23.81	2.41	23.10	2.48	22.30	2.57	21.88	2.62	21.54	2.66	20.73	2.73
		30	28	26.54	2.48	25.72	2.56	24.83	2.64	24.38	2.69	24.01	2.74	23.13	2.81
		35	32	29.26	2.54	28.33	2.63	27.37	2.70	26.88	2.77	26.48	2.82	25.53	2.88
		40	36	30.76	2.62	29.89	2.71	28.94	2.79	28.44	2.84	28.04	2.89	27.02	2.97
		45	41	32.62	2.71	31.84	2.80	30.90	2.89	30.39	2.94	29.98	2.98	28.89	3.07
		47	43	33.37	2.75	32.62	2.84	31.69	2.93	31.17	2.98	30.76	3.02	29.64	3.11
		50	46	33.46	2.73	32.79	2.81	31.98	2.89	31.51	2.94	31.14	2.97	30.09	3.05
		55	51	33.63	2.70	33.07	2.77	32.46	2.83	32.09	2.87	31.79	2.89	30.85	2.95
		60	56	33.79	2.67	33.35	2.72	32.94	2.77	32.66	2.80	32.43	2.81	31.60	2.86
		63	59	33.89	2.66	33.52	2.70	33.23	2.74	33.00	2.75	32.82	2.76	32.06	2.80
		68	64	33.99	2.64	33.69	2.67	33.52	2.70	33.35	2.71	33.21	2.72	32.52	2.74
	9 + 24	-4	-4.4	12.67	2.26	11.90	2.35	11.73	2.38	11.57	2.40	11.43	2.41	10.95	2.50
		0	-0.4	14.44	2.29	13.68	2.38	13.40	2.42	13.20	2.44	13.04	2.46	12.50	2.55
		5	4.5	16.60	2.33	15.85	2.42	15.46	2.47	15.21	2.50	15.00	2.52	14.40	2.60
		10	9	18.59	2.37	17.85	2.45	17.34	2.51	17.05	2.55	16.81	2.58	16.15	2.66
		17	15	21.24	2.42	20.51	2.50	19.86	2.57	19.50	2.62	19.21	2.65	18.47	2.73
		20	19	23.01	2.45	22.28	2.52	21.54	2.61	21.14	2.66	20.82	2.70	20.03	2.77
		25	23	25.97	2.51	25.20	2.58	24.32	2.68	23.86	2.74	23.49	2.78	22.61	2.85
		30	28	28.95	2.58	28.05	2.67	27.09	2.75	26.59	2.81	26.19	2.86	25.23	2.93
		35	32	31.92	2.65	30.90	2.75	29.85	2.82	29.32	2.89	28.89	2.94	27.84	3.01
		40	36	33.55	2.73	32.61	2.83	31.57	2.91	31.02	2.97	30.58	3.02	29.47	3.10
		45	41	35.58	2.83	34.73	2.92	33.71	3.01	33.15	3.07	32.70	3.11	31.51	3.20
		47	43	36.39	2.87	35.58	2.96	34.56	3.06	34.00	3.11	33.55	3.15	32.33	3.25
		50	46	36.50	2.85	35.77	2.94	34.88	3.02	34.37	3.07	33.97	3.10	32.82	3.19
		55	51	36.68	2.82	36.07	2.89	35.41	2.96	35.00	2.99	34.67	3.02	33.65	3.08
		60	56	36.86	2.79	36.38	2.84	35.93	2.90	35.62	2.92	35.38	2.93	34.47	2.98
		63	59	36.96	2.77	36.56	2.82	36.25	2.86	36.00	2.87	35.80	2.88	34.97	2.92
		68	64	37.07	2.75	36.75	2.79	36.56	2.82	36.38	2.83	36.23	2.83	35.47	2.86
	18 + 18	-4	-4.4	12.67	2.26	11.90	2.35	11.73	2.38	11.57	2.40	11.43	2.41	10.95	2.50
		0	-0.4	14.44	2.29	13.68	2.38	13.40	2.42	13.20	2.44	13.04	2.46	12.50	2.55
		5	4.5	16.60	2.33	15.85	2.42	15.46	2.47	15.21	2.50	15.00	2.52	14.40	2.60
		10	9	18.59	2.37	17.85	2.45	17.34	2.51	17.05	2.55	16.81	2.58	16.15	2.66
		17	15	21.24	2.42	20.51	2.50	19.86	2.57	19.50	2.62	19.21	2.65	18.47	2.73
		20	19	23.01	2.45	22.28	2.52	21.54	2.61	21.14	2.66	20.82	2.70	20.03	2.77
		25	23	25.97	2.51	25.20	2.58	24.32	2.68	23.86	2.74	23.49	2.78	22.61	2.85
		30	28	28.95	2.58	28.05	2.67	27.09	2.75	26.59	2.81	26.19	2.86	25.23	2.93
		35	32	31.92	2.65	30.90	2.75	29.85	2.82	29.32	2.89	28.89	2.94	27.84	3.01
		40	36	33.55	2.73	32.61	2.83	31.57	2.91	31.02	2.97	30.58	3.02	29.47	3.10
		45	41	35.58	2.83	34.73	2.92	33.71	3.01	33.15	3.07	32.70	3.11	31.51	3.20
		47	43	36.39	2.87	35.58	2.96	34.56	3.06	34.00	3.11	33.55	3.15	32.33	3.25
		50	46	36.50	2.85	35.77	2.94	34.88	3.02	34.37	3.07	33.97	3.10	32.82	3.19
		55	51	36.68	2.82	36.07	2.89	35.41	2.96	35.00	2.99	34.67	3.02	33.65	3.08
		60	56	36.86	2.79	36.38	2.84	35.93	2.90	35.62	2.92	35.38	2.93	34.47	2.98
		63	59	36.96	2.77	36.56	2.82	36.25	2.86	36.00	2.87	35.80	2.88	34.97	2.92
		68	64	37.07	2.75	36.75	2.79	36.56	2.82	36.38	2.83	36.23	2.83	35.47	2.86

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 360: LMU36CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Ducted Indoor Units	12 + 24	-4	-4.4	12.67	2.26	11.90	2.35	11.73	2.38	11.57	2.40	11.43	2.41	10.95	2.50
		0	-0.4	14.44	2.29	13.68	2.38	13.40	2.42	13.20	2.44	13.04	2.46	12.50	2.55
		5	4.5	16.60	2.33	15.85	2.42	15.46	2.47	15.21	2.50	15.00	2.52	14.40	2.60
		10	9	18.59	2.37	17.85	2.45	17.34	2.51	17.05	2.55	16.81	2.58	16.15	2.66
		17	15	21.24	2.42	20.51	2.50	19.86	2.57	19.50	2.62	19.21	2.65	18.47	2.73
		20	19	23.01	2.45	22.28	2.52	21.54	2.61	21.14	2.66	20.82	2.70	20.03	2.77
		25	23	25.97	2.51	25.20	2.58	24.32	2.68	23.86	2.74	23.49	2.78	22.61	2.85
		30	28	28.95	2.58	28.05	2.67	27.09	2.75	26.59	2.81	26.19	2.86	25.23	2.93
		35	32	31.92	2.65	30.90	2.75	29.85	2.82	29.32	2.89	28.89	2.94	27.84	3.01
		40	36	33.55	2.73	32.61	2.83	31.57	2.91	31.02	2.97	30.58	3.02	29.47	3.10
		45	41	35.58	2.83	34.73	2.92	33.71	3.01	33.15	3.07	32.70	3.11	31.51	3.20
		47	43	36.39	2.87	35.58	2.96	34.56	3.06	34.00	3.11	33.55	3.15	32.33	3.25
		50	46	36.50	2.85	35.77	2.94	34.88	3.02	34.37	3.07	33.97	3.10	32.82	3.19
		55	51	36.68	2.82	36.07	2.89	35.41	2.96	35.00	2.99	34.67	3.02	33.65	3.08
		60	56	36.86	2.79	36.38	2.84	35.93	2.90	35.62	2.92	35.38	2.93	34.47	2.98
		63	59	36.96	2.77	36.56	2.82	36.25	2.86	36.00	2.87	35.80	2.88	34.97	2.92
Three (3) Ducted Indoor Units	9 + 9 + 9	68	64	37.07	2.75	36.75	2.79	36.56	2.82	36.38	2.83	36.23	2.83	35.47	2.86
		-4	-4.4	10.45	1.92	9.82	2.00	9.68	2.02	9.54	2.03	9.43	2.05	9.03	2.12
		0	-0.4	11.91	1.95	11.28	2.02	11.06	2.05	10.89	2.07	10.76	2.09	10.31	2.16
		5	4.5	13.70	1.98	13.08	2.05	12.75	2.10	12.54	2.12	12.38	2.14	11.88	2.21
		10	9	15.34	2.01	14.72	2.08	14.31	2.13	14.06	2.16	13.87	2.19	13.32	2.26
		17	15	17.53	2.05	16.92	2.12	16.38	2.18	16.09	2.22	15.85	2.25	15.24	2.31
		20	19	18.99	2.08	18.38	2.14	17.77	2.22	17.44	2.26	17.17	2.29	16.52	2.35
		25	23	21.42	2.13	20.79	2.19	20.07	2.28	19.69	2.32	19.38	2.36	18.65	2.42
		30	28	23.88	2.19	23.14	2.26	22.35	2.33	21.94	2.39	21.61	2.43	20.81	2.49
		35	32	26.34	2.25	25.50	2.33	24.63	2.39	24.19	2.45	23.83	2.49	22.97	2.56
		40	36	27.68	2.32	26.90	2.40	26.04	2.47	25.59	2.52	25.23	2.56	24.32	2.63
		45	41	29.35	2.40	28.65	2.48	27.81	2.56	27.35	2.61	26.98	2.64	26.00	2.72
		47	43	30.03	2.43	29.35	2.51	28.52	2.60	28.05	2.64	27.68	2.68	26.67	2.76
		50	46	30.11	2.42	29.51	2.49	28.78	2.56	28.36	2.60	28.03	2.63	27.08	2.70
		55	51	30.26	2.39	29.76	2.45	29.21	2.51	28.87	2.54	28.61	2.56	27.76	2.62
		60	56	30.41	2.37	30.01	2.41	29.64	2.46	29.39	2.48	29.19	2.49	28.44	2.53
		63	59	30.50	2.35	30.16	2.39	29.90	2.43	29.70	2.44	29.53	2.45	28.85	2.48
		68	64	30.58	2.34	30.32	2.37	30.17	2.39	30.01	2.40	29.89	2.41	29.26	2.43
	9 + 9 + 12	-4	-4.4	11.62	2.04	10.91	2.12	10.75	2.14	10.60	2.16	10.48	2.17	10.04	2.25
		0	-0.4	13.24	2.07	12.54	2.14	12.29	2.18	12.10	2.20	11.95	2.21	11.46	2.29
		5	4.5	15.22	2.10	14.53	2.18	14.17	2.22	13.94	2.25	13.75	2.27	13.20	2.34
		10	9	17.05	2.13	16.36	2.21	15.90	2.26	15.63	2.29	15.41	2.32	14.80	2.39
		17	15	19.48	2.18	18.80	2.25	18.21	2.32	17.88	2.35	17.61	2.39	16.94	2.46
		20	19	21.10	2.21	20.42	2.27	19.74	2.35	19.38	2.40	19.08	2.43	18.36	2.50
		25	23	23.81	2.26	23.10	2.33	22.30	2.41	21.88	2.46	21.54	2.50	20.73	2.57
		30	28	26.54	2.33	25.72	2.40	24.83	2.48	24.38	2.53	24.01	2.57	23.13	2.64
		35	32	29.26	2.39	28.33	2.48	27.37	2.54	26.88	2.60	26.48	2.65	25.53	2.71
		40	36	30.76	2.46	29.89	2.55	28.94	2.62	28.44	2.67	28.04	2.72	27.02	2.79
		45	41	32.62	2.55	31.84	2.63	30.90	2.71	30.39	2.76	29.98	2.80	28.89	2.88
		47	43	33.37	2.58	32.62	2.67	31.69	2.75	31.17	2.80	30.76	2.84	29.64	2.92
		50	46	33.46	2.57	32.79	2.64	31.98	2.72	31.51	2.76	31.14	2.79	30.09	2.87
		55	51	33.63	2.54	33.07	2.60	32.46	2.66	32.09	2.69	31.79	2.72	30.85	2.78
		60	56	33.79	2.51	33.35	2.56	32.94	2.61	32.66	2.63	32.43	2.64	31.60	2.68
		63	59	33.89	2.50	33.52	2.54	33.23	2.57	33.00	2.59	32.82	2.60	32.06	2.63
		68	64	33.99	2.48	33.69	2.51	33.52	2.54	33.35	2.55	33.21	2.55	32.52	2.57

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 361: LMU36CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 12 + 12	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69
	9 + 9 + 18	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69
	12 + 12 + 12	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 362: LMU36CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	9 + 12 + 18	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69
	12 + 12 + 18	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69
	9 + 18 + 18	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 363: LMU36CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Ducted Indoor Units	12 + 18 + 18	-4	-4.4	12.67	2.13	11.90	2.22	11.73	2.24	11.57	2.26	11.43	2.27	10.95	2.35
		0	-0.4	14.44	2.16	13.68	2.24	13.40	2.28	13.20	2.30	13.04	2.32	12.50	2.40
		5	4.5	16.60	2.20	15.85	2.28	15.46	2.33	15.21	2.35	15.00	2.37	14.40	2.45
		10	9	18.59	2.23	17.85	2.31	17.34	2.37	17.05	2.40	16.81	2.43	16.15	2.50
		17	15	21.24	2.28	20.51	2.35	19.86	2.42	19.50	2.46	19.21	2.50	18.47	2.57
		20	19	23.01	2.31	22.28	2.38	21.54	2.46	21.14	2.51	20.82	2.54	20.03	2.61
		25	23	25.97	2.37	25.20	2.43	24.32	2.53	23.86	2.58	23.49	2.62	22.61	2.69
		30	28	28.95	2.43	28.05	2.51	27.09	2.59	26.59	2.65	26.19	2.69	25.23	2.76
		35	32	31.92	2.50	30.90	2.59	29.85	2.66	29.32	2.72	28.89	2.77	27.84	2.84
		40	36	33.55	2.57	32.61	2.66	31.57	2.74	31.02	2.80	30.58	2.84	29.47	2.92
		45	41	35.58	2.67	34.73	2.75	33.71	2.84	33.15	2.89	32.70	2.93	31.51	3.02
		47	43	36.39	2.70	35.58	2.79	34.56	2.88	34.00	2.93	33.55	2.97	32.33	3.06
		50	46	36.50	2.68	35.77	2.77	34.88	2.85	34.37	2.89	33.97	2.92	32.82	3.00
		55	51	36.68	2.66	36.07	2.72	35.41	2.79	35.00	2.82	34.67	2.84	33.65	2.90
		60	56	36.86	2.63	36.38	2.68	35.93	2.73	35.62	2.75	35.38	2.76	34.47	2.81
		63	59	36.96	2.61	36.56	2.65	36.25	2.69	36.00	2.71	35.80	2.72	34.97	2.75
		68	64	37.07	2.59	36.75	2.63	36.56	2.66	36.38	2.67	36.23	2.67	35.47	2.69
Four (4) Ducted Indoor Units	9 + 9 + 9 + 9	-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
		55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
		63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60
	9 + 9 + 9 + 12	-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
		55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
		63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 364: LMU36CHV Heating Capacity Table — Ducted Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 12 + 12	-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
		55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
	9 + 9 + 9 + 18	63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60
		-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
	9 + 12 + 12 + 12	55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
		63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60
		-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
		55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
		63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 365: LMU36CHV Heating Capacity Table — Ducted, continued, and Mixed Indoor Units.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Ducted Indoor Units	9 + 9 + 12 + 18	-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
		55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
		63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60
	12 + 12 + 12 + 12	-4	-4.4	12.67	2.06	11.90	2.14	11.73	2.17	11.57	2.18	11.43	2.19	10.95	2.27
		0	-0.4	14.44	2.09	13.68	2.17	13.40	2.20	13.20	2.22	13.04	2.24	12.50	2.32
		5	4.5	16.60	2.12	15.85	2.20	15.46	2.25	15.21	2.27	15.00	2.29	14.40	2.37
		10	9	18.59	2.16	17.85	2.23	17.34	2.29	17.05	2.32	16.81	2.34	16.15	2.42
		17	15	21.24	2.20	20.51	2.27	19.86	2.34	19.50	2.38	19.21	2.41	18.47	2.48
		20	19	23.01	2.23	22.28	2.30	21.54	2.38	21.14	2.42	20.82	2.46	20.03	2.52
		25	23	25.97	2.28	25.20	2.35	24.32	2.44	23.86	2.49	23.49	2.53	22.61	2.60
		30	28	28.95	2.35	28.05	2.43	27.09	2.50	26.59	2.56	26.19	2.60	25.23	2.67
		35	32	31.92	2.42	30.90	2.50	29.85	2.57	29.32	2.63	28.89	2.67	27.84	2.74
		40	36	33.55	2.49	32.61	2.57	31.57	2.64	31.02	2.70	30.58	2.74	29.47	2.82
		45	41	35.58	2.57	34.73	2.66	33.71	2.74	33.15	2.79	32.70	2.83	31.51	2.92
		47	43	36.39	2.61	35.58	2.70	34.56	2.78	34.00	2.83	33.55	2.87	32.33	2.95
		50	46	36.50	2.59	35.77	2.67	34.88	2.75	34.37	2.79	33.97	2.82	32.82	2.90
		55	51	36.68	2.57	36.07	2.63	35.41	2.69	35.00	2.72	34.67	2.75	33.65	2.81
		60	56	36.86	2.54	36.38	2.59	35.93	2.63	35.62	2.65	35.38	2.67	34.47	2.71
		63	59	36.96	2.52	36.56	2.56	36.25	2.60	36.00	2.61	35.80	2.62	34.97	2.66
		68	64	37.07	2.51	36.75	2.54	36.56	2.57	36.38	2.57	36.23	2.58	35.47	2.60
Two (2) Mixed Indoor Units	7 + 9	-4	-4.4	6.06	1.28	5.69	1.33	5.61	1.34	5.53	1.35	5.47	1.36	5.24	1.41
		0	-0.4	6.98	1.30	6.61	1.35	6.48	1.37	6.38	1.38	6.31	1.39	6.04	1.44
		5	4.5	8.47	1.33	8.06	1.37	7.87	1.40	7.75	1.42	7.65	1.43	7.34	1.48
		10	9	9.71	1.35	9.31	1.40	9.05	1.43	8.90	1.45	8.77	1.47	8.43	1.52
		17	15	11.07	1.39	10.68	1.43	10.34	1.47	10.16	1.50	10.01	1.52	9.63	1.56
		20	19	11.89	1.41	11.51	1.45	11.13	1.50	10.93	1.53	10.76	1.55	10.35	1.59
		25	23	13.28	1.45	12.88	1.49	12.44	1.55	12.20	1.58	12.02	1.60	11.56	1.65
		30	28	14.67	1.50	14.21	1.55	13.73	1.59	13.48	1.63	13.28	1.66	12.78	1.70
		35	32	16.06	1.54	15.55	1.60	15.02	1.64	14.75	1.68	14.54	1.71	14.01	1.75
		40	36	16.88	1.59	16.41	1.65	15.89	1.69	15.61	1.73	15.39	1.76	14.83	1.80
		45	41	17.91	1.65	17.48	1.70	16.96	1.75	16.68	1.79	16.46	1.81	15.86	1.86
		47	43	18.32	1.67	17.91	1.72	17.39	1.78	17.11	1.81	16.88	1.83	16.27	1.89
		50	46	18.37	1.66	18.00	1.71	17.55	1.76	17.30	1.78	17.10	1.81	16.52	1.85
		55	51	18.46	1.64	18.15	1.68	17.82	1.72	17.61	1.74	17.45	1.76	16.93	1.79
		60	56	18.55	1.62	18.31	1.65	18.08	1.69	17.93	1.70	17.80	1.71	17.35	1.73
		63	59	18.60	1.61	18.40	1.64	18.24	1.66	18.12	1.67	18.02	1.68	17.60	1.70
		68	64	18.66	1.60	18.49	1.62	18.40	1.64	18.31	1.65	18.23	1.65	17.85	1.66

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 366: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 9	-4	-4.4	6.82	1.41	6.40	1.47	6.31	1.48	6.23	1.49	6.16	1.50	5.89	1.56
		0	-0.4	7.86	1.44	7.44	1.49	7.29	1.51	7.18	1.53	7.09	1.54	6.80	1.59
		5	4.5	9.54	1.47	9.08	1.52	8.87	1.55	8.73	1.57	8.61	1.58	8.26	1.64
		10	9	10.93	1.49	10.48	1.55	10.19	1.58	10.02	1.61	9.88	1.62	9.48	1.67
		17	15	12.46	1.53	12.03	1.58	11.65	1.63	11.44	1.66	11.27	1.68	10.84	1.73
		20	19	13.39	1.56	12.97	1.60	12.53	1.66	12.30	1.69	12.12	1.71	11.65	1.76
		25	23	14.95	1.60	14.51	1.65	14.00	1.71	13.73	1.74	13.52	1.77	13.02	1.82
		30	28	16.52	1.65	16.00	1.71	15.46	1.76	15.18	1.80	14.94	1.83	14.40	1.88
		35	32	18.07	1.71	17.50	1.77	16.90	1.81	16.60	1.86	16.36	1.89	15.76	1.94
		40	36	18.99	1.76	18.46	1.82	17.87	1.87	17.56	1.91	17.31	1.94	16.69	1.99
		45	41	20.15	1.82	19.66	1.88	19.08	1.94	18.77	1.97	18.51	2.00	17.84	2.06
		47	43	20.61	1.84	20.15	1.91	19.57	1.97	19.25	2.00	18.99	2.03	18.30	2.09
		50	46	20.67	1.83	20.25	1.89	19.75	1.94	19.46	1.97	19.23	1.99	18.58	2.05
		55	51	20.77	1.81	20.42	1.86	20.05	1.90	19.82	1.92	19.63	1.94	19.05	1.98
		60	56	20.87	1.79	20.60	1.83	20.34	1.86	20.17	1.88	20.03	1.89	19.52	1.92
		63	59	20.93	1.78	20.70	1.81	20.52	1.84	20.38	1.85	20.27	1.85	19.80	1.88
		68	64	20.99	1.77	20.81	1.79	20.70	1.81	20.60	1.82	20.51	1.82	20.08	1.84
	7 + 12	-4	-4.4	7.20	1.47	6.76	1.53	6.66	1.55	6.57	1.56	6.50	1.57	6.22	1.63
		0	-0.4	8.29	1.50	7.85	1.56	7.70	1.58	7.58	1.60	7.49	1.61	7.18	1.66
		5	4.5	10.06	1.53	9.59	1.59	9.37	1.62	9.22	1.64	9.10	1.65	8.72	1.71
		10	9	11.54	1.56	11.07	1.61	10.76	1.66	10.58	1.68	10.43	1.70	10.02	1.75
		17	15	13.16	1.60	12.70	1.65	12.31	1.70	12.08	1.73	11.90	1.75	11.45	1.80
		20	19	14.14	1.63	13.69	1.68	13.23	1.73	12.99	1.77	12.79	1.79	12.31	1.84
		25	23	15.79	1.67	15.31	1.72	14.79	1.79	14.51	1.82	14.28	1.85	13.75	1.90
		30	28	17.44	1.73	16.90	1.79	16.32	1.84	16.02	1.88	15.78	1.91	15.20	1.96
		35	32	19.08	1.78	18.47	1.85	17.84	1.90	17.52	1.94	17.26	1.97	16.64	2.02
		40	36	20.05	1.84	19.49	1.90	18.87	1.95	18.54	1.99	18.28	2.03	17.61	2.08
		45	41	21.27	1.90	20.76	1.96	20.15	2.03	19.81	2.06	19.54	2.09	18.83	2.15
		47	43	21.75	1.93	21.27	1.99	20.66	2.05	20.32	2.09	20.05	2.12	19.32	2.18
		50	46	21.82	1.92	21.37	1.97	20.85	2.03	20.54	2.06	20.30	2.08	19.62	2.14
		55	51	21.92	1.89	21.56	1.94	21.16	1.99	20.92	2.01	20.72	2.03	20.11	2.07
		60	56	22.03	1.87	21.74	1.91	21.47	1.95	21.29	1.96	21.14	1.97	20.60	2.00
		63	59	22.09	1.86	21.85	1.89	21.66	1.92	21.51	1.93	21.40	1.94	20.90	1.96
		68	64	22.16	1.85	21.96	1.87	21.85	1.90	21.74	1.90	21.65	1.91	21.20	1.92
	9 + 12	-4	-4.4	7.96	1.59	7.47	1.66	7.37	1.68	7.26	1.69	7.18	1.70	6.88	1.76
		0	-0.4	9.17	1.62	8.68	1.68	8.51	1.71	8.38	1.73	8.28	1.74	7.93	1.80
		5	4.5	11.14	1.66	10.60	1.72	10.36	1.75	10.20	1.77	10.06	1.79	9.65	1.85
		10	9	12.76	1.69	12.25	1.75	11.90	1.79	11.70	1.81	11.54	1.83	11.09	1.89
		17	15	14.56	1.73	14.06	1.79	13.61	1.84	13.36	1.87	13.17	1.90	12.66	1.95
		20	19	15.64	1.76	15.15	1.81	14.64	1.87	14.37	1.91	14.16	1.94	13.61	1.99
		25	23	17.46	1.81	16.95	1.86	16.36	1.93	16.05	1.97	15.80	2.00	15.21	2.06
		30	28	19.30	1.87	18.70	1.93	18.06	1.99	17.72	2.03	17.46	2.07	16.81	2.12
		35	32	21.09	1.93	20.42	2.00	19.72	2.05	19.37	2.10	19.08	2.14	18.39	2.19
		40	36	22.16	1.99	21.54	2.05	20.85	2.11	20.49	2.16	20.20	2.19	19.47	2.25
		45	41	23.50	2.06	22.94	2.12	22.27	2.19	21.90	2.23	21.60	2.26	20.82	2.33
		47	43	24.04	2.08	23.50	2.15	22.83	2.22	22.46	2.26	22.16	2.29	21.36	2.36
		50	46	24.11	2.07	23.63	2.13	23.04	2.19	22.71	2.23	22.44	2.25	21.68	2.31
		55	51	24.23	2.05	23.83	2.10	23.39	2.15	23.12	2.17	22.91	2.19	22.23	2.24
		60	56	24.35	2.03	24.03	2.07	23.74	2.10	23.53	2.12	23.37	2.13	22.77	2.17
		63	59	24.42	2.01	24.15	2.05	23.94	2.08	23.78	2.09	23.65	2.10	23.10	2.12
		68	64	24.49	2.00	24.27	2.03	24.15	2.05	24.03	2.06	23.93	2.06	23.43	2.08

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 367: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 15	-4	-4.4	9.10	1.74	8.54	1.81	8.42	1.83	8.30	1.85	8.21	1.85	7.86	1.92
		0	-0.4	10.48	1.77	9.92	1.84	9.72	1.87	9.58	1.89	9.46	1.90	9.07	1.97
		5	4.5	12.74	1.81	12.13	1.88	11.85	1.92	11.67	1.94	11.52	1.95	11.05	2.02
		10	9	14.61	1.84	14.02	1.91	13.63	1.96	13.39	1.98	13.21	2.00	12.69	2.07
		17	15	16.67	1.89	16.08	1.95	15.57	2.01	15.29	2.05	15.07	2.07	14.49	2.13
		20	19	17.90	1.92	17.34	1.98	16.76	2.05	16.45	2.09	16.20	2.12	15.58	2.18
		25	23	19.99	1.98	19.40	2.04	18.72	2.11	18.37	2.15	18.08	2.19	17.41	2.25
		30	28	22.08	2.04	21.40	2.11	20.67	2.18	20.29	2.22	19.99	2.26	19.25	2.32
		35	32	24.10	2.11	23.33	2.18	22.54	2.24	22.13	2.29	21.81	2.33	21.02	2.39
		40	36	25.33	2.17	24.62	2.25	23.83	2.31	23.42	2.36	23.09	2.40	22.25	2.46
		45	41	26.86	2.25	26.22	2.32	25.45	2.39	25.03	2.44	24.69	2.47	23.79	2.54
		47	43	27.48	2.28	26.86	2.35	26.10	2.43	25.67	2.47	25.33	2.50	24.41	2.58
		50	46	27.56	2.26	27.00	2.33	26.33	2.40	25.95	2.43	25.65	2.46	24.78	2.53
		55	51	27.69	2.24	27.23	2.29	26.73	2.35	26.42	2.38	26.18	2.40	25.40	2.45
		60	56	27.83	2.22	27.47	2.26	27.13	2.30	26.90	2.32	26.71	2.33	26.03	2.37
		63	59	27.91	2.20	27.60	2.24	27.37	2.27	27.18	2.28	27.03	2.29	26.40	2.32
		68	64	27.99	2.19	27.74	2.21	27.61	2.24	27.46	2.25	27.35	2.25	26.78	2.27
	12 + 12	-4	-4.4	9.10	1.74	8.54	1.81	8.42	1.83	8.30	1.85	8.21	1.85	7.86	1.92
		0	-0.4	10.48	1.77	9.92	1.84	9.72	1.87	9.58	1.89	9.46	1.90	9.07	1.97
		5	4.5	12.74	1.81	12.13	1.88	11.85	1.92	11.67	1.94	11.52	1.95	11.05	2.02
		10	9	14.61	1.84	14.02	1.91	13.63	1.96	13.39	1.98	13.21	2.00	12.69	2.07
		17	15	16.67	1.89	16.08	1.95	15.57	2.01	15.29	2.05	15.07	2.07	14.49	2.13
		20	19	17.90	1.92	17.34	1.98	16.76	2.05	16.45	2.09	16.20	2.12	15.58	2.18
		25	23	19.99	1.98	19.40	2.04	18.72	2.11	18.37	2.15	18.08	2.19	17.41	2.25
		30	28	22.08	2.04	21.40	2.11	20.67	2.18	20.29	2.22	19.99	2.26	19.25	2.32
		35	32	24.10	2.11	23.33	2.18	22.54	2.24	22.13	2.29	21.81	2.33	21.02	2.39
		40	36	25.33	2.17	24.62	2.25	23.83	2.31	23.42	2.36	23.09	2.40	22.25	2.46
		45	41	26.86	2.25	26.22	2.32	25.45	2.39	25.03	2.44	24.69	2.47	23.79	2.54
		47	43	27.48	2.28	26.86	2.35	26.10	2.43	25.67	2.47	25.33	2.50	24.41	2.58
		50	46	27.56	2.26	27.00	2.33	26.33	2.40	25.95	2.43	25.65	2.46	24.78	2.53
		55	51	27.69	2.24	27.23	2.29	26.73	2.35	26.42	2.38	26.18	2.40	25.40	2.45
		60	56	27.83	2.22	27.47	2.26	27.13	2.30	26.90	2.32	26.71	2.33	26.03	2.37
		63	59	27.91	2.20	27.60	2.24	27.37	2.27	27.18	2.28	27.03	2.29	26.40	2.32
		68	64	27.99	2.19	27.74	2.21	27.61	2.24	27.46	2.25	27.35	2.25	26.78	2.27
	7 + 18	-4	-4.4	9.48	1.80	8.89	1.87	8.77	1.89	8.65	1.91	8.55	1.91	8.19	1.99
		0	-0.4	10.91	1.83	10.33	1.90	10.13	1.93	9.98	1.95	9.85	1.96	9.45	2.03
		5	4.5	13.28	1.87	12.65	1.94	12.35	1.98	12.16	2.00	12.00	2.02	11.51	2.09
		10	9	15.23	1.90	14.61	1.97	14.21	2.02	13.96	2.05	13.76	2.07	13.22	2.13
		17	15	17.36	1.95	16.76	2.01	16.23	2.08	15.94	2.11	15.70	2.14	15.10	2.20
		20	19	18.66	1.98	18.06	2.04	17.47	2.11	17.14	2.15	16.88	2.19	16.24	2.25
		25	23	20.83	2.04	20.21	2.10	19.51	2.18	19.15	2.22	18.84	2.26	18.13	2.32
		30	28	23.01	2.11	22.31	2.18	21.54	2.25	21.14	2.30	20.83	2.34	20.06	2.39
		35	32	25.11	2.18	24.31	2.25	23.48	2.31	23.06	2.37	22.72	2.41	21.90	2.47
		40	36	26.38	2.24	25.64	2.32	24.83	2.38	24.40	2.43	24.05	2.47	23.18	2.54
		45	41	27.98	2.32	27.32	2.40	26.51	2.47	26.07	2.52	25.72	2.55	24.78	2.63
		47	43	28.62	2.35	27.98	2.43	27.18	2.51	26.74	2.55	26.38	2.58	25.43	2.66
		50	46	28.71	2.34	28.13	2.41	27.43	2.48	27.03	2.51	26.72	2.54	25.81	2.61
		55	51	28.85	2.31	28.37	2.37	27.85	2.43	27.53	2.45	27.27	2.47	26.46	2.53
		60	56	28.99	2.29	28.61	2.33	28.26	2.37	28.02	2.39	27.82	2.41	27.11	2.44
		63	59	29.07	2.27	28.75	2.31	28.51	2.34	28.31	2.36	28.16	2.36	27.50	2.39
		68	64	29.16	2.26	28.90	2.29	28.76	2.31	28.61	2.32	28.49	2.32	27.90	2.34

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 368: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	9 + 18	-4	-4.4	10.24	1.92	9.61	2.00	9.47	2.02	9.34	2.03	9.24	2.04	8.84	2.12
		0	-0.4	11.79	1.95	11.16	2.03	10.94	2.06	10.78	2.08	10.64	2.09	10.20	2.17
		5	4.5	14.36	1.99	13.67	2.07	13.36	2.11	13.15	2.13	12.97	2.15	12.45	2.22
		10	9	16.46	2.03	15.79	2.10	15.35	2.15	15.09	2.18	14.88	2.21	14.29	2.28
		17	15	18.77	2.08	18.12	2.15	17.55	2.22	17.23	2.25	16.98	2.28	16.33	2.35
		20	19	20.18	2.12	19.53	2.18	18.88	2.26	18.53	2.30	18.25	2.33	17.55	2.40
		25	23	22.52	2.18	21.85	2.24	21.09	2.33	20.70	2.37	20.37	2.41	19.61	2.47
		30	28	24.88	2.25	24.11	2.32	23.28	2.40	22.85	2.45	22.51	2.49	21.69	2.55
		35	32	27.11	2.32	26.25	2.40	25.36	2.47	24.90	2.52	24.54	2.57	23.65	2.63
		40	36	28.50	2.39	27.70	2.47	26.81	2.54	26.35	2.60	25.98	2.64	25.04	2.71
		45	41	30.22	2.47	29.50	2.56	28.63	2.64	28.16	2.68	27.78	2.72	26.77	2.80
		47	43	30.91	2.51	30.22	2.59	29.36	2.67	28.88	2.72	28.50	2.76	27.46	2.84
		50	46	31.00	2.49	30.38	2.57	29.63	2.64	29.20	2.68	28.85	2.71	27.88	2.79
		55	51	31.16	2.47	30.64	2.53	30.07	2.59	29.73	2.62	29.45	2.64	28.58	2.70
		60	56	31.31	2.44	30.90	2.49	30.52	2.53	30.26	2.55	30.05	2.57	29.28	2.61
		63	59	31.40	2.42	31.06	2.46	30.79	2.50	30.58	2.51	30.41	2.52	29.70	2.55
		68	64	31.49	2.41	31.21	2.44	31.06	2.47	30.90	2.47	30.77	2.48	30.13	2.50
	12 + 15	-4	-4.4	10.24	1.92	9.61	2.00	9.47	2.02	9.34	2.03	9.24	2.04	8.84	2.12
		0	-0.4	11.79	1.95	11.16	2.03	10.94	2.06	10.78	2.08	10.64	2.09	10.20	2.17
		5	4.5	14.36	1.99	13.67	2.07	13.36	2.11	13.15	2.13	12.97	2.15	12.45	2.22
		10	9	16.46	2.03	15.79	2.10	15.35	2.15	15.09	2.18	14.88	2.21	14.29	2.28
		17	15	18.77	2.08	18.12	2.15	17.55	2.22	17.23	2.25	16.98	2.28	16.33	2.35
		20	19	20.18	2.12	19.53	2.18	18.88	2.26	18.53	2.30	18.25	2.33	17.55	2.40
		25	23	22.52	2.18	21.85	2.24	21.09	2.33	20.70	2.37	20.37	2.41	19.61	2.47
		30	28	24.88	2.25	24.11	2.32	23.28	2.40	22.85	2.45	22.51	2.49	21.69	2.55
		35	32	27.11	2.32	26.25	2.40	25.36	2.47	24.90	2.52	24.54	2.57	23.65	2.63
		40	36	28.50	2.39	27.70	2.47	26.81	2.54	26.35	2.60	25.98	2.64	25.04	2.71
		45	41	30.22	2.47	29.50	2.56	28.63	2.64	28.16	2.68	27.78	2.72	26.77	2.80
		47	43	30.91	2.51	30.22	2.59	29.36	2.67	28.88	2.72	28.50	2.76	27.46	2.84
		50	46	31.00	2.49	30.38	2.57	29.63	2.64	29.20	2.68	28.85	2.71	27.88	2.79
		55	51	31.16	2.47	30.64	2.53	30.07	2.59	29.73	2.62	29.45	2.64	28.58	2.70
		60	56	31.31	2.44	30.90	2.49	30.52	2.53	30.26	2.55	30.05	2.57	29.28	2.61
		63	59	31.40	2.42	31.06	2.46	30.79	2.50	30.58	2.51	30.41	2.52	29.70	2.55
		68	64	31.49	2.41	31.21	2.44	31.06	2.47	30.90	2.47	30.77	2.48	30.13	2.50
	12 + 18	-4	-4.4	11.37	2.07	10.67	2.15	10.52	2.17	10.38	2.19	10.26	2.20	9.82	2.28
		0	-0.4	13.09	2.10	12.40	2.18	12.15	2.22	11.97	2.24	11.82	2.25	11.33	2.33
		5	4.5	15.50	2.15	14.76	2.23	14.41	2.27	14.18	2.30	14.00	2.32	13.43	2.40
		10	9	17.76	2.19	17.04	2.26	16.56	2.32	16.28	2.35	16.06	2.38	15.43	2.45
		17	15	20.26	2.24	19.56	2.31	18.94	2.39	18.59	2.43	18.32	2.46	17.62	2.53
		20	19	21.77	2.28	21.08	2.35	20.37	2.43	20.00	2.47	19.69	2.51	18.94	2.58
		25	23	24.32	2.35	23.60	2.41	22.78	2.51	22.35	2.56	22.01	2.60	21.18	2.67
		30	28	27.22	2.42	26.38	2.50	25.47	2.58	25.01	2.64	24.63	2.68	23.73	2.75
		35	32	30.12	2.50	29.16	2.59	28.17	2.66	27.66	2.72	27.26	2.77	26.27	2.84
		40	36	31.65	2.57	30.76	2.66	29.78	2.74	29.27	2.80	28.85	2.84	27.81	2.92
		45	41	33.57	2.67	32.77	2.75	31.80	2.84	31.28	2.89	30.85	2.93	29.73	3.02
		47	43	34.34	2.70	33.57	2.79	32.61	2.88	32.08	2.93	31.65	2.97	30.50	3.06
		50	46	34.44	2.68	33.75	2.77	32.91	2.85	32.43	2.89	32.05	2.92	30.97	3.00
		55	51	34.61	2.66	34.03	2.72	33.41	2.79	33.02	2.82	32.72	2.84	31.75	2.90
		60	56	34.78	2.63	34.32	2.68	33.90	2.73	33.61	2.75	33.38	2.76	32.53	2.81
		63	59	34.88	2.61	34.50	2.65	34.20	2.69	33.97	2.71	33.78	2.72	32.99	2.75
		68	64	34.98	2.59	34.67	2.63	34.50	2.66	34.32	2.67	34.18	2.67	33.47	2.69

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 369: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	7 + 24	-4	-4.4	11.75	2.11	11.03	2.19	10.87	2.22	10.72	2.23	10.60	2.25	10.15	2.33
		0	-0.4	13.53	2.15	12.81	2.23	12.56	2.26	12.37	2.28	12.22	2.30	11.71	2.38
		5	4.5	15.71	2.19	14.99	2.27	14.62	2.32	14.38	2.34	14.19	2.37	13.62	2.44
		10	9	18.11	2.23	17.37	2.31	16.89	2.37	16.59	2.40	16.37	2.43	15.72	2.50
		17	15	20.38	2.29	19.67	2.36	19.05	2.44	18.71	2.48	18.43	2.51	17.72	2.58
		20	19	22.16	2.33	21.45	2.40	20.74	2.48	20.35	2.53	20.04	2.56	19.28	2.63
		25	23	25.13	2.39	24.39	2.46	23.54	2.56	23.10	2.61	22.74	2.65	21.88	2.72
		30	28	28.13	2.47	27.26	2.55	26.32	2.63	25.84	2.69	25.45	2.74	24.52	2.81
		35	32	31.12	2.55	30.13	2.64	29.11	2.71	28.58	2.77	28.16	2.83	27.15	2.89
		40	36	32.71	2.63	31.79	2.72	30.78	2.79	30.24	2.85	29.82	2.90	28.74	2.98
		45	41	34.69	2.72	33.86	2.81	32.87	2.90	32.32	2.95	31.88	2.99	30.72	3.08
		47	43	35.48	2.76	34.69	2.85	33.70	2.94	33.15	2.99	32.71	3.03	31.52	3.12
		50	46	35.59	2.74	34.87	2.82	34.01	2.90	33.52	2.95	33.12	2.98	32.00	3.06
		55	51	35.76	2.71	35.17	2.78	34.52	2.84	34.12	2.88	33.81	2.90	32.81	2.96
		60	56	35.94	2.68	35.47	2.73	35.03	2.78	34.73	2.80	34.49	2.82	33.61	2.87
		63	59	36.04	2.66	35.65	2.71	35.34	2.75	35.10	2.76	34.90	2.77	34.09	2.81
		68	64	36.15	2.65	35.83	2.68	35.65	2.71	35.47	2.72	35.32	2.73	34.58	2.75
	9 + 24	-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
		60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
		68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81
	15 + 18	-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
		60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
		68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 370: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	18 + 18	-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
		60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
	12 + 24	68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81
		-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
	15 + 24	60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
		68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81
		-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
		60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
		68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 371: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Two (2) Mixed Indoor Units	18 + 24*	-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
		60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
	24 + 24*	68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81
		-4	-4.4	12.40	2.16	11.64	2.24	11.48	2.27	11.32	2.29	11.19	2.30	10.72	2.38
		0	-0.4	14.28	2.20	13.52	2.28	13.26	2.32	13.06	2.34	12.90	2.35	12.36	2.44
		5	4.5	16.59	2.24	15.83	2.32	15.44	2.37	15.19	2.40	14.99	2.42	14.38	2.50
		10	9	18.70	2.29	17.95	2.36	17.44	2.42	17.14	2.46	16.90	2.48	16.24	2.56
		17	15	21.52	2.34	20.77	2.42	20.11	2.49	19.75	2.53	19.46	2.57	18.71	2.64
		20	19	23.40	2.38	22.65	2.45	21.89	2.54	21.49	2.58	21.16	2.62	20.36	2.69
		25	23	26.54	2.45	25.75	2.52	24.86	2.62	24.38	2.67	24.01	2.71	23.11	2.78
		30	28	29.70	2.53	28.78	2.61	27.79	2.70	27.28	2.75	26.87	2.80	25.89	2.87
		35	32	32.86	2.61	31.81	2.71	30.73	2.77	30.18	2.84	29.74	2.89	28.66	2.96
		40	36	34.53	2.69	33.56	2.78	32.49	2.86	31.93	2.92	31.48	2.97	30.34	3.05
		45	41	36.63	2.78	35.75	2.88	34.70	2.97	34.12	3.02	33.66	3.06	32.44	3.15
		47	43	37.47	2.82	36.63	2.91	35.58	3.01	35.00	3.06	34.53	3.10	33.28	3.19
		50	46	37.58	2.80	36.82	2.89	35.91	2.97	35.39	3.02	34.97	3.05	33.79	3.13
		55	51	37.76	2.77	37.13	2.84	36.45	2.91	36.03	2.94	35.69	2.97	34.64	3.03
		60	56	37.94	2.74	37.45	2.80	36.99	2.85	36.67	2.87	36.42	2.89	35.49	2.93
		63	59	38.05	2.73	37.64	2.77	37.31	2.81	37.06	2.83	36.85	2.84	36.00	2.87
		68	64	38.16	2.71	37.83	2.74	37.64	2.78	37.45	2.78	37.29	2.79	36.51	2.81
Three (3) Mixed Indoor Units	7 + 7 + 9	-4	-4.4	8.72	1.66	8.18	1.72	8.07	1.74	7.96	1.76	7.87	1.76	7.53	1.83
		0	-0.4	10.04	1.69	9.51	1.75	9.32	1.78	9.18	1.79	9.07	1.81	8.69	1.87
		5	4.5	12.21	1.72	11.62	1.78	11.36	1.82	11.18	1.84	11.03	1.86	10.58	1.92
		10	9	14.00	1.76	13.42	1.82	13.05	1.86	12.83	1.89	12.65	1.91	12.15	1.97
		17	15	15.96	1.80	15.41	1.86	14.92	1.91	14.65	1.95	14.43	1.97	13.88	2.03
		20	19	17.16	1.83	16.61	1.88	16.05	1.95	15.75	1.98	15.52	2.01	14.93	2.07
		25	23	19.15	1.88	18.58	1.94	17.93	2.01	17.59	2.05	17.32	2.08	16.67	2.14
		30	28	21.15	1.94	20.50	2.01	19.80	2.07	19.43	2.12	19.14	2.15	18.44	2.21
		35	32	23.10	2.01	22.36	2.08	21.60	2.13	21.21	2.18	20.90	2.22	20.15	2.27
		40	36	24.27	2.06	23.59	2.14	22.84	2.20	22.44	2.24	22.13	2.28	21.33	2.34
		45	41	25.74	2.14	25.13	2.21	24.39	2.28	23.98	2.32	23.66	2.35	22.80	2.42
		47	43	26.33	2.17	25.74	2.24	25.01	2.31	24.60	2.35	24.27	2.38	23.39	2.45
		50	46	26.41	2.15	25.88	2.22	25.24	2.28	24.87	2.32	24.58	2.34	23.75	2.41
		55	51	26.54	2.13	26.10	2.18	25.62	2.23	25.32	2.26	25.09	2.28	24.35	2.33
		60	56	26.67	2.11	26.32	2.15	26.00	2.19	25.77	2.20	25.60	2.22	24.94	2.25
		63	59	26.75	2.09	26.45	2.13	26.23	2.16	26.05	2.17	25.90	2.18	25.30	2.21
		68	64	26.82	2.08	26.59	2.11	26.46	2.13	26.32	2.14	26.21	2.14	25.66	2.16

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 372: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 9	-4	-4.4	9.48	1.77	8.89	1.84	8.77	1.86	8.65	1.88	8.55	1.88	8.19	1.96
		0	-0.4	10.91	1.80	10.33	1.87	10.13	1.90	9.98	1.92	9.85	1.93	9.45	2.00
		5	4.5	13.28	1.84	12.65	1.91	12.35	1.95	12.16	1.97	12.00	1.99	11.51	2.05
		10	9	15.23	1.87	14.61	1.94	14.21	1.99	13.96	2.02	13.76	2.04	13.22	2.10
		17	15	17.36	1.92	16.76	1.98	16.23	2.04	15.94	2.08	15.70	2.11	15.10	2.17
		20	19	18.66	1.95	18.06	2.01	17.47	2.08	17.14	2.12	16.88	2.15	16.24	2.21
		25	23	20.83	2.01	20.21	2.07	19.51	2.15	19.15	2.19	18.84	2.22	18.13	2.28
		30	28	23.01	2.08	22.31	2.14	21.54	2.21	21.14	2.26	20.83	2.30	20.06	2.36
		35	32	25.11	2.14	24.31	2.22	23.48	2.28	23.06	2.33	22.72	2.37	21.90	2.43
		40	36	26.38	2.20	25.64	2.28	24.83	2.35	24.40	2.40	24.05	2.43	23.18	2.50
		45	41	27.98	2.28	27.32	2.36	26.51	2.43	26.07	2.48	25.72	2.51	24.78	2.59
		47	43	28.62	2.31	27.98	2.39	27.18	2.47	26.74	2.51	26.38	2.54	25.43	2.62
		50	46	28.71	2.30	28.13	2.37	27.43	2.44	27.03	2.47	26.72	2.50	25.81	2.57
		55	51	28.85	2.28	28.37	2.33	27.85	2.39	27.53	2.41	27.27	2.44	26.46	2.49
		60	56	28.99	2.25	28.61	2.29	28.26	2.34	28.02	2.35	27.82	2.37	27.11	2.41
		63	59	29.07	2.24	28.75	2.27	28.51	2.31	28.31	2.32	28.16	2.33	27.50	2.36
		68	64	29.16	2.22	28.90	2.25	28.76	2.28	28.61	2.28	28.49	2.29	27.90	2.31
	7 + 7 + 12	-4	-4.4	9.86	1.80	9.25	1.87	9.12	1.89	8.99	1.91	8.89	1.91	8.51	1.99
		0	-0.4	11.35	1.83	10.75	1.90	10.53	1.93	10.38	1.95	10.25	1.96	9.82	2.03
		5	4.5	13.82	1.87	13.16	1.94	12.85	1.98	12.65	2.00	12.49	2.02	11.98	2.09
		10	9	15.84	1.90	15.20	1.97	14.78	2.02	14.53	2.05	14.32	2.07	13.76	2.13
		17	15	18.07	1.95	17.44	2.01	16.89	2.08	16.58	2.11	16.34	2.14	15.71	2.20
		20	19	19.42	1.98	18.80	2.04	18.17	2.11	17.84	2.15	17.57	2.19	16.90	2.25
		25	23	21.68	2.04	21.03	2.10	20.30	2.18	19.92	2.22	19.61	2.26	18.87	2.32
		30	28	23.95	2.11	23.21	2.18	22.41	2.25	22.00	2.30	21.67	2.34	20.88	2.39
		35	32	26.11	2.18	25.28	2.25	24.42	2.31	23.98	2.37	23.63	2.41	22.77	2.47
		40	36	27.44	2.24	26.67	2.32	25.82	2.38	25.37	2.43	25.01	2.47	24.11	2.54
		45	41	29.10	2.32	28.41	2.40	27.57	2.47	27.11	2.52	26.75	2.55	25.78	2.63
		47	43	29.77	2.35	29.10	2.43	28.27	2.51	27.81	2.55	27.44	2.58	26.44	2.66
		50	46	29.86	2.34	29.25	2.41	28.53	2.48	28.12	2.51	27.79	2.54	26.85	2.61
		55	51	30.00	2.31	29.50	2.37	28.96	2.43	28.63	2.45	28.36	2.47	27.52	2.53
		60	56	30.15	2.29	29.76	2.33	29.39	2.37	29.14	2.39	28.94	2.41	28.20	2.44
		63	59	30.24	2.27	29.91	2.31	29.65	2.34	29.44	2.36	29.28	2.36	28.60	2.39
		68	64	30.32	2.26	30.06	2.29	29.91	2.31	29.75	2.32	29.63	2.32	29.01	2.34
	9 + 9 + 9	-4	-4.4	10.24	1.83	9.61	1.90	9.47	1.92	9.34	1.93	9.24	1.94	8.84	2.02
		0	-0.4	11.79	1.86	11.16	1.93	10.94	1.96	10.78	1.98	10.64	1.99	10.20	2.06
		5	4.5	14.36	1.90	13.67	1.97	13.36	2.01	13.15	2.03	12.97	2.05	12.45	2.12
		10	9	16.46	1.93	15.79	2.00	15.35	2.05	15.09	2.08	14.88	2.10	14.29	2.17
		17	15	18.77	1.98	18.12	2.05	17.55	2.11	17.23	2.14	16.98	2.17	16.33	2.24
		20	19	20.18	2.01	19.53	2.08	18.88	2.15	18.53	2.19	18.25	2.22	17.55	2.28
		25	23	22.52	2.07	21.85	2.13	21.09	2.21	20.70	2.26	20.37	2.30	19.61	2.36
		30	28	24.88	2.14	24.11	2.21	23.28	2.28	22.85	2.33	22.51	2.37	21.69	2.43
		35	32	27.11	2.21	26.25	2.29	25.36	2.35	24.90	2.40	24.54	2.45	23.65	2.51
		40	36	28.50	2.28	27.70	2.35	26.81	2.42	26.35	2.47	25.98	2.51	25.04	2.58
		45	41	30.22	2.36	29.50	2.43	28.63	2.51	28.16	2.56	27.78	2.59	26.77	2.67
		47	43	30.91	2.39	30.22	2.47	29.36	2.55	28.88	2.59	28.50	2.63	27.46	2.70
		50	46	31.00	2.37	30.38	2.44	29.63	2.52	29.20	2.55	28.85	2.58	27.88	2.65
		55	51	31.16	2.35	30.64	2.41	30.07	2.46	29.73	2.49	29.45	2.51	28.58	2.57
		60	56	31.31	2.32	30.90	2.37	30.52	2.41	30.26	2.43	30.05	2.44	29.28	2.48
		63	59	31.40	2.31	31.06	2.35	30.79	2.38	30.58	2.39	30.41	2.40	29.70	2.43
		68	64	31.49	2.29	31.21	2.32	31.06	2.35	30.90	2.36	30.77	2.36	30.13	2.38

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 373: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 9 + 12	-4	-4.4	10.61	1.86	9.96	1.94	9.82	1.96	9.68	1.97	9.58	1.98	9.17	2.06
		0	-0.4	12.22	1.90	11.57	1.97	11.34	2.00	11.17	2.02	11.03	2.03	10.58	2.10
		5	4.5	14.90	1.94	14.19	2.00	13.86	2.05	13.64	2.07	13.46	2.09	12.92	2.16
		10	9	17.08	1.97	16.39	2.04	15.93	2.09	15.66	2.12	15.43	2.14	14.82	2.21
		17	15	19.48	2.02	18.80	2.09	18.21	2.15	17.88	2.19	17.61	2.21	16.93	2.28
		20	19	20.93	2.05	20.26	2.12	19.59	2.19	19.23	2.23	18.93	2.26	18.21	2.32
		25	23	23.36	2.11	22.67	2.18	21.88	2.26	21.47	2.30	21.14	2.34	20.34	2.40
		30	28	25.82	2.18	25.02	2.26	24.15	2.33	23.72	2.38	23.36	2.42	22.50	2.48
		35	32	28.11	2.25	27.21	2.33	26.29	2.39	25.82	2.45	25.44	2.49	24.52	2.56
		40	36	29.54	2.32	28.71	2.40	27.80	2.47	27.32	2.52	26.93	2.56	25.95	2.63
		45	41	31.33	2.40	30.58	2.48	29.68	2.56	29.19	2.61	28.80	2.64	27.75	2.72
		47	43	32.05	2.43	31.33	2.51	30.44	2.60	29.94	2.64	29.54	2.68	28.47	2.76
		50	46	32.14	2.42	31.49	2.49	30.71	2.56	30.27	2.60	29.91	2.63	28.90	2.70
		55	51	32.30	2.39	31.76	2.45	31.18	2.51	30.82	2.54	30.53	2.56	29.63	2.62
		60	56	32.46	2.37	32.03	2.41	31.64	2.46	31.37	2.48	31.15	2.49	30.36	2.53
		63	59	32.55	2.35	32.20	2.39	31.92	2.43	31.70	2.44	31.52	2.45	30.79	2.48
		68	64	32.65	2.34	32.36	2.37	32.20	2.39	32.03	2.40	31.90	2.41	31.23	2.43
	9 + 9 + 12	-4	-4.4	11.37	1.95	10.67	2.02	10.52	2.05	10.38	2.06	10.26	2.07	9.82	2.15
		0	-0.4	13.09	1.98	12.40	2.06	12.15	2.09	11.97	2.11	11.82	2.12	11.33	2.20
		5	4.5	15.50	2.02	14.76	2.10	14.41	2.14	14.18	2.16	14.00	2.18	13.43	2.26
		10	9	17.76	2.06	17.04	2.13	16.56	2.19	16.28	2.22	16.06	2.24	15.43	2.31
		17	15	20.26	2.11	19.56	2.18	18.94	2.25	18.59	2.29	18.32	2.32	17.62	2.38
		20	19	21.77	2.15	21.08	2.21	20.37	2.29	20.00	2.33	19.69	2.37	18.94	2.43
		25	23	24.32	2.21	23.60	2.27	22.78	2.36	22.35	2.41	22.01	2.45	21.18	2.51
		30	28	27.22	2.28	26.38	2.36	25.47	2.43	25.01	2.48	24.63	2.53	23.73	2.59
		35	32	30.12	2.36	29.16	2.44	28.17	2.50	27.66	2.56	27.26	2.61	26.27	2.67
		40	36	31.65	2.42	30.76	2.51	29.78	2.58	29.27	2.63	28.85	2.68	27.81	2.75
		45	41	33.57	2.51	32.77	2.59	31.80	2.68	31.28	2.72	30.85	2.76	29.73	2.84
		47	43	34.34	2.54	33.57	2.63	32.61	2.71	32.08	2.76	31.65	2.80	30.50	2.88
		50	46	34.44	2.53	33.75	2.60	32.91	2.68	32.43	2.72	32.05	2.75	30.97	2.83
		55	51	34.61	2.50	34.03	2.56	33.41	2.62	33.02	2.65	32.72	2.68	31.75	2.74
		60	56	34.78	2.48	34.32	2.52	33.90	2.57	33.61	2.59	33.38	2.60	32.53	2.64
		63	59	34.88	2.46	34.50	2.50	34.20	2.54	33.97	2.55	33.78	2.56	32.99	2.59
		68	64	34.98	2.44	34.67	2.47	34.50	2.50	34.32	2.51	34.18	2.52	33.47	2.54
	7 + 9 + 15	-4	-4.4	11.75	1.99	11.03	2.07	10.87	2.09	10.72	2.11	10.60	2.12	10.15	2.20
		0	-0.4	13.53	2.02	12.81	2.10	12.56	2.14	12.37	2.15	12.22	2.17	11.71	2.25
		5	4.5	15.71	2.07	14.99	2.14	14.62	2.19	14.38	2.21	14.19	2.23	13.62	2.31
		10	9	18.11	2.11	17.37	2.18	16.89	2.23	16.59	2.26	16.37	2.29	15.72	2.36
		17	15	20.38	2.16	19.67	2.23	19.05	2.30	18.71	2.33	18.43	2.37	17.72	2.43
		20	19	22.16	2.19	21.45	2.26	20.74	2.34	20.35	2.38	20.04	2.42	19.28	2.48
		25	23	25.13	2.26	24.39	2.32	23.54	2.41	23.10	2.46	22.74	2.50	21.88	2.57
		30	28	28.13	2.33	27.26	2.41	26.32	2.48	25.84	2.54	25.45	2.58	24.52	2.65
		35	32	31.12	2.41	30.13	2.49	29.11	2.56	28.58	2.62	28.16	2.66	27.15	2.73
		40	36	32.71	2.48	31.79	2.56	30.78	2.64	30.24	2.69	29.82	2.74	28.74	2.81
		45	41	34.69	2.57	33.86	2.65	32.87	2.73	32.32	2.78	31.88	2.82	30.72	2.91
		47	43	35.48	2.60	34.69	2.69	33.70	2.77	33.15	2.82	32.71	2.86	31.52	2.94
		50	46	35.59	2.58	34.87	2.66	34.01	2.74	33.52	2.78	33.12	2.81	32.00	2.89
		55	51	35.76	2.56	35.17	2.62	34.52	2.68	34.12	2.71	33.81	2.74	32.81	2.80
		60	56	35.94	2.53	35.47	2.58	35.03	2.63	34.73	2.65	34.49	2.66	33.61	2.70
		63	59	36.04	2.51	35.65	2.55	35.34	2.59	35.10	2.60	34.90	2.62	34.09	2.65
		68	64	36.15	2.50	35.83	2.53	35.65	2.56	35.47	2.57	35.32	2.57	34.58	2.59

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 374: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 12	-4	-4.4	11.75	1.99	11.03	2.07	10.87	2.09	10.72	2.11	10.60	2.12	10.15	2.20
		0	-0.4	13.53	2.02	12.81	2.10	12.56	2.14	12.37	2.15	12.22	2.17	11.71	2.25
		5	4.5	15.71	2.07	14.99	2.14	14.62	2.19	14.38	2.21	14.19	2.23	13.62	2.31
		10	9	18.11	2.11	17.37	2.18	16.89	2.23	16.59	2.26	16.37	2.29	15.72	2.36
		17	15	20.38	2.16	19.67	2.23	19.05	2.30	18.71	2.33	18.43	2.37	17.72	2.43
		20	19	22.16	2.19	21.45	2.26	20.74	2.34	20.35	2.38	20.04	2.42	19.28	2.48
		25	23	25.13	2.26	24.39	2.32	23.54	2.41	23.10	2.46	22.74	2.50	21.88	2.57
		30	28	28.13	2.33	27.26	2.41	26.32	2.48	25.84	2.54	25.45	2.58	24.52	2.65
		35	32	31.12	2.41	30.13	2.49	29.11	2.56	28.58	2.62	28.16	2.66	27.15	2.73
		40	36	32.71	2.48	31.79	2.56	30.78	2.64	30.24	2.69	29.82	2.74	28.74	2.81
		45	41	34.69	2.57	33.86	2.65	32.87	2.73	32.32	2.78	31.88	2.82	30.72	2.91
		47	43	35.48	2.60	34.69	2.69	33.70	2.77	33.15	2.82	32.71	2.86	31.52	2.94
		50	46	35.59	2.58	34.87	2.66	34.01	2.74	33.52	2.78	33.12	2.81	32.00	2.89
		55	51	35.76	2.56	35.17	2.62	34.52	2.68	34.12	2.71	33.81	2.74	32.81	2.80
		60	56	35.94	2.53	35.47	2.58	35.03	2.63	34.73	2.65	34.49	2.66	33.61	2.70
		63	59	36.04	2.51	35.65	2.55	35.34	2.59	35.10	2.60	34.90	2.62	34.09	2.65
		68	64	36.15	2.50	35.83	2.53	35.65	2.56	35.47	2.57	35.32	2.57	34.58	2.59
	7 + 7 + 18	-4	-4.4	12.13	2.03	11.38	2.11	11.22	2.14	11.07	2.15	10.94	2.16	10.48	2.24
		0	-0.4	13.97	2.07	13.22	2.15	12.96	2.18	12.77	2.20	12.61	2.21	12.09	2.29
		5	4.5	16.22	2.11	15.48	2.19	15.10	2.23	14.85	2.26	14.65	2.28	14.06	2.35
		10	9	18.74	2.15	17.97	2.22	17.48	2.28	17.17	2.31	16.94	2.34	16.27	2.41
		17	15	21.04	2.20	20.31	2.28	19.67	2.35	19.31	2.38	19.03	2.42	18.29	2.49
		20	19	22.87	2.24	22.15	2.31	21.41	2.39	21.01	2.43	20.69	2.47	19.91	2.54
		25	23	25.95	2.31	25.18	2.37	24.30	2.46	23.84	2.51	23.47	2.55	22.59	2.62
		30	28	29.04	2.38	28.14	2.46	27.17	2.54	26.67	2.59	26.27	2.64	25.31	2.70
		35	32	32.13	2.46	31.10	2.55	30.05	2.61	29.51	2.67	29.07	2.72	28.02	2.79
		40	36	33.77	2.53	32.82	2.62	31.77	2.69	31.22	2.75	30.78	2.79	29.66	2.87
		45	41	35.81	2.62	34.96	2.71	33.93	2.79	33.36	2.84	32.91	2.88	31.72	2.97
		47	43	36.63	2.66	35.81	2.74	34.79	2.83	34.22	2.88	33.77	2.92	32.54	3.01
		50	46	36.74	2.64	36.00	2.72	35.11	2.80	34.60	2.84	34.19	2.87	33.04	2.95
		55	51	36.92	2.61	36.31	2.68	35.63	2.74	35.23	2.77	34.90	2.80	33.87	2.85
		60	56	37.10	2.58	36.61	2.63	36.16	2.68	35.85	2.70	35.61	2.72	34.70	2.76
		63	59	37.20	2.57	36.80	2.61	36.48	2.65	36.23	2.66	36.03	2.67	35.19	2.70
		68	64	37.31	2.55	36.98	2.58	36.80	2.61	36.61	2.62	36.46	2.63	35.70	2.65
	9 + 9 + 15	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 375: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 12 + 12	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	7 + 9 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	7 + 12 + 15	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 376: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 9 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 12 + 15	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	12 + 12 + 12	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 377: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 12 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	7 + 7 + 24	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 12 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 378: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	9 + 15 + 15	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
	12 + 12 + 15	63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
		-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
	7 + 9 + 24	55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
		-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 379: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 15 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 9 + 24*	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 15 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 380: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 12 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	12 + 15 + 15	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	7 + 12 + 24*	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 381: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	7 + 18 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 12 + 24*	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 18 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 382: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 15 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	7 + 15 + 24*	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	9 + 15 + 24*	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 383: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Three (3) Mixed Indoor Units	12 + 12 + 24*	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	12 + 18 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65
	15 + 15 + 18	-4	-4.4	12.40	2.03	11.64	2.11	11.48	2.14	11.32	2.15	11.19	2.16	10.72	2.24
		0	-0.4	14.28	2.07	13.52	2.15	13.26	2.18	13.06	2.20	12.90	2.21	12.36	2.29
		5	4.5	16.59	2.11	15.83	2.19	15.44	2.23	15.19	2.26	14.99	2.28	14.38	2.35
		10	9	18.70	2.15	17.95	2.22	17.44	2.28	17.14	2.31	16.90	2.34	16.24	2.41
		17	15	21.52	2.20	20.77	2.28	20.11	2.35	19.75	2.38	19.46	2.42	18.71	2.49
		20	19	23.40	2.24	22.65	2.31	21.89	2.39	21.49	2.43	21.16	2.47	20.36	2.54
		25	23	26.54	2.31	25.75	2.37	24.86	2.46	24.38	2.51	24.01	2.55	23.11	2.62
		30	28	29.70	2.38	28.78	2.46	27.79	2.54	27.28	2.59	26.87	2.64	25.89	2.70
		35	32	32.86	2.46	31.81	2.55	30.73	2.61	30.18	2.67	29.74	2.72	28.66	2.79
		40	36	34.53	2.53	33.56	2.62	32.49	2.69	31.93	2.75	31.48	2.79	30.34	2.87
		45	41	36.63	2.62	35.75	2.71	34.70	2.79	34.12	2.84	33.66	2.88	32.44	2.97
		47	43	37.47	2.66	36.63	2.74	35.58	2.83	35.00	2.88	34.53	2.92	33.28	3.01
		50	46	37.58	2.64	36.82	2.72	35.91	2.80	35.39	2.84	34.97	2.87	33.79	2.95
		55	51	37.76	2.61	37.13	2.68	36.45	2.74	36.03	2.77	35.69	2.80	34.64	2.85
		60	56	37.94	2.58	37.45	2.63	36.99	2.68	36.67	2.70	36.42	2.72	35.49	2.76
		63	59	38.05	2.57	37.64	2.61	37.31	2.65	37.06	2.66	36.85	2.67	36.00	2.70
		68	64	38.16	2.55	37.83	2.58	37.64	2.61	37.45	2.62	37.29	2.63	36.51	2.65

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 384: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 7 + 9	-4	-4.4	11.37	1.93	10.67	2.01	10.52	2.03	10.38	2.05	10.26	2.06	9.82	2.13
		0	-0.4	13.09	1.97	12.40	2.04	12.15	2.07	11.97	2.09	11.82	2.11	11.33	2.18
		5	4.5	15.50	2.01	14.76	2.08	14.41	2.12	14.18	2.15	14.00	2.17	13.43	2.24
		10	9	17.76	2.05	17.04	2.12	16.56	2.17	16.28	2.20	16.06	2.22	15.43	2.29
		17	15	20.26	2.10	19.56	2.16	18.94	2.23	18.59	2.27	18.32	2.30	17.62	2.37
		20	19	21.77	2.13	21.08	2.20	20.37	2.27	20.00	2.31	19.69	2.35	18.94	2.41
		25	23	24.32	2.19	23.60	2.26	22.78	2.34	22.35	2.39	22.01	2.43	21.18	2.49
		30	28	27.22	2.27	26.38	2.34	25.47	2.41	25.01	2.47	24.63	2.51	23.73	2.57
		35	32	30.12	2.34	29.16	2.42	28.17	2.48	27.66	2.54	27.26	2.59	26.27	2.65
		40	36	31.65	2.41	30.76	2.49	29.78	2.56	29.27	2.61	28.85	2.66	27.81	2.73
		45	41	33.57	2.49	32.77	2.58	31.80	2.66	31.28	2.70	30.85	2.74	29.73	2.82
		47	43	34.34	2.53	33.57	2.61	32.61	2.69	32.08	2.74	31.65	2.78	30.50	2.86
		50	46	34.44	2.51	33.75	2.59	32.91	2.66	32.43	2.70	32.05	2.73	30.97	2.81
		55	51	34.61	2.48	34.03	2.55	33.41	2.61	33.02	2.64	32.72	2.66	31.75	2.72
		60	56	34.78	2.46	34.32	2.51	33.90	2.55	33.61	2.57	33.38	2.59	32.53	2.63
	7 + 7 + 9 + 9	63	59	34.88	2.44	34.50	2.48	34.20	2.52	33.97	2.53	33.78	2.54	32.99	2.57
		68	64	34.98	2.43	34.67	2.46	34.50	2.49	34.32	2.49	34.18	2.50	33.47	2.52
		-4	-4.4	12.13	1.97	11.38	2.05	11.22	2.07	11.07	2.08	10.94	2.10	10.48	2.17
		0	-0.4	13.97	2.00	13.22	2.08	12.96	2.11	12.77	2.13	12.61	2.15	12.09	2.22
		5	4.5	16.22	2.05	15.48	2.12	15.10	2.16	14.85	2.19	14.65	2.21	14.06	2.28
		10	9	18.74	2.08	17.97	2.16	17.48	2.21	17.17	2.24	16.94	2.26	16.27	2.34
		17	15	21.04	2.14	20.31	2.20	19.67	2.27	19.31	2.31	19.03	2.34	18.29	2.41
		20	19	22.87	2.17	22.15	2.24	21.41	2.31	21.01	2.36	20.69	2.39	19.91	2.46
		25	23	25.95	2.23	25.18	2.30	24.30	2.39	23.84	2.43	23.47	2.47	22.59	2.54
		30	28	29.04	2.31	28.14	2.38	27.17	2.46	26.67	2.51	26.27	2.55	25.31	2.62
		35	32	32.13	2.38	31.10	2.47	30.05	2.53	29.51	2.59	29.07	2.64	28.02	2.70
		40	36	33.77	2.45	32.82	2.54	31.77	2.61	31.22	2.66	30.78	2.71	29.66	2.78
		45	41	35.81	2.54	34.96	2.62	33.93	2.70	33.36	2.75	32.91	2.79	31.72	2.87
		47	43	36.63	2.57	35.81	2.66	34.79	2.74	34.22	2.79	33.77	2.83	32.54	2.91
		50	46	36.74	2.56	36.00	2.63	35.11	2.71	34.60	2.75	34.19	2.78	33.04	2.86
	7 + 7 + 7 + 12	55	51	36.92	2.53	36.31	2.59	35.63	2.65	35.23	2.68	34.90	2.71	33.87	2.77
		60	56	37.10	2.50	36.61	2.55	36.16	2.60	35.85	2.62	35.61	2.63	34.70	2.67
		63	59	37.20	2.49	36.80	2.53	36.48	2.56	36.23	2.58	36.03	2.59	35.19	2.62
		68	64	37.31	2.47	36.98	2.50	36.80	2.53	36.61	2.54	36.46	2.54	35.70	2.56
		-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 385: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 9	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
	7 + 7 + 9 + 12	63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
		-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
	9 + 9 + 9 + 9	55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
		-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 386: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 9 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 9 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 12 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 387: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 7 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	9 + 9 + 9 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 9 + 9 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 388: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 12 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 9 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 12 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 389: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 9 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	9 + 9 + 12 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 9 + 9 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 390: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 9 + 12 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 12 + 12 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 12 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 391: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 7 + 7 + 24*	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	9 + 9 + 9 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	9 + 9 + 12 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 392: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 12 + 12 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
	7 + 9 + 12 + 18	63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
		-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
	7 + 9 + 15 + 15	55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
		-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F LMU36CHV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 393: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	7 + 12 + 12 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 9 + 24*	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	7 + 7 + 15 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

*The indoor unit must be non-ducted type.

Table 394: LMU36CHV Heating Capacity Table — Mixed Indoor Units, continued.

Connected Indoor Units	Combination Capacity Index	Outdoor Air Temp.		Indoor Air Temp. °F DB											
		°F DB	°F WB	61		64		68		70		72		75	
				TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Four (4) Mixed Indoor Units	9 + 9 + 12 + 18	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	9 + 9 + 15 + 15	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91
		50	46	37.58	2.56	36.82	2.63	35.91	2.71	35.39	2.75	34.97	2.78	33.79	2.86
		55	51	37.76	2.53	37.13	2.59	36.45	2.65	36.03	2.68	35.69	2.71	34.64	2.77
		60	56	37.94	2.50	37.45	2.55	36.99	2.60	36.67	2.62	36.42	2.63	35.49	2.67
		63	59	38.05	2.49	37.64	2.53	37.31	2.56	37.06	2.58	36.85	2.59	36.00	2.62
		68	64	38.16	2.47	37.83	2.50	37.64	2.53	37.45	2.54	37.29	2.54	36.51	2.56
	12 + 12 + 12 + 12	-4	-4.4	12.40	1.97	11.64	2.05	11.48	2.07	11.32	2.08	11.19	2.10	10.72	2.17
		0	-0.4	14.28	2.00	13.52	2.08	13.26	2.11	13.06	2.13	12.90	2.15	12.36	2.22
		5	4.5	16.59	2.05	15.83	2.12	15.44	2.16	15.19	2.19	14.99	2.21	14.38	2.28
		10	9	18.70	2.08	17.95	2.16	17.44	2.21	17.14	2.24	16.90	2.26	16.24	2.34
		17	15	21.52	2.14	20.77	2.20	20.11	2.27	19.75	2.31	19.46	2.34	18.71	2.41
		20	19	23.40	2.17	22.65	2.24	21.89	2.31	21.49	2.36	21.16	2.39	20.36	2.46
		25	23	26.54	2.23	25.75	2.30	24.86	2.39	24.38	2.43	24.01	2.47	23.11	2.54
		30	28	29.70	2.31	28.78	2.38	27.79	2.46	27.28	2.51	26.87	2.55	25.89	2.62
		35	32	32.86	2.38	31.81	2.47	30.73	2.53	30.18	2.59	29.74	2.64	28.66	2.70
		40	36	34.53	2.45	33.56	2.54	32.49	2.61	31.93	2.66	31.48	2.71	30.34	2.78
		45	41	36.63	2.54	35.75	2.62	34.70	2.70	34.12	2.75	33.66	2.79	32.44	2.87
		47	43	37.47	2.57	36.63	2.66	35.58	2.74	35.00	2.79	34.53	2.83	33.28	2.91

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal capacity as rated: 0 ft. above sea level with 25 ft. of refrigerant piping.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU480HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 395: LMU480HV Heating Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 65 (135%)	-4	-4.4	22.87	2.51	21.16	2.62	21.06	2.64	20.81	2.65	20.62	2.66	19.69	2.76
	0	-0.4	27.52	2.68	25.88	2.79	25.48	2.82	25.12	2.84	24.83	2.86	23.78	2.97
	5	4.5	33.03	2.89	31.48	2.99	30.74	3.05	30.24	3.08	29.84	3.11	28.64	3.22
	10	9	36.72	3.08	35.24	3.18	34.26	3.26	33.67	3.31	33.20	3.34	31.89	3.45
	17	15	40.79	3.33	39.37	3.43	38.13	3.54	37.44	3.60	36.89	3.65	35.47	3.75
	20	19	43.25	3.50	41.87	3.60	40.47	3.73	39.72	3.80	39.12	3.85	37.64	3.96
	25	23	47.37	3.79	45.97	3.90	44.37	4.04	43.53	4.12	42.86	4.19	41.25	4.30
	30	28	51.54	4.09	49.94	4.23	48.22	4.36	47.34	4.45	46.63	4.53	44.92	4.64
	35	32	55.69	4.40	53.92	4.55	52.08	4.67	51.15	4.78	50.40	4.87	48.58	4.98
	40	36	58.53	4.52	56.89	4.68	55.07	4.81	54.12	4.91	53.36	4.99	51.42	5.13
	45	41	62.08	4.68	60.60	4.84	58.81	4.99	57.83	5.08	57.05	5.16	54.98	5.31
	47	43	63.50	4.75	62.08	4.91	60.31	5.06	59.32	5.15	58.53	5.22	56.40	5.38
	50	46	63.68	4.72	62.40	4.86	60.86	5.00	59.97	5.08	59.27	5.14	57.27	5.27
	55	51	64.00	4.67	62.93	4.78	61.77	4.90	61.06	4.95	60.50	5.00	58.71	5.11
	60	56	64.31	4.62	63.47	4.71	62.69	4.79	62.15	4.83	61.72	4.86	60.14	4.94
	63	59	64.49	4.59	63.79	4.66	63.24	4.73	62.81	4.76	62.46	4.78	61.01	4.83
	68	64	64.68	4.56	64.11	4.62	63.79	4.67	63.47	4.68	63.20	4.69	61.88	4.73
Non-Ducted Indoor Units 62 (130%)	-4	-4.4	22.51	2.44	20.83	2.54	20.72	2.56	20.48	2.57	20.29	2.58	19.38	2.68
	0	-0.4	27.08	2.60	25.47	2.71	25.08	2.74	24.72	2.76	24.44	2.78	23.40	2.88
	5	4.5	32.51	2.80	30.99	2.91	30.25	2.96	29.76	2.99	29.37	3.02	28.18	3.12
	10	9	36.14	2.99	34.68	3.09	33.71	3.17	33.13	3.21	32.67	3.24	31.38	3.35
	17	15	40.14	3.23	38.74	3.33	37.52	3.44	36.84	3.50	36.30	3.54	34.91	3.64
	20	19	42.56	3.39	41.21	3.50	39.83	3.62	39.09	3.69	38.50	3.74	37.04	3.84
	25	23	46.62	3.68	45.24	3.78	43.67	3.92	42.84	4.00	42.18	4.07	40.59	4.17
	30	28	50.72	3.97	49.15	4.10	47.46	4.23	46.59	4.32	45.89	4.40	44.21	4.51
	35	32	54.81	4.27	53.07	4.42	51.26	4.53	50.34	4.64	49.60	4.72	47.81	4.84
	40	36	57.60	4.39	55.99	4.54	54.20	4.67	53.26	4.77	52.51	4.85	50.61	4.98
	45	41	61.10	4.55	59.64	4.70	57.88	4.85	56.92	4.93	56.15	5.01	54.11	5.15
	47	43	62.49	4.61	61.10	4.76	59.35	4.92	58.38	5.00	57.60	5.07	55.51	5.22
	50	46	62.68	4.58	61.41	4.72	59.89	4.86	59.02	4.93	58.33	4.99	56.36	5.12
	55	51	62.98	4.53	61.94	4.64	60.79	4.76	60.10	4.81	59.54	4.85	57.78	4.96
	60	56	63.29	4.48	62.46	4.57	61.70	4.66	61.17	4.69	60.74	4.72	59.19	4.79
	63	59	63.47	4.46	62.78	4.53	62.24	4.60	61.81	4.62	61.47	4.64	60.04	4.69
	68	64	63.65	4.43	63.10	4.48	62.78	4.54	62.46	4.55	62.20	4.56	60.90	4.60
Non-Ducted Indoor Units 58 (120%)	-4	-4.4	22.03	2.35	20.38	2.45	20.28	2.46	20.05	2.47	19.86	2.48	18.97	2.58
	0	-0.4	26.50	2.50	24.92	2.60	24.54	2.64	24.19	2.66	23.92	2.67	22.90	2.77
	5	4.5	31.81	2.70	30.32	2.80	29.60	2.85	29.12	2.88	28.74	2.91	27.58	3.00
	10	9	35.37	2.87	33.94	2.97	32.99	3.05	32.42	3.09	31.97	3.12	30.71	3.22
	17	15	39.28	3.11	37.92	3.21	36.72	3.31	36.06	3.36	35.52	3.41	34.16	3.51
	20	19	41.65	3.27	40.33	3.37	38.98	3.48	38.26	3.55	37.68	3.60	36.25	3.70
	25	23	45.62	3.54	44.27	3.64	42.73	3.78	41.92	3.85	41.28	3.91	39.72	4.02
	30	28	49.63	3.82	48.10	3.95	46.44	4.07	45.59	4.16	44.91	4.23	43.26	4.34
	35	32	53.64	4.11	51.93	4.25	50.16	4.36	49.26	4.46	48.54	4.55	46.78	4.66
	40	36	56.37	4.23	54.79	4.37	53.04	4.50	52.12	4.59	51.39	4.67	49.52	4.79
	45	41	59.79	4.38	58.36	4.52	56.64	4.66	55.70	4.75	54.95	4.82	52.95	4.96
	47	43	61.15	4.44	59.79	4.58	58.08	4.73	57.13	4.81	56.37	4.88	54.32	5.02
	50	46	61.33	4.41	60.10	4.54	58.61	4.67	57.76	4.74	57.08	4.80	55.15	4.93
	55	51	61.63	4.36	60.61	4.47	59.49	4.57	58.81	4.63	58.26	4.67	56.54	4.77
	60	56	61.93	4.31	61.13	4.40	60.37	4.48	59.86	4.51	59.44	4.54	57.92	4.61
	63	59	62.11	4.29	61.43	4.36	60.90	4.42	60.49	4.44	60.15	4.46	58.76	4.51
	68	64	62.29	4.26	61.75	4.31	61.44	4.36	61.12	4.38	60.87	4.38	59.60	4.42

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 396: LMU480HV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 53 (110%)	-4	-4.4	21.42	2.23	19.82	2.32	19.72	2.34	19.49	2.34	19.31	2.35	18.45	2.44
	0	-0.4	25.77	2.37	24.24	2.47	23.86	2.50	23.53	2.52	23.26	2.53	22.27	2.63
	5	4.5	30.94	2.56	29.49	2.65	28.79	2.70	28.32	2.73	27.95	2.75	26.82	2.85
	10	9	34.40	2.72	33.01	2.82	32.08	2.89	31.53	2.93	31.09	2.96	29.87	3.05
	17	15	38.20	2.95	36.87	3.04	35.71	3.14	35.06	3.19	34.55	3.23	33.22	3.32
	20	19	40.51	3.10	39.22	3.19	37.91	3.30	37.20	3.36	36.64	3.41	35.25	3.50
	25	23	44.37	3.35	43.06	3.45	41.56	3.58	40.77	3.65	40.14	3.71	38.63	3.81
	30	28	48.27	3.62	46.77	3.74	45.17	3.86	44.34	3.94	43.68	4.01	42.07	4.11
	35	32	52.16	3.89	50.50	4.03	48.78	4.14	47.91	4.23	47.20	4.31	45.50	4.41
	40	36	54.82	4.01	53.28	4.14	51.58	4.26	50.69	4.35	49.97	4.42	48.16	4.54
	45	41	58.14	4.15	56.75	4.29	55.08	4.42	54.17	4.50	53.44	4.56	51.50	4.70
	47	43	59.47	4.20	58.14	4.34	56.48	4.48	55.56	4.56	54.82	4.62	52.83	4.76
	50	46	59.65	4.18	58.44	4.30	57.00	4.43	56.17	4.49	55.51	4.55	53.64	4.67
	55	51	59.94	4.13	58.95	4.24	57.86	4.34	57.19	4.39	56.66	4.43	54.98	4.52
	60	56	60.23	4.09	59.45	4.17	58.72	4.25	58.21	4.28	57.81	4.30	56.33	4.37
	63	59	60.40	4.06	59.75	4.13	59.23	4.19	58.82	4.21	58.50	4.23	57.14	4.28
	68	64	60.58	4.04	60.05	4.09	59.75	4.14	59.44	4.15	59.20	4.16	57.96	4.19
Non-Ducted Indoor Units 48 (100%)	-4	-4.4	20.82	2.11	19.26	2.20	19.17	2.21	18.95	2.22	18.77	2.23	17.93	2.32
	0	-0.4	25.05	2.25	23.56	2.34	23.19	2.37	22.87	2.39	22.61	2.40	21.65	2.49
	5	4.5	30.07	2.42	28.66	2.51	27.98	2.56	27.53	2.59	27.17	2.61	26.07	2.70
	10	9	33.43	2.58	32.08	2.67	31.18	2.74	30.65	2.77	30.22	2.80	29.03	2.89
	17	15	37.13	2.79	35.84	2.88	34.71	2.97	34.08	3.02	33.58	3.06	32.29	3.15
	20	19	39.37	2.93	38.12	3.02	36.84	3.13	36.16	3.18	35.61	3.23	34.26	3.32
	25	23	43.12	3.18	41.85	3.27	40.39	3.39	39.63	3.46	39.02	3.51	37.55	3.61
	30	28	46.91	3.43	45.46	3.54	43.90	3.65	43.09	3.73	42.45	3.80	40.89	3.89
	35	32	50.70	3.69	49.08	3.82	47.41	3.92	46.56	4.01	45.88	4.08	44.22	4.18
	40	36	53.28	3.79	51.79	3.93	50.13	4.04	49.27	4.12	48.57	4.19	46.81	4.30
	45	41	56.51	3.93	55.16	4.06	53.54	4.19	52.65	4.26	51.94	4.32	50.05	4.45
	47	43	57.80	3.98	56.51	4.12	54.90	4.25	54.00	4.32	53.28	4.38	51.34	4.51
	50	46	57.97	3.96	56.80	4.08	55.40	4.19	54.59	4.26	53.95	4.31	52.13	4.42
	55	51	58.26	3.92	57.29	4.01	56.23	4.11	55.59	4.16	55.07	4.19	53.44	4.28
	60	56	58.54	3.87	57.78	3.95	57.07	4.02	56.58	4.05	56.19	4.08	54.75	4.14
	63	59	58.71	3.85	58.07	3.91	57.57	3.97	57.17	3.99	56.86	4.01	55.54	4.05
	68	64	58.88	3.82	58.36	3.87	58.07	3.92	57.77	3.93	57.54	3.94	56.33	3.97
Non-Ducted Indoor Units 43 (90%)	-4	-4.4	18.24	1.89	16.87	1.97	16.79	1.99	16.60	1.99	16.44	2.00	15.70	2.08
	0	-0.4	21.94	2.02	20.63	2.10	20.32	2.13	20.03	2.14	19.80	2.15	18.96	2.23
	5	4.5	26.34	2.18	25.10	2.26	24.51	2.30	24.11	2.32	23.80	2.34	22.83	2.42
	10	9	29.28	2.32	28.10	2.40	27.31	2.46	26.85	2.49	26.47	2.52	25.43	2.60
	17	15	32.52	2.51	31.39	2.59	30.40	2.67	29.85	2.71	29.41	2.75	28.28	2.83
	20	19	34.49	2.63	33.39	2.71	32.27	2.81	31.67	2.86	31.19	2.90	30.01	2.98
	25	23	37.77	2.85	36.65	2.93	35.38	3.05	34.71	3.11	34.17	3.16	32.89	3.24
	30	28	41.09	3.08	39.82	3.18	38.45	3.28	37.75	3.35	37.18	3.41	35.82	3.50
	35	32	44.41	3.31	42.99	3.43	41.53	3.52	40.78	3.60	40.19	3.67	38.73	3.76
	40	36	46.67	3.41	45.36	3.53	43.91	3.63	43.15	3.70	42.54	3.76	41.00	3.86
	45	41	49.50	3.53	48.32	3.65	46.89	3.76	46.12	3.83	45.49	3.88	43.84	4.00
	47	43	50.63	3.58	49.50	3.70	48.09	3.81	47.30	3.88	46.67	3.93	44.97	4.05
	50	46	50.78	3.56	49.76	3.66	48.52	3.77	47.82	3.82	47.26	3.87	45.66	3.97
	55	51	51.03	3.52	50.18	3.60	49.26	3.69	48.69	3.73	48.24	3.77	46.81	3.85
	60	56	51.28	3.48	50.61	3.55	49.99	3.61	49.56	3.64	49.22	3.66	47.96	3.72
	63	59	51.42	3.46	50.86	3.51	50.42	3.57	50.08	3.58	49.80	3.60	48.65	3.64
	68	64	51.57	3.44	51.12	3.48	50.87	3.52	50.61	3.53	50.40	3.54	49.34	3.57

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU480HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 397: LMU480HV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 38 (80%)	-4	-4.4	16.12	1.68	14.91	1.75	14.84	1.76	14.67	1.77	14.53	1.77	13.88	1.84
	0	-0.4	19.39	1.79	18.24	1.86	17.95	1.89	17.70	1.90	17.50	1.91	16.76	1.98
	5	4.5	23.28	1.93	22.19	2.00	21.66	2.04	21.31	2.06	21.03	2.08	20.18	2.15
	10	9	25.88	2.06	24.83	2.13	24.14	2.18	23.72	2.21	23.39	2.23	22.47	2.30
	17	15	28.74	2.22	27.74	2.29	26.87	2.37	26.38	2.40	25.99	2.44	24.99	2.51
	20	19	30.48	2.34	29.50	2.41	28.52	2.49	27.99	2.54	27.57	2.57	26.52	2.64
	25	23	33.38	2.53	32.39	2.60	31.27	2.70	30.67	2.75	30.20	2.80	29.06	2.87
	30	28	36.31	2.73	35.19	2.82	33.98	2.91	33.36	2.97	32.86	3.02	31.65	3.10
	35	32	39.24	2.94	37.99	3.04	36.70	3.12	36.04	3.19	35.51	3.25	34.23	3.33
	40	36	41.24	3.02	40.09	3.13	38.81	3.21	38.14	3.28	37.60	3.34	36.24	3.42
	45	41	43.74	3.13	42.70	3.23	41.44	3.33	40.75	3.39	40.20	3.44	38.74	3.54
	47	43	44.74	3.17	43.74	3.28	42.49	3.38	41.80	3.44	41.24	3.49	39.74	3.59
	50	46	44.88	3.15	43.97	3.25	42.88	3.34	42.26	3.39	41.76	3.43	40.35	3.52
	55	51	45.09	3.12	44.35	3.20	43.53	3.27	43.03	3.31	42.63	3.34	41.37	3.41
	60	56	45.31	3.09	44.72	3.15	44.17	3.20	43.80	3.23	43.49	3.25	42.38	3.30
	63	59	45.45	3.07	44.95	3.11	44.56	3.16	44.26	3.18	44.01	3.19	42.99	3.23
	68	64	45.58	3.05	45.18	3.08	44.95	3.12	44.72	3.13	44.54	3.14	43.61	3.16
Non-Ducted Indoor Units 34 (70%)	-4	-4.4	14.42	1.50	13.34	1.57	13.28	1.58	13.12	1.58	13.00	1.59	12.42	1.65
	0	-0.4	17.35	1.60	16.32	1.67	16.06	1.69	15.84	1.70	15.66	1.71	14.99	1.77
	5	4.5	20.83	1.73	19.85	1.79	19.38	1.83	19.07	1.84	18.82	1.86	18.06	1.92
	10	9	23.15	1.84	22.22	1.90	21.60	1.95	21.23	1.98	20.93	2.00	20.11	2.06
	17	15	25.72	1.99	24.82	2.05	24.04	2.12	23.60	2.15	23.26	2.18	22.36	2.24
	20	19	27.27	2.09	26.40	2.15	25.52	2.23	25.04	2.27	24.67	2.30	23.73	2.37
	25	23	29.87	2.26	28.98	2.33	27.97	2.42	27.45	2.47	27.02	2.51	26.00	2.57
	30	28	32.49	2.45	31.49	2.53	30.40	2.61	29.85	2.66	29.40	2.71	28.32	2.78
	35	32	35.11	2.63	34.00	2.72	32.84	2.79	32.25	2.86	31.78	2.91	30.63	2.98
	40	36	36.90	2.71	35.87	2.80	34.72	2.88	34.12	2.94	33.64	2.99	32.42	3.07
	45	41	39.14	2.80	38.20	2.90	37.08	2.99	36.46	3.04	35.97	3.08	34.66	3.17
	47	43	40.03	2.84	39.14	2.93	38.02	3.03	37.40	3.08	36.90	3.12	35.56	3.22
	50	46	40.15	2.82	39.34	2.91	38.37	2.99	37.81	3.04	37.37	3.07	36.11	3.15
	55	51	40.35	2.79	39.68	2.86	38.95	2.93	38.50	2.96	38.14	2.99	37.01	3.05
	60	56	40.54	2.76	40.02	2.82	39.52	2.87	39.19	2.89	38.92	2.91	37.92	2.95
	63	59	40.66	2.74	40.22	2.79	39.87	2.83	39.60	2.84	39.38	2.86	38.46	2.89
	68	64	40.78	2.73	40.42	2.76	40.22	2.79	40.01	2.80	39.85	2.81	39.02	2.83
Non-Ducted Indoor Units 29 (60%)	-4	-4.4	12.30	1.29	11.38	1.34	11.32	1.35	11.19	1.36	11.09	1.36	10.59	1.42
	0	-0.4	14.80	1.37	13.92	1.43	13.70	1.45	13.51	1.46	13.36	1.47	12.79	1.52
	5	4.5	17.76	1.48	16.93	1.53	16.53	1.56	16.26	1.58	16.05	1.59	15.40	1.65
	10	9	19.75	1.58	18.95	1.63	18.42	1.67	18.10	1.69	17.85	1.71	17.15	1.77
	17	15	21.93	1.71	21.17	1.76	20.50	1.82	20.13	1.85	19.84	1.87	19.07	1.92
	20	19	23.26	1.79	22.52	1.85	21.77	1.91	21.36	1.95	21.04	1.97	20.24	2.03
	25	23	25.48	1.94	24.72	2.00	23.86	2.07	23.41	2.11	23.05	2.15	22.18	2.20
	30	28	27.71	2.10	26.86	2.17	25.93	2.23	25.46	2.28	25.08	2.32	24.15	2.38
	35	32	29.95	2.25	29.00	2.33	28.01	2.39	27.51	2.45	27.10	2.49	26.12	2.56
	40	36	31.48	2.32	30.59	2.40	29.62	2.47	29.10	2.52	28.69	2.56	27.65	2.63
	45	41	33.38	2.40	32.59	2.48	31.63	2.56	31.10	2.61	30.68	2.64	29.57	2.72
	47	43	34.15	2.43	33.38	2.51	32.43	2.60	31.90	2.64	31.48	2.68	30.33	2.76
	50	46	34.25	2.42	33.56	2.49	32.73	2.56	32.25	2.60	31.87	2.63	30.80	2.70
	55	51	34.41	2.39	33.84	2.45	33.22	2.51	32.84	2.54	32.53	2.56	31.57	2.62
	60	56	34.58	2.37	34.13	2.41	33.71	2.46	33.42	2.48	33.19	2.49	32.34	2.53
	63	59	34.68	2.35	34.30	2.39	34.01	2.43	33.77	2.44	33.59	2.45	32.81	2.48
	68	64	34.78	2.34	34.48	2.37	34.31	2.39	34.13	2.40	33.99	2.41	33.28	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 398: LMU480HV Heating Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 24 (50%)	-4	-4.4	10.18	1.07	9.42	1.12	9.37	1.13	9.26	1.13	9.18	1.13	8.76	1.18
	0	-0.4	12.25	1.15	11.52	1.19	11.34	1.21	11.18	1.21	11.05	1.22	10.58	1.27
	5	4.5	14.70	1.23	14.01	1.28	13.68	1.30	13.46	1.32	13.28	1.33	12.74	1.37
	10	9	16.34	1.31	15.68	1.36	15.25	1.39	14.98	1.41	14.77	1.43	14.19	1.47
	17	15	18.15	1.42	17.52	1.47	16.97	1.51	16.66	1.54	16.42	1.56	15.78	1.60
	20	19	19.25	1.49	18.63	1.54	18.01	1.59	17.68	1.62	17.41	1.65	16.75	1.69
	25	23	21.08	1.62	20.46	1.66	19.75	1.73	19.37	1.76	19.07	1.79	18.36	1.84
	30	28	22.94	1.75	22.23	1.81	21.46	1.86	21.07	1.90	20.75	1.93	19.99	1.98
	35	32	24.79	1.88	24.00	1.94	23.18	2.00	22.76	2.04	22.43	2.08	21.62	2.13
	40	36	26.05	1.93	25.32	2.00	24.51	2.06	24.09	2.10	23.75	2.13	22.89	2.19
	45	41	27.63	2.00	26.97	2.07	26.17	2.13	25.74	2.17	25.39	2.20	24.47	2.27
	47	43	28.26	2.03	27.63	2.10	26.84	2.16	26.40	2.20	26.05	2.23	25.10	2.30
	50	46	28.34	2.02	27.77	2.08	27.08	2.14	26.69	2.17	26.38	2.19	25.49	2.25
	55	51	28.48	1.99	28.01	2.04	27.49	2.09	27.18	2.12	26.92	2.14	26.13	2.18
	60	56	28.62	1.97	28.25	2.01	27.90	2.05	27.66	2.06	27.47	2.08	26.77	2.11
	63	59	28.70	1.96	28.39	1.99	28.14	2.02	27.95	2.03	27.80	2.04	27.15	2.06
	68	64	28.79	1.95	28.53	1.97	28.39	2.00	28.25	2.00	28.13	2.01	27.54	2.02
Ducted Indoor Units 65 (135%)	-4	-4.4	24.27	2.73	22.55	2.84	22.37	2.87	22.10	2.88	21.88	2.89	20.91	3.00
	0	-0.4	28.12	2.90	26.50	3.01	26.06	3.05	25.69	3.07	25.39	3.09	24.32	3.20
	5	4.5	32.71	3.10	31.19	3.21	30.44	3.27	29.95	3.31	29.55	3.34	28.36	3.45
	10	9	35.78	3.28	34.34	3.40	33.37	3.48	32.80	3.53	32.34	3.56	31.07	3.68
	17	15	39.16	3.53	37.79	3.64	36.60	3.76	35.94	3.82	35.41	3.87	34.05	3.98
	20	19	41.20	3.70	39.89	3.81	38.56	3.94	37.84	4.01	37.27	4.07	35.85	4.18
	25	23	44.63	3.98	43.31	4.10	41.80	4.25	41.01	4.34	40.38	4.41	38.86	4.52
	30	28	48.10	4.28	46.61	4.42	45.01	4.56	44.18	4.66	43.52	4.74	41.92	4.86
	35	32	51.56	4.58	49.92	4.75	48.22	4.87	47.35	4.98	46.66	5.07	44.97	5.20
	40	36	54.19	4.72	52.67	4.88	50.99	5.02	50.11	5.12	49.40	5.21	47.61	5.35
	45	41	57.47	4.88	56.10	5.05	54.45	5.20	53.54	5.30	52.82	5.38	50.90	5.53
	47	43	58.79	4.95	57.47	5.12	55.83	5.28	54.92	5.37	54.19	5.44	52.22	5.61
	50	46	58.96	4.92	57.77	5.07	56.34	5.21	55.53	5.29	54.87	5.36	53.02	5.50
	55	51	59.25	4.87	58.27	4.99	57.19	5.11	56.53	5.17	56.01	5.21	54.35	5.32
	60	56	59.54	4.82	58.76	4.91	58.04	5.00	57.54	5.04	57.14	5.07	55.68	5.15
	63	59	59.71	4.79	59.06	4.86	58.55	4.94	58.15	4.96	57.83	4.98	56.48	5.04
	68	64	59.88	4.75	59.36	4.82	59.06	4.87	58.76	4.88	58.52	4.90	57.29	4.94
Ducted Indoor Units 62 (130%)	-4	-4.4	23.89	2.65	22.19	2.76	22.02	2.79	21.75	2.80	21.54	2.81	20.59	2.92
	0	-0.4	27.68	2.81	26.08	2.92	25.65	2.96	25.28	2.99	24.99	3.00	23.94	3.11
	5	4.5	32.20	3.01	30.70	3.12	29.96	3.18	29.48	3.22	29.09	3.24	27.92	3.35
	10	9	35.22	3.19	33.80	3.30	32.85	3.38	32.29	3.43	31.84	3.47	30.58	3.58
	17	15	38.54	3.43	37.20	3.54	36.03	3.65	35.38	3.71	34.86	3.76	33.51	3.87
	20	19	40.56	3.59	39.26	3.70	37.95	3.83	37.25	3.90	36.69	3.96	35.29	4.07
	25	23	43.93	3.87	42.63	3.98	41.15	4.13	40.37	4.22	39.75	4.28	38.25	4.39
	30	28	47.35	4.16	45.88	4.30	44.30	4.43	43.49	4.53	42.84	4.61	41.27	4.72
	35	32	50.76	4.46	49.14	4.61	47.47	4.73	46.61	4.84	45.93	4.93	44.27	5.05
	40	36	53.34	4.59	51.84	4.74	50.19	4.88	49.32	4.98	48.63	5.06	46.86	5.20
	45	41	56.57	4.75	55.22	4.91	53.60	5.06	52.71	5.15	51.99	5.23	50.11	5.38
	47	43	57.87	4.81	56.57	4.97	54.96	5.13	54.06	5.22	53.34	5.29	51.40	5.45
	50	46	58.04	4.78	56.87	4.93	55.46	5.07	54.66	5.15	54.01	5.21	52.19	5.35
	55	51	58.32	4.73	57.35	4.85	56.29	4.96	55.65	5.02	55.13	5.07	53.50	5.17
	60	56	58.60	4.68	57.84	4.77	57.13	4.86	56.64	4.90	56.25	4.93	54.81	5.00
	63	59	58.77	4.65	58.13	4.73	57.63	4.80	57.24	4.82	56.92	4.84	55.60	4.90
	68	64	58.94	4.62	58.43	4.68	58.14	4.74	57.84	4.75	57.60	4.76	56.40	4.80

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU480HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 399: LMU480HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 58 (120%)	-4	-4.4	23.37	2.55	21.72	2.65	21.55	2.67	21.29	2.68	21.08	2.69	20.14	2.80
	0	-0.4	27.09	2.70	25.52	2.81	25.10	2.84	24.74	2.87	24.45	2.88	23.42	2.99
	5	4.5	31.51	2.89	30.04	3.00	29.32	3.05	28.85	3.09	28.47	3.11	27.32	3.22
	10	9	34.46	3.06	33.07	3.17	32.15	3.25	31.59	3.29	31.15	3.33	29.93	3.43
	17	15	37.72	3.29	36.40	3.40	35.26	3.50	34.62	3.56	34.11	3.61	32.80	3.71
	20	19	39.69	3.45	38.42	3.55	37.14	3.68	36.45	3.74	35.90	3.80	34.53	3.90
	25	23	42.99	3.71	41.72	3.82	40.27	3.97	39.50	4.05	38.89	4.11	37.43	4.22
	30	28	46.33	4.00	44.90	4.13	43.35	4.25	42.56	4.35	41.92	4.42	40.38	4.53
	35	32	49.67	4.28	48.08	4.43	46.45	4.54	45.61	4.65	44.94	4.73	43.32	4.85
	40	36	52.20	4.40	50.73	4.55	49.11	4.68	48.26	4.78	47.58	4.86	45.86	4.99
	45	41	55.36	4.56	54.04	4.71	52.45	4.86	51.57	4.94	50.88	5.02	49.03	5.16
	47	43	56.63	4.62	55.36	4.77	53.78	4.93	52.90	5.01	52.20	5.08	50.30	5.23
	50	46	56.79	4.59	55.65	4.73	54.27	4.87	53.48	4.94	52.85	5.00	51.07	5.13
	55	51	57.07	4.54	56.12	4.65	55.09	4.76	54.45	4.82	53.95	4.86	52.35	4.97
	60	56	57.35	4.49	56.60	4.58	55.90	4.66	55.43	4.70	55.04	4.73	53.64	4.80
	63	59	57.51	4.46	56.89	4.54	56.39	4.60	56.01	4.63	55.70	4.65	54.41	4.70
	68	64	57.68	4.44	57.17	4.49	56.89	4.55	56.60	4.56	56.36	4.57	55.19	4.60
Ducted Indoor Units 53 (110%)	-4	-4.4	22.73	2.42	21.12	2.52	20.96	2.54	20.70	2.55	20.50	2.56	19.59	2.66
	0	-0.4	26.35	2.57	24.82	2.67	24.41	2.70	24.06	2.72	23.78	2.74	22.78	2.84
	5	4.5	30.64	2.75	29.22	2.85	28.52	2.90	28.05	2.93	27.69	2.96	26.57	3.06
	10	9	33.52	2.91	32.17	3.01	31.27	3.09	30.73	3.13	30.30	3.16	29.11	3.26
	17	15	36.68	3.13	35.41	3.23	34.29	3.33	33.67	3.38	33.17	3.43	31.90	3.53
	20	19	38.60	3.28	37.37	3.38	36.12	3.49	35.45	3.56	34.91	3.61	33.59	3.71
	25	23	41.81	3.53	40.57	3.63	39.16	3.77	38.42	3.84	37.83	3.90	36.40	4.01
	30	28	45.06	3.80	43.67	3.92	42.17	4.04	41.39	4.13	40.77	4.20	39.27	4.31
	35	32	48.30	4.06	46.77	4.21	45.17	4.32	44.36	4.42	43.71	4.50	42.13	4.61
	40	36	50.77	4.18	49.34	4.33	47.77	4.45	46.94	4.54	46.28	4.62	44.60	4.74
	45	41	53.84	4.33	52.56	4.47	51.01	4.61	50.16	4.70	49.48	4.77	47.69	4.90
	47	43	55.07	4.39	53.84	4.53	52.30	4.68	51.45	4.76	50.77	4.82	48.92	4.97
	50	46	55.24	4.36	54.12	4.49	52.78	4.62	52.02	4.69	51.41	4.75	49.67	4.88
	55	51	55.51	4.32	54.58	4.42	53.58	4.53	52.96	4.58	52.47	4.62	50.92	4.72
	60	56	55.77	4.27	55.05	4.35	54.37	4.43	53.91	4.46	53.53	4.49	52.17	4.56
	63	59	55.94	4.24	55.33	4.31	54.85	4.37	54.47	4.40	54.17	4.41	52.91	4.47
	68	64	56.10	4.21	55.61	4.27	55.33	4.32	55.05	4.33	54.82	4.34	53.67	4.38
Ducted Indoor Units 48 (100%)	-4	-4.4	22.09	2.29	20.53	2.38	20.37	2.40	20.12	2.41	19.92	2.42	19.04	2.51
	0	-0.4	25.60	2.43	24.12	2.52	23.72	2.55	23.38	2.57	23.11	2.59	22.14	2.68
	5	4.5	29.78	2.60	28.40	2.69	27.71	2.74	27.26	2.77	26.90	2.80	25.82	2.89
	10	9	32.57	2.75	31.26	2.85	30.38	2.92	29.86	2.96	29.44	2.99	28.29	3.08
	17	15	35.65	2.96	34.41	3.05	33.32	3.15	32.72	3.20	32.24	3.24	31.00	3.34
	20	19	37.51	3.10	36.32	3.19	35.10	3.30	34.45	3.36	33.93	3.41	32.64	3.51
	25	23	40.63	3.34	39.43	3.43	38.06	3.56	37.34	3.63	36.76	3.69	35.38	3.79
	30	28	43.79	3.59	42.44	3.71	40.98	3.82	40.23	3.90	39.62	3.97	38.17	4.07
	35	32	46.94	3.84	45.45	3.98	43.90	4.08	43.11	4.18	42.48	4.25	40.95	4.36
	40	36	49.34	3.95	47.95	4.09	46.42	4.21	45.62	4.29	44.97	4.36	43.34	4.48
	45	41	52.33	4.09	51.08	4.23	49.57	4.36	48.75	4.44	48.09	4.50	46.34	4.64
	47	43	53.52	4.15	52.33	4.29	50.83	4.42	50.00	4.50	49.34	4.56	47.54	4.70
	50	46	53.68	4.12	52.60	4.25	51.29	4.37	50.55	4.44	49.96	4.49	48.27	4.61
	55	51	53.94	4.08	53.05	4.18	52.07	4.28	51.47	4.33	50.99	4.37	49.48	4.46
	60	56	54.20	4.04	53.50	4.11	52.84	4.19	52.39	4.22	52.03	4.25	50.69	4.31
	63	59	54.36	4.01	53.77	4.07	53.30	4.14	52.94	4.16	52.65	4.17	51.42	4.22
	68	64	54.52	3.98	54.04	4.03	53.77	4.08	53.49	4.09	53.27	4.10	52.16	4.14

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 400: LMU480HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 43 (90%)	-4	-4.4	19.35	2.04	17.98	2.12	17.84	2.14	17.62	2.15	17.45	2.16	16.68	2.24
	0	-0.4	22.43	2.16	21.13	2.25	20.78	2.28	20.48	2.29	20.25	2.31	19.39	2.39
	5	4.5	26.09	2.31	24.88	2.40	24.28	2.44	23.88	2.47	23.57	2.49	22.62	2.58
	10	9	28.53	2.45	27.38	2.54	26.62	2.60	26.16	2.63	25.79	2.66	24.78	2.75
	17	15	31.23	2.64	30.14	2.72	29.19	2.80	28.66	2.85	28.24	2.89	27.15	2.97
	20	19	32.86	2.76	31.81	2.84	30.75	2.94	30.18	3.00	29.72	3.04	28.59	3.12
	25	23	35.60	2.97	34.54	3.06	33.34	3.17	32.71	3.24	32.20	3.29	30.99	3.38
	30	28	38.36	3.20	37.17	3.30	35.90	3.40	35.24	3.48	34.71	3.54	33.43	3.63
	35	32	41.12	3.42	39.81	3.54	38.46	3.64	37.77	3.72	37.21	3.79	35.87	3.88
	40	36	43.22	3.52	42.00	3.64	40.66	3.75	39.96	3.83	39.40	3.89	37.97	3.99
	45	41	45.84	3.65	44.74	3.77	43.42	3.89	42.70	3.96	42.13	4.01	40.60	4.13
	47	43	46.88	3.70	45.84	3.82	44.53	3.94	43.80	4.01	43.22	4.06	41.65	4.19
	50	46	47.02	3.67	46.07	3.78	44.93	3.89	44.28	3.95	43.76	4.00	42.28	4.11
	55	51	47.25	3.64	46.47	3.73	45.61	3.81	45.09	3.86	44.67	3.89	43.35	3.97
	60	56	47.48	3.60	46.86	3.67	46.29	3.73	45.89	3.76	45.57	3.78	44.41	3.84
	63	59	47.62	3.57	47.10	3.63	46.69	3.69	46.37	3.70	46.12	3.72	45.05	3.76
	68	64	47.76	3.55	47.34	3.60	47.10	3.64	46.86	3.65	46.67	3.66	45.69	3.69
Ducted Indoor Units 38 (80%)	-4	-4.4	17.10	1.79	15.89	1.86	15.76	1.88	15.57	1.89	15.42	1.89	14.74	1.97
	0	-0.4	19.82	1.90	18.67	1.97	18.36	2.00	18.10	2.01	17.89	2.02	17.14	2.10
	5	4.5	23.05	2.03	21.98	2.10	21.45	2.15	21.10	2.17	20.82	2.19	19.98	2.26
	10	9	25.21	2.15	24.19	2.23	23.52	2.28	23.11	2.31	22.79	2.34	21.89	2.41
	17	15	27.59	2.31	26.63	2.39	25.79	2.46	25.33	2.50	24.95	2.54	23.99	2.61
	20	19	29.03	2.42	28.11	2.50	27.17	2.58	26.67	2.63	26.26	2.67	25.26	2.74
	25	23	31.45	2.61	30.52	2.68	29.46	2.79	28.90	2.84	28.45	2.89	27.38	2.96
	30	28	33.89	2.81	32.84	2.90	31.72	2.99	31.13	3.05	30.67	3.11	29.54	3.19
	35	32	36.33	3.00	35.18	3.11	33.98	3.19	33.37	3.27	32.88	3.33	31.69	3.41
	40	36	38.19	3.09	37.11	3.20	35.93	3.29	35.31	3.36	34.81	3.41	33.55	3.50
	45	41	40.50	3.20	39.53	3.31	38.37	3.41	37.73	3.47	37.22	3.52	35.87	3.63
	47	43	41.43	3.25	40.50	3.35	39.34	3.46	38.70	3.52	38.19	3.57	36.80	3.67
	50	46	41.55	3.23	40.71	3.32	39.70	3.42	39.13	3.47	38.67	3.51	37.36	3.61
	55	51	41.75	3.19	41.06	3.27	40.30	3.35	39.84	3.39	39.47	3.42	38.30	3.49
	60	56	41.95	3.16	41.41	3.22	40.90	3.28	40.55	3.30	40.27	3.32	39.24	3.37
	63	59	42.07	3.14	41.62	3.19	41.26	3.24	40.97	3.25	40.75	3.26	39.80	3.30
	68	64	42.20	3.12	41.83	3.16	41.62	3.19	41.40	3.20	41.23	3.21	40.37	3.24
Ducted Indoor Units 34 (70%)	-4	-4.4	15.30	1.59	14.22	1.65	14.11	1.66	13.93	1.67	13.80	1.68	13.19	1.74
	0	-0.4	17.73	1.68	16.71	1.75	16.43	1.77	16.20	1.78	16.01	1.79	15.33	1.86
	5	4.5	20.62	1.80	19.67	1.87	19.19	1.90	18.88	1.92	18.63	1.94	17.88	2.00
	10	9	22.56	1.91	21.65	1.97	21.04	2.02	20.68	2.05	20.39	2.07	19.59	2.14
	17	15	24.69	2.05	23.83	2.12	23.08	2.18	22.66	2.22	22.33	2.25	21.47	2.31
	20	19	25.98	2.15	25.15	2.21	24.31	2.29	23.86	2.33	23.50	2.37	22.61	2.43
	25	23	28.14	2.31	27.31	2.38	26.36	2.47	25.86	2.52	25.46	2.56	24.50	2.63
	30	28	30.33	2.49	29.39	2.57	28.38	2.65	27.86	2.71	27.44	2.75	26.43	2.82
	35	32	32.51	2.66	31.48	2.76	30.41	2.83	29.86	2.90	29.42	2.95	28.36	3.02
	40	36	34.17	2.74	33.21	2.84	32.15	2.92	31.59	2.98	31.15	3.03	30.02	3.11
	45	41	36.24	2.84	35.37	2.93	34.33	3.02	33.76	3.08	33.31	3.12	32.10	3.21
	47	43	37.07	2.88	36.24	2.97	35.21	3.07	34.63	3.12	34.17	3.16	32.93	3.26
	50	46	37.18	2.86	36.43	2.94	35.53	3.03	35.01	3.08	34.60	3.11	33.43	3.20
	55	51	37.36	2.83	36.74	2.90	36.06	2.97	35.65	3.00	35.32	3.03	34.27	3.09
	60	56	37.54	2.80	37.05	2.85	36.60	2.90	36.28	2.93	36.03	2.94	35.11	2.99
	63	59	37.65	2.78	37.24	2.82	36.92	2.87	36.66	2.88	36.46	2.89	35.62	2.93
	68	64	37.76	2.76	37.43	2.80	37.24	2.83	37.05	2.84	36.90	2.84	36.13	2.87

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU480HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 401: LMU480HV Heating Capacity Table — Ducted, continued, and Mixed Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 29 (60%)	-4	-4.4	13.05	1.34	12.13	1.39	12.03	1.40	11.89	1.41	11.77	1.41	11.25	1.47
	0	-0.4	15.13	1.42	14.25	1.47	14.02	1.49	13.82	1.50	13.65	1.51	13.08	1.57
	5	4.5	17.59	1.52	16.78	1.57	16.37	1.60	16.11	1.62	15.90	1.63	15.25	1.69
	10	9	19.24	1.61	18.47	1.66	17.95	1.70	17.64	1.73	17.40	1.75	16.71	1.80
	17	15	21.06	1.73	20.33	1.78	19.69	1.84	19.33	1.87	19.05	1.89	18.31	1.95
	20	19	22.16	1.81	21.46	1.87	20.74	1.93	20.35	1.97	20.05	1.99	19.28	2.05
	25	23	24.01	1.95	23.30	2.01	22.49	2.08	22.06	2.12	21.72	2.16	20.90	2.21
	30	28	25.87	2.10	25.07	2.17	24.21	2.23	23.77	2.28	23.41	2.32	22.55	2.38
	35	32	27.73	2.24	26.85	2.32	25.94	2.39	25.47	2.44	25.10	2.49	24.19	2.55
	40	36	29.15	2.31	28.33	2.39	27.43	2.46	26.95	2.51	26.57	2.55	25.61	2.62
	45	41	30.91	2.39	30.18	2.47	29.29	2.55	28.80	2.60	28.41	2.63	27.38	2.71
	47	43	31.62	2.43	30.91	2.51	30.03	2.59	29.54	2.63	29.15	2.67	28.09	2.75
	50	46	31.71	2.41	31.07	2.48	30.30	2.55	29.87	2.59	29.51	2.62	28.52	2.69
	55	51	31.87	2.38	31.34	2.44	30.76	2.50	30.41	2.53	30.13	2.55	29.23	2.61
	60	56	32.02	2.36	31.61	2.40	31.22	2.45	30.95	2.47	30.74	2.48	29.95	2.52
	63	59	32.12	2.34	31.77	2.38	31.49	2.42	31.28	2.43	31.10	2.44	30.38	2.47
	68	64	32.21	2.33	31.93	2.36	31.77	2.39	31.60	2.39	31.47	2.40	30.82	2.42
Ducted Indoor Units 24 (50%)	-4	-4.4	10.80	1.09	10.03	1.13	9.96	1.14	9.83	1.15	9.74	1.15	9.31	1.20
	0	-0.4	12.52	1.15	11.79	1.20	11.60	1.22	11.43	1.22	11.30	1.23	10.82	1.28
	5	4.5	14.56	1.23	13.88	1.28	13.55	1.30	13.33	1.32	13.15	1.33	12.62	1.38
	10	9	15.92	1.31	15.28	1.35	14.85	1.39	14.60	1.41	14.39	1.42	13.83	1.47
	17	15	17.42	1.41	16.82	1.45	16.29	1.50	15.99	1.52	15.76	1.54	15.15	1.59
	20	19	18.34	1.47	17.75	1.52	17.16	1.57	16.84	1.60	16.59	1.62	15.96	1.67
	25	23	19.86	1.59	19.27	1.63	18.60	1.69	18.25	1.73	17.97	1.76	17.29	1.80
	30	28	21.40	1.71	20.74	1.76	20.03	1.82	19.66	1.86	19.37	1.89	18.66	1.94
	35	32	22.95	1.83	22.22	1.89	21.46	1.94	21.07	1.99	20.76	2.02	20.01	2.07
	40	36	24.12	1.88	23.44	1.95	22.69	2.00	22.30	2.04	21.98	2.08	21.19	2.13
	45	41	25.58	1.95	24.97	2.01	24.23	2.07	23.83	2.11	23.51	2.14	22.65	2.20
	47	43	26.16	1.97	25.58	2.04	24.85	2.10	24.44	2.14	24.12	2.17	23.24	2.23
	50	46	26.24	1.96	25.71	2.02	25.07	2.08	24.71	2.11	24.42	2.13	23.59	2.19
	55	51	26.37	1.94	25.93	1.99	25.45	2.04	25.16	2.06	24.92	2.08	24.19	2.12
	60	56	26.49	1.92	26.15	1.96	25.83	1.99	25.61	2.01	25.43	2.02	24.78	2.05
	63	59	26.57	1.91	26.28	1.94	26.05	1.97	25.88	1.98	25.73	1.98	25.14	2.01
	68	64	26.65	1.89	26.41	1.92	26.28	1.94	26.15	1.95	26.04	1.95	25.50	1.97
Mixed Indoor Units 65 (135%)	-4	-4.4	23.57	2.62	21.85	2.73	21.71	2.75	21.46	2.76	21.25	2.77	20.30	2.88
	0	-0.4	27.82	2.79	26.19	2.90	25.77	2.94	25.40	2.96	25.11	2.97	24.05	3.08
	5	4.5	32.87	2.99	31.34	3.10	30.59	3.16	30.09	3.20	29.70	3.22	28.50	3.33
	10	9	36.25	3.18	34.79	3.29	33.81	3.37	33.23	3.42	32.77	3.45	31.48	3.56
	17	15	39.97	3.43	38.58	3.54	37.36	3.65	36.69	3.71	36.15	3.76	34.76	3.87
	20	19	42.23	3.60	40.88	3.71	39.52	3.83	38.78	3.90	38.20	3.96	36.74	4.07
	25	23	46.00	3.88	44.64	4.00	43.09	4.15	42.27	4.23	41.62	4.30	40.05	4.41
	30	28	49.82	4.19	48.28	4.32	46.62	4.46	45.76	4.56	45.08	4.63	43.42	4.75
	35	32	53.63	4.49	51.92	4.65	50.15	4.77	49.25	4.88	48.53	4.97	46.78	5.09
	40	36	56.36	4.62	54.78	4.78	53.03	4.92	52.11	5.02	51.38	5.10	49.52	5.24
	45	41	59.78	4.78	58.35	4.94	56.63	5.10	55.69	5.19	54.94	5.27	52.94	5.42
	47	43	61.14	4.85	59.78	5.01	58.07	5.17	57.12	5.26	56.36	5.33	54.31	5.49
	50	46	61.32	4.82	60.09	4.96	58.60	5.11	57.75	5.18	57.07	5.25	55.14	5.39
	55	51	61.62	4.77	60.60	4.89	59.48	5.00	58.80	5.06	58.25	5.10	56.53	5.21
	60	56	61.92	4.72	61.12	4.81	60.36	4.90	59.85	4.93	59.43	4.96	57.91	5.04
	63	59	62.10	4.69	61.42	4.76	60.89	4.83	60.48	4.86	60.14	4.88	58.75	4.94
	68	64	62.28	4.66	61.73	4.72	61.43	4.77	61.11	4.78	60.86	4.79	59.59	4.83

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 402: LMU480HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 62 (130%)	-4	-4.4	23.20	2.55	21.51	2.65	21.37	2.67	21.12	2.68	20.92	2.69	19.98	2.80
	0	-0.4	27.38	2.71	25.78	2.82	25.36	2.85	25.00	2.87	24.72	2.89	23.67	3.00
	5	4.5	32.35	2.91	30.84	3.01	30.11	3.07	29.62	3.11	29.23	3.13	28.05	3.24
	10	9	35.68	3.09	34.24	3.20	33.28	3.27	32.71	3.32	32.25	3.35	30.98	3.46
	17	15	39.34	3.33	37.97	3.44	36.78	3.54	36.11	3.60	35.58	3.65	34.21	3.76
	20	19	41.56	3.49	40.24	3.60	38.89	3.72	38.17	3.79	37.59	3.85	36.17	3.96
	25	23	45.28	3.77	43.94	3.88	42.41	4.03	41.61	4.11	40.96	4.17	39.42	4.28
	30	28	49.03	4.07	47.51	4.20	45.88	4.33	45.04	4.43	44.37	4.50	42.74	4.62
	35	32	52.78	4.36	51.10	4.52	49.36	4.63	48.48	4.74	47.77	4.83	46.04	4.95
	40	36	55.47	4.49	53.91	4.64	52.20	4.78	51.29	4.88	50.57	4.96	48.74	5.09
	45	41	58.83	4.65	57.43	4.80	55.74	4.95	54.81	5.04	54.07	5.12	52.11	5.26
	47	43	60.18	4.71	58.83	4.87	57.15	5.02	56.22	5.11	55.47	5.18	53.46	5.33
	50	46	60.36	4.68	59.14	4.82	57.68	4.96	56.84	5.04	56.17	5.10	54.27	5.23
	55	51	60.65	4.63	59.65	4.75	58.54	4.86	57.87	4.92	57.33	4.96	55.64	5.07
	60	56	60.95	4.58	60.15	4.67	59.41	4.76	58.90	4.79	58.50	4.82	57.00	4.90
	63	59	61.12	4.55	60.46	4.63	59.93	4.70	59.52	4.72	59.20	4.74	57.82	4.80
	68	64	61.30	4.52	60.76	4.58	60.46	4.64	60.15	4.65	59.90	4.66	58.65	4.70
Mixed Indoor Units 58 (120%)	-4	-4.4	22.70	2.45	21.05	2.55	20.91	2.57	20.66	2.58	20.47	2.59	19.55	2.69
	0	-0.4	26.79	2.60	25.22	2.71	24.82	2.74	24.46	2.76	24.18	2.78	23.16	2.88
	5	4.5	31.66	2.79	30.18	2.90	29.46	2.95	28.98	2.98	28.60	3.01	27.45	3.11
	10	9	34.91	2.97	33.50	3.07	32.57	3.15	32.01	3.19	31.56	3.22	30.32	3.33
	17	15	38.49	3.20	37.16	3.30	35.98	3.41	35.33	3.46	34.81	3.51	33.47	3.61
	20	19	40.67	3.36	39.37	3.46	38.06	3.58	37.35	3.64	36.78	3.70	35.39	3.80
	25	23	44.30	3.62	42.99	3.73	41.50	3.87	40.71	3.95	40.08	4.01	38.57	4.12
	30	28	47.98	3.91	46.49	4.04	44.90	4.16	44.07	4.25	43.41	4.33	41.82	4.43
	35	32	51.65	4.19	50.00	4.34	48.30	4.45	47.43	4.56	46.74	4.64	45.05	4.75
	40	36	54.28	4.31	52.75	4.46	51.07	4.59	50.19	4.69	49.48	4.76	47.69	4.89
	45	41	57.57	4.47	56.19	4.62	54.54	4.76	53.63	4.85	52.91	4.92	50.99	5.06
	47	43	58.88	4.53	57.57	4.68	55.92	4.83	55.01	4.91	54.28	4.98	52.31	5.13
	50	46	59.06	4.50	57.87	4.63	56.43	4.77	55.62	4.84	54.96	4.90	53.11	5.03
	55	51	59.35	4.45	58.36	4.56	57.28	4.67	56.63	4.72	56.10	4.77	54.44	4.87
	60	56	59.63	4.40	58.86	4.49	58.13	4.57	57.64	4.61	57.24	4.63	55.77	4.71
	63	59	59.81	4.38	59.15	4.45	58.64	4.51	58.24	4.54	57.92	4.55	56.58	4.61
	68	64	59.98	4.35	59.45	4.40	59.16	4.45	58.86	4.47	58.61	4.48	57.39	4.51
Mixed Indoor Units 53 (110%)	-4	-4.4	22.08	2.32	20.47	2.42	20.34	2.44	20.10	2.45	19.91	2.45	19.02	2.55
	0	-0.4	26.06	2.47	24.53	2.57	24.14	2.60	23.80	2.62	23.52	2.64	22.53	2.73
	5	4.5	30.79	2.65	29.36	2.75	28.65	2.80	28.19	2.83	27.82	2.86	26.70	2.95
	10	9	33.96	2.82	32.59	2.91	31.68	2.99	31.13	3.03	30.70	3.06	29.49	3.16
	17	15	37.45	3.04	36.14	3.14	35.00	3.23	34.37	3.29	33.86	3.33	32.56	3.43
	20	19	39.56	3.19	38.30	3.28	37.02	3.40	36.33	3.46	35.78	3.51	34.42	3.61
	25	23	43.10	3.44	41.82	3.54	40.36	3.67	39.60	3.75	38.99	3.81	37.52	3.91
	30	28	46.67	3.71	45.22	3.83	43.67	3.95	42.87	4.04	42.23	4.11	40.68	4.21
	35	32	50.24	3.98	48.64	4.12	46.98	4.23	46.14	4.32	45.46	4.40	43.82	4.51
	40	36	52.80	4.09	51.32	4.24	49.68	4.36	48.82	4.45	48.13	4.52	46.39	4.64
	45	41	56.00	4.24	54.66	4.38	53.05	4.52	52.17	4.60	51.47	4.67	49.60	4.80
	47	43	57.28	4.30	56.00	4.44	54.40	4.58	53.51	4.66	52.80	4.72	50.88	4.87
	50	46	57.45	4.27	56.29	4.40	54.89	4.53	54.10	4.59	53.46	4.65	51.66	4.77
	55	51	57.73	4.22	56.77	4.33	55.72	4.43	55.08	4.48	54.57	4.52	52.96	4.62
	60	56	58.01	4.18	57.25	4.26	56.55	4.34	56.06	4.37	55.68	4.40	54.25	4.47
	63	59	58.18	4.15	57.54	4.22	57.04	4.28	56.65	4.30	56.34	4.32	55.03	4.37
	68	64	58.34	4.13	57.83	4.18	57.55	4.23	57.25	4.24	57.01	4.25	55.82	4.28

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 403: LMU480HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 48 (100%)	-4	-4.4	21.46	2.20	19.90	2.29	19.77	2.31	19.53	2.32	19.35	2.32	18.48	2.41
	0	-0.4	25.33	2.34	23.84	2.43	23.46	2.46	23.13	2.48	22.86	2.49	21.89	2.59
	5	4.5	29.92	2.51	28.53	2.60	27.85	2.65	27.40	2.68	27.04	2.70	25.94	2.79
	10	9	33.00	2.67	31.67	2.76	30.78	2.83	30.25	2.86	29.83	2.89	28.66	2.99
	17	15	36.39	2.88	35.12	2.97	34.02	3.06	33.40	3.11	32.91	3.15	31.64	3.24
	20	19	38.44	3.02	37.22	3.11	35.97	3.21	35.31	3.27	34.77	3.32	33.45	3.41
	25	23	41.88	3.26	40.64	3.35	39.22	3.48	38.48	3.55	37.89	3.60	36.46	3.70
	30	28	45.35	3.51	43.95	3.63	42.44	3.74	41.66	3.82	41.04	3.89	39.53	3.98
	35	32	48.82	3.76	47.27	3.90	45.66	4.00	44.84	4.09	44.18	4.17	42.58	4.27
	40	36	51.31	3.87	49.87	4.01	48.28	4.12	47.44	4.21	46.77	4.28	45.08	4.39
	45	41	54.42	4.01	53.12	4.15	51.55	4.27	50.70	4.35	50.01	4.41	48.20	4.54
	47	43	55.66	4.07	54.42	4.20	52.86	4.34	52.00	4.41	51.31	4.47	49.44	4.60
	50	46	55.83	4.04	54.70	4.16	53.35	4.28	52.57	4.35	51.95	4.40	50.20	4.52
	55	51	56.10	4.00	55.17	4.10	54.15	4.19	53.53	4.24	53.03	4.28	51.46	4.37
	60	56	56.37	3.96	55.64	4.03	54.95	4.11	54.48	4.14	54.11	4.16	52.72	4.23
	63	59	56.53	3.93	55.92	3.99	55.44	4.05	55.06	4.07	54.75	4.09	53.48	4.14
	68	64	56.70	3.90	56.20	3.95	55.92	4.00	55.63	4.01	55.41	4.02	54.25	4.05
Mixed Indoor Units 43 (90%)	-4	-4.4	18.80	1.96	17.43	2.05	17.32	2.06	17.11	2.07	16.95	2.08	16.19	2.16
	0	-0.4	22.18	2.09	20.88	2.17	20.55	2.20	20.26	2.22	20.02	2.23	19.18	2.31
	5	4.5	26.21	2.24	24.99	2.32	24.39	2.37	24.00	2.39	23.68	2.41	22.73	2.50
	10	9	28.91	2.38	27.74	2.46	26.97	2.53	26.50	2.56	26.13	2.59	25.10	2.67
	17	15	31.87	2.57	30.77	2.65	29.80	2.73	29.26	2.78	28.83	2.81	27.72	2.90
	20	19	33.67	2.69	32.60	2.78	31.51	2.87	30.93	2.92	30.46	2.97	29.30	3.05
	25	23	36.68	2.91	35.60	2.99	34.36	3.11	33.71	3.17	33.19	3.22	31.94	3.30
	30	28	39.73	3.14	38.50	3.24	37.17	3.34	36.49	3.41	35.95	3.47	34.63	3.56
	35	32	42.77	3.36	41.40	3.48	39.99	3.57	39.28	3.66	38.70	3.72	37.30	3.81
	40	36	44.94	3.46	43.68	3.58	42.29	3.68	41.56	3.76	40.97	3.82	39.49	3.92
	45	41	47.67	3.58	46.53	3.70	45.16	3.82	44.41	3.89	43.81	3.94	42.22	4.06
	47	43	48.76	3.63	47.67	3.75	46.31	3.87	45.55	3.94	44.94	3.99	43.31	4.11
	50	46	48.90	3.61	47.91	3.72	46.73	3.83	46.05	3.88	45.51	3.93	43.97	4.04
	55	51	49.14	3.57	48.33	3.66	47.43	3.75	46.89	3.79	46.45	3.82	45.08	3.91
	60	56	49.38	3.53	48.74	3.60	48.14	3.67	47.72	3.70	47.40	3.72	46.18	3.78
	63	59	49.52	3.51	48.98	3.57	48.56	3.62	48.23	3.64	47.96	3.65	46.85	3.70
	68	64	49.67	3.49	49.23	3.53	48.99	3.57	48.73	3.58	48.53	3.59	47.52	3.62
Mixed Indoor Units 38 (80%)	-4	-4.4	16.61	1.73	15.40	1.81	15.30	1.82	15.12	1.83	14.97	1.83	14.31	1.91
	0	-0.4	19.60	1.84	18.45	1.92	18.16	1.94	17.90	1.96	17.69	1.97	16.95	2.04
	5	4.5	23.16	1.98	22.08	2.05	21.55	2.09	21.21	2.11	20.93	2.13	20.08	2.21
	10	9	25.54	2.10	24.51	2.18	23.83	2.23	23.42	2.26	23.09	2.28	22.18	2.36
	17	15	28.17	2.27	27.19	2.34	26.33	2.41	25.85	2.45	25.47	2.49	24.49	2.56
	20	19	29.75	2.38	28.81	2.45	27.85	2.54	27.33	2.58	26.91	2.62	25.89	2.69
	25	23	32.42	2.57	31.46	2.64	30.36	2.74	29.79	2.80	29.33	2.84	28.22	2.92
	30	28	35.10	2.77	34.02	2.86	32.85	2.95	32.25	3.01	31.76	3.07	30.60	3.14
	35	32	37.79	2.97	36.59	3.08	35.34	3.16	34.71	3.23	34.20	3.29	32.96	3.37
	40	36	39.72	3.06	38.60	3.16	37.37	3.25	36.72	3.32	36.20	3.38	34.89	3.46
	45	41	42.12	3.17	41.12	3.27	39.90	3.37	39.24	3.43	38.71	3.48	37.31	3.59
	47	43	43.08	3.21	42.12	3.31	40.92	3.42	40.25	3.48	39.72	3.53	38.27	3.63
	50	46	43.21	3.19	42.34	3.28	41.29	3.38	40.69	3.43	40.21	3.47	38.86	3.56
	55	51	43.42	3.15	42.70	3.23	41.91	3.31	41.43	3.35	41.05	3.38	39.83	3.45
	60	56	43.63	3.12	43.07	3.18	42.54	3.24	42.17	3.26	41.88	3.28	40.81	3.33
	63	59	43.76	3.10	43.28	3.15	42.91	3.20	42.62	3.21	42.38	3.23	41.40	3.27
	68	64	43.89	3.08	43.50	3.12	43.29	3.16	43.06	3.17	42.89	3.17	41.99	3.20

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 404: LMU480HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 34 (70%)	-4	-4.4	14.86	1.55	13.78	1.61	13.69	1.62	13.53	1.63	13.40	1.63	12.80	1.70
	0	-0.4	17.54	1.64	16.51	1.71	16.25	1.73	16.01	1.74	15.83	1.75	15.16	1.82
	5	4.5	20.72	1.76	19.76	1.83	19.28	1.86	18.97	1.88	18.72	1.90	17.97	1.96
	10	9	22.85	1.87	21.93	1.94	21.32	1.99	20.95	2.01	20.66	2.03	19.85	2.10
	17	15	25.20	2.02	24.32	2.09	23.56	2.15	23.13	2.19	22.79	2.21	21.91	2.28
	20	19	26.62	2.12	25.77	2.18	24.91	2.26	24.45	2.30	24.08	2.33	23.16	2.40
	25	23	29.00	2.29	28.14	2.35	27.16	2.44	26.65	2.49	26.24	2.53	25.25	2.60
	30	28	31.41	2.47	30.43	2.55	29.39	2.63	28.85	2.69	28.42	2.73	27.37	2.80
	35	32	33.81	2.65	32.73	2.74	31.62	2.81	31.05	2.88	30.59	2.93	29.49	3.00
	40	36	35.53	2.72	34.53	2.82	33.43	2.90	32.85	2.96	32.39	3.01	31.22	3.09
	45	41	37.68	2.82	36.78	2.91	35.70	3.00	35.11	3.06	34.63	3.10	33.38	3.19
	47	43	38.55	2.86	37.68	2.95	36.61	3.05	36.01	3.10	35.53	3.14	34.24	3.24
	50	46	38.66	2.84	37.88	2.93	36.94	3.01	36.41	3.06	35.98	3.09	34.76	3.18
	55	51	38.85	2.81	38.20	2.88	37.50	2.95	37.07	2.98	36.72	3.01	35.64	3.07
	60	56	39.04	2.78	38.53	2.83	38.05	2.89	37.73	2.91	37.47	2.93	36.51	2.97
	63	59	39.15	2.76	38.72	2.81	38.39	2.85	38.13	2.86	37.92	2.88	37.03	2.91
	68	64	39.26	2.74	38.92	2.78	38.73	2.81	38.53	2.82	38.37	2.83	37.57	2.85
Mixed Indoor Units 29 (60%)	-4	-4.4	12.68	1.32	11.75	1.37	11.68	1.38	11.54	1.39	11.43	1.39	10.92	1.45
	0	-0.4	14.96	1.40	14.08	1.45	13.86	1.47	13.66	1.48	13.50	1.49	12.93	1.55
	5	4.5	17.68	1.50	16.85	1.56	16.45	1.59	16.18	1.60	15.97	1.62	15.33	1.67
	10	9	19.50	1.60	18.71	1.65	18.19	1.69	17.87	1.71	17.62	1.73	16.93	1.79
	17	15	21.50	1.72	20.75	1.78	20.10	1.83	19.73	1.86	19.44	1.89	18.69	1.94
	20	19	22.71	1.80	21.99	1.86	21.25	1.92	20.86	1.96	20.54	1.99	19.76	2.04
	25	23	24.74	1.95	24.01	2.01	23.17	2.08	22.73	2.12	22.38	2.16	21.54	2.21
	30	28	26.79	2.10	25.96	2.17	25.07	2.24	24.61	2.29	24.24	2.33	23.35	2.38
	35	32	28.84	2.25	27.92	2.33	26.97	2.39	26.49	2.45	26.10	2.49	25.16	2.56
	40	36	30.31	2.32	29.46	2.40	28.52	2.47	28.03	2.52	27.63	2.56	26.63	2.63
	45	41	32.15	2.40	31.38	2.48	30.46	2.56	29.95	2.61	29.55	2.64	28.47	2.72
	47	43	32.88	2.43	32.15	2.51	31.23	2.60	30.72	2.64	30.31	2.68	29.21	2.76
	50	46	32.98	2.42	32.31	2.49	31.52	2.56	31.06	2.60	30.69	2.63	29.66	2.70
	55	51	33.14	2.39	32.59	2.45	31.99	2.51	31.62	2.54	31.33	2.56	30.40	2.62
	60	56	33.30	2.37	32.87	2.41	32.46	2.46	32.19	2.48	31.96	2.49	31.15	2.53
	63	59	33.40	2.35	33.03	2.39	32.75	2.43	32.53	2.44	32.35	2.45	31.59	2.48
	68	64	33.50	2.34	33.20	2.37	33.04	2.39	32.87	2.40	32.73	2.41	32.05	2.43
Mixed Indoor Units 24 (50%)	-4	-4.4	10.49	1.08	9.73	1.13	9.66	1.13	9.55	1.14	9.46	1.14	9.04	1.19
	0	-0.4	12.38	1.15	11.65	1.20	11.47	1.21	11.31	1.22	11.17	1.23	10.70	1.27
	5	4.5	14.63	1.23	13.95	1.28	13.61	1.30	13.39	1.32	13.22	1.33	12.68	1.38
	10	9	16.13	1.31	15.48	1.36	15.05	1.39	14.79	1.41	14.58	1.42	14.01	1.47
	17	15	17.79	1.41	17.17	1.46	16.63	1.51	16.33	1.53	16.09	1.55	15.47	1.60
	20	19	18.79	1.48	18.19	1.53	17.59	1.58	17.26	1.61	17.00	1.63	16.35	1.68
	25	23	20.47	1.60	19.87	1.65	19.17	1.71	18.81	1.75	18.52	1.77	17.82	1.82
	30	28	22.17	1.73	21.48	1.78	20.75	1.84	20.37	1.88	20.06	1.91	19.32	1.96
	35	32	23.87	1.85	23.11	1.92	22.32	1.97	21.92	2.01	21.60	2.05	20.82	2.10
	40	36	25.08	1.91	24.38	1.97	23.60	2.03	23.19	2.07	22.86	2.10	22.04	2.16
	45	41	26.60	1.97	25.97	2.04	25.20	2.10	24.78	2.14	24.45	2.17	23.56	2.24
	47	43	27.21	2.00	26.60	2.07	25.84	2.13	25.42	2.17	25.08	2.20	24.17	2.27
	50	46	27.29	1.99	26.74	2.05	26.08	2.11	25.70	2.14	25.40	2.16	24.54	2.22
	55	51	27.42	1.97	26.97	2.02	26.47	2.06	26.17	2.09	25.92	2.11	25.16	2.15
	60	56	27.56	1.95	27.20	1.98	26.86	2.02	26.63	2.04	26.45	2.05	25.77	2.08
	63	59	27.64	1.93	27.34	1.96	27.10	1.99	26.91	2.00	26.77	2.01	26.14	2.04
	68	64	27.72	1.92	27.47	1.95	27.34	1.97	27.20	1.97	27.08	1.98	26.52	1.99

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU540HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 405: LMU540HV Heating Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 73 (135%)	-4	-4.4	23.70	3.58	21.92	3.72	21.81	3.76	21.56	3.78	21.36	3.79	20.40	3.94
	0	-0.4	28.51	3.71	26.81	3.85	26.40	3.91	26.03	3.94	25.73	3.97	24.64	4.11
	5	4.5	34.23	3.88	32.62	4.02	31.85	4.10	31.33	4.14	30.92	4.18	29.67	4.32
	10	9	38.06	4.03	36.52	4.17	35.50	4.27	34.89	4.33	34.40	4.38	33.05	4.51
	17	15	42.27	4.23	40.80	4.37	39.51	4.50	38.80	4.58	38.22	4.64	36.75	4.77
	20	19	44.82	4.37	43.39	4.50	41.94	4.66	41.17	4.74	40.54	4.81	39.00	4.94
	25	23	49.10	4.61	47.64	4.74	45.98	4.92	45.11	5.02	44.42	5.10	42.75	5.23
	30	28	53.41	4.86	51.76	5.02	49.98	5.18	49.06	5.29	48.33	5.38	46.55	5.52
	35	32	57.72	5.12	55.88	5.30	53.98	5.44	53.01	5.57	52.23	5.67	50.35	5.81
	40	36	60.66	5.27	58.96	5.45	57.08	5.61	56.09	5.73	55.30	5.82	53.30	5.97
	45	41	64.34	5.46	62.80	5.64	60.95	5.82	59.94	5.92	59.13	6.01	56.98	6.18
	47	43	65.81	5.53	64.34	5.72	62.50	5.90	61.48	6.00	60.66	6.08	58.46	6.26
	50	46	66.00	5.50	64.67	5.66	63.07	5.83	62.16	5.91	61.43	5.98	59.35	6.15
	55	51	66.33	5.44	65.23	5.57	64.02	5.71	63.29	5.77	62.70	5.82	60.84	5.95
	60	56	66.65	5.38	65.78	5.49	64.97	5.59	64.42	5.63	63.97	5.66	62.33	5.75
	63	59	66.84	5.35	66.11	5.43	65.54	5.51	65.09	5.54	64.73	5.56	63.23	5.63
	68	64	67.04	5.31	66.45	5.38	66.12	5.44	65.78	5.46	65.51	5.47	64.14	5.51
Non-Ducted Indoor Units 70 (130%)	-4	-4.4	23.48	3.52	21.72	3.66	21.62	3.70	21.37	3.72	21.17	3.74	20.22	3.88
	0	-0.4	28.25	3.66	26.57	3.80	26.16	3.85	25.79	3.88	25.50	3.91	24.42	4.05
	5	4.5	33.92	3.82	32.33	3.96	31.56	4.04	31.05	4.08	30.65	4.12	29.41	4.26
	10	9	37.71	3.97	36.19	4.11	35.18	4.21	34.57	4.27	34.09	4.31	32.75	4.45
	17	15	41.89	4.17	40.43	4.30	39.16	4.44	38.45	4.51	37.88	4.57	36.43	4.70
	20	19	44.42	4.30	43.00	4.43	41.57	4.59	40.80	4.67	40.18	4.74	38.65	4.87
	25	23	48.66	4.54	47.21	4.67	45.57	4.84	44.71	4.94	44.02	5.02	42.36	5.15
	30	28	52.93	4.79	51.29	4.95	49.53	5.10	48.62	5.21	47.90	5.30	46.14	5.44
	35	32	57.21	5.04	55.38	5.22	53.50	5.36	52.54	5.48	51.77	5.58	49.90	5.72
	40	36	60.12	5.19	58.43	5.37	56.57	5.52	55.59	5.64	54.80	5.73	52.82	5.88
	45	41	63.76	5.38	62.24	5.56	60.41	5.73	59.40	5.83	58.60	5.92	56.47	6.09
	47	43	65.22	5.45	63.76	5.63	61.94	5.81	60.93	5.91	60.12	5.99	57.93	6.17
	50	46	65.41	5.42	64.09	5.58	62.51	5.74	61.60	5.83	60.88	5.89	58.82	6.05
	55	51	65.73	5.36	64.64	5.49	63.45	5.62	62.72	5.68	62.14	5.74	60.30	5.86
	60	56	66.05	5.30	65.19	5.40	64.39	5.50	63.84	5.54	63.40	5.58	61.78	5.66
	63	59	66.24	5.27	65.52	5.35	64.96	5.43	64.51	5.46	64.15	5.48	62.66	5.55
	68	64	66.44	5.23	65.85	5.30	65.52	5.36	65.19	5.38	64.92	5.39	63.56	5.43
Non-Ducted Indoor Units 65 (120%)	-4	-4.4	23.13	3.43	21.40	3.57	21.29	3.60	21.05	3.62	20.85	3.64	19.91	3.77
	0	-0.4	27.83	3.56	26.17	3.69	25.77	3.75	25.40	3.78	25.11	3.80	24.05	3.94
	5	4.5	33.41	3.72	31.84	3.85	31.09	3.93	30.58	3.97	30.18	4.01	28.96	4.14
	10	9	37.15	3.86	35.64	3.99	34.65	4.09	34.05	4.15	33.58	4.19	32.26	4.33
	17	15	41.26	4.06	39.82	4.19	38.57	4.32	37.87	4.39	37.31	4.44	35.88	4.57
	20	19	43.75	4.19	42.35	4.31	40.94	4.46	40.18	4.55	39.57	4.61	38.07	4.74
	25	23	47.92	4.41	46.50	4.54	44.88	4.71	44.03	4.81	43.36	4.89	41.72	5.01
	30	28	52.13	4.66	50.52	4.81	48.78	4.96	47.89	5.07	47.17	5.16	45.44	5.29
	35	32	56.34	4.91	54.55	5.08	52.69	5.21	51.74	5.34	50.99	5.43	49.14	5.56
	40	36	59.21	5.05	57.55	5.23	55.71	5.37	54.75	5.49	53.98	5.58	52.02	5.72
	45	41	62.80	5.23	61.30	5.41	59.49	5.57	58.51	5.67	57.72	5.76	55.62	5.92
	47	43	64.24	5.30	62.80	5.48	61.01	5.65	60.01	5.75	59.21	5.83	57.06	6.00
	50	46	64.43	5.27	63.13	5.43	61.56	5.58	60.67	5.67	59.96	5.74	57.93	5.89
	55	51	64.74	5.21	63.67	5.34	62.49	5.47	61.77	5.53	61.20	5.58	59.39	5.70
	60	56	65.05	5.16	64.21	5.26	63.42	5.35	62.88	5.39	62.44	5.43	60.84	5.51
	63	59	65.24	5.12	64.53	5.21	63.97	5.28	63.54	5.31	63.19	5.33	61.72	5.40
	68	64	65.43	5.09	64.86	5.16	64.54	5.22	64.20	5.23	63.94	5.24	62.60	5.28

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 406: LMU540HV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 59 (110%)	-4	-4.4	22.71	3.31	21.01	3.45	20.90	3.48	20.66	3.50	20.47	3.52	19.55	3.65
	0	-0.4	27.32	3.44	25.69	3.57	25.30	3.62	24.94	3.65	24.66	3.68	23.61	3.81
	5	4.5	32.80	3.59	31.27	3.72	30.52	3.80	30.03	3.84	29.63	3.87	28.44	4.00
	10	9	36.47	3.73	35.00	3.86	34.02	3.96	33.43	4.01	32.97	4.06	31.67	4.18
	17	15	40.51	3.92	39.10	4.05	37.87	4.17	37.18	4.24	36.63	4.30	35.22	4.42
	20	19	42.95	4.05	41.59	4.17	40.20	4.32	39.45	4.40	38.85	4.46	37.38	4.58
	25	23	47.05	4.27	45.66	4.39	44.07	4.56	43.24	4.65	42.57	4.72	40.97	4.85
	30	28	51.19	4.51	49.60	4.66	47.90	4.80	47.02	4.90	46.32	4.99	44.61	5.11
	35	32	55.32	4.75	53.56	4.92	51.73	5.04	50.80	5.16	50.06	5.25	48.25	5.38
	40	36	58.14	4.88	56.50	5.05	54.70	5.20	53.75	5.31	53.00	5.39	51.08	5.54
	45	41	61.66	5.06	60.19	5.23	58.41	5.39	57.44	5.49	56.67	5.57	54.61	5.73
	47	43	63.07	5.13	61.66	5.30	59.90	5.47	58.92	5.56	58.14	5.64	56.02	5.80
	50	46	63.26	5.09	61.98	5.25	60.45	5.40	59.57	5.48	58.87	5.55	56.88	5.69
	55	51	63.56	5.04	62.51	5.17	61.36	5.29	60.65	5.35	60.09	5.40	58.31	5.51
	60	56	63.87	4.99	63.04	5.08	62.27	5.18	61.73	5.22	61.31	5.25	59.74	5.33
	63	59	64.06	4.95	63.36	5.03	62.81	5.11	62.38	5.14	62.04	5.16	60.60	5.22
	68	64	64.24	4.92	63.68	4.99	63.36	5.04	63.04	5.06	62.78	5.07	61.47	5.11
Non-Ducted Indoor Units 54 (100%)	-4	-4.4	22.35	3.22	20.68	3.35	20.58	3.38	20.34	3.40	20.15	3.41	19.25	3.54
	0	-0.4	26.89	3.34	25.29	3.47	24.90	3.52	24.55	3.55	24.27	3.57	23.24	3.70
	5	4.5	32.29	3.49	30.78	3.62	30.04	3.69	29.56	3.73	29.17	3.76	27.99	3.89
	10	9	35.90	3.63	34.45	3.75	33.49	3.84	32.91	3.90	32.45	3.94	31.17	4.06
	17	15	39.87	3.81	38.49	3.93	37.27	4.05	36.60	4.12	36.06	4.17	34.67	4.30
	20	19	42.28	3.93	40.94	4.05	39.57	4.19	38.83	4.27	38.25	4.33	36.79	4.45
	25	23	46.32	4.15	44.94	4.27	43.38	4.43	42.56	4.52	41.90	4.59	40.33	4.71
	30	28	50.39	4.38	48.83	4.52	47.15	4.66	46.28	4.76	45.59	4.85	43.92	4.97
	35	32	54.45	4.61	52.72	4.77	50.93	4.90	50.01	5.01	49.28	5.10	47.50	5.23
	40	36	57.23	4.74	55.62	4.91	53.85	5.05	52.92	5.15	52.17	5.24	50.28	5.38
	45	41	60.70	4.91	59.25	5.08	57.50	5.23	56.55	5.33	55.78	5.41	53.76	5.56
	47	43	62.09	4.98	60.70	5.14	58.96	5.31	58.00	5.40	57.23	5.47	55.15	5.64
	50	46	62.27	4.95	61.01	5.10	59.50	5.24	58.64	5.32	57.95	5.39	55.99	5.53
	55	51	62.57	4.90	61.53	5.02	60.40	5.14	59.70	5.19	59.15	5.24	57.40	5.35
	60	56	62.88	4.84	62.06	4.94	61.29	5.03	60.77	5.07	60.35	5.10	58.81	5.17
	63	59	63.06	4.81	62.37	4.89	61.83	4.96	61.41	4.99	61.07	5.01	59.65	5.07
	68	64	63.24	4.78	62.69	4.84	62.37	4.90	62.05	4.91	61.80	4.92	60.51	4.96
Non-Ducted Indoor Units 49 (90%)	-4	-4.4	21.15	2.90	19.56	3.01	19.47	3.04	19.24	3.06	19.06	3.07	18.21	3.19
	0	-0.4	25.44	3.01	23.93	3.12	23.56	3.17	23.23	3.19	22.96	3.21	21.99	3.33
	5	4.5	30.55	3.14	29.12	3.25	28.42	3.32	27.96	3.36	27.60	3.39	26.48	3.50
	10	9	33.96	3.26	32.59	3.38	31.68	3.46	31.14	3.51	30.70	3.55	29.49	3.66
	17	15	37.72	3.43	36.41	3.54	35.26	3.65	34.62	3.71	34.11	3.76	32.80	3.87
	20	19	40.00	3.54	38.73	3.65	37.43	3.77	36.74	3.84	36.18	3.90	34.81	4.01
	25	23	43.82	3.73	42.52	3.84	41.04	3.98	40.26	4.06	39.64	4.13	38.15	4.24
	30	28	47.67	3.94	46.19	4.07	44.61	4.19	43.79	4.29	43.13	4.36	41.55	4.47
	35	32	51.52	4.15	49.88	4.30	48.18	4.41	47.31	4.51	46.62	4.59	44.93	4.70
	40	36	54.14	4.27	52.62	4.42	50.94	4.54	50.06	4.64	49.35	4.71	47.57	4.84
	45	41	57.42	4.42	56.05	4.57	54.40	4.71	53.50	4.80	52.77	4.87	50.86	5.01
	47	43	58.73	4.48	57.42	4.63	55.78	4.78	54.87	4.86	54.14	4.93	52.17	5.07
	50	46	58.91	4.45	57.72	4.59	56.29	4.72	55.47	4.79	54.82	4.85	52.97	4.98
	55	51	59.19	4.41	58.21	4.51	57.14	4.62	56.48	4.67	55.96	4.72	54.30	4.82
	60	56	59.48	4.36	58.71	4.44	57.99	4.52	57.49	4.56	57.09	4.59	55.63	4.66
	63	59	59.65	4.33	59.00	4.40	58.49	4.47	58.09	4.49	57.77	4.51	56.43	4.56
	68	64	59.83	4.30	59.30	4.36	59.01	4.41	58.71	4.42	58.46	4.43	57.24	4.47

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU540HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 407: LMU540HV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[°])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 43 (80%)	-4	-4.4	18.73	2.51	17.32	2.61	17.24	2.64	17.04	2.65	16.88	2.66	16.12	2.76
	0	-0.4	22.53	2.60	21.19	2.70	20.86	2.74	20.57	2.77	20.34	2.78	19.47	2.88
	5	4.5	27.05	2.72	25.78	2.82	25.17	2.88	24.76	2.91	24.44	2.93	23.45	3.03
	10	9	30.08	2.83	28.86	2.92	28.05	3.00	27.57	3.04	27.19	3.07	26.12	3.17
	17	15	33.41	2.97	32.24	3.06	31.23	3.16	30.66	3.21	30.21	3.25	29.05	3.35
	20	19	35.42	3.06	34.29	3.16	33.15	3.27	32.53	3.33	32.04	3.38	30.82	3.47
	25	23	38.80	3.23	37.65	3.33	36.34	3.45	35.65	3.52	35.10	3.58	33.78	3.67
	30	28	42.21	3.41	40.91	3.53	39.50	3.63	38.78	3.71	38.20	3.78	36.79	3.87
	35	32	45.62	3.59	44.17	3.72	42.66	3.82	41.90	3.91	41.28	3.98	39.79	4.07
	40	36	47.94	3.70	46.60	3.83	45.11	3.93	44.33	4.02	43.71	4.08	42.12	4.19
	45	41	50.85	3.83	49.63	3.96	48.17	4.08	47.37	4.15	46.73	4.21	45.04	4.34
	47	43	52.01	3.88	50.85	4.01	49.40	4.14	48.59	4.21	47.94	4.27	46.20	4.40
	50	46	52.17	3.86	51.11	3.97	49.85	4.09	49.13	4.15	48.55	4.20	46.91	4.31
	55	51	52.42	3.82	51.55	3.91	50.60	4.00	50.02	4.05	49.55	4.09	48.09	4.17
	60	56	52.67	3.78	51.99	3.85	51.35	3.92	50.91	3.95	50.56	3.97	49.27	4.03
	63	59	52.83	3.75	52.25	3.81	51.80	3.87	51.45	3.89	51.16	3.90	49.97	3.95
	68	64	52.98	3.73	52.52	3.77	52.25	3.82	51.99	3.83	51.77	3.84	50.69	3.87
Non-Ducted Indoor Units 38 (70%)	-4	-4.4	16.55	2.19	15.31	2.28	15.23	2.30	15.06	2.31	14.92	2.32	14.25	2.41
	0	-0.4	19.91	2.27	18.73	2.36	18.44	2.39	18.18	2.41	17.97	2.43	17.21	2.51
	5	4.5	23.90	2.37	22.79	2.46	22.24	2.51	21.88	2.54	21.60	2.56	20.73	2.64
	10	9	26.58	2.46	25.50	2.55	24.79	2.61	24.37	2.65	24.03	2.68	23.08	2.76
	17	15	29.52	2.59	28.49	2.67	27.60	2.75	27.10	2.80	26.70	2.84	25.67	2.92
	20	19	31.30	2.67	30.31	2.75	29.29	2.85	28.75	2.90	28.32	2.94	27.24	3.02
	25	23	34.29	2.82	33.27	2.90	32.12	3.01	31.51	3.07	31.02	3.12	29.86	3.20
	30	28	37.30	2.98	36.15	3.07	34.91	3.17	34.27	3.24	33.75	3.29	32.51	3.38
	35	32	40.32	3.13	39.03	3.24	37.70	3.33	37.02	3.41	36.48	3.47	35.16	3.55
	40	36	42.37	3.22	41.18	3.34	39.87	3.43	39.18	3.50	38.62	3.56	37.22	3.65
	45	41	44.94	3.34	43.86	3.45	42.57	3.56	41.86	3.62	41.30	3.67	39.80	3.78
	47	43	45.96	3.38	44.94	3.50	43.65	3.61	42.94	3.67	42.37	3.72	40.83	3.83
	50	46	46.10	3.36	45.17	3.46	44.05	3.56	43.41	3.62	42.90	3.66	41.45	3.76
	55	51	46.32	3.33	45.56	3.41	44.71	3.49	44.20	3.53	43.79	3.56	42.50	3.64
	60	56	46.55	3.29	45.94	3.36	45.38	3.42	44.99	3.44	44.68	3.46	43.54	3.52
	63	59	46.68	3.27	46.18	3.32	45.78	3.37	45.46	3.39	45.21	3.40	44.16	3.44
	68	64	46.82	3.25	46.41	3.29	46.18	3.33	45.94	3.34	45.75	3.35	44.80	3.37
Non-Ducted Indoor Units 32 (60%)	-4	-4.4	13.94	1.80	12.89	1.87	12.83	1.89	12.68	1.90	12.56	1.91	12.00	1.98
	0	-0.4	16.77	1.87	15.77	1.94	15.53	1.97	15.31	1.98	15.13	2.00	14.49	2.07
	5	4.5	20.13	1.95	19.19	2.02	18.73	2.06	18.43	2.09	18.19	2.10	17.45	2.18
	10	9	22.38	2.03	21.48	2.10	20.88	2.15	20.52	2.18	20.23	2.20	19.44	2.27
	17	15	24.86	2.13	24.00	2.20	23.24	2.27	22.82	2.30	22.48	2.33	21.62	2.40
	20	19	26.36	2.20	25.52	2.27	24.67	2.34	24.21	2.39	23.85	2.42	22.94	2.49
	25	23	28.88	2.32	28.02	2.39	27.05	2.48	26.53	2.53	26.12	2.57	25.14	2.63
	30	28	31.41	2.45	30.44	2.53	29.40	2.61	28.86	2.66	28.42	2.71	27.38	2.78
	35	32	33.95	2.58	32.87	2.67	31.75	2.74	31.18	2.80	30.72	2.85	29.61	2.92
	40	36	35.68	2.65	34.68	2.74	33.57	2.82	32.99	2.88	32.52	2.93	31.35	3.01
	45	41	37.84	2.75	36.94	2.84	35.85	2.93	35.25	2.98	34.78	3.02	33.51	3.11
	47	43	38.71	2.78	37.84	2.88	36.76	2.97	36.16	3.02	35.68	3.06	34.38	3.15
	50	46	38.82	2.77	38.04	2.85	37.10	2.93	36.56	2.98	36.13	3.01	34.91	3.09
	55	51	39.01	2.74	38.36	2.81	37.65	2.87	37.22	2.90	36.88	2.93	35.79	2.99
	60	56	39.20	2.71	38.69	2.76	38.21	2.81	37.89	2.83	37.62	2.85	36.66	2.89
	63	59	39.31	2.69	38.88	2.73	38.55	2.78	38.28	2.79	38.07	2.80	37.19	2.83
	68	64	39.43	2.67	39.08	2.71	38.89	2.74	38.69	2.75	38.53	2.75	37.72	2.78

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 408: LMU540HV Heating Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 27 (50%)	-4	-4.4	11.76	1.48	10.88	1.54	10.82	1.55	10.70	1.56	10.60	1.57	10.12	1.63
	0	-0.4	14.15	1.53	13.31	1.59	13.10	1.62	12.92	1.63	12.77	1.64	12.23	1.70
	5	4.5	16.98	1.60	16.19	1.66	15.80	1.69	15.55	1.71	15.35	1.73	14.73	1.79
	10	9	18.89	1.67	18.12	1.72	17.62	1.77	17.31	1.79	17.07	1.81	16.40	1.87
	17	15	20.98	1.75	20.25	1.81	19.61	1.86	19.25	1.89	18.97	1.92	18.24	1.97
	20	19	22.24	1.81	21.53	1.86	20.81	1.92	20.43	1.96	20.12	1.99	19.36	2.04
	25	23	24.36	1.90	23.64	1.96	22.82	2.03	22.39	2.07	22.04	2.11	21.21	2.16
	30	28	26.51	2.01	25.68	2.08	24.80	2.14	24.35	2.19	23.98	2.23	23.10	2.28
	35	32	28.64	2.12	27.73	2.19	26.79	2.25	26.31	2.30	25.92	2.34	24.98	2.40
	40	36	30.10	2.18	29.26	2.25	28.33	2.32	27.84	2.37	27.44	2.41	26.45	2.47
	45	41	31.93	2.26	31.17	2.33	30.25	2.40	29.75	2.45	29.34	2.48	28.28	2.55
	47	43	32.66	2.29	31.93	2.36	31.02	2.44	30.51	2.48	30.10	2.51	29.01	2.59
	50	46	32.75	2.27	32.09	2.34	31.30	2.41	30.85	2.44	30.48	2.47	29.45	2.54
	55	51	32.91	2.25	32.37	2.30	31.77	2.36	31.41	2.39	31.11	2.41	30.19	2.46
	60	56	33.07	2.22	32.64	2.27	32.24	2.31	31.97	2.33	31.75	2.34	30.93	2.38
	63	59	33.17	2.21	32.81	2.25	32.53	2.28	32.30	2.29	32.12	2.30	31.38	2.33
	68	64	33.27	2.20	32.97	2.22	32.81	2.25	32.64	2.26	32.51	2.26	31.83	2.28
Non-Ducted Indoor Units 24 (40%)	-4	-4.4	10.45	1.29	9.67	1.34	9.62	1.35	9.51	1.36	9.42	1.37	9.00	1.42
	0	-0.4	12.58	1.34	11.83	1.39	11.64	1.41	11.48	1.42	11.35	1.43	10.87	1.48
	5	4.5	15.10	1.40	14.39	1.45	14.05	1.48	13.82	1.49	13.64	1.51	13.09	1.56
	10	9	16.79	1.45	16.11	1.50	15.66	1.54	15.39	1.56	15.17	1.58	14.58	1.63
	17	15	18.64	1.52	18.00	1.57	17.43	1.62	17.11	1.65	16.86	1.67	16.21	1.72
	20	19	19.77	1.57	19.14	1.62	18.50	1.68	18.16	1.71	17.88	1.73	17.20	1.78
	25	23	21.66	1.66	21.02	1.71	20.28	1.77	19.90	1.81	19.59	1.84	18.86	1.88
	30	28	23.56	1.75	22.83	1.81	22.05	1.86	21.64	1.91	21.32	1.94	20.53	1.99
	35	32	25.46	1.84	24.65	1.91	23.81	1.96	23.38	2.00	23.04	2.04	22.21	2.09
	40	36	26.76	1.90	26.01	1.96	25.18	2.02	24.74	2.06	24.39	2.09	23.51	2.15
	45	41	28.38	1.96	27.70	2.03	26.89	2.09	26.44	2.13	26.08	2.16	25.14	2.23
	47	43	29.03	1.99	28.38	2.06	27.57	2.12	27.12	2.16	26.76	2.19	25.79	2.26
	50	46	29.12	1.98	28.53	2.04	27.82	2.10	27.42	2.13	27.10	2.15	26.18	2.21
	55	51	29.26	1.96	28.77	2.01	28.24	2.05	27.92	2.08	27.66	2.10	26.84	2.14
	60	56	29.40	1.94	29.02	1.97	28.66	2.01	28.41	2.03	28.22	2.04	27.50	2.07
	63	59	29.48	1.92	29.16	1.96	28.91	1.99	28.71	2.00	28.56	2.00	27.89	2.03
	68	64	29.57	1.91	29.31	1.94	29.17	1.96	29.02	1.96	28.90	1.97	28.29	1.99
Ducted Indoor Units 73 (135%)	-4	-4.4	28.56	3.71	26.58	3.86	26.34	3.90	26.02	3.92	25.76	3.94	24.62	4.09
	0	-0.4	32.68	3.83	30.81	3.98	30.29	4.04	29.85	4.07	29.50	4.10	28.26	4.24
	5	4.5	37.58	3.98	35.84	4.13	34.97	4.21	34.40	4.26	33.95	4.29	32.58	4.44
	10	9	40.85	4.12	39.21	4.26	38.11	4.37	37.45	4.43	36.93	4.48	35.48	4.62
	17	15	44.46	4.30	42.91	4.44	41.56	4.58	40.81	4.66	40.21	4.72	38.66	4.85
	20	19	46.65	4.43	45.16	4.56	43.65	4.72	42.84	4.81	42.20	4.88	40.59	5.01
	25	23	50.31	4.65	48.82	4.78	47.12	4.96	46.23	5.06	45.52	5.14	43.81	5.28
	30	28	54.02	4.88	52.35	5.04	50.55	5.20	49.62	5.31	48.88	5.41	47.08	5.54
	35	32	57.72	5.12	55.88	5.30	53.98	5.44	53.01	5.57	52.23	5.67	50.35	5.81
	40	36	60.66	5.27	58.96	5.45	57.08	5.61	56.09	5.73	55.30	5.82	53.30	5.97
	45	41	64.34	5.46	62.80	5.64	60.95	5.82	59.94	5.92	59.13	6.01	56.98	6.18
	47	43	65.81	5.53	64.34	5.72	62.50	5.90	61.48	6.00	60.66	6.08	58.46	6.26
	50	46	66.00	5.50	64.67	5.66	63.07	5.83	62.16	5.91	61.43	5.98	59.35	6.15
	55	51	66.33	5.44	65.23	5.57	64.02	5.71	63.29	5.77	62.70	5.82	60.84	5.95
	60	56	66.65	5.38	65.78	5.49	64.97	5.59	64.42	5.63	63.97	5.66	62.33	5.75
	63	59	66.84	5.35	66.11	5.43	65.54	5.51	65.09	5.54	64.73	5.56	63.23	5.63
	68	64	67.04	5.31	66.45	5.38	66.12	5.44	65.78	5.46	65.51	5.47	64.14	5.51

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU540HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 409: LMU540HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 70 (130%)	-4	-4.4	28.30	3.67	26.34	3.82	26.11	3.86	25.78	3.88	25.53	3.90	24.40	4.05
	0	-0.4	32.39	3.79	30.53	3.94	30.02	4.00	29.58	4.03	29.24	4.06	28.01	4.20
	5	4.5	37.24	3.94	35.52	4.08	34.66	4.17	34.10	4.21	33.65	4.25	32.29	4.39
	10	9	40.49	4.08	38.86	4.22	37.77	4.32	37.12	4.38	36.60	4.43	35.16	4.57
	17	15	44.06	4.26	42.53	4.40	41.19	4.53	40.44	4.61	39.85	4.67	38.32	4.81
	20	19	46.23	4.38	44.76	4.52	43.26	4.67	42.46	4.76	41.82	4.83	40.23	4.96
	25	23	49.86	4.60	48.39	4.73	46.70	4.91	45.82	5.01	45.11	5.09	43.41	5.22
	30	28	53.54	4.83	51.88	4.99	50.10	5.15	49.18	5.26	48.44	5.35	46.66	5.49
	35	32	57.21	5.07	55.38	5.25	53.50	5.39	52.54	5.51	51.77	5.61	49.90	5.75
	40	36	60.12	5.22	58.43	5.40	56.57	5.55	55.59	5.67	54.80	5.76	52.82	5.91
	45	41	63.76	5.40	62.24	5.58	60.41	5.76	59.40	5.86	58.60	5.95	56.47	6.12
	47	43	65.22	5.48	63.76	5.66	61.94	5.84	60.93	5.94	60.12	6.02	57.93	6.20
	50	46	65.41	5.44	64.09	5.61	62.51	5.77	61.60	5.86	60.88	5.92	58.82	6.08
	55	51	65.73	5.39	64.64	5.52	63.45	5.65	62.72	5.71	62.14	5.76	60.30	5.89
	60	56	66.05	5.33	65.19	5.43	64.39	5.53	63.84	5.57	63.40	5.60	61.78	5.69
	63	59	66.24	5.29	65.52	5.38	64.96	5.46	64.51	5.49	64.15	5.51	62.66	5.57
Ducted Indoor Units 65 (120%)	68	64	66.44	5.26	65.85	5.33	65.52	5.39	65.19	5.40	64.92	5.41	63.56	5.46
	-4	-4.4	27.88	3.60	25.94	3.75	25.71	3.79	25.39	3.81	25.14	3.82	24.03	3.97
	0	-0.4	31.90	3.72	30.07	3.87	29.56	3.92	29.14	3.96	28.79	3.98	27.58	4.12
	5	4.5	36.68	3.87	34.98	4.01	34.14	4.09	33.58	4.14	33.14	4.17	31.80	4.31
	10	9	39.88	4.00	38.27	4.14	37.20	4.24	36.56	4.30	36.05	4.35	34.63	4.49
	17	15	43.40	4.18	41.89	4.32	40.57	4.45	39.83	4.52	39.25	4.58	37.74	4.72
	20	19	45.53	4.30	44.08	4.43	42.61	4.59	41.82	4.67	41.19	4.74	39.62	4.87
	25	23	49.11	4.51	47.65	4.65	46.00	4.82	45.13	4.92	44.43	5.00	42.76	5.13
	30	28	52.73	4.75	51.10	4.90	49.34	5.05	48.44	5.16	47.71	5.25	45.96	5.38
	35	32	56.34	4.98	54.55	5.15	52.69	5.29	51.74	5.41	50.99	5.51	49.14	5.64
	40	36	59.21	5.12	57.55	5.30	55.71	5.45	54.75	5.56	53.98	5.65	52.02	5.80
	45	41	62.80	5.30	61.30	5.48	59.49	5.65	58.51	5.75	57.72	5.84	55.62	6.01
	47	43	64.24	5.38	62.80	5.55	61.01	5.73	60.01	5.83	59.21	5.91	57.06	6.09
	50	46	64.43	5.34	63.13	5.50	61.56	5.66	60.67	5.75	59.96	5.81	57.93	5.97
	55	51	64.74	5.29	63.67	5.42	62.49	5.54	61.77	5.61	61.20	5.66	59.39	5.78
	60	56	65.05	5.23	64.21	5.33	63.42	5.43	62.88	5.47	62.44	5.50	60.84	5.59
Ducted Indoor Units 59 (110%)	63	59	65.24	5.20	64.53	5.28	63.97	5.36	63.54	5.39	63.19	5.41	61.72	5.47
	68	64	65.43	5.16	64.86	5.23	64.54	5.29	64.20	5.30	63.94	5.31	62.60	5.36
	-4	-4.4	27.37	3.52	25.47	3.66	25.25	3.70	24.93	3.72	24.68	3.73	23.60	3.88
	0	-0.4	31.32	3.63	29.53	3.77	29.03	3.83	28.61	3.86	28.27	3.89	27.08	4.03
	5	4.5	36.01	3.78	34.35	3.91	33.52	3.99	32.97	4.04	32.54	4.07	31.23	4.21
	10	9	39.15	3.91	37.58	4.04	36.52	4.14	35.90	4.20	35.39	4.24	34.00	4.38
	17	15	42.61	4.08	41.13	4.21	39.83	4.34	39.11	4.42	38.53	4.47	37.05	4.60
	20	19	44.70	4.20	43.28	4.33	41.84	4.48	41.06	4.56	40.44	4.63	38.90	4.75
	25	23	48.22	4.41	46.79	4.53	45.16	4.70	44.31	4.80	43.62	4.88	41.98	5.00
	30	28	51.77	4.63	50.17	4.78	48.44	4.93	47.56	5.04	46.84	5.13	45.12	5.26
	35	32	55.32	4.86	53.56	5.03	51.73	5.16	50.80	5.28	50.06	5.38	48.25	5.51
	40	36	58.14	5.00	56.50	5.17	54.70	5.32	53.75	5.43	53.00	5.52	51.08	5.66
	45	41	61.66	5.18	60.19	5.35	58.41	5.51	57.44	5.62	56.67	5.70	54.61	5.86
	47	43	63.07	5.25	61.66	5.42	59.90	5.59	58.92	5.69	58.14	5.77	56.02	5.94
	50	46	63.26	5.21	61.98	5.37	60.45	5.53	59.57	5.61	58.87	5.68	56.88	5.83
	55	51	63.56	5.16	62.51	5.29	61.36	5.41	60.65	5.47	60.09	5.52	58.31	5.64
	60	56	63.87	5.10	63.04	5.20	62.27	5.30	61.73	5.34	61.31	5.37	59.74	5.45
	63	59	64.06	5.07	63.36	5.15	62.81	5.23	62.38	5.26	62.04	5.28	60.60	5.34
	68	64	64.24	5.04	63.68	5.10	63.36	5.16	63.04	5.18	62.78	5.19	61.47	5.23

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 410: LMU540HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 54 (100%)	-4	-4.4	26.94	3.45	25.07	3.59	24.85	3.62	24.54	3.64	24.30	3.66	23.23	3.80
	0	-0.4	30.83	3.56	29.07	3.70	28.57	3.75	28.16	3.79	27.83	3.81	26.66	3.95
	5	4.5	35.45	3.70	33.81	3.84	32.99	3.92	32.46	3.96	32.03	3.99	30.74	4.13
	10	9	38.54	3.83	36.99	3.96	35.95	4.06	35.33	4.12	34.84	4.16	33.47	4.29
	17	15	41.94	4.00	40.49	4.13	39.21	4.26	38.50	4.33	37.93	4.39	36.47	4.51
	20	19	44.01	4.12	42.60	4.24	41.18	4.39	40.42	4.47	39.81	4.54	38.29	4.66
	25	23	47.47	4.32	46.06	4.45	44.46	4.61	43.62	4.71	42.94	4.78	41.33	4.91
	30	28	50.96	4.54	49.38	4.69	47.69	4.84	46.81	4.94	46.11	5.03	44.42	5.15
	35	32	54.45	4.76	52.72	4.93	50.93	5.06	50.01	5.18	49.28	5.27	47.50	5.40
	40	36	57.23	4.90	55.62	5.07	53.85	5.21	52.92	5.32	52.17	5.41	50.28	5.56
	45	41	60.70	5.08	59.25	5.25	57.50	5.41	56.55	5.51	55.78	5.59	53.76	5.75
	47	43	62.09	5.15	60.70	5.32	58.96	5.49	58.00	5.58	57.23	5.66	55.15	5.83
	50	46	62.27	5.11	61.01	5.27	59.50	5.42	58.64	5.50	57.95	5.57	55.99	5.72
	55	51	62.57	5.06	61.53	5.18	60.40	5.31	59.70	5.37	59.15	5.42	57.40	5.53
	60	56	62.88	5.00	62.06	5.10	61.29	5.20	60.77	5.23	60.35	5.27	58.81	5.35
	63	59	63.06	4.97	62.37	5.05	61.83	5.13	61.41	5.15	61.07	5.18	59.65	5.24
	68	64	63.24	4.94	62.69	5.00	62.37	5.06	62.05	5.08	61.80	5.09	60.51	5.13
Ducted Indoor Units 49 (90%)	-4	-4.4	25.14	3.11	23.40	3.24	23.19	3.27	22.91	3.29	22.68	3.31	21.68	3.43
	0	-0.4	28.77	3.22	27.13	3.34	26.67	3.39	26.28	3.42	25.97	3.44	24.88	3.57
	5	4.5	33.08	3.34	31.56	3.47	30.79	3.54	30.29	3.58	29.89	3.61	28.69	3.73
	10	9	35.97	3.46	34.52	3.58	33.55	3.67	32.98	3.72	32.52	3.76	31.24	3.88
	17	15	39.15	3.62	37.78	3.73	36.59	3.85	35.93	3.91	35.40	3.96	34.04	4.08
	20	19	41.07	3.72	39.76	3.83	38.43	3.97	37.72	4.04	37.15	4.10	35.74	4.21
	25	23	44.30	3.90	42.99	4.02	41.49	4.17	40.71	4.25	40.08	4.32	38.57	4.43
	30	28	47.56	4.10	46.09	4.24	44.51	4.37	43.69	4.46	43.04	4.54	41.45	4.66
	35	32	50.82	4.30	49.20	4.46	47.53	4.57	46.67	4.68	45.99	4.76	44.33	4.88
	40	36	53.41	4.43	51.91	4.58	50.26	4.71	49.38	4.81	48.69	4.89	46.92	5.02
	45	41	56.65	4.58	55.29	4.74	53.67	4.88	52.77	4.97	52.06	5.05	50.17	5.19
	47	43	57.94	4.65	56.65	4.80	55.03	4.95	54.13	5.04	53.41	5.11	51.47	5.26
	50	46	58.11	4.62	56.94	4.76	55.53	4.89	54.73	4.97	54.08	5.03	52.26	5.16
	55	51	58.40	4.57	57.43	4.68	56.37	4.79	55.72	4.85	55.20	4.89	53.57	5.00
	60	56	58.68	4.52	57.92	4.61	57.20	4.69	56.71	4.73	56.32	4.76	54.88	4.83
	63	59	58.85	4.49	58.21	4.56	57.71	4.63	57.31	4.66	56.99	4.67	55.67	4.73
	68	64	59.02	4.46	58.50	4.52	58.21	4.57	57.91	4.58	57.67	4.59	56.47	4.63
Ducted Indoor Units 43 (80%)	-4	-4.4	22.06	2.71	20.53	2.82	20.35	2.84	20.10	2.86	19.90	2.87	19.02	2.98
	0	-0.4	25.25	2.80	23.80	2.90	23.40	2.95	23.06	2.97	22.79	2.99	21.83	3.10
	5	4.5	29.03	2.91	27.69	3.01	27.02	3.07	26.58	3.11	26.23	3.13	25.17	3.24
	10	9	31.56	3.01	30.29	3.11	29.44	3.19	28.94	3.23	28.53	3.27	27.41	3.37
	17	15	34.35	3.14	33.16	3.24	32.11	3.34	31.53	3.40	31.07	3.44	29.87	3.54
	20	19	36.04	3.23	34.89	3.33	33.73	3.45	33.10	3.51	32.60	3.56	31.36	3.66
	25	23	38.87	3.39	37.72	3.49	36.41	3.62	35.72	3.69	35.17	3.75	33.84	3.85
	30	28	41.74	3.57	40.44	3.68	39.05	3.80	38.34	3.88	37.76	3.95	36.38	4.05
	35	32	44.60	3.74	43.18	3.87	41.71	3.97	40.96	4.06	40.36	4.14	38.90	4.24
	40	36	46.87	3.85	45.55	3.98	44.10	4.09	43.34	4.18	42.72	4.25	41.18	4.36
	45	41	49.71	3.98	48.52	4.12	47.09	4.25	46.31	4.32	45.68	4.38	44.03	4.51
	47	43	50.85	4.04	49.71	4.17	48.29	4.31	47.50	4.38	46.87	4.44	45.16	4.57
	50	46	50.99	4.01	49.97	4.13	48.73	4.25	48.02	4.32	47.46	4.37	45.86	4.49
	55	51	51.24	3.97	50.39	4.07	49.46	4.17	48.90	4.21	48.44	4.25	47.01	4.34
	60	56	51.49	3.93	50.82	4.00	50.20	4.08	49.77	4.11	49.42	4.13	48.16	4.20
	63	59	51.64	3.90	51.08	3.97	50.64	4.03	50.29	4.05	50.01	4.06	48.85	4.11
	68	64	51.79	3.88	51.34	3.93	51.08	3.97	50.82	3.98	50.61	3.99	49.55	4.03

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Performance Data

MULTI F MAX LMU540HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 411: LMU540HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 38 (70%)	-4	-4.4	19.50	2.37	18.15	2.47	17.99	2.49	17.76	2.51	17.59	2.52	16.81	2.62
	0	-0.4	22.31	2.45	21.04	2.55	20.68	2.58	20.38	2.61	20.14	2.62	19.30	2.72
	5	4.5	25.66	2.55	24.47	2.64	23.88	2.69	23.49	2.72	23.18	2.75	22.25	2.84
	10	9	27.90	2.64	26.77	2.73	26.02	2.80	25.58	2.83	25.22	2.86	24.22	2.95
	17	15	30.36	2.76	29.30	2.84	28.38	2.93	27.87	2.98	27.46	3.02	26.40	3.11
	20	19	31.85	2.83	30.84	2.92	29.81	3.02	29.25	3.08	28.81	3.12	27.72	3.21
	25	23	34.35	2.97	33.34	3.06	32.18	3.18	31.57	3.24	31.08	3.29	29.91	3.38
	30	28	36.89	3.13	35.74	3.23	34.52	3.33	33.88	3.40	33.38	3.46	32.15	3.55
	35	32	39.41	3.28	38.16	3.39	36.86	3.48	36.20	3.56	35.67	3.63	34.38	3.72
	40	36	41.42	3.37	40.26	3.49	38.97	3.59	38.30	3.66	37.76	3.72	36.39	3.82
	45	41	43.93	3.49	42.88	3.61	41.62	3.72	40.93	3.79	40.38	3.84	38.91	3.96
	47	43	44.94	3.54	43.93	3.66	42.68	3.77	41.98	3.84	41.42	3.89	39.92	4.01
	50	46	45.07	3.52	44.16	3.62	43.07	3.73	42.44	3.79	41.94	3.83	40.53	3.93
	55	51	45.29	3.48	44.54	3.57	43.72	3.65	43.21	3.69	42.81	3.73	41.55	3.81
	60	56	45.51	3.44	44.92	3.51	44.36	3.58	43.98	3.60	43.68	3.62	42.56	3.68
	63	59	45.64	3.42	45.14	3.48	44.75	3.53	44.45	3.55	44.20	3.56	43.17	3.60
	68	64	45.77	3.40	45.37	3.44	45.15	3.48	44.91	3.49	44.73	3.50	43.79	3.53
Ducted Indoor Units 32 (60%)	-4	-4.4	16.42	1.96	15.28	2.04	15.15	2.07	14.96	2.08	14.81	2.09	14.16	2.17
	0	-0.4	18.79	2.03	17.71	2.11	17.41	2.14	17.16	2.16	16.96	2.17	16.25	2.25
	5	4.5	21.61	2.11	20.61	2.19	20.11	2.23	19.78	2.26	19.52	2.28	18.73	2.35
	10	9	23.49	2.18	22.54	2.26	21.91	2.32	21.54	2.35	21.23	2.37	20.40	2.45
	17	15	25.56	2.28	24.68	2.35	23.90	2.43	23.47	2.47	23.12	2.50	22.23	2.57
	20	19	26.82	2.35	25.97	2.42	25.10	2.50	24.63	2.55	24.26	2.59	23.34	2.66
	25	23	28.93	2.46	28.07	2.53	27.10	2.63	26.58	2.68	26.17	2.73	25.19	2.80
	30	28	31.06	2.59	30.10	2.67	29.07	2.76	28.53	2.82	28.10	2.87	27.07	2.94
	35	32	33.19	2.71	32.13	2.81	31.04	2.88	30.48	2.95	30.03	3.00	28.95	3.08
	40	36	34.88	2.79	33.90	2.89	32.82	2.97	32.25	3.03	31.80	3.08	30.64	3.17
	45	41	36.99	2.89	36.11	2.99	35.05	3.08	34.46	3.14	34.00	3.18	32.76	3.28
	47	43	37.84	2.93	36.99	3.03	35.94	3.13	35.35	3.18	34.88	3.22	33.61	3.32
	50	46	37.95	2.91	37.19	3.00	36.26	3.09	35.74	3.13	35.32	3.17	34.13	3.26
	55	51	38.14	2.88	37.50	2.95	36.81	3.02	36.39	3.06	36.05	3.09	34.98	3.15
	60	56	38.32	2.85	37.82	2.91	37.36	2.96	37.04	2.98	36.78	3.00	35.84	3.05
	63	59	38.43	2.83	38.01	2.88	37.69	2.92	37.43	2.94	37.22	2.95	36.36	2.98
	68	64	38.54	2.82	38.21	2.85	38.02	2.88	37.82	2.89	37.67	2.90	36.88	2.92
Ducted Indoor Units 27 (50%)	-4	-4.4	13.86	1.63	12.89	1.70	12.78	1.71	12.62	1.72	12.50	1.73	11.95	1.80
	0	-0.4	15.86	1.69	14.95	1.75	14.70	1.78	14.48	1.79	14.31	1.80	13.71	1.87
	5	4.5	18.23	1.75	17.39	1.82	16.97	1.85	16.69	1.87	16.47	1.89	15.81	1.95
	10	9	19.82	1.81	19.02	1.87	18.49	1.92	18.17	1.95	17.92	1.97	17.21	2.03
	17	15	21.57	1.89	20.82	1.95	20.17	2.02	19.80	2.05	19.51	2.08	18.76	2.14
	20	19	22.63	1.95	21.91	2.01	21.18	2.08	20.79	2.12	20.47	2.15	19.70	2.21
	25	23	24.41	2.04	23.69	2.10	22.86	2.18	22.43	2.23	22.09	2.26	21.25	2.32
	30	28	26.21	2.15	25.40	2.22	24.53	2.29	24.08	2.34	23.72	2.38	22.84	2.44
	35	32	28.01	2.25	27.11	2.33	26.19	2.39	25.72	2.45	25.34	2.49	24.43	2.56
	40	36	29.43	2.32	28.61	2.40	27.69	2.47	27.21	2.52	26.83	2.56	25.86	2.63
	45	41	31.22	2.40	30.47	2.48	29.57	2.56	29.08	2.61	28.69	2.64	27.65	2.72
	47	43	31.93	2.43	31.22	2.51	30.33	2.60	29.83	2.64	29.43	2.68	28.36	2.76
	50	46	32.02	2.42	31.38	2.49	30.60	2.56	30.16	2.60	29.80	2.63	28.80	2.70
	55	51	32.18	2.39	31.65	2.45	31.06	2.51	30.71	2.54	30.42	2.56	29.52	2.62
	60	56	32.34	2.37	31.92	2.41	31.52	2.46	31.25	2.48	31.04	2.49	30.24	2.53
	63	59	32.43	2.35	32.08	2.39	31.80	2.43	31.58	2.44	31.41	2.45	30.68	2.48
	68	64	32.53	2.34	32.24	2.37	32.08	2.39	31.92	2.40	31.78	2.41	31.12	2.43

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 412: LMU540HV Heating Capacity Table — Ducted, continued, and Mixed Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 24 (40%)	-4	-4.4	12.31	1.43	11.46	1.48	11.36	1.50	11.22	1.51	11.11	1.52	10.62	1.57
	0	-0.4	14.09	1.47	13.28	1.53	13.06	1.55	12.87	1.57	12.72	1.58	12.19	1.63
	5	4.5	16.20	1.53	15.45	1.59	15.08	1.62	14.84	1.64	14.64	1.65	14.05	1.71
	10	9	17.62	1.59	16.91	1.64	16.43	1.68	16.15	1.70	15.92	1.72	15.30	1.78
	17	15	19.17	1.66	18.50	1.71	17.92	1.76	17.60	1.79	17.34	1.82	16.67	1.87
	20	19	20.11	1.70	19.47	1.76	18.82	1.82	18.47	1.85	18.19	1.88	17.50	1.93
	25	23	21.69	1.79	21.05	1.84	20.32	1.91	19.94	1.95	19.63	1.98	18.89	2.03
	30	28	23.29	1.88	22.57	1.94	21.80	2.00	21.40	2.05	21.08	2.08	20.30	2.13
	35	32	24.89	1.97	24.10	2.04	23.28	2.09	22.86	2.14	22.52	2.18	21.71	2.24
	40	36	26.16	2.03	25.42	2.10	24.61	2.16	24.19	2.20	23.84	2.24	22.98	2.30
	45	41	27.74	2.10	27.08	2.17	26.28	2.24	25.85	2.28	25.50	2.31	24.57	2.38
	47	43	28.38	2.13	27.74	2.20	26.95	2.27	26.51	2.31	26.16	2.34	25.21	2.41
	50	46	28.46	2.12	27.89	2.18	27.20	2.24	26.80	2.28	26.49	2.30	25.59	2.37
	55	51	28.60	2.09	28.13	2.15	27.61	2.20	27.29	2.22	27.04	2.24	26.24	2.29
	60	56	28.74	2.07	28.36	2.11	28.02	2.15	27.78	2.17	27.58	2.18	26.88	2.21
	63	59	28.82	2.06	28.51	2.09	28.26	2.12	28.07	2.13	27.91	2.14	27.26	2.17
	68	64	28.91	2.05	28.65	2.07	28.51	2.10	28.36	2.10	28.25	2.11	27.66	2.12
Mixed Indoor Units 73 (135%)	-4	-4.4	26.13	3.63	24.25	3.78	24.08	3.82	23.79	3.84	23.56	3.86	22.51	4.00
	0	-0.4	30.59	3.76	28.81	3.91	28.34	3.97	27.94	4.00	27.62	4.02	26.45	4.17
	5	4.5	35.90	3.92	34.23	4.06	33.41	4.15	32.87	4.19	32.44	4.23	31.13	4.37
	10	9	39.45	4.07	37.86	4.21	36.80	4.31	36.17	4.37	35.67	4.42	34.26	4.56
	17	15	43.36	4.26	41.86	4.40	40.54	4.54	39.80	4.61	39.22	4.67	37.71	4.81
	20	19	45.73	4.39	44.28	4.53	42.80	4.68	42.00	4.77	41.37	4.84	39.80	4.97
	25	23	49.70	4.62	48.23	4.76	46.55	4.94	45.67	5.04	44.97	5.12	43.28	5.25
	30	28	53.71	4.87	52.05	5.03	50.26	5.19	49.34	5.30	48.60	5.39	46.82	5.53
	35	32	57.72	5.12	55.88	5.30	53.98	5.44	53.01	5.57	52.23	5.67	50.35	5.81
	40	36	60.66	5.27	58.96	5.45	57.08	5.61	56.09	5.73	55.30	5.82	53.30	5.97
	45	41	64.34	5.46	62.80	5.64	60.95	5.82	59.94	5.92	59.13	6.01	56.98	6.18
	47	43	65.81	5.53	64.34	5.72	62.50	5.90	61.48	6.00	60.66	6.08	58.46	6.26
	50	46	66.00	5.50	64.67	5.66	63.07	5.83	62.16	5.91	61.43	5.98	59.35	6.15
	55	51	66.33	5.44	65.23	5.57	64.02	5.71	63.29	5.77	62.70	5.82	60.84	5.95
	60	56	66.65	5.38	65.78	5.49	64.97	5.59	64.42	5.63	63.97	5.66	62.33	5.75
	63	59	66.84	5.35	66.11	5.43	65.54	5.51	65.09	5.54	64.73	5.56	63.23	5.63
	68	64	67.04	5.31	66.45	5.38	66.12	5.44	65.78	5.46	65.51	5.47	64.14	5.51
Mixed Indoor Units 70 (130%)	-4	-4.4	25.89	3.58	24.03	3.73	23.86	3.77	23.58	3.79	23.35	3.80	22.31	3.95
	0	-0.4	30.32	3.71	28.55	3.86	28.09	3.91	27.69	3.95	27.37	3.97	26.21	4.11
	5	4.5	35.58	3.87	33.93	4.01	33.11	4.09	32.58	4.14	32.15	4.17	30.85	4.31
	10	9	39.10	4.01	37.52	4.15	36.47	4.26	35.85	4.31	35.35	4.36	33.95	4.50
	17	15	42.98	4.21	41.48	4.34	40.17	4.48	39.45	4.55	38.87	4.61	37.37	4.74
	20	19	45.32	4.34	43.88	4.47	42.42	4.62	41.63	4.71	41.00	4.78	39.44	4.91
	25	23	49.26	4.56	47.80	4.69	46.14	4.87	45.26	4.97	44.57	5.05	42.89	5.18
	30	28	53.23	4.81	51.59	4.97	49.81	5.12	48.90	5.23	48.17	5.32	46.40	5.46
	35	32	57.21	5.05	55.38	5.23	53.50	5.37	52.54	5.49	51.77	5.59	49.90	5.73
	40	36	60.12	5.20	58.43	5.38	56.57	5.53	55.59	5.65	54.80	5.74	52.82	5.89
	45	41	63.76	5.39	62.24	5.57	60.41	5.74	59.40	5.84	58.60	5.93	56.47	6.10
	47	43	65.22	5.46	63.76	5.64	61.94	5.82	60.93	5.92	60.12	6.00	57.93	6.18
	50	46	65.41	5.42	64.09	5.59	62.51	5.75	61.60	5.84	60.88	5.90	58.82	6.06
	55	51	65.73	5.37	64.64	5.50	63.45	5.63	62.72	5.69	62.14	5.75	60.30	5.87
	60	56	66.05	5.31	65.19	5.41	64.39	5.51	63.84	5.55	63.40	5.59	61.78	5.67
	63	59	66.24	5.28	65.52	5.36	64.96	5.44	64.51	5.47	64.15	5.49	62.66	5.56
	68	64	66.44	5.24	65.85	5.31	65.52	5.37	65.19	5.38	64.92	5.40	63.56	5.44

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).



MULTI F MAX LMU540HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 413: LMU540HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 65 (120%)	-4	-4.4	25.50	3.51	23.67	3.65	23.50	3.68	23.22	3.70	22.99	3.72	21.97	3.86
	0	-0.4	29.86	3.63	28.12	3.77	27.66	3.83	27.27	3.86	26.95	3.88	25.82	4.02
	5	4.5	35.04	3.79	33.41	3.92	32.61	4.00	32.08	4.05	31.66	4.08	30.38	4.22
	10	9	38.51	3.93	36.96	4.06	35.92	4.16	35.31	4.22	34.81	4.27	33.44	4.40
	17	15	42.33	4.11	40.86	4.25	39.57	4.38	38.85	4.45	38.28	4.51	36.81	4.64
	20	19	44.64	4.24	43.22	4.37	41.78	4.52	41.00	4.60	40.38	4.67	38.85	4.80
	25	23	48.52	4.46	47.08	4.59	45.44	4.76	44.58	4.86	43.89	4.94	42.24	5.07
	30	28	52.43	4.70	50.81	4.86	49.06	5.01	48.16	5.12	47.44	5.21	45.70	5.34
	35	32	56.34	4.94	54.55	5.12	52.69	5.25	51.74	5.37	50.99	5.47	49.14	5.60
	40	36	59.21	5.09	57.55	5.26	55.71	5.41	54.75	5.52	53.98	5.62	52.02	5.76
	45	41	62.80	5.27	61.30	5.44	59.49	5.61	58.51	5.71	57.72	5.80	55.62	5.96
	47	43	64.24	5.34	62.80	5.52	61.01	5.69	60.01	5.79	59.21	5.87	57.06	6.04
	50	46	64.43	5.31	63.13	5.46	61.56	5.62	60.67	5.71	59.96	5.77	57.93	5.93
	55	51	64.74	5.25	63.67	5.38	62.49	5.51	61.77	5.57	61.20	5.62	59.39	5.74
	60	56	65.05	5.19	64.21	5.29	63.42	5.39	62.88	5.43	62.44	5.46	60.84	5.55
	63	59	65.24	5.16	64.53	5.24	63.97	5.32	63.54	5.35	63.19	5.37	61.72	5.43
	68	64	65.43	5.13	64.86	5.19	64.54	5.25	64.20	5.27	63.94	5.28	62.60	5.32
Mixed Indoor Units 59 (110%)	-4	-4.4	25.04	3.41	23.24	3.55	23.08	3.58	22.80	3.60	22.58	3.62	21.57	3.76
	0	-0.4	29.32	3.53	27.61	3.67	27.16	3.72	26.77	3.75	26.47	3.78	25.35	3.91
	5	4.5	34.41	3.68	32.81	3.81	32.02	3.89	31.50	3.94	31.09	3.97	29.83	4.10
	10	9	37.81	3.82	36.29	3.95	35.27	4.05	34.66	4.10	34.18	4.15	32.83	4.28
	17	15	41.56	4.00	40.11	4.13	38.85	4.26	38.15	4.33	37.58	4.38	36.14	4.51
	20	19	43.83	4.12	42.43	4.25	41.02	4.40	40.26	4.48	39.65	4.54	38.14	4.67
	25	23	47.63	4.34	46.22	4.46	44.62	4.63	43.77	4.73	43.10	4.80	41.47	4.93
	30	28	51.48	4.57	49.88	4.72	48.17	4.87	47.29	4.98	46.58	5.06	44.87	5.19
	35	32	55.32	4.81	53.56	4.98	51.73	5.11	50.80	5.22	50.06	5.32	48.25	5.45
	40	36	58.14	4.95	56.50	5.12	54.70	5.26	53.75	5.37	53.00	5.46	51.08	5.60
	45	41	61.66	5.12	60.19	5.29	58.41	5.46	57.44	5.56	56.67	5.64	54.61	5.80
	47	43	63.07	5.19	61.66	5.36	59.90	5.53	58.92	5.63	58.14	5.71	56.02	5.88
	50	46	63.26	5.16	61.98	5.31	60.45	5.47	59.57	5.55	58.87	5.62	56.88	5.77
	55	51	63.56	5.10	62.51	5.23	61.36	5.35	60.65	5.42	60.09	5.46	58.31	5.58
	60	56	63.87	5.05	63.04	5.15	62.27	5.24	61.73	5.28	61.31	5.31	59.74	5.40
	63	59	64.06	5.02	63.36	5.10	62.81	5.17	62.38	5.20	62.04	5.22	60.60	5.28
	68	64	64.24	4.98	63.68	5.05	63.36	5.11	63.04	5.12	62.78	5.13	61.47	5.17
Mixed Indoor Units 54 (100%)	-4	-4.4	24.65	3.32	22.88	3.46	22.71	3.49	22.44	3.51	22.22	3.53	21.24	3.66
	0	-0.4	28.86	3.44	27.18	3.58	26.74	3.63	26.36	3.66	26.05	3.68	24.95	3.82
	5	4.5	33.87	3.59	32.29	3.72	31.52	3.80	31.01	3.84	30.60	3.87	29.37	4.00
	10	9	37.22	3.72	35.72	3.85	34.72	3.95	34.12	4.00	33.65	4.04	32.32	4.17
	17	15	40.91	3.90	39.49	4.03	38.24	4.15	37.55	4.22	37.00	4.28	35.57	4.40
	20	19	43.14	4.02	41.77	4.14	40.38	4.29	39.63	4.37	39.03	4.43	37.54	4.55
	25	23	46.89	4.23	45.50	4.35	43.92	4.52	43.09	4.61	42.42	4.68	40.83	4.81
	30	28	50.67	4.46	49.11	4.61	47.42	4.75	46.55	4.85	45.85	4.94	44.17	5.06
	35	32	54.45	4.69	52.72	4.85	50.93	4.98	50.01	5.09	49.28	5.19	47.50	5.31
	40	36	57.23	4.82	55.62	4.99	53.85	5.13	52.92	5.24	52.17	5.32	50.28	5.47
	45	41	60.70	4.99	59.25	5.16	57.50	5.32	56.55	5.42	55.78	5.50	53.76	5.66
	47	43	62.09	5.06	60.70	5.23	58.96	5.40	58.00	5.49	57.23	5.56	55.15	5.73
	50	46	62.27	5.03	61.01	5.18	59.50	5.33	58.64	5.41	57.95	5.48	55.99	5.62
	55	51	62.57	4.98	61.53	5.10	60.40	5.22	59.70	5.28	59.15	5.33	57.40	5.44
	60	56	62.88	4.92	62.06	5.02	61.29	5.11	60.77	5.15	60.35	5.18	58.81	5.26
	63	59	63.06	4.89	62.37	4.97	61.83	5.05	61.41	5.07	61.07	5.09	59.65	5.15
	68	64	63.24	4.86	62.69	4.92	62.37	4.98	62.05	4.99	61.80	5.00	60.51	5.05

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 414: LMU540HV Heating Capacity Table —Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 49 (90%)	-4	-4.4	23.16	3.00	21.49	3.12	21.34	3.15	21.09	3.17	20.88	3.18	19.96	3.30
	0	-0.4	27.12	3.10	25.54	3.22	25.12	3.27	24.77	3.30	24.48	3.32	23.45	3.44
	5	4.5	31.82	3.24	30.35	3.35	29.62	3.42	29.14	3.46	28.75	3.49	27.59	3.61
	10	9	34.98	3.36	33.56	3.47	32.62	3.56	32.06	3.61	31.62	3.65	30.37	3.76
	17	15	38.44	3.52	37.10	3.63	35.93	3.74	35.28	3.80	34.76	3.85	33.43	3.97
	20	19	40.54	3.63	39.25	3.74	37.94	3.86	37.24	3.94	36.67	3.99	35.28	4.10
	25	23	44.06	3.81	42.76	3.93	41.27	4.07	40.49	4.16	39.86	4.22	38.36	4.33
	30	28	47.62	4.02	46.14	4.15	44.56	4.28	43.74	4.37	43.09	4.45	41.50	4.56
	35	32	51.17	4.22	49.54	4.38	47.85	4.49	46.99	4.59	46.30	4.68	44.63	4.79
	40	36	53.78	4.35	52.26	4.50	50.60	4.63	49.72	4.72	49.02	4.80	47.24	4.93
	45	41	57.03	4.50	55.67	4.65	54.03	4.80	53.13	4.89	52.42	4.96	50.51	5.10
	47	43	58.34	4.56	57.03	4.72	55.41	4.87	54.50	4.95	53.78	5.02	51.82	5.17
	50	46	58.51	4.54	57.33	4.67	55.91	4.81	55.10	4.88	54.45	4.94	52.61	5.07
	55	51	58.80	4.49	57.82	4.60	56.75	4.71	56.10	4.76	55.58	4.80	53.94	4.91
	60	56	59.08	4.44	58.31	4.53	57.59	4.61	57.10	4.64	56.71	4.67	55.26	4.74
	63	59	59.25	4.41	58.61	4.48	58.10	4.55	57.70	4.57	57.38	4.59	56.05	4.65
	68	64	59.42	4.38	58.90	4.44	58.61	4.49	58.31	4.50	58.07	4.51	56.86	4.55
Mixed Indoor Units 43 (80%)	-4	-4.4	20.42	2.60	18.95	2.71	18.82	2.74	18.59	2.75	18.41	2.76	17.59	2.87
	0	-0.4	23.91	2.70	22.52	2.80	22.15	2.84	21.84	2.87	21.58	2.88	20.67	2.99
	5	4.5	28.06	2.81	26.75	2.91	26.11	2.97	25.69	3.01	25.35	3.03	24.33	3.13
	10	9	30.84	2.92	29.59	3.02	28.76	3.09	28.27	3.13	27.87	3.17	26.78	3.27
	17	15	33.89	3.06	32.71	3.15	31.68	3.25	31.11	3.31	30.65	3.35	29.47	3.45
	20	19	35.74	3.15	34.60	3.25	33.45	3.36	32.83	3.42	32.33	3.47	31.10	3.57
	25	23	38.85	3.31	37.70	3.41	36.38	3.54	35.70	3.61	35.15	3.67	33.82	3.76
	30	28	41.98	3.49	40.68	3.61	39.28	3.72	38.56	3.80	37.99	3.87	36.59	3.96
	35	32	45.11	3.67	43.68	3.80	42.19	3.90	41.43	3.99	40.82	4.06	39.35	4.16
	40	36	47.41	3.78	46.08	3.91	44.61	4.02	43.84	4.10	43.22	4.17	41.65	4.28
	45	41	50.28	3.91	49.08	4.04	47.64	4.17	46.85	4.24	46.21	4.30	44.53	4.43
	47	43	51.43	3.97	50.28	4.10	48.85	4.23	48.05	4.30	47.41	4.36	45.69	4.49
	50	46	51.59	3.94	50.54	4.06	49.29	4.18	48.58	4.24	48.01	4.29	46.39	4.40
	55	51	51.84	3.90	50.98	3.99	50.04	4.09	49.46	4.14	49.00	4.17	47.55	4.26
	60	56	52.09	3.86	51.41	3.93	50.78	4.00	50.34	4.03	50.00	4.06	48.72	4.12
	63	59	52.24	3.83	51.67	3.89	51.22	3.95	50.87	3.97	50.59	3.99	49.42	4.04
	68	64	52.39	3.81	51.93	3.86	51.67	3.90	51.41	3.91	51.20	3.92	50.13	3.95
Mixed Indoor Units 38 (70%)	-4	-4.4	18.04	2.27	16.75	2.36	16.63	2.39	16.43	2.40	16.27	2.41	15.55	2.50
	0	-0.4	21.13	2.35	19.90	2.44	19.57	2.48	19.30	2.50	19.07	2.52	18.27	2.61
	5	4.5	24.79	2.45	23.64	2.54	23.07	2.59	22.70	2.62	22.40	2.64	21.50	2.73
	10	9	27.25	2.54	26.15	2.63	25.42	2.70	24.98	2.73	24.63	2.76	23.66	2.85
	17	15	29.95	2.67	28.91	2.75	28.00	2.84	27.49	2.88	27.08	2.92	26.04	3.01
	20	19	31.59	2.75	30.58	2.83	29.56	2.93	29.01	2.98	28.57	3.03	27.49	3.11
	25	23	34.33	2.89	33.31	2.97	32.15	3.09	31.54	3.15	31.06	3.20	29.89	3.28
	30	28	37.10	3.05	35.95	3.15	34.71	3.24	34.08	3.31	33.57	3.37	32.33	3.46
	35	32	39.86	3.20	38.59	3.31	37.28	3.40	36.61	3.48	36.07	3.54	34.77	3.63
	40	36	41.90	3.29	40.72	3.41	39.42	3.50	38.74	3.58	38.19	3.64	36.81	3.73
	45	41	44.43	3.41	43.37	3.53	42.10	3.63	41.40	3.70	40.84	3.75	39.35	3.86
	47	43	45.45	3.46	44.43	3.57	43.17	3.69	42.46	3.75	41.90	3.80	40.37	3.92
	50	46	45.58	3.44	44.66	3.54	43.56	3.64	42.93	3.70	42.42	3.74	40.99	3.84
	55	51	45.81	3.40	45.05	3.48	44.22	3.57	43.71	3.61	43.30	3.64	42.02	3.72
	60	56	46.03	3.36	45.43	3.43	44.87	3.49	44.49	3.52	44.18	3.54	43.05	3.59
	63	59	46.16	3.34	45.66	3.40	45.26	3.45	44.96	3.46	44.71	3.48	43.67	3.52
	68	64	46.30	3.32	45.89	3.36	45.66	3.40	45.43	3.41	45.24	3.42	44.30	3.45

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU540HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 415: LMU540HV Heating Capacity Table —Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 32 (60%)	-4	-4.4	15.20	1.88	14.10	1.95	14.00	1.97	13.84	1.98	13.70	1.99	13.09	2.07
	0	-0.4	17.79	1.94	16.76	2.02	16.49	2.05	16.25	2.07	16.06	2.08	15.38	2.15
	5	4.5	20.88	2.03	19.91	2.10	19.43	2.14	19.12	2.17	18.87	2.19	18.11	2.26
	10	9	22.95	2.10	22.02	2.17	21.41	2.23	21.04	2.26	20.74	2.28	19.93	2.36
	17	15	25.22	2.20	24.35	2.27	23.58	2.34	23.15	2.38	22.81	2.41	21.93	2.48
	20	19	26.60	2.27	25.75	2.34	24.89	2.42	24.43	2.47	24.06	2.50	23.15	2.57
	25	23	28.91	2.39	28.05	2.46	27.08	2.55	26.57	2.60	26.16	2.64	25.17	2.71
	30	28	31.24	2.52	30.28	2.60	29.24	2.68	28.70	2.74	28.27	2.79	27.23	2.86
	35	32	33.57	2.65	32.50	2.74	31.40	2.81	30.83	2.88	30.38	2.93	29.28	3.00
	40	36	35.28	2.72	34.29	2.82	33.20	2.90	32.63	2.96	32.17	3.01	31.00	3.09
	45	41	37.42	2.82	36.53	2.91	35.45	3.00	34.86	3.06	34.39	3.10	33.14	3.19
	47	43	38.28	2.86	37.42	2.95	36.35	3.05	35.76	3.10	35.28	3.14	34.00	3.24
	50	46	38.39	2.84	37.62	2.93	36.69	3.01	36.15	3.06	35.73	3.09	34.52	3.18
	55	51	38.58	2.81	37.94	2.88	37.24	2.95	36.81	2.98	36.47	3.01	35.39	3.07
	60	56	38.77	2.78	38.26	2.83	37.79	2.89	37.47	2.91	37.21	2.93	36.26	2.97
Mixed Indoor Units 27 (50%)	63	59	38.88	2.76	38.45	2.81	38.12	2.85	37.86	2.86	37.65	2.88	36.78	2.91
	68	64	38.99	2.74	38.65	2.78	38.46	2.81	38.26	2.82	38.10	2.83	37.31	2.85
	-4	-4.4	12.82	1.55	11.90	1.61	11.82	1.63	11.67	1.64	11.56	1.65	11.05	1.71
	0	-0.4	15.01	1.61	14.14	1.67	13.91	1.69	13.71	1.71	13.55	1.72	12.98	1.78
	5	4.5	17.62	1.67	16.80	1.73	16.40	1.77	16.13	1.79	15.92	1.81	15.28	1.87
	10	9	19.36	1.74	18.58	1.80	18.06	1.84	17.75	1.87	17.50	1.89	16.81	1.95
	17	15	21.28	1.82	20.54	1.88	19.89	1.94	19.53	1.97	19.24	1.99	18.50	2.05
	20	19	22.44	1.87	21.73	1.93	21.00	2.00	20.61	2.04	20.30	2.07	19.53	2.12
	25	23	24.39	1.97	23.67	2.03	22.85	2.11	22.41	2.15	22.07	2.18	21.24	2.24
	30	28	26.36	2.08	25.54	2.15	24.67	2.21	24.21	2.26	23.85	2.30	22.97	2.36
	35	32	28.33	2.18	27.42	2.26	26.49	2.32	26.01	2.38	25.63	2.42	24.71	2.48
	40	36	29.77	2.25	28.93	2.33	28.01	2.39	27.53	2.44	27.14	2.48	26.15	2.55
	45	41	31.57	2.33	30.82	2.41	29.91	2.48	29.41	2.53	29.02	2.56	27.96	2.64
	47	43	32.29	2.36	31.57	2.44	30.67	2.52	30.17	2.56	29.77	2.59	28.69	2.67
	50	46	32.39	2.35	31.74	2.42	30.95	2.49	30.50	2.52	30.14	2.55	29.13	2.62
Mixed Indoor Units 24 (40%)	55	51	32.55	2.32	32.01	2.38	31.42	2.43	31.06	2.46	30.77	2.48	29.86	2.54
	60	56	32.71	2.30	32.28	2.34	31.88	2.38	31.61	2.40	31.39	2.42	30.59	2.45
	63	59	32.80	2.28	32.44	2.32	32.16	2.35	31.94	2.36	31.77	2.37	31.03	2.40
	68	64	32.90	2.27	32.61	2.30	32.45	2.32	32.28	2.33	32.15	2.33	31.47	2.35
	-4	-4.4	11.40	1.36	10.58	1.41	10.50	1.43	10.38	1.43	10.28	1.44	9.82	1.49
	0	-0.4	13.35	1.40	12.57	1.46	12.36	1.48	12.19	1.49	12.05	1.50	11.54	1.56
	5	4.5	15.66	1.46	14.93	1.52	14.57	1.55	14.34	1.57	14.15	1.58	13.58	1.63
	10	9	17.21	1.52	16.52	1.57	16.06	1.61	15.78	1.63	15.56	1.65	14.95	1.70
	17	15	18.92	1.59	18.26	1.64	17.68	1.69	17.36	1.72	17.11	1.74	16.45	1.80
	20	19	19.95	1.64	19.32	1.69	18.67	1.75	18.32	1.78	18.05	1.81	17.36	1.86
	25	23	21.68	1.73	21.04	1.78	20.31	1.84	19.92	1.88	19.62	1.91	18.88	1.96
	30	28	23.43	1.82	22.71	1.88	21.93	1.94	21.52	1.98	21.20	2.01	20.42	2.06
	35	32	25.18	1.91	24.38	1.98	23.55	2.03	23.13	2.08	22.79	2.12	21.96	2.17
	40	36	26.46	1.97	25.72	2.04	24.90	2.09	24.47	2.14	24.12	2.17	23.25	2.23
	45	41	28.07	2.04	27.40	2.11	26.59	2.17	26.15	2.21	25.80	2.24	24.86	2.31
	47	43	28.71	2.07	28.07	2.13	27.27	2.20	26.82	2.24	26.46	2.27	25.50	2.34

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 416: LMU600HV Heating Capacity Table — Non-Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 81 (135%)	-4	-4.4	27.21	4.06	25.22	4.22	25.07	4.27	24.77	4.30	24.53	4.32	23.44	4.48
	0	-0.4	32.20	4.13	30.31	4.29	29.83	4.36	29.41	4.39	29.07	4.42	27.84	4.58
	5	4.5	38.14	4.22	36.36	4.37	35.49	4.47	34.92	4.52	34.46	4.56	33.07	4.71
	10	9	42.11	4.31	40.41	4.45	39.28	4.57	38.61	4.63	38.07	4.68	36.57	4.83
	17	15	46.48	4.42	44.87	4.56	43.45	4.70	42.67	4.78	42.04	4.84	40.42	4.98
	20	19	49.13	4.49	47.57	4.63	45.98	4.79	45.13	4.88	44.44	4.95	42.75	5.08
	25	23	53.57	4.63	51.98	4.76	50.17	4.94	49.23	5.04	48.47	5.12	46.64	5.26
	30	28	58.05	4.79	56.25	4.94	54.32	5.10	53.33	5.21	52.53	5.30	50.60	5.43
	35	32	62.53	4.94	60.54	5.12	58.48	5.25	57.43	5.37	56.58	5.47	54.54	5.60
	40	36	65.71	5.09	63.87	5.26	61.83	5.41	60.76	5.52	59.90	5.62	57.73	5.76
	45	41	69.70	5.27	68.03	5.44	66.03	5.61	64.93	5.71	64.05	5.80	61.73	5.96
	47	43	71.29	5.34	69.70	5.52	67.71	5.69	66.60	5.79	65.71	5.87	63.33	6.04
	50	46	71.50	5.31	70.06	5.46	68.32	5.62	67.33	5.71	66.54	5.77	64.29	5.93
	55	51	71.85	5.25	70.66	5.38	69.35	5.51	68.56	5.57	67.92	5.62	65.91	5.74
	60	56	72.20	5.19	71.26	5.29	70.38	5.39	69.78	5.43	69.30	5.46	67.53	5.55
	63	59	72.41	5.16	71.62	5.24	71.00	5.32	70.51	5.35	70.12	5.37	68.50	5.43
	68	64	72.62	5.13	71.98	5.19	71.62	5.25	71.26	5.27	70.96	5.28	69.48	5.32
Non-Ducted Indoor Units 78 (130%)	-4	-4.4	27.06	4.01	25.08	4.17	24.93	4.22	24.63	4.24	24.40	4.26	23.31	4.42
	0	-0.4	32.03	4.08	30.14	4.24	29.66	4.30	29.24	4.34	28.91	4.37	27.68	4.53
	5	4.5	37.93	4.17	36.16	4.32	35.29	4.41	34.72	4.46	34.27	4.50	32.88	4.65
	10	9	41.88	4.25	40.19	4.40	39.06	4.51	38.39	4.57	37.86	4.62	36.37	4.77
	17	15	46.22	4.36	44.62	4.50	43.21	4.64	42.43	4.72	41.80	4.78	40.20	4.92
	20	19	48.86	4.44	47.30	4.57	45.72	4.73	44.87	4.82	44.20	4.89	42.52	5.02
	25	23	53.27	4.57	51.69	4.70	49.90	4.88	48.95	4.98	48.20	5.06	46.38	5.19
	30	28	57.73	4.73	55.94	4.88	54.02	5.03	53.03	5.14	52.24	5.23	50.32	5.36
	35	32	62.18	4.88	60.20	5.06	58.15	5.19	57.11	5.31	56.27	5.41	54.24	5.54
	40	36	65.35	5.02	63.51	5.20	61.49	5.35	60.42	5.46	59.57	5.55	57.41	5.69
	45	41	69.31	5.20	67.65	5.38	65.66	5.54	64.57	5.65	63.70	5.73	61.38	5.89
	47	43	70.89	5.27	69.31	5.45	67.33	5.62	66.23	5.72	65.35	5.80	62.97	5.97
	50	46	71.10	5.24	69.67	5.40	67.94	5.55	66.96	5.64	66.17	5.71	63.94	5.86
	55	51	71.45	5.19	70.27	5.31	68.97	5.44	68.18	5.50	67.54	5.55	65.54	5.67
	60	56	71.80	5.13	70.86	5.23	69.99	5.33	69.39	5.37	68.91	5.40	67.15	5.48
	63	59	72.01	5.10	71.22	5.18	70.61	5.26	70.12	5.28	69.74	5.30	68.11	5.37
	68	64	72.21	5.06	71.58	5.13	71.22	5.19	70.86	5.20	70.57	5.21	69.09	5.26
Non-Ducted Indoor Units 72 (120%)	-4	-4.4	26.76	3.92	24.80	4.07	24.65	4.12	24.36	4.15	24.12	4.17	23.05	4.32
	0	-0.4	31.67	3.99	29.81	4.14	29.33	4.21	28.92	4.24	28.58	4.27	27.37	4.42
	5	4.5	37.50	4.08	35.75	4.22	34.90	4.31	34.33	4.36	33.88	4.40	32.52	4.55
	10	9	41.41	4.16	39.74	4.30	38.63	4.41	37.96	4.47	37.43	4.52	35.96	4.66
	17	15	45.71	4.26	44.12	4.40	42.73	4.54	41.95	4.61	41.34	4.67	39.75	4.81
	20	19	48.31	4.34	46.77	4.47	45.21	4.62	44.37	4.71	43.70	4.78	42.04	4.91
	25	23	52.68	4.47	51.12	4.60	49.34	4.77	48.41	4.87	47.66	4.94	45.86	5.08
	30	28	57.08	4.62	55.32	4.77	53.42	4.92	52.44	5.03	51.65	5.11	49.75	5.24
	35	32	61.49	4.77	59.53	4.94	57.50	5.07	56.47	5.19	55.64	5.28	53.63	5.41
	40	36	64.62	4.91	62.80	5.08	60.80	5.22	59.75	5.33	58.91	5.42	56.77	5.57
	45	41	68.54	5.08	66.90	5.26	64.93	5.42	63.85	5.52	62.99	5.60	60.70	5.76
	47	43	70.10	5.15	68.54	5.32	66.58	5.50	65.49	5.59	64.62	5.67	62.27	5.84
	50	46	70.31	5.12	68.89	5.28	67.19	5.43	66.21	5.51	65.43	5.58	63.22	5.73
	55	51	70.65	5.07	69.48	5.19	68.20	5.32	67.41	5.38	66.79	5.43	64.81	5.54
	60	56	70.99	5.01	70.07	5.11	69.21	5.20	68.62	5.24	68.14	5.27	66.40	5.36
	63	59	71.20	4.98	70.42	5.06	69.82	5.14	69.34	5.16	68.96	5.18	67.35	5.25
	68	64	71.41	4.95	70.78	5.01	70.43	5.07	70.07	5.08	69.78	5.10	68.32	5.14

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU600HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 417: LMU600HV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 66 (110%)	-4	-4.4	26.45	3.83	24.52	3.98	24.37	4.02	24.08	4.05	23.85	4.07	22.78	4.22
	0	-0.4	31.31	3.90	29.47	4.04	29.00	4.11	28.59	4.14	28.26	4.17	27.06	4.32
	5	4.5	37.07	3.98	35.35	4.12	34.50	4.21	33.94	4.26	33.50	4.30	32.14	4.44
	10	9	40.94	4.06	39.28	4.20	38.18	4.31	37.53	4.36	37.00	4.41	35.55	4.55
	17	15	45.18	4.17	43.61	4.30	42.24	4.43	41.47	4.50	40.86	4.56	39.29	4.70
	20	19	47.76	4.24	46.24	4.36	44.69	4.51	43.87	4.60	43.20	4.67	41.56	4.79
	25	23	52.07	4.36	50.53	4.49	48.77	4.66	47.85	4.75	47.11	4.83	45.34	4.96
	30	28	56.43	4.51	54.68	4.66	52.81	4.81	51.84	4.91	51.06	5.00	49.18	5.12
	35	32	60.78	4.66	58.85	4.83	56.84	4.95	55.82	5.07	55.00	5.16	53.02	5.28
	40	36	63.88	4.80	62.08	4.96	60.11	5.10	59.06	5.21	58.23	5.30	56.12	5.44
	45	41	67.75	4.97	66.13	5.13	64.18	5.29	63.12	5.39	62.27	5.47	60.00	5.62
	47	43	69.30	5.03	67.75	5.20	65.82	5.37	64.74	5.46	63.88	5.53	61.56	5.70
	50	46	69.50	5.00	68.10	5.15	66.42	5.30	65.45	5.38	64.68	5.45	62.50	5.59
	55	51	69.84	4.95	68.68	5.07	67.42	5.19	66.64	5.25	66.02	5.30	64.07	5.41
	60	56	70.18	4.90	69.27	4.99	68.42	5.08	67.83	5.12	67.36	5.15	65.64	5.23
	63	59	70.39	4.87	69.62	4.94	69.02	5.02	68.54	5.04	68.17	5.06	66.58	5.12
	68	64	70.59	4.83	69.97	4.90	69.62	4.95	69.27	4.97	68.98	4.98	67.54	5.02
Non-Ducted Indoor Units 60 (100%)	-4	-4.4	26.15	3.73	24.24	3.88	24.09	3.93	23.80	3.95	23.58	3.97	22.52	4.12
	0	-0.4	30.95	3.80	29.13	3.95	28.66	4.01	28.26	4.05	27.93	4.07	26.75	4.22
	5	4.5	36.65	3.89	34.94	4.03	34.11	4.11	33.55	4.16	33.11	4.19	31.78	4.33
	10	9	40.47	3.96	38.83	4.10	37.75	4.20	37.10	4.26	36.58	4.31	35.14	4.44
	17	15	44.67	4.07	43.11	4.20	41.76	4.33	41.00	4.40	40.40	4.46	38.84	4.58
	20	19	47.21	4.13	45.71	4.26	44.18	4.41	43.36	4.49	42.71	4.55	41.09	4.68
	25	23	51.48	4.26	49.95	4.38	48.22	4.55	47.30	4.64	46.57	4.71	44.82	4.84
	30	28	55.79	4.41	54.06	4.55	52.20	4.69	51.24	4.79	50.48	4.88	48.62	5.00
	35	32	60.09	4.55	58.17	4.71	56.19	4.83	55.18	4.95	54.38	5.04	52.41	5.16
	40	36	63.15	4.68	61.38	4.84	59.42	4.98	58.39	5.09	57.57	5.17	55.48	5.31
	45	41	66.98	4.85	65.38	5.01	63.45	5.17	62.40	5.26	61.55	5.34	59.32	5.49
	47	43	68.51	4.91	66.98	5.08	65.06	5.24	64.00	5.33	63.15	5.40	60.85	5.56
	50	46	68.71	4.88	67.32	5.03	65.66	5.18	64.71	5.25	63.94	5.32	61.78	5.46
	55	51	69.04	4.83	67.90	4.95	66.65	5.07	65.88	5.13	65.27	5.17	63.34	5.28
	60	56	69.38	4.78	68.48	4.87	67.63	4.96	67.06	5.00	66.59	5.03	64.89	5.11
	63	59	69.58	4.75	68.82	4.83	68.23	4.90	67.76	4.92	67.39	4.94	65.82	5.00
	68	64	69.78	4.72	69.17	4.78	68.83	4.84	68.47	4.85	68.19	4.86	66.77	4.90
Non-Ducted Indoor Units 54 (90%)	-4	-4.4	24.42	3.34	22.63	3.48	22.49	3.52	22.23	3.54	22.01	3.56	21.03	3.69
	0	-0.4	28.90	3.40	27.20	3.53	26.77	3.59	26.39	3.62	26.08	3.65	24.98	3.78
	5	4.5	34.22	3.48	32.63	3.60	31.85	3.68	31.33	3.72	30.92	3.75	29.67	3.88
	10	9	37.79	3.55	36.26	3.67	35.25	3.76	34.64	3.81	34.16	3.85	32.81	3.98
	17	15	41.71	3.64	40.26	3.75	38.99	3.87	38.28	3.94	37.72	3.99	36.27	4.10
	20	19	44.09	3.70	42.68	3.81	41.26	3.94	40.49	4.02	39.88	4.08	38.36	4.19
	25	23	48.07	3.81	46.64	3.92	45.02	4.07	44.17	4.15	43.49	4.22	41.85	4.33
	30	28	52.09	3.94	50.48	4.07	48.74	4.20	47.85	4.29	47.13	4.36	45.40	4.47
	35	32	56.11	4.07	54.32	4.22	52.47	4.33	51.53	4.43	50.77	4.51	48.94	4.62
	40	36	58.97	4.19	57.31	4.34	55.48	4.46	54.52	4.55	53.75	4.63	51.80	4.75
	45	41	62.54	4.34	61.05	4.48	59.25	4.62	58.26	4.71	57.48	4.78	55.39	4.91
	47	43	63.97	4.40	62.54	4.54	60.75	4.69	59.76	4.77	58.97	4.83	56.82	4.98
	50	46	64.16	4.37	62.86	4.50	61.31	4.63	60.42	4.70	59.71	4.76	57.69	4.89
	55	51	64.47	4.32	63.40	4.43	62.23	4.54	61.52	4.59	60.94	4.63	59.14	4.73
	60	56	64.78	4.28	63.94	4.36	63.15	4.44	62.61	4.47	62.18	4.50	60.59	4.57
	63	59	64.97	4.25	64.26	4.32	63.71	4.38	63.27	4.41	62.92	4.42	61.46	4.48
	68	64	65.16	4.22	64.59	4.28	64.27	4.33	63.94	4.34	63.67	4.35	62.34	4.38

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 418: LMU600HV Heating Capacity Table — Non-Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 48 (80%)	-4	-4.4	22.33	2.96	20.70	3.07	20.57	3.11	20.33	3.13	20.13	3.15	19.23	3.26
	0	-0.4	26.43	3.01	24.87	3.13	24.48	3.18	24.13	3.20	23.85	3.23	22.84	3.34
	5	4.5	31.30	3.08	29.84	3.19	29.12	3.25	28.65	3.29	28.28	3.32	27.13	3.43
	10	9	34.56	3.14	33.16	3.25	32.23	3.33	31.68	3.37	31.24	3.41	30.01	3.52
	17	15	38.14	3.22	36.82	3.32	35.66	3.42	35.01	3.48	34.49	3.53	33.17	3.63
	20	19	40.32	3.27	39.03	3.37	37.73	3.49	37.03	3.55	36.47	3.61	35.08	3.71
	25	23	43.96	3.37	42.66	3.47	41.17	3.60	40.39	3.67	39.77	3.73	38.27	3.83
	30	28	47.64	3.49	46.16	3.60	44.58	3.71	43.76	3.80	43.10	3.86	41.52	3.96
	35	32	51.31	3.60	49.68	3.73	47.98	3.83	47.12	3.92	46.43	3.99	44.75	4.08
	40	36	53.92	3.71	52.41	3.84	50.74	3.94	49.86	4.03	49.16	4.09	47.37	4.20
	45	41	57.19	3.84	55.83	3.97	54.18	4.09	53.28	4.16	52.56	4.22	50.65	4.35
	47	43	58.50	3.89	57.19	4.02	55.56	4.15	54.65	4.22	53.92	4.28	51.96	4.41
	50	46	58.67	3.87	57.49	3.98	56.06	4.10	55.25	4.16	54.60	4.21	52.76	4.32
	55	51	58.96	3.83	57.98	3.92	56.91	4.01	56.26	4.06	55.73	4.10	54.08	4.18
	60	56	59.24	3.79	58.47	3.86	57.75	3.93	57.26	3.96	56.86	3.98	55.41	4.04
	63	59	59.42	3.76	58.77	3.82	58.26	3.88	57.86	3.90	57.54	3.91	56.21	3.96
	68	64	59.59	3.74	59.06	3.78	58.77	3.83	58.47	3.84	58.23	3.85	57.01	3.88
Non-Ducted Indoor Units 42 (70%)	-4	-4.4	19.73	2.56	18.29	2.67	18.18	2.70	17.96	2.72	17.79	2.73	17.00	2.83
	0	-0.4	23.36	2.61	21.98	2.71	21.63	2.75	21.33	2.78	21.08	2.80	20.19	2.90
	5	4.5	27.66	2.67	26.37	2.76	25.74	2.82	25.32	2.85	24.99	2.88	23.98	2.98
	10	9	30.54	2.72	29.31	2.81	28.49	2.89	28.00	2.93	27.61	2.96	26.52	3.05
	17	15	33.71	2.79	32.54	2.88	31.51	2.97	30.94	3.02	30.49	3.06	29.31	3.15
	20	19	35.63	2.84	34.50	2.93	33.35	3.03	32.73	3.08	32.23	3.13	31.01	3.21
	25	23	38.85	2.93	37.70	3.01	36.39	3.12	35.70	3.19	35.15	3.24	33.83	3.32
	30	28	42.10	3.02	40.80	3.12	39.40	3.22	38.67	3.29	38.09	3.35	36.69	3.43
	35	32	45.35	3.12	43.90	3.24	42.41	3.32	41.65	3.40	41.04	3.46	39.55	3.54
	40	36	47.66	3.22	46.32	3.33	44.84	3.42	44.07	3.49	43.44	3.55	41.87	3.64
	45	41	50.55	3.33	49.34	3.44	47.89	3.55	47.09	3.61	46.45	3.66	44.77	3.77
	47	43	51.70	3.37	50.55	3.49	49.10	3.60	48.30	3.66	47.66	3.71	45.93	3.82
	50	46	51.85	3.35	50.81	3.45	49.55	3.55	48.83	3.61	48.26	3.65	46.63	3.75
	55	51	52.11	3.32	51.24	3.40	50.30	3.48	49.72	3.52	49.26	3.55	47.80	3.63
	60	56	52.36	3.28	51.68	3.35	51.04	3.41	50.61	3.43	50.26	3.45	48.97	3.51
	63	59	52.51	3.26	51.94	3.31	51.49	3.36	51.14	3.38	50.86	3.39	49.67	3.43
	68	64	52.66	3.24	52.20	3.28	51.94	3.32	51.68	3.33	51.46	3.34	50.39	3.36
Non-Ducted Indoor Units 36 (60%)	-4	-4.4	16.92	2.17	15.68	2.26	15.58	2.28	15.40	2.30	15.25	2.31	14.57	2.40
	0	-0.4	20.02	2.21	18.84	2.30	18.54	2.33	18.28	2.35	18.07	2.37	17.31	2.45
	5	4.5	23.71	2.26	22.60	2.34	22.06	2.39	21.71	2.42	21.42	2.44	20.56	2.52
	10	9	26.18	2.31	25.12	2.38	24.42	2.44	24.00	2.48	23.66	2.50	22.73	2.58
	17	15	28.89	2.36	27.89	2.44	27.01	2.52	26.52	2.56	26.13	2.59	25.13	2.67
	20	19	30.54	2.40	29.57	2.48	28.58	2.56	28.05	2.61	27.63	2.65	26.58	2.72
	25	23	33.30	2.48	32.31	2.55	31.19	2.65	30.60	2.70	30.13	2.74	28.99	2.81
	30	28	36.09	2.56	34.97	2.65	33.77	2.73	33.15	2.79	32.65	2.84	31.45	2.91
	35	32	38.87	2.65	37.63	2.74	36.35	2.81	35.70	2.88	35.17	2.93	33.90	3.00
	40	36	40.85	2.72	39.70	2.82	38.44	2.90	37.77	2.96	37.24	3.01	35.89	3.09
	45	41	43.33	2.82	42.29	2.91	41.04	3.00	40.36	3.06	39.82	3.10	38.37	3.19
	47	43	44.32	2.86	43.33	2.95	42.09	3.05	41.40	3.10	40.85	3.14	39.36	3.24
	50	46	44.45	2.84	43.55	2.93	42.47	3.01	41.86	3.06	41.36	3.09	39.97	3.18
	55	51	44.66	2.81	43.92	2.88	43.11	2.95	42.62	2.98	42.22	3.01	40.97	3.07
	60	56	44.88	2.78	44.30	2.83	43.75	2.89	43.38	2.91	43.08	2.93	41.98	2.97
	63	59	45.01	2.76	44.52	2.81	44.13	2.85	43.83	2.86	43.59	2.88	42.58	2.91
	68	64	45.14	2.74	44.74	2.78	44.52	2.81	44.29	2.82	44.11	2.83	43.19	2.85

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU600HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 419: LMU600HV Heating Capacity Table — Non-Ducted, continued, and Ducted Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Non-Ducted Indoor Units 30 (50%)	-4	-4.4	14.10	1.78	13.07	1.85	12.98	1.87	12.83	1.88	12.71	1.89	12.14	1.96
	0	-0.4	16.68	1.81	15.70	1.88	15.45	1.91	15.23	1.93	15.06	1.94	14.42	2.01
	5	4.5	19.76	1.85	18.84	1.92	18.38	1.96	18.09	1.98	17.85	2.00	17.13	2.07
	10	9	21.81	1.89	20.93	1.95	20.35	2.00	20.00	2.03	19.72	2.05	18.94	2.12
	17	15	24.08	1.94	23.24	2.00	22.51	2.06	22.10	2.10	21.78	2.12	20.94	2.18
	20	19	25.45	1.97	24.64	2.03	23.82	2.10	23.38	2.14	23.02	2.17	22.15	2.23
	25	23	27.75	2.03	26.93	2.09	25.99	2.17	25.50	2.21	25.11	2.25	24.16	2.31
	30	28	30.07	2.10	29.14	2.17	28.14	2.24	27.62	2.28	27.21	2.32	26.21	2.38
	35	32	32.39	2.17	31.36	2.25	30.29	2.30	29.75	2.36	29.31	2.40	28.25	2.46
	40	36	34.04	2.23	33.08	2.31	32.03	2.37	31.48	2.42	31.03	2.46	29.91	2.53
	45	41	36.10	2.31	35.24	2.39	34.20	2.46	33.64	2.51	33.18	2.54	31.98	2.62
	47	43	36.93	2.34	36.10	2.42	35.07	2.50	34.50	2.54	34.04	2.57	32.80	2.65
	50	46	37.04	2.33	36.29	2.40	35.39	2.47	34.88	2.50	34.47	2.53	33.31	2.60
	55	51	37.22	2.30	36.60	2.36	35.93	2.42	35.51	2.44	35.18	2.47	34.14	2.52
	60	56	37.40	2.28	36.91	2.32	36.46	2.36	36.15	2.38	35.90	2.40	34.98	2.43
	63	59	37.51	2.26	37.10	2.30	36.78	2.33	36.53	2.35	36.33	2.36	35.48	2.38
	68	64	37.62	2.25	37.29	2.28	37.10	2.30	36.91	2.31	36.76	2.32	35.99	2.33
Non-Ducted Indoor Units 24 (40%)	-4	-4.4	11.28	1.39	10.45	1.44	10.39	1.46	10.26	1.47	10.17	1.48	9.71	1.53
	0	-0.4	13.35	1.41	12.56	1.47	12.36	1.49	12.19	1.50	12.05	1.51	11.54	1.57
	5	4.5	15.81	1.44	15.07	1.50	14.71	1.53	14.47	1.54	14.28	1.56	13.70	1.61
	10	9	17.45	1.47	16.75	1.52	16.28	1.56	16.00	1.58	15.78	1.60	15.15	1.65
	17	15	19.26	1.51	18.59	1.56	18.01	1.61	17.68	1.63	17.42	1.66	16.75	1.70
	20	19	20.36	1.54	19.71	1.58	19.05	1.64	18.70	1.67	18.42	1.69	17.72	1.74
	25	23	22.20	1.58	21.54	1.63	20.79	1.69	20.40	1.72	20.09	1.75	19.33	1.80
	30	28	24.06	1.64	23.31	1.69	22.51	1.74	22.10	1.78	21.77	1.81	20.97	1.86
	35	32	25.91	1.69	25.09	1.75	24.23	1.80	23.80	1.84	23.45	1.87	22.60	1.92
	40	36	27.23	1.74	26.47	1.80	25.62	1.85	25.18	1.89	24.83	1.92	23.93	1.97
	45	41	28.88	1.80	28.19	1.86	27.36	1.92	26.91	1.95	26.55	1.98	25.58	2.04
	47	43	29.54	1.83	28.88	1.89	28.06	1.95	27.60	1.98	27.23	2.01	26.24	2.07
	50	46	29.63	1.81	29.03	1.87	28.31	1.92	27.90	1.95	27.58	1.97	26.64	2.03
	55	51	29.78	1.80	29.28	1.84	28.74	1.88	28.41	1.90	28.15	1.92	27.31	1.96
	60	56	29.92	1.78	29.53	1.81	29.17	1.84	28.92	1.86	28.72	1.87	27.98	1.90
	63	59	30.01	1.76	29.68	1.79	29.42	1.82	29.22	1.83	29.06	1.84	28.39	1.86
	68	64	30.09	1.75	29.83	1.78	29.68	1.80	29.53	1.80	29.41	1.80	28.79	1.82
Ducted Indoor Units 81 (135%)	-4	-4.4	32.24	3.89	30.03	4.05	29.75	4.09	29.37	4.12	29.07	4.14	27.80	4.30
	0	-0.4	36.52	4.00	34.44	4.15	33.85	4.22	33.36	4.25	32.96	4.28	31.58	4.43
	5	4.5	41.60	4.13	39.68	4.28	38.72	4.37	38.09	4.42	37.59	4.46	36.07	4.60
	10	9	45.01	4.25	43.19	4.39	41.98	4.51	41.26	4.57	40.68	4.62	39.08	4.76
	17	15	48.75	4.41	47.05	4.55	45.57	4.69	44.75	4.77	44.09	4.83	42.39	4.97
	20	19	51.02	4.51	49.39	4.65	47.75	4.81	46.86	4.90	46.15	4.97	44.40	5.11
	25	23	54.83	4.70	53.20	4.84	51.35	5.02	50.38	5.12	49.60	5.20	47.74	5.34
	30	28	58.68	4.91	56.86	5.07	54.91	5.23	53.90	5.35	53.10	5.44	51.15	5.57
	35	32	62.53	5.12	60.54	5.30	58.48	5.44	57.43	5.57	56.58	5.67	54.54	5.81
	40	36	65.71	5.27	63.87	5.45	61.83	5.61	60.76	5.73	59.90	5.82	57.73	5.97
	45	41	69.70	5.46	68.03	5.64	66.03	5.82	64.93	5.92	64.05	6.01	61.73	6.18
	47	43	71.29	5.53	69.70	5.72	67.71	5.90	66.60	6.00	65.71	6.08	63.33	6.26
	50	46	71.50	5.50	70.06	5.66	68.32	5.83	67.33	5.91	66.54	5.98	64.29	6.15
	55	51	71.85	5.44	70.66	5.57	69.35	5.71	68.56	5.77	67.92	5.82	65.91	5.95
	60	56	72.20	5.38	71.26	5.49	70.38	5.59	69.78	5.63	69.30	5.66	67.53	5.75
	63	59	72.41	5.35	71.62	5.43	71.00	5.51	70.51	5.54	70.12	5.56	68.50	5.63
	68	64	72.62	5.31	71.98	5.38	71.62	5.44	71.26	5.46	70.96	5.47	69.48	5.51

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 420: LMU600HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 78 (130%)	-4	-4.4	32.06	3.87	29.87	4.02	29.58	4.07	29.21	4.09	28.91	4.11	27.65	4.27
	0	-0.4	36.31	3.97	34.25	4.13	33.66	4.19	33.17	4.22	32.78	4.25	31.41	4.41
	5	4.5	41.37	4.10	39.46	4.25	38.51	4.34	37.88	4.39	37.38	4.43	35.87	4.57
	10	9	44.76	4.22	42.95	4.37	41.75	4.48	41.03	4.54	40.46	4.59	38.87	4.73
	17	15	48.48	4.38	46.79	4.52	45.32	4.66	44.50	4.74	43.84	4.80	42.16	4.94
	20	19	50.74	4.48	49.12	4.62	47.48	4.78	46.60	4.87	45.89	4.94	44.15	5.08
	25	23	54.52	4.67	52.91	4.81	51.07	4.99	50.10	5.09	49.33	5.17	47.47	5.31
	30	28	58.35	4.88	56.55	5.04	54.61	5.20	53.60	5.31	52.80	5.40	50.86	5.54
	35	32	62.18	5.09	60.20	5.27	58.15	5.40	57.11	5.53	56.27	5.63	54.24	5.77
	40	36	65.35	5.24	63.51	5.42	61.49	5.57	60.42	5.69	59.57	5.78	57.41	5.93
	45	41	69.31	5.42	67.65	5.60	65.66	5.78	64.57	5.88	63.70	5.97	61.38	6.14
	47	43	70.89	5.50	69.31	5.68	67.33	5.86	66.23	5.96	65.35	6.04	62.97	6.22
	50	46	71.10	5.46	69.67	5.62	67.94	5.79	66.96	5.87	66.17	5.94	63.94	6.10
	55	51	71.45	5.40	70.27	5.54	68.97	5.67	68.18	5.73	67.54	5.78	65.54	5.91
	60	56	71.80	5.35	70.86	5.45	69.99	5.55	69.39	5.59	68.91	5.62	67.15	5.71
	63	59	72.01	5.31	71.22	5.40	70.61	5.48	70.12	5.51	69.74	5.53	68.11	5.59
	68	64	72.21	5.28	71.58	5.34	71.22	5.41	70.86	5.42	70.57	5.43	69.09	5.48
Ducted Indoor Units 72 (120%)	-4	-4.4	31.70	3.80	29.53	3.96	29.25	4.00	28.88	4.02	28.59	4.04	27.34	4.20
	0	-0.4	35.91	3.91	33.87	4.06	33.28	4.12	32.80	4.15	32.42	4.18	31.05	4.33
	5	4.5	40.91	4.03	39.02	4.18	38.07	4.27	37.46	4.31	36.96	4.35	35.47	4.50
	10	9	44.26	4.15	42.47	4.29	41.28	4.40	40.57	4.46	40.00	4.51	38.43	4.65
	17	15	47.94	4.30	46.27	4.44	44.81	4.58	44.00	4.66	43.35	4.72	41.69	4.85
	20	19	50.17	4.41	48.57	4.54	46.95	4.70	46.08	4.79	45.38	4.86	43.66	4.99
	25	23	53.91	4.59	52.32	4.73	50.50	4.90	49.54	5.00	48.78	5.08	46.94	5.22
	30	28	57.70	4.80	55.92	4.96	54.00	5.11	53.01	5.22	52.21	5.31	50.29	5.44
	35	32	61.49	5.00	59.53	5.18	57.50	5.31	56.47	5.44	55.64	5.54	53.63	5.67
	40	36	64.62	5.15	62.80	5.33	60.80	5.48	59.75	5.59	58.91	5.68	56.77	5.83
	45	41	68.54	5.33	66.90	5.51	64.93	5.68	63.85	5.78	62.99	5.87	60.70	6.04
	47	43	70.10	5.40	68.54	5.58	66.58	5.76	65.49	5.86	64.62	5.94	62.27	6.12
	50	46	70.31	5.37	68.89	5.53	67.19	5.69	66.21	5.78	65.43	5.84	63.22	6.00
	55	51	70.65	5.31	69.48	5.44	68.20	5.57	67.41	5.64	66.79	5.69	64.81	5.81
	60	56	70.99	5.26	70.07	5.36	69.21	5.46	68.62	5.50	68.14	5.53	66.40	5.62
	63	59	71.20	5.22	70.42	5.31	69.82	5.39	69.34	5.41	68.96	5.43	67.35	5.50
	68	64	71.41	5.19	70.78	5.25	70.43	5.32	70.07	5.33	69.78	5.34	68.32	5.39
Ducted Indoor Units 66 (110%)	-4	-4.4	31.34	3.74	29.19	3.89	28.92	3.93	28.55	3.95	28.26	3.97	27.02	4.12
	0	-0.4	35.50	3.84	33.48	3.99	32.90	4.05	32.43	4.08	32.04	4.11	30.70	4.26
	5	4.5	40.44	3.96	38.58	4.11	37.64	4.19	37.03	4.24	36.54	4.28	35.07	4.42
	10	9	43.75	4.08	41.99	4.22	40.81	4.32	40.11	4.38	39.55	4.43	37.99	4.57
	17	15	47.39	4.23	45.74	4.37	44.30	4.50	43.50	4.58	42.86	4.64	41.21	4.77
	20	19	49.60	4.33	48.02	4.46	46.41	4.62	45.55	4.70	44.86	4.77	43.16	4.90
	25	23	53.30	4.51	51.72	4.65	49.92	4.82	48.97	4.92	48.22	5.00	46.40	5.13
	30	28	57.04	4.72	55.28	4.87	53.38	5.02	52.40	5.13	51.61	5.22	49.72	5.35
	35	32	60.78	4.92	58.85	5.09	56.84	5.22	55.82	5.35	55.00	5.44	53.02	5.57
	40	36	63.88	5.06	62.08	5.24	60.11	5.38	59.06	5.50	58.23	5.59	56.12	5.73
	45	41	67.75	5.24	66.13	5.42	64.18	5.58	63.12	5.68	62.27	5.77	60.00	5.93
	47	43	69.30	5.31	67.75	5.49	65.82	5.66	64.74	5.76	63.88	5.84	61.56	6.01
	50	46	69.50	5.28	68.10	5.44	66.42	5.59	65.45	5.68	64.68	5.75	62.50	5.90
	55	51	69.84	5.22	68.68	5.35	67.42	5.48	66.64	5.54	66.02	5.59	64.07	5.71
	60	56	70.18	5.17	69.27	5.27	68.42	5.36	67.83	5.40	67.36	5.43	65.64	5.52
	63	59	70.39	5.13	69.62	5.22	69.02	5.29	68.54	5.32	68.17	5.34	66.58	5.41
	68	64	70.59	5.10	69.97	5.16	69.62	5.23	69.27	5.24	68.98	5.25	67.54	5.29

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 421: LMU600HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
	°F DB	°F WB	61		64		68		70		72		75	
			TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 60 (100%)	-4	-4.4	30.98	3.67	28.86	3.82	28.59	3.86	28.23	3.89	27.94	3.90	26.71	4.05
	0	-0.4	35.09	3.77	33.10	3.92	32.53	3.98	32.06	4.01	31.68	4.04	30.35	4.18
	5	4.5	39.98	3.90	38.14	4.04	37.21	4.12	36.60	4.17	36.12	4.20	34.67	4.34
	10	9	43.25	4.01	41.51	4.15	40.34	4.25	39.65	4.31	39.09	4.35	37.56	4.49
	17	15	46.85	4.16	45.22	4.29	43.79	4.42	43.00	4.50	42.37	4.56	40.74	4.69
	20	19	49.03	4.26	47.47	4.39	45.88	4.54	45.03	4.62	44.35	4.69	42.66	4.82
	25	23	52.69	4.44	51.13	4.56	49.35	4.74	48.41	4.83	47.67	4.91	45.87	5.04
	30	28	56.39	4.63	54.64	4.79	52.77	4.93	51.80	5.04	51.02	5.13	49.15	5.26
	35	32	60.09	4.83	58.17	5.00	56.19	5.13	55.18	5.25	54.38	5.35	52.41	5.48
	40	36	63.15	4.97	61.38	5.14	59.42	5.29	58.39	5.40	57.57	5.49	55.48	5.63
	45	41	66.98	5.15	65.38	5.32	63.45	5.49	62.40	5.59	61.55	5.67	59.32	5.83
	47	43	68.51	5.22	66.98	5.39	65.06	5.56	64.00	5.66	63.15	5.74	60.85	5.91
	50	46	68.71	5.19	67.32	5.34	65.66	5.50	64.71	5.58	63.94	5.65	61.78	5.80
	55	51	69.04	5.13	67.90	5.26	66.65	5.38	65.88	5.44	65.27	5.49	63.34	5.61
	60	56	69.38	5.08	68.48	5.17	67.63	5.27	67.06	5.31	66.59	5.34	64.89	5.42
	63	59	69.58	5.04	68.82	5.12	68.23	5.20	67.76	5.23	67.39	5.25	65.82	5.31
	68	64	69.78	5.01	69.17	5.08	68.83	5.13	68.47	5.15	68.19	5.16	66.77	5.20
Ducted Indoor Units 54 (90%)	-4	-4.4	28.93	3.29	26.95	3.42	26.69	3.46	26.36	3.48	26.09	3.50	24.94	3.63
	0	-0.4	32.77	3.38	30.91	3.51	30.37	3.56	29.93	3.59	29.58	3.62	28.34	3.75
	5	4.5	37.33	3.49	35.61	3.62	34.74	3.69	34.18	3.73	33.73	3.77	32.37	3.89
	10	9	40.38	3.59	38.76	3.71	37.67	3.81	37.02	3.86	36.50	3.90	35.07	4.02
	17	15	43.74	3.72	42.22	3.84	40.89	3.96	40.15	4.03	39.56	4.08	38.04	4.20
	20	19	45.78	3.81	44.32	3.93	42.84	4.07	42.05	4.14	41.41	4.20	39.84	4.32
	25	23	49.20	3.97	47.74	4.09	46.08	4.24	45.21	4.33	44.51	4.40	42.83	4.51
	30	28	52.65	4.15	51.02	4.29	49.27	4.42	48.37	4.52	47.64	4.59	45.89	4.71
	35	32	56.11	4.33	54.32	4.48	52.47	4.60	51.53	4.71	50.77	4.79	48.94	4.91
	40	36	58.97	4.45	57.31	4.61	55.48	4.74	54.52	4.84	53.75	4.92	51.80	5.05
	45	41	62.54	4.61	61.05	4.77	59.25	4.91	58.26	5.00	57.48	5.08	55.39	5.22
	47	43	63.97	4.68	62.54	4.83	60.75	4.98	59.76	5.07	58.97	5.14	56.82	5.29
	50	46	64.16	4.65	62.86	4.78	61.31	4.92	60.42	5.00	59.71	5.06	57.69	5.19
	55	51	64.47	4.60	63.40	4.71	62.23	4.82	61.52	4.88	60.94	4.92	59.14	5.03
	60	56	64.78	4.55	63.94	4.64	63.15	4.72	62.61	4.76	62.18	4.78	60.59	4.86
	63	59	64.97	4.52	64.26	4.59	63.71	4.66	63.27	4.68	62.92	4.70	61.46	4.76
	68	64	65.16	4.49	64.59	4.55	64.27	4.60	63.94	4.61	63.67	4.62	62.34	4.66
Ducted Indoor Units 48 (80%)	-4	-4.4	26.45	2.91	24.64	3.02	24.41	3.06	24.10	3.08	23.86	3.09	22.81	3.21
	0	-0.4	29.96	2.99	28.26	3.10	27.78	3.15	27.37	3.18	27.05	3.20	25.91	3.31
	5	4.5	34.14	3.08	32.56	3.20	31.77	3.26	31.26	3.30	30.84	3.33	29.60	3.44
	10	9	36.93	3.17	35.44	3.28	34.45	3.36	33.86	3.41	33.38	3.45	32.07	3.56
	17	15	40.00	3.29	38.61	3.40	37.39	3.50	36.72	3.56	36.18	3.61	34.79	3.71
	20	19	41.87	3.37	40.53	3.47	39.18	3.59	38.45	3.66	37.87	3.71	36.43	3.81
	25	23	44.99	3.51	43.66	3.61	42.14	3.75	41.34	3.83	40.70	3.89	39.17	3.99
	30	28	48.15	3.67	46.66	3.79	45.06	3.91	44.23	3.99	43.57	4.06	41.97	4.16
	35	32	51.31	3.82	49.68	3.96	47.98	4.06	47.12	4.16	46.43	4.23	44.75	4.34
	40	36	53.92	3.94	52.41	4.07	50.74	4.19	49.86	4.27	49.16	4.35	47.37	4.46
	45	41	57.19	4.08	55.83	4.21	54.18	4.34	53.28	4.42	52.56	4.48	50.65	4.62
	47	43	58.50	4.13	57.19	4.27	55.56	4.40	54.65	4.48	53.92	4.54	51.96	4.68
	50	46	58.67	4.10	57.49	4.23	56.06	4.35	55.25	4.42	54.60	4.47	52.76	4.59
	55	51	58.96	4.06	57.98	4.16	56.91	4.26	56.26	4.31	55.73	4.35	54.08	4.44
	60	56	59.24	4.02	58.47	4.10	57.75	4.17	57.26	4.20	56.86	4.23	55.41	4.29
	63	59	59.42	3.99	58.77	4.06	58.26	4.12	57.86	4.14	57.54	4.15	56.21	4.20
	68	64	59.59	3.97	59.06	4.02	58.77	4.06	58.47	4.08	58.23	4.08	57.01	4.12

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and 60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 422: LMU600HV Heating Capacity Table — Ducted Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 42 (70%)	-4	-4.4	23.38	2.52	21.78	2.63	21.57	2.65	21.30	2.67	21.09	2.68	20.16	2.78
	0	-0.4	26.48	2.59	24.98	2.69	24.55	2.73	24.19	2.76	23.91	2.78	22.90	2.88
	5	4.5	30.17	2.68	28.78	2.77	28.08	2.83	27.62	2.86	27.26	2.89	26.16	2.99
	10	9	32.64	2.75	31.33	2.85	30.45	2.92	29.92	2.96	29.50	2.99	28.34	3.09
	17	15	35.36	2.86	34.13	2.95	33.05	3.04	32.45	3.09	31.97	3.13	30.74	3.22
	20	19	37.00	2.93	35.82	3.02	34.63	3.12	33.98	3.18	33.47	3.22	32.20	3.31
	25	23	39.76	3.05	38.58	3.14	37.24	3.26	36.54	3.32	35.97	3.37	34.62	3.46
	30	28	42.56	3.18	41.24	3.29	39.82	3.39	39.09	3.47	38.51	3.53	37.09	3.61
	35	32	45.35	3.32	43.90	3.44	42.41	3.53	41.65	3.61	41.04	3.68	39.55	3.76
	40	36	47.66	3.42	46.32	3.54	44.84	3.64	44.07	3.71	43.44	3.77	41.87	3.87
	45	41	50.55	3.54	49.34	3.66	47.89	3.77	47.09	3.84	46.45	3.89	44.77	4.01
	47	43	51.70	3.59	50.55	3.71	49.10	3.82	48.30	3.89	47.66	3.94	45.93	4.06
	50	46	51.85	3.56	50.81	3.67	49.55	3.78	48.83	3.83	48.26	3.88	46.63	3.98
	55	51	52.11	3.53	51.24	3.61	50.30	3.70	49.72	3.74	49.26	3.78	47.80	3.86
	60	56	52.36	3.49	51.68	3.56	51.04	3.62	50.61	3.65	50.26	3.67	48.97	3.73
	63	59	52.51	3.47	51.94	3.52	51.49	3.58	51.14	3.59	50.86	3.61	49.67	3.65
	68	64	52.66	3.44	52.20	3.49	51.94	3.53	51.68	3.54	51.46	3.55	50.39	3.58
Ducted Indoor Units 36 (60%)	-4	-4.4	20.04	2.14	18.67	2.22	18.49	2.25	18.26	2.26	18.07	2.27	17.28	2.36
	0	-0.4	22.70	2.19	21.41	2.28	21.04	2.31	20.74	2.33	20.49	2.35	19.63	2.43
	5	4.5	25.86	2.26	24.67	2.35	24.07	2.39	23.68	2.42	23.37	2.44	22.42	2.53
	10	9	27.98	2.33	26.85	2.41	26.10	2.47	25.65	2.50	25.29	2.53	24.29	2.61
	17	15	30.30	2.42	29.25	2.49	28.33	2.57	27.82	2.61	27.41	2.65	26.35	2.73
	20	19	31.72	2.47	30.70	2.55	29.68	2.64	29.13	2.69	28.69	2.73	27.60	2.80
	25	23	34.08	2.58	33.07	2.65	31.92	2.75	31.32	2.81	30.84	2.85	29.67	2.93
	30	28	36.48	2.69	35.35	2.78	34.13	2.87	33.51	2.93	33.01	2.98	31.79	3.06
	35	32	38.87	2.81	37.63	2.91	36.35	2.98	35.70	3.05	35.17	3.11	33.90	3.18
	40	36	40.85	2.89	39.70	2.99	38.44	3.07	37.77	3.14	37.24	3.19	35.89	3.28
	45	41	43.33	2.99	42.29	3.09	41.04	3.19	40.36	3.25	39.82	3.29	38.37	3.39
	47	43	44.32	3.03	43.33	3.13	42.09	3.23	41.40	3.29	40.85	3.33	39.36	3.43
	50	46	44.45	3.01	43.55	3.10	42.47	3.19	41.86	3.24	41.36	3.28	39.97	3.37
	55	51	44.66	2.98	43.92	3.06	43.11	3.13	42.62	3.16	42.22	3.19	40.97	3.26
	60	56	44.88	2.95	44.30	3.01	43.75	3.06	43.38	3.09	43.08	3.10	41.98	3.15
	63	59	45.01	2.93	44.52	2.98	44.13	3.02	43.83	3.04	43.59	3.05	42.58	3.09
	68	64	45.14	2.91	44.74	2.95	44.52	2.98	44.29	2.99	44.11	3.00	43.19	3.02
Ducted Indoor Units 30 (50%)	-4	-4.4	16.70	1.75	15.56	1.82	15.41	1.84	15.22	1.85	15.06	1.86	14.40	1.93
	0	-0.4	18.92	1.80	17.84	1.87	17.53	1.90	17.28	1.91	17.08	1.93	16.36	2.00
	5	4.5	21.55	1.86	20.56	1.93	20.06	1.97	19.73	1.99	19.47	2.01	18.69	2.07
	10	9	23.31	1.91	22.38	1.98	21.75	2.03	21.37	2.05	21.07	2.08	20.25	2.14
	17	15	25.25	1.98	24.38	2.05	23.61	2.11	23.18	2.15	22.84	2.17	21.96	2.24
	20	19	26.43	2.03	25.59	2.09	24.73	2.17	24.27	2.21	23.91	2.24	23.00	2.30
	25	23	28.40	2.12	27.56	2.18	26.60	2.26	26.10	2.31	25.70	2.34	24.73	2.40
	30	28	30.40	2.21	29.46	2.28	28.45	2.35	27.92	2.41	27.51	2.45	26.49	2.51
	35	32	32.39	2.30	31.36	2.39	30.29	2.45	29.75	2.51	29.31	2.55	28.25	2.61
	40	36	34.04	2.37	33.08	2.45	32.03	2.52	31.48	2.58	31.03	2.62	29.91	2.69
	45	41	36.10	2.46	35.24	2.54	34.20	2.62	33.64	2.66	33.18	2.70	31.98	2.78
	47	43	36.93	2.49	36.10	2.57	35.07	2.65	34.50	2.70	34.04	2.74	32.80	2.82
	50	46	37.04	2.47	36.29	2.55	35.39	2.62	34.88	2.66	34.47	2.69	33.31	2.77
	55	51	37.22	2.45	36.60	2.51	35.93	2.57	35.51	2.60	35.18	2.62	34.14	2.68
	60	56	37.40	2.42	36.91	2.47	36.46	2.51	36.15	2.53	35.90	2.55	34.98	2.59
	63	59	37.51	2.41	37.10	2.44	36.78	2.48	36.53	2.49	36.33	2.50	35.48	2.53
	68	64	37.62	2.39	37.29	2.42	37.10	2.45	36.91	2.46	36.76	2.46	35.99	2.48

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU600HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 423: LMU600HV Heating Capacity Table — Ducted, continued, Mixed Indoor Units.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Ducted Indoor Units 24 (40%)	-4	-4.4	13.36	1.37	12.45	1.42	12.33	1.44	12.17	1.45	12.05	1.46	11.52	1.51
	0	-0.4	15.13	1.41	14.27	1.46	14.03	1.48	13.82	1.50	13.66	1.51	13.09	1.56
	5	4.5	17.24	1.45	16.45	1.50	16.05	1.54	15.79	1.55	15.58	1.57	14.95	1.62
	10	9	18.65	1.49	17.90	1.55	17.40	1.58	17.10	1.61	16.86	1.62	16.20	1.67
	17	15	20.20	1.55	19.50	1.60	18.89	1.65	18.54	1.68	18.27	1.70	17.57	1.75
	20	19	21.14	1.59	20.47	1.64	19.79	1.69	19.42	1.72	19.13	1.75	18.40	1.80
	25	23	22.72	1.65	22.05	1.70	21.28	1.77	20.88	1.80	20.56	1.83	19.78	1.88
	30	28	24.32	1.73	23.57	1.78	22.76	1.84	22.34	1.88	22.00	1.91	21.20	1.96
	35	32	25.91	1.80	25.09	1.87	24.23	1.91	23.80	1.96	23.45	1.99	22.60	2.04
	40	36	27.23	1.85	26.47	1.92	25.62	1.97	25.18	2.01	24.83	2.05	23.93	2.10
	45	41	28.88	1.92	28.19	1.98	27.36	2.05	26.91	2.08	26.55	2.11	25.58	2.17
	47	43	29.54	1.95	28.88	2.01	28.06	2.07	27.60	2.11	27.23	2.14	26.24	2.20
	50	46	29.63	1.93	29.03	1.99	28.31	2.05	27.90	2.08	27.58	2.10	26.64	2.16
	55	51	29.78	1.91	29.28	1.96	28.74	2.01	28.41	2.03	28.15	2.05	27.31	2.09
	60	56	29.92	1.89	29.53	1.93	29.17	1.96	28.92	1.98	28.72	1.99	27.98	2.02
	63	59	30.01	1.88	29.68	1.91	29.42	1.94	29.22	1.95	29.06	1.96	28.39	1.98
	68	64	30.09	1.87	29.83	1.89	29.68	1.91	29.53	1.92	29.41	1.92	28.79	1.94
Mixed Indoor Units 81 (135%)	-4	-4.4	29.72	3.98	27.63	4.14	27.41	4.18	27.07	4.21	26.80	4.23	25.62	4.39
	0	-0.4	34.36	4.07	32.38	4.22	31.84	4.29	31.38	4.33	31.02	4.35	29.71	4.51
	5	4.5	39.87	4.18	38.02	4.33	37.11	4.42	36.50	4.47	36.02	4.51	34.57	4.66
	10	9	43.56	4.28	41.80	4.43	40.63	4.54	39.93	4.60	39.37	4.65	37.83	4.80
	17	15	47.62	4.41	45.96	4.56	44.51	4.70	43.71	4.77	43.06	4.84	41.41	4.98
	20	19	50.08	4.51	48.48	4.64	46.86	4.80	45.99	4.89	45.30	4.96	43.58	5.10
	25	23	54.20	4.67	52.59	4.80	50.76	4.99	49.80	5.09	49.04	5.17	47.19	5.30
	30	28	58.37	4.85	56.56	5.01	54.62	5.17	53.61	5.28	52.81	5.37	50.87	5.51
	35	32	62.53	5.04	60.54	5.22	58.48	5.35	57.43	5.48	56.58	5.58	54.54	5.71
	40	36	65.71	5.18	63.87	5.36	61.83	5.51	60.76	5.63	59.90	5.72	57.73	5.87
	45	41	69.70	5.37	68.03	5.55	66.03	5.72	64.93	5.82	64.05	5.91	61.73	6.08
	47	43	71.29	5.44	69.70	5.62	67.71	5.80	66.60	5.90	65.71	5.98	63.33	6.16
	50	46	71.50	5.41	70.06	5.57	68.32	5.73	67.33	5.82	66.54	5.88	64.29	6.04
	55	51	71.85	5.35	70.66	5.48	69.35	5.61	68.56	5.67	67.92	5.73	65.91	5.85
	60	56	72.20	5.29	71.26	5.39	70.38	5.49	69.78	5.53	69.30	5.57	67.53	5.65
	63	59	72.41	5.26	71.62	5.34	71.00	5.42	70.51	5.45	70.12	5.47	68.50	5.54
	68	64	72.62	5.22	71.98	5.29	71.62	5.35	71.26	5.37	70.96	5.38	69.48	5.42
Mixed Indoor Units 78 (130%)	-4	-4.4	29.56	3.94	27.47	4.09	27.25	4.14	26.92	4.17	26.66	4.19	25.48	4.34
	0	-0.4	34.17	4.03	32.20	4.18	31.66	4.25	31.21	4.28	30.84	4.31	29.54	4.46
	5	4.5	39.65	4.14	37.81	4.28	36.90	4.37	36.30	4.42	35.82	4.46	34.38	4.61
	10	9	43.32	4.24	41.57	4.38	40.41	4.49	39.71	4.55	39.16	4.60	37.62	4.75
	17	15	47.35	4.37	45.71	4.51	44.26	4.65	43.46	4.73	42.82	4.79	41.18	4.93
	20	19	49.80	4.46	48.21	4.60	46.60	4.75	45.74	4.84	45.05	4.91	43.33	5.05
	25	23	53.90	4.62	52.30	4.76	50.48	4.93	49.53	5.03	48.76	5.11	46.93	5.25
	30	28	58.04	4.80	56.25	4.96	54.31	5.11	53.32	5.23	52.52	5.32	50.59	5.45
	35	32	62.18	4.98	60.20	5.16	58.15	5.30	57.11	5.42	56.27	5.52	54.24	5.65
	40	36	65.35	5.13	63.51	5.31	61.49	5.46	60.42	5.57	59.57	5.66	57.41	5.81
	45	41	69.31	5.31	67.65	5.49	65.66	5.66	64.57	5.76	63.70	5.85	61.38	6.02
	47	43	70.89	5.39	69.31	5.56	67.33	5.74	66.23	5.84	65.35	5.92	62.97	6.10
	50	46	71.10	5.35	69.67	5.51	67.94	5.67	66.96	5.76	66.17	5.82	63.94	5.98
	55	51	71.45	5.29	70.27	5.43	68.97	5.55	68.18	5.62	67.54	5.67	65.54	5.79
	60	56	71.80	5.24	70.86	5.34	69.99	5.44	69.39	5.48	68.91	5.51	67.15	5.60
	63	59	72.01	5.20	71.22	5.29	70.61	5.37	70.12	5.39	69.74	5.42	68.11	5.48
	68	64	72.21	5.17	71.58	5.24	71.22	5.30	70.86	5.31	70.57	5.32	69.09	5.37

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 424: LMU600HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 72 (120%)	-4	-4.4	29.23	3.86	27.17	4.02	26.95	4.06	26.62	4.09	26.36	4.11	25.19	4.26
	0	-0.4	33.79	3.95	31.84	4.10	31.31	4.17	30.86	4.20	30.50	4.23	29.21	4.38
	5	4.5	39.21	4.06	37.39	4.20	36.49	4.29	35.90	4.34	35.42	4.38	33.99	4.53
	10	9	42.83	4.16	41.11	4.30	39.95	4.41	39.27	4.47	38.72	4.52	37.20	4.66
	17	15	46.82	4.29	45.19	4.42	43.77	4.56	42.98	4.64	42.34	4.70	40.72	4.84
	20	19	49.24	4.38	47.67	4.51	46.08	4.66	45.23	4.75	44.54	4.82	42.85	4.95
	25	23	53.30	4.53	51.72	4.67	49.92	4.84	48.97	4.94	48.22	5.02	46.40	5.15
	30	28	57.39	4.71	55.62	4.87	53.71	5.02	52.72	5.13	51.93	5.22	50.02	5.35
	35	32	61.49	4.89	59.53	5.07	57.50	5.20	56.47	5.32	55.64	5.41	53.63	5.55
	40	36	64.62	5.03	62.80	5.21	60.80	5.36	59.75	5.47	58.91	5.56	56.77	5.70
	45	41	68.54	5.21	66.90	5.39	64.93	5.55	63.85	5.66	62.99	5.74	60.70	5.90
	47	43	70.10	5.28	68.54	5.46	66.58	5.63	65.49	5.73	64.62	5.81	62.27	5.98
	50	46	70.31	5.25	68.89	5.41	67.19	5.56	66.21	5.65	65.43	5.72	63.22	5.87
	55	51	70.65	5.19	69.48	5.32	68.20	5.45	67.41	5.51	66.79	5.56	64.81	5.68
	60	56	70.99	5.14	70.07	5.24	69.21	5.33	68.62	5.37	68.14	5.41	66.40	5.49
	63	59	71.20	5.11	70.42	5.19	69.82	5.27	69.34	5.29	68.96	5.31	67.35	5.38
	68	64	71.41	5.07	70.78	5.14	70.43	5.20	70.07	5.21	69.78	5.22	68.32	5.27
Mixed Indoor Units 66 (110%)	-4	-4.4	28.89	3.78	26.86	3.93	26.64	3.98	26.32	4.00	26.06	4.02	24.90	4.17
	0	-0.4	33.40	3.87	31.47	4.02	30.95	4.08	30.51	4.11	30.15	4.14	28.88	4.29
	5	4.5	38.76	3.97	36.96	4.12	36.07	4.20	35.48	4.25	35.02	4.29	33.61	4.43
	10	9	42.34	4.07	40.64	4.21	39.50	4.31	38.82	4.37	38.28	4.42	36.77	4.56
	17	15	46.29	4.20	44.68	4.33	43.27	4.47	42.49	4.54	41.86	4.60	40.25	4.73
	20	19	48.68	4.28	47.13	4.41	45.55	4.57	44.71	4.65	44.03	4.72	42.36	4.85
	25	23	52.69	4.44	51.12	4.57	49.35	4.74	48.41	4.84	47.67	4.91	45.87	5.04
	30	28	56.74	4.61	54.98	4.77	53.09	4.91	52.12	5.02	51.34	5.11	49.45	5.24
	35	32	60.78	4.79	58.85	4.96	56.84	5.09	55.82	5.21	55.00	5.30	53.02	5.43
	40	36	63.88	4.93	62.08	5.10	60.11	5.24	59.06	5.35	58.23	5.44	56.12	5.58
	45	41	67.75	5.10	66.13	5.27	64.18	5.44	63.12	5.54	62.27	5.62	60.00	5.78
	47	43	69.30	5.17	67.75	5.34	65.82	5.51	64.74	5.61	63.88	5.69	61.56	5.86
	50	46	69.50	5.14	68.10	5.29	66.42	5.45	65.45	5.53	64.68	5.60	62.50	5.75
	55	51	69.84	5.09	68.68	5.21	67.42	5.34	66.64	5.40	66.02	5.44	64.07	5.56
	60	56	70.18	5.03	69.27	5.13	68.42	5.22	67.83	5.26	67.36	5.29	65.64	5.38
	63	59	70.39	5.00	69.62	5.08	69.02	5.16	68.54	5.18	68.17	5.20	66.58	5.27
	68	64	70.59	4.97	69.97	5.03	69.62	5.09	69.27	5.10	68.98	5.11	67.54	5.16
Mixed Indoor Units 60 (100%)	-4	-4.4	28.56	3.71	26.55	3.86	26.34	3.90	26.02	3.92	25.76	3.94	24.62	4.09
	0	-0.4	33.02	3.79	31.11	3.94	30.60	4.00	30.16	4.03	29.81	4.06	28.55	4.20
	5	4.5	38.31	3.89	36.54	4.04	35.66	4.12	35.08	4.17	34.62	4.20	33.22	4.34
	10	9	41.86	3.99	40.17	4.13	39.05	4.23	38.37	4.29	37.84	4.33	36.35	4.47
	17	15	45.76	4.12	44.17	4.25	42.77	4.38	42.00	4.45	41.38	4.51	39.79	4.64
	20	19	48.12	4.20	46.59	4.33	45.03	4.48	44.20	4.56	43.53	4.63	41.87	4.75
	25	23	52.08	4.35	50.54	4.48	48.78	4.65	47.86	4.74	47.12	4.82	45.35	4.94
	30	28	56.09	4.52	54.35	4.67	52.48	4.82	51.52	4.92	50.75	5.01	48.89	5.13
	35	32	60.09	4.69	58.17	4.86	56.19	4.99	55.18	5.10	54.38	5.20	52.41	5.32
	40	36	63.15	4.83	61.38	5.00	59.42	5.14	58.39	5.25	57.57	5.33	55.48	5.48
	45	41	66.98	5.00	65.38	5.17	63.45	5.33	62.40	5.43	61.55	5.51	59.32	5.67
	47	43	68.51	5.07	66.98	5.24	65.06	5.41	64.00	5.50	63.15	5.57	60.85	5.74
	50	46	68.71	5.04	67.32	5.19	65.66	5.34	64.71	5.42	63.94	5.49	61.78	5.63
	55	51	69.04	4.99	67.90	5.11	66.65	5.23	65.88	5.29	65.27	5.34	63.34	5.45
	60	56	69.38	4.93	68.48	5.03	67.63	5.12	67.06	5.16	66.59	5.19	64.89	5.27
	63	59	69.58	4.90	68.82	4.98	68.23	5.05	67.76	5.08	67.39	5.10	65.82	5.16
	68	64	69.78	4.87	69.17	4.93	68.83	4.99	68.47	5.00	68.19	5.01	66.77	5.06

TC = Total Capacity (kBtu/h).
PI = Power Input (kW).
Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.
0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

MULTI F MAX LMU600HV

Heating Capacity Tables

MULTI F
MULTI F MAX

Table 425: LMU600HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 54 (90%)	-4	-4.4	26.67	3.32	24.79	3.45	24.59	3.49	24.29	3.51	24.05	3.53	22.99	3.66
	0	-0.4	30.83	3.39	29.05	3.52	28.57	3.58	28.16	3.61	27.83	3.63	26.66	3.76
	5	4.5	35.77	3.48	34.12	3.61	33.29	3.68	32.75	3.73	32.32	3.76	31.02	3.89
	10	9	39.09	3.57	37.51	3.69	36.46	3.78	35.83	3.84	35.33	3.88	33.94	4.00
	17	15	42.73	3.68	41.24	3.80	39.94	3.92	39.22	3.98	38.64	4.03	37.15	4.15
	20	19	44.93	3.76	43.50	3.87	42.05	4.00	41.27	4.08	40.64	4.14	39.10	4.25
	25	23	48.63	3.89	47.19	4.01	45.55	4.16	44.69	4.24	44.00	4.31	42.34	4.42
	30	28	52.37	4.05	50.75	4.18	49.01	4.31	48.11	4.40	47.39	4.48	45.65	4.59
	35	32	56.11	4.20	54.32	4.35	52.47	4.46	51.53	4.57	50.77	4.65	48.94	4.76
	40	36	58.97	4.32	57.31	4.47	55.48	4.60	54.52	4.69	53.75	4.77	51.80	4.90
	45	41	62.54	4.48	61.05	4.63	59.25	4.77	58.26	4.86	57.48	4.93	55.39	5.07
	47	43	63.97	4.54	62.54	4.69	60.75	4.84	59.76	4.92	58.97	4.99	56.82	5.14
	50	46	64.16	4.51	62.86	4.64	61.31	4.78	60.42	4.85	59.71	4.91	57.69	5.04
	55	51	64.47	4.46	63.40	4.57	62.23	4.68	61.52	4.73	60.94	4.77	59.14	4.88
	60	56	64.78	4.41	63.94	4.50	63.15	4.58	62.61	4.61	62.18	4.64	60.59	4.71
	63	59	64.97	4.38	64.26	4.45	63.71	4.52	63.27	4.54	62.92	4.56	61.46	4.62
	68	64	65.16	4.36	64.59	4.41	64.27	4.46	63.94	4.48	63.67	4.48	62.34	4.52
Mixed Indoor Units 48 (80%)	-4	-4.4	24.39	2.93	22.67	3.05	22.49	3.08	22.21	3.10	21.99	3.12	21.02	3.24
	0	-0.4	28.20	3.00	26.57	3.11	26.13	3.16	25.75	3.19	25.45	3.21	24.38	3.33
	5	4.5	32.72	3.08	31.20	3.19	30.45	3.26	29.95	3.29	29.56	3.32	28.37	3.44
	10	9	35.74	3.16	34.30	3.26	33.34	3.35	32.77	3.39	32.31	3.43	31.04	3.54
	17	15	39.07	3.26	37.71	3.36	36.52	3.46	35.86	3.52	35.34	3.57	33.98	3.67
	20	19	41.09	3.32	39.78	3.42	38.45	3.54	37.74	3.61	37.17	3.66	35.76	3.76
	25	23	44.47	3.44	43.16	3.54	41.66	3.68	40.87	3.75	40.24	3.81	38.72	3.91
	30	28	47.89	3.58	46.41	3.70	44.82	3.81	43.99	3.89	43.34	3.96	41.74	4.06
	35	32	51.31	3.71	49.68	3.85	47.98	3.94	47.12	4.04	46.43	4.11	44.75	4.21
	40	36	53.92	3.82	52.41	3.95	50.74	4.07	49.86	4.15	49.16	4.22	47.37	4.33
	45	41	57.19	3.96	55.83	4.09	54.18	4.22	53.28	4.29	52.56	4.35	50.65	4.48
	47	43	58.50	4.01	57.19	4.14	55.56	4.28	54.65	4.35	53.92	4.41	51.96	4.54
	50	46	58.67	3.99	57.49	4.11	56.06	4.22	55.25	4.29	54.60	4.34	52.76	4.46
	55	51	58.96	3.94	57.98	4.04	56.91	4.14	56.26	4.18	55.73	4.22	54.08	4.31
	60	56	59.24	3.90	58.47	3.98	57.75	4.05	57.26	4.08	56.86	4.10	55.41	4.17
	63	59	59.42	3.88	58.77	3.94	58.26	4.00	57.86	4.02	57.54	4.03	56.21	4.08
	68	64	59.59	3.85	59.06	3.90	58.77	3.95	58.47	3.96	58.23	3.97	57.01	4.00
Mixed Indoor Units 42 (70%)	-4	-4.4	21.56	2.54	20.04	2.64	19.88	2.67	19.63	2.69	19.44	2.70	18.58	2.80
	0	-0.4	24.92	2.60	23.48	2.70	23.09	2.74	22.76	2.76	22.49	2.78	21.55	2.88
	5	4.5	28.91	2.67	27.57	2.77	26.91	2.82	26.47	2.86	26.12	2.88	25.07	2.98
	10	9	31.59	2.73	30.32	2.83	29.47	2.90	28.96	2.94	28.56	2.97	27.43	3.06
	17	15	34.53	2.82	33.33	2.91	32.28	3.00	31.70	3.05	31.23	3.09	30.03	3.18
	20	19	36.32	2.88	35.16	2.97	33.99	3.07	33.36	3.13	32.85	3.17	31.60	3.26
	25	23	39.31	2.98	38.14	3.07	36.82	3.19	36.12	3.25	35.56	3.30	34.22	3.39
	30	28	42.33	3.10	41.02	3.20	39.61	3.30	38.88	3.37	38.30	3.43	36.89	3.52
	35	32	45.35	3.22	43.90	3.33	42.41	3.42	41.65	3.50	41.04	3.56	39.55	3.65
	40	36	47.66	3.31	46.32	3.43	44.84	3.52	44.07	3.60	43.44	3.66	41.87	3.75
	45	41	50.55	3.43	49.34	3.54	47.89	3.65	47.09	3.72	46.45	3.77	44.77	3.88
	47	43	51.70	3.48	50.55	3.59	49.10	3.71	48.30	3.77	47.66	3.82	45.93	3.94
	50	46	51.85	3.45	50.81	3.56	49.55	3.66	48.83	3.72	48.26	3.76	46.63	3.86
	55	51	52.11	3.42	51.24	3.50	50.30	3.59	49.72	3.63	49.26	3.66	47.80	3.74
	60	56	52.36	3.38	51.68	3.45	51.04	3.51	50.61	3.54	50.26	3.56	48.97	3.61
	63	59	52.51	3.36	51.94	3.41	51.49	3.46	51.14	3.48	50.86	3.50	49.67	3.54
	68	64	52.66	3.34	52.20	3.38	51.94	3.42	51.68	3.43	51.46	3.44	50.39	3.47

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Table 426: LMU600HV Heating Capacity Table — Mixed Indoor Units, continued.

Combination Capacity Index (kBtu/h[%])	Outdoor Air Temp.		Indoor Air Temp. °F DB											
			61		64		68		70		72		75	
	°F DB	°F WB	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
Mixed Indoor Units 36 (60%)	-4	-4.4	18.48	2.16	17.17	2.24	17.04	2.27	16.83	2.28	16.66	2.29	15.93	2.38
	0	-0.4	21.36	2.21	20.13	2.29	19.79	2.33	19.51	2.35	19.28	2.36	18.47	2.45
	5	4.5	24.78	2.27	23.64	2.35	23.07	2.40	22.69	2.42	22.39	2.45	21.49	2.53
	10	9	27.08	2.32	25.99	2.40	25.26	2.46	24.82	2.49	24.48	2.52	23.51	2.60
	17	15	29.60	2.39	28.57	2.47	27.67	2.55	27.17	2.59	26.77	2.62	25.74	2.70
	20	19	31.13	2.44	30.14	2.52	29.13	2.60	28.59	2.65	28.16	2.69	27.09	2.77
	25	23	33.69	2.53	32.69	2.61	31.56	2.70	30.96	2.76	30.48	2.80	29.33	2.88
	30	28	36.28	2.63	35.16	2.72	33.95	2.80	33.33	2.86	32.83	2.91	31.62	2.99
	35	32	38.87	2.73	37.63	2.83	36.35	2.90	35.70	2.97	35.17	3.02	33.90	3.10
	40	36	40.85	2.81	39.70	2.91	38.44	2.99	37.77	3.05	37.24	3.10	35.89	3.19
	45	41	43.33	2.91	42.29	3.01	41.04	3.10	40.36	3.16	39.82	3.20	38.37	3.30
	47	43	44.32	2.95	43.33	3.05	42.09	3.15	41.40	3.20	40.85	3.24	39.36	3.34
	50	46	44.45	2.93	43.55	3.02	42.47	3.11	41.86	3.15	41.36	3.19	39.97	3.28
	55	51	44.66	2.90	43.92	2.97	43.11	3.04	42.62	3.08	42.22	3.11	40.97	3.17
	60	56	44.88	2.87	44.30	2.93	43.75	2.98	43.38	3.00	43.08	3.02	41.98	3.07
	63	59	45.01	2.85	44.52	2.90	44.13	2.94	43.83	2.96	43.59	2.97	42.58	3.00
	68	64	45.14	2.83	44.74	2.87	44.52	2.90	44.29	2.91	44.11	2.92	43.19	2.94
Mixed Indoor Units 30 (50%)	-4	-4.4	15.40	1.77	14.31	1.84	14.20	1.86	14.02	1.87	13.88	1.88	13.27	1.95
	0	-0.4	17.80	1.81	16.77	1.88	16.49	1.90	16.26	1.92	16.07	1.93	15.39	2.00
	5	4.5	20.65	1.86	19.70	1.92	19.22	1.96	18.91	1.98	18.66	2.00	17.91	2.07
	10	9	22.56	1.90	21.65	1.97	21.05	2.02	20.69	2.04	20.40	2.06	19.59	2.13
	17	15	24.67	1.96	23.81	2.02	23.06	2.09	22.64	2.12	22.31	2.15	21.45	2.21
	20	19	25.94	2.00	25.11	2.06	24.28	2.13	23.83	2.17	23.46	2.20	22.57	2.26
	25	23	28.08	2.07	27.24	2.13	26.30	2.21	25.80	2.26	25.40	2.29	24.45	2.35
	30	28	30.23	2.15	29.30	2.23	28.29	2.29	27.77	2.35	27.36	2.39	26.35	2.45
	35	32	32.39	2.24	31.36	2.32	30.29	2.38	29.75	2.43	29.31	2.48	28.25	2.54
	40	36	34.04	2.30	33.08	2.38	32.03	2.45	31.48	2.50	31.03	2.54	29.91	2.61
	45	41	36.10	2.38	35.24	2.46	34.20	2.54	33.64	2.59	33.18	2.62	31.98	2.70
	47	43	36.93	2.42	36.10	2.50	35.07	2.58	34.50	2.62	34.04	2.66	32.80	2.74
	50	46	37.04	2.40	36.29	2.47	35.39	2.54	34.88	2.58	34.47	2.61	33.31	2.68
	55	51	37.22	2.38	36.60	2.43	35.93	2.49	35.51	2.52	35.18	2.54	34.14	2.60
	60	56	37.40	2.35	36.91	2.40	36.46	2.44	36.15	2.46	35.90	2.47	34.98	2.51
	63	59	37.51	2.33	37.10	2.37	36.78	2.41	36.53	2.42	36.33	2.43	35.48	2.46
	68	64	37.62	2.32	37.29	2.35	37.10	2.38	36.91	2.38	36.76	2.39	35.99	2.41
Mixed Indoor Units 24 (40%)	-4	-4.4	12.32	1.38	11.45	1.44	11.36	1.45	11.22	1.46	11.11	1.47	10.62	1.52
	0	-0.4	14.24	1.41	13.42	1.47	13.19	1.49	13.01	1.50	12.85	1.51	12.31	1.57
	5	4.5	16.52	1.45	15.76	1.50	15.38	1.54	15.13	1.55	14.93	1.57	14.33	1.62
	10	9	18.05	1.49	17.32	1.54	16.84	1.58	16.55	1.60	16.32	1.62	15.68	1.67
	17	15	19.73	1.53	19.05	1.58	18.45	1.63	18.11	1.66	17.85	1.68	17.16	1.73
	20	19	20.75	1.57	20.09	1.61	19.42	1.67	19.06	1.70	18.77	1.72	18.06	1.77
	25	23	22.46	1.62	21.80	1.67	21.04	1.73	20.64	1.77	20.32	1.80	19.56	1.84
	30	28	24.19	1.69	23.44	1.74	22.63	1.80	22.22	1.83	21.89	1.87	21.08	1.91
	35	32	25.91	1.75	25.09	1.81	24.23	1.86	23.80	1.90	23.45	1.94	22.60	1.98
	40	36	27.23	1.80	26.47	1.86	25.62	1.92	25.18	1.96	24.83	1.99	23.93	2.04
	45	41	28.88	1.86	28.19	1.93	27.36	1.99	26.91	2.02	26.55	2.05	25.58	2.11
	47	43	29.54	1.89	28.88	1.95	28.06	2.02	27.60	2.05	27.23	2.08	26.24	2.14
	50	46	29.63	1.88	29.03	1.93	28.31	1.99	27.90	2.02	27.58	2.04	26.64	2.10
	55	51	29.78	1.86	29.28	1.90	28.74	1.95	28.41	1.97	28.15	1.99	27.31	2.03
	60	56	29.92	1.84	29.53	1.87	29.17	1.91	28.92	1.92	28.72	1.93	27.98	1.96
	63	59	30.01	1.83	29.68	1.86	29.42	1.88	29.22	1.89	29.06	1.90	28.39	1.92
	68	64	30.09	1.81	29.83	1.84	29.68	1.86	29.53	1.86	29.41	1.87	28.79	1.88

TC = Total Capacity (kBtu/h).

PI = Power Input (kW).

Nominal Capacity as rated: 0 ft. above sea level with Piping Length as Main Pipe (16.4 ft.) + Branch
pipe (98.4 ft.) = 115 ft.

0 ft. level difference between outdoor and indoor units.

Nominal heating capacity rating obtained with air entering the indoor unit at 70°F dry bulb (DB) and
60°F wet bulb (WB), and outdoor ambient conditions of 47°F dry bulb (DB) and 43°F wet bulb (WB).

Inverter



LG Electronics, U.S.A., Inc.
Commercial Air Conditioning Division
4300 North Point Parkway
Alpharetta, Georgia 30022
www.lg-vrf.com

LG Electronics Products Support
1-888-865-3026 USA
Follow the prompts for HVAC products.

PD_MultiFODU_01_16
Supersedes: PD_MultiFODU_06_15