Date: For: File Resubmit Approval Other-PO No.: Architect: GC: Engr: Mech: Rep:

(Project Manager)



# **PMBD3640** Four-Port Branch Distribution Unit



#### Performance:

Job Name/Location:

Max. Nominal Port Capacity (Btu/h)	24,000
(each port)	
Max. Nominal Unit Capacity (Btu/h) (sum of ports)	73,000
Connected Indoor Unit Capacity (Btu/h)	7,000 ~ 24,000
Power Input (W)	32

### **Electrical:**

Power Supply (V¹/Hz/Ø)	208-230/60/1
Rated Amps (A)	0.16

### Piping:

### Piping Connections to Outdoor Unit:

Liquid Line (in., O.D.)	ø3/8
Vapor Line (in., O.D.)	ø3/4

## Piping Connections to Indoor Unit:

Liquid Line (in., O.D.)	Ø1/4 x 4
Vapor Line (in., O.D.)	Ø3/8 x 4

### Features:

- Distributes refrigerant to indoor units
- Internal components are insulated
- Flare joints provided for easy installation
- Compact design

## **Operating Range:**

Temperature Range (°F DB)	0 ~ 150
Maximum Humidity	80%

#### **Unit Data:**

Net Weight (lbs.)	15.7
Shipping Weight (lbs.)	18

#### Notes:

- Acceptable operating voltage: 187V-253V.
   All communication / power (connection) cable must be a minimum of 14 AWG, 4-conductor from the outdoor unit to the branch distribution unit; 14 AWG, 4-conductor from the branch distribution unit to the indoor unit; stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoor indoor unit; stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoo unit only); and must comply with applicable local and national codes.

  3. Piping lengths:

  • Maximum height difference between branch distribution unit and indoor units - 32.8 feet.

  • Maximum height difference between branch distribution unit and branch distribution unit - 49.2 feet.

  • Maximum piping length between branch distribution unit and indoor units - 49.2 feet.

  • Maximum piping length between branch distribution unit and indoor units - 49.2 feet.

  • The branch distribution unit should be installed inside of a building.

  5. Must follow installation instructions in the applicable LG installation manual.

  6. Power wiring cable size must comply with the applicable local and national codes.

Tag No:



Job Name/Location:

# **PMBD3640**

## Four-Port Branch Distribution Unit



