Job Name/Location: Tag No.:

Date:For:FileResubmitPO No.:ApprovalOther______

Architect: GC:
Engr: Mech:

Rep:

(Company) (Project Manager)

ARUM264DTE5

(a) ARUM096DTE5

Multi V™ 5 with LGRED° 460V ODU

(b) ARUM168DTE5

22 Ton Dual Frame Heat Pump and Heat Recovery

Performance:

Cooling Mode:

Nominal Capacity (Btu/h)	264,000
Power Input¹ (kW)	17.56

Heating Mode:

Nominal Capacity (Btu/h)	297,000
Power Input¹ (kW)	20.72

Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change without notice. Current certified ratings are available at www.ahridirectory.org.

Electrical:

Frame	(a) ARUM096DTE5	(b) ARUM168DTE5
Power Supply (V/Hz/Ø)¹	460/60/3	460/60/3
MOP (A)	25	35
MCA (A)	16.4	28.5
Rated Amps (A)	14.1	25.6
Compressor A (A)	9.1	11.4
Compressor B (B)	-	9.2
Fan (A)	5.0	5.0

Piping:2

1		
Frame	(a) ARUM096DTE5	(b) ARUM168DTE5
Refrigerant Charge (lbs.)	23.2	26.5
Liquid (in., O.D.) High Pressure Vapor	3/8 Braze	5/8 Braze
(Heat Recovery only; in, O.D.)	3/4 Braze	7/8 Braze
Low Pressure Vapor (in., O.D.)	7/8 Braze	1-1/8 Braze

Standard Features:

- Advanced Smart Load Control
- Intelligent Heating
- HiPOR (High Pressure Oil Return)
- Smart Oil Control
- Night Quiet Operation
- Fault Detection and Diagnosis
- Active Refrigerant Control
- Variable Heat Path Exchanger
- Subcooling and Vapor Injection
 Control
- Liquid Cooled Inverter Controller
- Advanced Comfort Cooling

Required Accessories:

☐ ARCNB21 (Frame Connector Y-branch, 3 pipe heat recovery)
☐ ARCNN21 (Frame Connector Y-branch, 2 pipe heat pump)

Optional Accessories:

- ☐ Air Guide ZAGDKA52A (2 required)
- ☐ Hail Guard Kit ZHGDKA52A (2 required)
- \square Low Ambient Baffle Kit ZLABKA52A (2), Control Kit -

PRVC2 (1 per system)

☐ Base Pan Heater - ZPLT2A52A

**Cooling operating range can be extended to -13°F if the optional low ambient baffle kit and low ambient control kit are installed. This is the range in which the unit can operate as continuous operation.







Operating Range:

Cooling (°F Heating (°F Synchronou	WB)	5 - 122 -22 - 61
Cooling E	Based (°F DB)	14 - 81
Heating	Based (°F WB)	14 - 61

Unit Data:

Refrigerant Type		R410A
Refrigerant Control		EEV
Max. Number of Indoor Units ³		42
Sound Pressure ⁴ dB(A)		63.0
Weight		03.0
Frame	(a) ARUM096DTE5	(b) ARUM168DTE5
Net (lbs.)	507	639
Shipping (lbs.)	534	666
Communication Cable (No x AWG)	5	2 x 18
Heat Exchanger Coating		Black Coated Fin™

Compressor:

Туре	HSS DC Scroll
Quantity	3
Oil / Type	PVE / FVC68D

Fan:

Туре	Propeller
Quantity (a) + (b)	4
Motor Drive	Brushless Digitally Controlled Direct
Air Flow Rate (a) + (b) (CFM)	22,600

Notes:

- Power wiring cable size must comply with the applicable local and national codes.
 Cables terminate at each frame.
- 2. For main pipe segment size, refer to the LATS Multi V tree diagram.
- 3. The combination ratio must be between 50-130%.
- 4. Sound pressure levels are tested in an anechoic chamber under ISO Standard 3745 for the combination of outdoor units.
- 5. Communication cable between ODU and IDUs must be 2-conductor, 18 AWG, twisted, stranded, and shielded. Ensure the communication cable shield is properly grounded to the Main ODU chassis only. Do not ground the communication cable at any other point. Wiring must comply with all applicable local and national codes.
- 6. Acceptable operating voltage: 414-528V
- 7. The order of these units on the submittal (i.e., a+b) does not represent the installation order. Highest capacity unit is used as the Main, followed by the smaller size as Sub 1.









ARUM264DTE5

Multi V™ 5 with LGRED° 460V ODU

(a) ARUM096DTE5 (b) ARUM168DTE5





Tag No.:

Date:


PO No.: _


22 Ton Dual Frame Heat Pump and Heat Recovery







Note: Please refer to multi-frame placement information and piping rules in the Multi V 5 Engineering Manual and the Multi V 5 Installation Manual. Minimum spacing between frames is 1 inch.







Airflow	D Airflow Airflow Airflow	W	Piping Routin Holes two -
	Allilow		
	Top View		



28-25/32"
5/8"
3-15/16"
40-15/16"
11 – 15/16"
11 – 1/16"
10 – 1/2"
8 – 7/16"
8 – 1/8"
6 – 1/16"
4 – 15/16"
7 – 1/2"
4 – 13/16"
4 – 5/16"
3 – 5/8"
3"

W	48-13/16"
Н	66-17/32"
D	29-29/32"
L1	6-5/16"
L2	3-3/4"
L3	5-29/32"
L4	5-13/32"
L5	2-25/32"
L6	24-9/32"
L7	2-25/32"
L8	4-1/32"
L9	6 – 1/2"
L10	5 – 9/16"
L11	8 – 5/8"
L12	6 – 7/16"
L13	9 – 15/16"
L14	3 – 5/8"

Center of Gravity

Χ	23-7/32"
Υ	15-5/8"
Z	25-9/16"

All dimensions have a tolerance of ± 0.25 in. [Unit: inch]




= Center of Gravity

Job Name/Location:		

ΑF	RUI	M26	54D	Γ	E5
	1	4704	• • •		005

Multi V™ 5 with LGRED° 460V ODU

22 Ton Dual Frame Heat Pump and Heat Recovery



AHRI Data:

Reference Number	Indoor Type	Cooling Capacity (95°F)	EER (95°F)	IEER	SCHE	High Heating Capacity (47°F)	High COP (47°F)	Low Heating Capacity (17°F)	Low COP (17°F)
205281479	Ducted Indoor Units	252,000	11.50	21.50	24.60	282,000	3.38	182,000	2.38
202524555	Non-Ducted Indoor Units	252,000	12.50	22.00	25.00	282,000	3.56	182,000	2.52