Job Name/Location: Tag No.: For: File Resubmit Date: Approval Other PO No.: GC: Architect: Mech: Engr: Rep: (Project Manager)

ARUM312BTE5 (a) ARUM096BTE5 Multi V<sup>™</sup> 5 with LGRED° 208-230V ODU (b) ARUM216BTE5

26 Ton Dual Frame Heat Pump and Heat Recovery







## Performance:

Cooling Mode:

Nominal Capacity (Btu/h)	312,000
Power Input¹ (kW)	20.70

## Heating Mode:

Nominal Capacity (Btu/h)	351,000
Power Input¹ (kW)	24.49

Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change without notice. Current certified ratings are available at www.ahridirectory.org.

#### **Electrical:**

Frame	(a) ARUM096BTE5	(b) ARUM216BTE5
Power Supply (V/Hz/Ø) <sup>1</sup>	208-230/60/3	208-230/60/3
MOP (A)	40	80
MCA (A)	28.5	60.3
Rated Amps (A)	24.4	54.2
Compressor A (A)	16.4	24.3
Compressor B (B)	-	21.9
Fan (A)	8.0	8.0

### Piping:2

(a) ARUM096BTE5	(b) ARUM216BTE5
23.2	37.5
3/8 Braze	5/8 Braze
3/4 Braze	1-1/8 Braze
7/8 Braze	1-1/8 Braze
	23.2 3/8 Braze 3/4 Braze

### **Standard Features:**

- Advanced Smart Load Control
- Intelligent Heating
- HiPOR (High Pressure Oil Return)
- Smart Oil Control
- Night Quiet Operation
- Fault Detection and Diagnosis
- Active Refrigerant Control
- Variable Heat Path Exchanger
- Subcooling and Vapor Injection Control
- Liquid Cooled Inverter Controller
- Advanced Comfort Cooling

## **Required Accessories:**

☐ ARCNB21 (Frame Connector Y-branch, 3 pipe heat recovery) ☐ ARCNN21 (Frame Connector Y-branch, 2 pipe heat pump)

## **Optional Accessories:**

- ☐ Air Guide ZAGDKA52A (2 required)
- ☐ Hail Guard Kit ZHGDKA52A (2 required)
- Low Ambient Baffle Kit ZLABKA52A (2), Control Kit -PRVC2 (1 per system)
- ☐ Base Pan Heater ZPLT1A52A
- \*\*Cooling range with the Low Ambient Baffle Kit (sold separately) is -9.9°F to +122°F and is achieved only when all indoor units are operating in cooling mode. Does not impact heat recovery system synchronous operating range.

# **Operating Range:**

Cooling (°F DB)**	5 - 122
Heating (°F WB)	-22 - 61
Synchronous	
Cooling Based (°F DB)	14 - 81
Heating Based (°F WB)	14 - 61

#### **Unit Data:**

Omit Patar		
Refrigerant Type		R410A
Refrigerant Control		EEV
Max. Number of Indoor Units <sup>3</sup>		52
Sound Pressure <sup>4</sup> dB(A)		65.0
Weight		33.3
Frame	(a) ARUM096BTE5	(b) ARUM216BTE5
Net (lbs.)	507	666
Shipping (lbs.)	534	694
Communication Cable (No x AWG)	5	2 x 18
Heat Exchanger Coating		Black Coated Fin™

#### Compressor:

Туре	HSS DC Scroll
Quantity	3
Oil / Type	PVE / FVC68D

#### Fan:

Туре	Propeller
Quantity (a) + (b)	4
Motor Drive	Brushless Digitally Controlled Direct
Air Flow Rate (a) + (b) (CFM)	22,600

## Notes:

- 1. Power wiring cable size must comply with the applicable local and national codes. Cables terminate at each frame.
- 2. For main pipe segment size, refer to the LATS Multi V tree diagram.
- 3. The combination ratio must be between 50-130%.
- 4. Sound pressure levels are tested in an anechoic chamber under ISO Standard 3745 for the combination of outdoor units.
- 5. Communication cable between ODU and IDUs must be 2-conductor, 18 AWG, twisted, stranded, and shielded. Ensure the communication cable shield is properly grounded to the Master ODU chassis only. Do not ground the communication cable at any other point. Wiring must comply with all applicable local and national codes.
- 6. Acceptable operating voltage: 187 253V
- 7. The order of these units on the submittal (i.e., a+b) does not represent the installation order. Highest capacity unit is used as the Master, followed by the smaller size as Slave 1.
- 8. Low ambient performance with LGRED° heat technology is included in Multi V 5 units produced after February 2019.







## ARUM312BTE5

Multi V™ 5 with LGRED° 208-230V ODU

26 Ton Dual Frame Heat Pump and Heat Recovery


## (a) ARUM096BTE5







Tag No.: Date:

PO No.:






Note: Please refer to multi-frame placement information and piping rules in the Multi V 5 Engineering Manual and the Multi V 5 Installation Manual. Minimum spacing between frames is 1 inch.



> Two (2) 7/8" Diameter Wire Routing Holes (Bottom) 19/32" Dameter Hole

> > (Pitch of foundation bolt holes)



Top View Rottom Mounting Holes	Airflow Airflow  Airflow	M5 M6 Power Cord Routing Hole (Bottom); two (2) - ø2"  Two (2) 7/8" Diame Routing Holes (Bot  19/32" Dameter Ho  Piping Routing Holes (Bottom); two - ø2-5/8," ø2-1/8" M3 M4
. Dottom wounting rioles	Top View	Bottom Mounting Holes

7/8" Diameter Leak Test Hole

Left Side View

M1	28-25/32"
M2	5/8"
М3	3-15/16"
M4	40-15/16"
M5	11 – 15/16"
M6	11 – 1/16"
M7	10 – 1/2"
M8	8 – 7/16"
M9	8 – 1/8"
M10	6 – 1/16"
M11	4 – 15/16"
M12	7 – 1/2"
M13	4 – 13/16"
M14	4 – 5/16"
M15	3 – 5/8"
M16	3"

W	48-13/16"
Н	66-17/32"
D	29-29/32"
L1	6-5/16"
L2	3-3/4"
L3	5-29/32"
L4	5-13/32"
L5	2-25/32"
L6	24-9/32"
L7	2-25/32"
L8	4-1/32"
L9	6 – 1/2"
L10	5 – 9/16"
L11	8 – 5/8"
L12	6 – 7/16"
L13	9 – 15/16"
L14	3 – 5/8"

## Center of Gravity

Χ	23-7/32"
Υ	15-5/8"
Z	25-9/16"

All dimensions have a tolerance of  $\pm$  0.25 in.



= Center of Gravity