Job Name/Location: Tag No.:

(Project Manager)

File For: Resubmit Date: Approval Other PO No.:

GC: Architect:

Mech: Engr:

Rep:

ARUM312BTE5

(a) ARUM096BTE5

Multi V[™] 5 with LGRED° 208-230V ODU

(b) ARUM216BTE5

26 Ton Dual Frame Heat Pump and Heat Recovery

Operating Range:



| Unit Data: | | | | |
|---|-----------------|-------------------|--|--|
| Refrigerant Type | | R410A | | |
| Refrigerant Control | | EEV | | |
| Max. Number of Indoor Units ³ | | 52 | | |
| Sound Pressure ⁴ dB(A) | | 65.0 | | |
| Weight | | 00.0 | | |
| Frame | (a) ARUM096BTE5 | (b) ARUM216BTE5 | | |
| Net (lbs.) | 507 | 666 | | |
| Shipping (lbs.) | 534 | 694 | | |
| Communication Cable (No x AWG) ⁵ | • | 2 x 18 | | |
| Heat Exchanger Coating | | Black Coated Fin™ | | |

Compressor:

| Туре | HSS DC Scroll |
|------------|---------------|
| Quantity | 3 |
| Oil / Type | PVE / FVC68D |

Fan:

| Туре | Propeller |
|-------------------------------|---------------------------------------|
| Quantity (a) + (b) | 4 |
| Motor Drive | Brushless Digitally Controlled Direct |
| Air Flow Rate (a) + (b) (CFM) | 22,600 |

Notes:

- 1. Power wiring cable size must comply with the applicable local and national codes. Cables terminate at each frame.
- 2. For main pipe segment size, refer to the LATS Multi V tree diagram.
- 3. The combination ratio must be between 50-130%.
- 4. Sound pressure levels are tested in an anechoic chamber under ISO Standard 3745 for the combination of outdoor units.
- 5. Communication cable between ODU and IDUs must be 2-conductor, 18 AWG, twisted, stranded, and shielded. Ensure the communication cable shield is properly grounded to the Main ODU chassis only. Do not ground the communication cable at any other point. Wiring must comply with all applicable local and national codes.
- 6. Acceptable operating voltage: 187 253V
- 7. The order of these units on the submittal (i.e., a+b) does not represent the installation order. Highest capacity unit is used as the Main, followed by the smaller size as Sub 1.

Performance:

Cooling Mode:

| Nominal Capacity (Btu/h) | 312,000 |
|--------------------------|---------|
| Power Input¹ (kW) | 20.70 |

Heating Mode:

| Nominal Capacity (Btu/h) | 351,000 |
|--------------------------|---------|
| Power Input¹ (kW) | 24.49 |

Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change without notice. Current certified ratings are available at www.ahridirectory.org.

Electrical:

| Frame | (a) ARUM096BTE5 | (b) ARUM216BTE5 |
|------------------------|-----------------|-----------------|
| Power Supply (V/Hz/Ø)¹ | 208-230/60/3 | 208-230/60/3 |
| MOP (A) | 40 | 80 |
| MCA (A) | 28.5 | 60.3 |
| Rated Amps (A) | 24.4 | 54.2 |
| Compressor A (A) | 16.4 | 24.3 |
| Compressor B (B) | - | 21.9 |
| Fan (A) | 8.0 | 8.0 |
| | | |

Piping:2

| Frame | (a) ARUM096BTE5 | (b) ARUM216BTE5 |
|--|-----------------|-----------------|
| Refrigerant Charge (lbs.) | 23.2 | 37.5 |
| Liquid (in., O.D.) High Pressure Vapor | 3/8 Braze | 5/8 Braze |
| (Heat Recovery only; in, O.D.) | 3/4 Braze | 1-1/8 Braze |
| Low Pressure Vapor (in., O.D.) | 7/8 Braze | 1-1/8 Braze |

Standard Features:

- Advanced Smart Load Control
- Intelligent Heating
- HiPOR (High Pressure Oil Return)
- Smart Oil Control
- Night Quiet Operation
- Fault Detection and Diagnosis
- Active Refrigerant Control
- Variable Heat Path Exchanger
- Subcooling and Vapor Injection Control
- Liquid Cooled Inverter Controller
- Advanced Comfort Cooling

Required Accessories:

☐ ARCNB21 (Frame Connector Y-branch, 3 pipe heat recovery) ☐ ARCNN21 (Frame Connector Y-branch, 2 pipe heat pump)

Optional Accessories:

☐ Air Guide - ZAGDKA52A (2 required)

☐ Hail Guard Kit - ZHGDKA52A (2 required)

Low Ambient Baffle Kit - ZLABKA52A (2), Control Kit -PRVC2 (1 per system)

☐ Base Pan Heater - ZPLT1A52A

**Cooling range with the Low Ambient Baffle Kit (sold separately) is -9.9°F to +122°F and is achieved only when all indoor units are operating in cooling mode. Does not impact heat recovery system synchronous operating range.





ARUM312BTE5

Multi V[™] 5 with LGRED° 208-230V ODU

26 Ton Dual Frame Heat Pump and Heat Recovery

(a) ARUM096BTE5






Tag No.:


Date:

PO No.: _





7/8" Diameter Leak Test Hole

Left Side View



Note: Please refer to multi-frame placement information and piping rules in the Multi V 5 Engineering Manual and the Multi V 5 Installation Manual. Minimum spacing between frames is 1 inch.





| M1 | 28-25/32" |
|-----|-------------|
| M2 | 5/8" |
| M3 | 3-15/16" |
| M4 | 40-15/16" |
| M5 | 11 – 15/16" |
| M6 | 11 – 1/16" |
| M7 | 10 – 1/2" |
| M8 | 8 – 7/16" |
| M9 | 8 – 1/8" |
| M10 | 6 – 1/16" |
| M11 | 4 – 15/16" |
| M12 | 7 – 1/2" |
| M13 | 4 – 13/16" |
| M14 | 4 – 5/16" |
| M15 | 3 – 5/8" |
| M16 | 3" |

| W | 48-13/16" |
|-----|------------|
| Н | 66-17/32" |
| D | 29-29/32" |
| L1 | 6-5/16" |
| L2 | 3-3/4" |
| L3 | 5-29/32" |
| L4 | 5-13/32" |
| L5 | 2-25/32" |
| L6 | 24-9/32" |
| L7 | 2-25/32" |
| L8 | 4-1/32" |
| L9 | 6 – 1/2" |
| L10 | 5 – 9/16" |
| L11 | 8 – 5/8" |
| L12 | 6 – 7/16" |
| L13 | 9 – 15/16" |
| L14 | 3 – 5/8" |

Center of Gravity

| X | 23-7/32" |
|---|----------|
| Y | 15-5/8" |
| Z | 25-9/16" |

All dimensions have a tolerance of $\pm\,0.25$ in. [Unit: inch]




= Center of Gravity

| loh | Name | /Location: |
|-----|---------|-------------|
| 300 | IVALLIC | , Location. |

ARUM312BTE5

Multi V[™] 5 with LGRED° 208-230V ODU

26 Ton Dual Frame Heat Pump and Heat Recovery



AHRI Data:

| Reference Number | Indoor Type | Cooling Capacity (95°F) | EER (95°F) | IEER | SCHE | High Heating Capacity (47°F) | High COP (47°F) | Low Heating Capacity (17°F) | Low COP (17°F) |
|---------------------|----------------------------|----------------------------|------------|-------|-------|---------------------------------|--------------------|--------------------------------|----------------|
| 205281474 | Ducted Indoor Units | 298,000 | 11.00 | 21.00 | 21.00 | 332,000 | 3.25 | 222,000 | 2.30 |
| 202519365 | Non-Ducted Indoor Units | 298,000 | 11.00 | 22.00 | 24.00 | 332,000 | 3.53 | 222,000 | 2.48 |