Job Name/Location: For: File Resubmit Date: Approval Other PO No.: GC: Architect: Mech: Engr: Rep: (Project Manager) ARUM336BTE5 (a) ARUM121BTE5 Multi V[™] 5 with LGRED° 208-230V ODU (b) ARUM216BTE5 28 Ton Dual Frame Heat Pump and Heat Recovery Performance: Cooling Mode: Nominal Capacity (Btu/h) 336.000 Power Input1 (kW) 23.09 Heating Mode: Nominal Capacity (Btu/h) 378,000 Power Input1 (kW) 26.95 Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change without notice. Current certified ratings are available at www.ahridirectory.org. **Electrical:** Frame (a) ARUM121BTE5 (b) ARUM216BTE5 Power Supply (V/Hz/Ø)1 208-230/60/3 208-230/60/3 MOP (A) 40 ጸበ MCA (A) 30.9 60.3 Rated Amps (A) 26.3 54.2 Compressor A (A) 18.3 24.3 Compressor B (B) 21.9 Fan (A) 8.0 8.0 Piping:2 Frame (b) ARUM216BTE5 Fan: (a) ARUM121BTE5 Refrigerant Charge (lbs.) 37.5 23.2 Liquid (in., O.D.) 1/2 Braze 5/8 Braze **High Pressure Vapor** (Heat Recovery only; in, O.D.) 3/4 Braze 1-1/8 Braze Low Pressure Vapor 1-1/8 Braze 1-1/8 Braze (in., O.D.) Notes: **Standard Features:** • Advanced Smart Load Control • Active Refrigerant Control • Variable Heat Path Exchanger • Intelligent Heating

Tag No.:



Operating Range:

Cooling (°F DB)** Heating (°F WB)	5 - 122 -22 - 61
Synchronous	
Cooling Based (°F DB)	14 - 81
Heating Based (°F WB)	14 - 61

Unit Data:

Refrigerant Type		R410A
Refrigerant Control		EEV
Max. Number of Indoor Units ³		55
Sound Pressure ⁴ dB(A)		65.0
Weight		03.0
Frame	(a) ARUM121BTE5	(b) ARUM216BTE5
Net (lbs.)	507	666
Shipping (lbs.)	534	694
Communication Cable (No x AWG)	5	2 x 18
Heat Exchanger Coating		Black Coated Fin™

Compressor:

Туре	HSS DC Scroll
Quantity	3
Oil / Type	PVE / FVC68D

Туре	Propeller
Quantity (a) + (b)	4
Motor Drive	Brushless Digitally Controlled Direct
Air Flow Rate (a) + (b) (CFM)	22,600

- 1. Power wiring cable size must comply with the applicable local and national codes. Cables terminate at each frame.
- 2. For main pipe segment size, refer to the LATS Multi V tree diagram.
- 3. The combination ratio must be between 50-130%.
- 4. Sound pressure levels are tested in an anechoic chamber under ISO Standard 3745 for the combination of outdoor units.
- 5. Communication cable between ODU and IDUs must be 2-conductor, 18 AWG, twisted, stranded, and shielded. Ensure the communication cable shield is properly grounded to the Master ODU chassis only. Do not ground the communication cable at any other point. Wiring must comply with all applicable local and national codes.
- 6. Acceptable operating voltage: 187 253V
- 7. The order of these units on the submittal (i.e., a+b) does not represent the installation order. Highest capacity unit is used as the Master, followed by the smaller size as Slave 1.
- 8. Low ambient performance with LGRED° heat technology is included in Multi V 5 units produced after February 2019.







Required Accessories:

• Night Quiet Operation

• Smart Oil Control

☐ ARCNB21 (Frame Connector Y-branch, 3 pipe heat recovery) ☐ ARCNN21 (Frame Connector Y-branch, 2 pipe heat pump)

Optional Accessories:

☐ Air Guide - ZAGDKA52A (2 required)

• HiPOR (High Pressure Oil Return)

• Fault Detection and Diagnosis

☐ Hail Guard Kit - ZHGDKA52A (2 required)

Low Ambient Baffle Kit - ZLABKA52A (2), Control Kit -

PRVC2 (1 per system)

☐ Base Pan Heater - ZPLT1A52A

**Cooling range with the Low Ambient Baffle Kit (sold separately) is -9.9°F to +122°F and is achieved only when all indoor units are operating in cooling mode. Does not impact heat recovery system synchronous operating range.

• Subcooling and Vapor Injection

• Liquid Cooled Inverter Controller

• Advanced Comfort Cooling

Control

ARUM336BTE5

Multi V™ 5 with LGRED° 208-230V ODU

28 Ton Dual Frame Heat Pump and Heat Recovery



(b) ARUM216BTE5




Tag No.:

Date:


PO No.:


7/8" Diameter Leak Test Hole

Left Side View



Note: Please refer to multi-frame placement information and piping rules in the Multi V 5 Engineering Manual and the Multi V 5 Installation Manual. Minimum spacing between frames is 1 inch.





Airflow Airflow	Power Cord Routing Hole (Bottom); two (2) - ø2" Two (2) 7/8" Diameter W Routing Holes (Bottom) 19/32" Dameter Hole Piping Routing Holes (Bottom); two - ø2-5/8," ø2-1/8"	of foundation holf holes)
△ Airflow	Ø2-1/8" M3 M4	oitch (
T	(Pitch of foundation bolt holes)	=
Top View	Bottom Mounting Holes	

M1	28-25/32"
M2	5/8"
M3	3-15/16"
M4	40-15/16"
M5	11 – 15/16"
M6	11 – 1/16"
M7	10 – 1/2"
M8	8 – 7/16"
M9	8 – 1/8"
M10	6 – 1/16"
M11	4 – 15/16"
M12	7 – 1/2"
M13	4 – 13/16"
M14	4 – 5/16"
M15	3 – 5/8"
M16	3"

(Pitch of foundation bolt holes

W	48-13/16"
Н	66-17/32"
D	29-29/32"
L1	6-5/16"
L2	3-3/4"
L3	5-29/32"
L4	5-13/32"
L5	2-25/32"
L6	24-9/32"
L7	2-25/32"
L8	4-1/32"
L9	6 – 1/2"
L10	5 – 9/16"
L11	8 – 5/8"
L12	6 – 7/16"
L13	9 – 15/16"
L14	3 – 5/8"

Center of Gravity

X	23-7/32"
Υ	15-5/8"
Z	25-9/16"

All dimensions have a tolerance of \pm 0.25 in. [Unit: inch]



= Center of Gravity