

Date:

For: File Resubmit

PO No.:

Approval Other _____

Architect:

GC:

Engr:

Mech:

Rep:

(Company)

(Project Manager)

ARUB410DT2 (a) ARUB154DT2
Multi V™ Sync II (b) ARUB154DT2
33.5 Ton Outdoor Unit (c) ARUB096DT2



Performance:

Cooling Mode:

Capacity (Btu/h)	401,700
Capacity (tons)	33.5
Power Input (kW)	35.1

Heating Mode:

Capacity (Btu/h)	451,400
Power Input (kW)	32.1

Cooling Nominal Test Conditions:

Indoor: 80°F DB /67°F WB
 Outdoor 95° DB

Heating Nominal Test Conditions:

Indoor: 70°F DB
 Outdoor 47°F DB /43°F WB

Electrical:

	(a) ARUB154DT2	(b) ARUB154DT2	(c) ARUB096DT2
Power Supply (V/Hz/Ph)	460/60/3	460/60/3	460/60/3
MOP (A)	45	45	35
MCA (A)	33	33	27
Rated Amps (A)	31.9	31.9	23.8
Compressor A (A)	18.0	18.0	11.0
Compressor B (A)	11.5	11.5	10.4
Fan Motor (A)	2.4	2.4	2.4
Max Starting Current (A)	84.4	84.4	75.8

Piping:

	(a) ARUB154DT2	(b) ARUB154DT2	(c) ARUB096DT2
Refrigerant Charge (lbs)	17.6	17.6	17.6
Liquid Line (in, OD)	1/2 Flare	1/2 Flare	3/8 Flare
Vapor Line High (in, OD)	7/8 Braze	7/8 Braze	3/4 Braze
Vapor Line Low (in, OD)	1-1/8 Braze	1-1/8 Braze	7/8 Braze

Standard Features:

- Limited Warranty with LG Certified Installation
 - Two Year Functional Parts Warranty
 - Additional Four Year Compressor Warranty
- Black Box Function
- Night Quiet Operation
- Fault Detection and Diagnosis

Operating Range:

Cooling (°F DB)	23 - 110
Heating (°F WB)	-4 - 60
Synchronous (°F DB)	14 -81

Unit Data:

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Num of Indoor Units ¹	64
Sound Pressure ² dB(A)	63
Net Unit Weight (a) + (b) + (c) (lbs)	628 + 628 + 628
Shipping Weight (a) + (b) + (c) (lbs)	664 + 664 + 664
Communication Cable (No. x AWG)	
Outdoor to Indoor ³	2 x 18
Outdoor to Outdoor ⁴	2 x 18
Heat Exchanger Coating	GoldFin™

Compressor:

Inverter Scroll Quantity	3
Constant Scroll Quantity	2
Oil / Type	PVE/FVC68D

Fan:

Type	Propeller
Quantity (a) + (b) + (c)	2 + 2 + 2
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (a) + (b) + (c) (CFM)	6,700 + 6,700 + 6,700

Notes:

- 1.The combination ratio must be between 50-130%.
- 2.Sound pressure levels are tested in an anechoic chamber under Korea Standard KSA0701 for the combination of outdoor units.
- 3.All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code. Cables terminate at each frame.
- 4.All communication cable to be minimum 18 AWG, 2-conductor, stranded and must comply with applicable local and national code. Cables terminate at each frame.
- 5.The data mentioned in the above tables is applied with non-ducted indoor units.
- 6.This data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination ratio between 95 – 105%.
- 7.The voltage tolerance is ± 10%.
- 8.Power wiring cable size must comply with the applicable local and national code. Cables terminate at each frame.
- 9.Requires ARCNB20 and ARCNB30 connecting branch pipes to connect components.



