

Date: _____ For: File Resubmit
 PO No.: _____ Approval Other _____

Architect: _____ GC: _____

Engr: _____ Mech: _____

Rep: _____
 (Company) (Project Manager)

ARUB450DT2 (a) ARUB154DT2
Multi V™ Sync II (b) ARUB154DT2
36.5 Ton Outdoor Unit (c) ARUB134DT2



Performance:

Cooling Mode:

Capacity (Btu/h)	439,600
Capacity (tons)	36.5
Power Input (kW)	39.8

Heating Mode:

Capacity (Btu/h)	494,500
Power Input (kW)	35.4

Cooling Nominal Test Conditions: Indoor: 80°F DB /67°F WB
 Outdoor 95° DB
 Heating Nominal Test Conditions: Indoor: 70°F DB
 Outdoor 47°F DB /43°F WB

Electrical:

	(a) ARUB154DT2	(b) ARUB154DT2	(c) ARUB134DT2
Power Supply (V/Hz/Ph)	460/60/3	460/60/3	460/60/3
MOP (A)	45	45	40
MCA (A)	33	33	32
Rated Amps (A)	31.9	31.9	28.9
Compressor A (A)	18.0	18.0	15.0
Compressor B (A)	11.5	11.5	11.5
Fan Motor (A)	2.4	2.4	2.4
Max Starting Current (A)	84.4	84.4	83.9

Piping:

	(a) ARUB154DT2	(b) ARUB154DT2	(c) ARUB134DT2
Refrigerant Charge (lbs)	17.6	17.6	17.6
Liquid Line (in, OD)	1/2 Flare	1/2 Flare	1/2 Flare
Vapor Line High (in, OD)	7/8 Braze	7/8 Braze	3/4 Braze
Vapor Line Low (in, OD)	1-1/8 Braze	1-1/8 Braze	1-1/8 Braze

Standard Features:

- Limited Warranty with LG Certified Installation
 - Two Year Functional Parts Warranty
 - Additional Four Year Compressor Warranty
- Black Box Function
- Night Quiet Operation
- Fault Detection and Diagnosis

Operating Range:

Cooling (°F DB)	23 - 110
Heating (°F WB)	-4 - 60
Synchronous (°F DB)	14 -81

Unit Data:

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Num of Indoor Units ¹	64
Sound Pressure ² dB(A)	63
Net Unit Weight (a) + (b) + (c) (lbs)	628 + 628 + 628
Shipping Weight (a) + (b) + (c) (lbs)	664 + 664 + 664
Communication Cable (No. x AWG)	
Outdoor to Indoor ³	2 x 18
Outdoor to Outdoor ⁴	2 x 18
Heat Exchanger Coating	GoldFin™

Compressor:

Inverter Scroll Quantity	3
Constant Scroll Quantity	2
Oil / Type	PVE/FVC68D

Fan:

Type	Propeller
Quantity (a) + (b) + (c)	2 + 2 + 2
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (a) + (b) + (c) (CFM)	6,700 + 6,700 + 6,700

Notes:

- The combination ratio must be between 50-130%.
- Sound pressure levels are tested in an anechoic chamber under Korea Standard KSA0701 for the combination of outdoor units.
- All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code. Cables terminate at each frame.
- All communication cable to be minimum 18 AWG, 2-conductor, stranded and must comply with applicable local and national code. Cables terminate at each frame.
- The data mentioned in the above tables is applied with non-ducted indoor units.
- This data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination ratio between 95 – 105%.
- The voltage tolerance is ± 10%.
- Power wiring cable size must comply with the applicable local and national code. Cables terminate at each frame.
- Requires ARCNB20 and ARCNB30 connecting branch pipes to connect components.



Job Name/Location:

ARUB450DT2
 Multi V™ Sync II
 36.5 Ton Outdoor Unit


(a) ARUB154DT2
 (b) ARUB154DT2
 (c) ARUB134DT2



Tag #:

Date:

PO No.:



Center of Gravity

	(a) ARUB154DT2	(b) ARUB154DT2	(c) ARUB134DT2
X	21-3/4	21-3/4	21-3/4
Y	12	12	12
Z	21-5/16	21-5/16	21-5/16

= Center of Gravity

W	50-3/8
H	63-5/16
D	28-11/16
L1	27-3/8
L2	27-11/16
L3	20-5/8
L4	23
L5	29-7/8
L6	7-3/8
L7	5-7/8
L8	3-3/16
L9	56-1/8
L10	3-7/8
M1	35-7/16
M2	27-9/16

Note - All dimensions have a tolerance of ± 0.25 in.