

Job Name/Location:

Tag #:

Date:

For: File Resubmit

PO No.:

Approval Other _____

Architect:

GC:

Engr:

Mech:

Rep:

(Company)

(Project Manager)

Header Kits

7 Port




Insulation Properties:

Material	Polyolefin Foam
UL94 Flame Classification	HF-1


Fitting Properties:

Material	Copper
Design Pressure	551 PSIG

Outlet Ports



7-Port Header Dimensions



Not to scale

Model	Insulation for Header	
	Qty	
	Liquid	Vapor
ARBL057	1	1
ARBL107	1	1



Model	Tube End Caps		
	Qty		
	Ø1/4	Ø1/2	Ø5/8
ARBL057	2	2	-
ARBL107	2	2	2



Model	Insulation for Tube End Caps	
	Qty	
	Model	Qty
ARBL057	4	
ARBL107	6	

Header Connection Diameters (in, ID)								
Model	Header Type	Port Identifier						
		1	2	3	4	5	6	7
ARBL057	Liquid	-	3/8	1/2	3/8	1/4	3/8	1/4
	Vapor	1	5/8	3/4	5/8	1/2	5/8	1/2
ARBL107	Liquid	-	3/8	1/2	3/8	1/4	3/8	1/4
	Vapor	7/8	1	1-1/8	3/4	5/8	5/8	1/2

Header Dimensions ¹ (in)											
Model	Header Type	A	B	C	D	E	F	G	H	I	J
ARBL057	Liquid	5-29/32	4-23/32	4-23/32	7-3/32	9-15/32	11-27/32	14-7/32	16-13/32	18-31/32	21-1/4
	Vapor	5-29/32	4-23/32	4-23/32	7-3/32	9-15/32	11-27/32	14-7/32	16-13/32	18-31/32	21-1/4
ARBL107	Liquid	5-29/32	4-23/32	4-23/32	7-3/32	9-15/32	11-27/32	14-7/32	16-13/32	18-31/32	27-9/16
	Vapor	5-29/32	4-23/32	6-5/16	8-11/16	11-1/16	13-7/16	15-13/16	18-3/16	20-9/16	22-27/32

Notes:

- 1.LG header fittings must be used. Field supplied header fittings are not permitted.
- 2.Kit components must be kept dry and free of debris before installation.
- 3.Must follow installation instructions in the applicable LG installation manual.