Job Name/Location:

Date:

PO No.:

Architect:

Engr:

Mech:

Rep:

(Company)

(Project Manager)

© LG

AMATIVE

AMATIV

ARUB288BTE4

(a) ARUB144BTE4

Multi V™ IV Heat Recovery 24.0 Ton Outdoor Unit

(b) ARUB144BTE4

Performance:

Cooling Mode:

Nominal Capacity (Btu/h)	288,000
Power Input ¹ (kW)	19.28

Heating Mode:

Nominal Capacity (Btu/h)	324,000
Power Input¹ (kW)	21.70

Nominal Capacity is outside the scope of AHRI Standard 1230 and based on the following conditions: Indoor: 80°F DB / 67°F WB Indoor: 70°F DB

Outdoor 95°F DB Outdoor 47°F DB / 43°F WB

Electrical: (a) ARUB144BTE4 (b) ARUB144BTE4

	1 -7	· · / ·
Power Supply (V/Hz/Ø)	208-230/60/3	208-230/60/3
MOP (A)	60	60
MCA (A)	48.8	48.8
Rated Amps (A)	44.0	44.0
Compressor A (A)	19.0	19.0
Compressor B (A)	19.0	19.0
Fan (A)	6.0	6.0

Piping:	(a) ARUB144BTE4	(b) ARUB144BTE4
Refrigerant Charge (lbs)	23.6	23.6
Liquid Line ² (in, OD)	1/2	1/2
Vapor Line High² (in, OD)	7/8	7/8
Vapor Line Low² (in, OD)	1-1/8	1-1/8

Standard Features:

- •HiPOR (high pressure oil return)
- •Smart Oil Control
- •Split Frame Defrost
- Night Quiet Operation
- Fault Detection and Diagnosis

Required Accessories:

ARCNB21 (frame connector Y-branch)

Optional Accessories:

- Air Guide (8-12 ton outdoor units) PRAGX3S0 (4 required)
- Hail Guard Kit ZHGDKA04A (2 required)
- Low Ambient Baffle Kit ZLABKA03A (2 required), Control Kit PRVC2 (1 per system)
 - **(-9.9°F achieved only when all IDU's are operating in cooling mode. Does not impact synchronous operating range.)

Operating Range:

Tag #:

Cooling (°F DB)**	14-122
Heating (°F WB)	-13 - 61
Synchronous	
Cooling Based (°F DB)	14 – 81
Heating Based (°F WB)	14 – 61

Unit Data:

Refrigerant Type	R410A
Refrigerant Control	EEV
Max Number of Indoor Units ³	45
Sound Pressure ⁴ dB(A)	62.5
Net Unit Weight (a) + (b) (lbs)	628 + 628
Shipping Weight (a) + (b) (lbs)	661 + 661
Communication Cable⁵ (No x AWG)	2 x 18
Heat Exchanger Coating	GoldFin™

Compressor:

Туре	HSS DC Scroll
Quantity	4
Oil/Type	PVE/FVC68D

Fan:

Туре	Propeller
Quantity	4
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow Rate (CFM)	20,400

Notes:

- 1.For AHRI ratings, refer to the AHRI website http://www.ahridirectory.org.
- 2.For main pipe segment size, refer to the LATS Multi V tree diagram.
- 3. The combination ratio must be between 50-130%.
- 4.Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745 for the combination of outdoor units.
- 5.All communication cable to be minimum 18 AWG, 2-conductor, stranded, shielded and must comply with applicable local and national code. Cables terminate at each frame. 6.Nominal data is rated 0 ft above sea level, with 25 ft of refrigerant line per indoor unit and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination ratio between 95-105%.
- 7. Power wiring cable size must comply with the applicable local and national code. Cables terminate at each frame.
- 8. The voltage tolerance is \pm 10%.







ARUB288BTE4
Multi V™ IV Heat Recovery
24.0 Ton Outdoor Unit

(a) ARUB144BTE4 (b) ARUB144BTE4



Tag #:
Date:
PO No.:

