Job Name/Location: Tag #: For: File Resubmit Date: Approval Other\_ PO No .: Architect: GC: Mech: Engr: Rep:

(Project Manager)

# LCN098HV4

Multi F Ceiling Cassette Indoor Unit 9,000 Btu/h



#### Performance:

(Company)

Nominal Cooling Capacity (Btu/h)	9,000
Nominal Heating Capacity (Btu/h)	10,400

Cooling Nominal Test Conditions: Indoor: 80°F DB / 67°F WB Outdoor: 95°F DB / 75°F WB

Heating Nominal Test Conditions: Indoor: 70°F DB / 60°F WB Outdoor: 47°F DB / 43°F WB

### Electrical:

Power Supply (V¹/Hz/Ø)	208-230/60/1
Rated Amps (A)	0.25

# Piping:

Installed Liquid Pipe (in., O.D.)	ø1/4
Installed Vapor Pipe (in., O.D.)	ø3/8
Liquid Connection (in., O.D.)	ø1/4
Vapor Connection (in., O.D.)	ø3/8
Drain (in., O.D. / I.D.)	1-1/4, 1
Temperature Sensor	Thermistor

## **Controls Features:**

- Two thermistor control
- 24-Hour on / off timer
- Auto operation
- Auto restart
- · Chaos swing
- Control lock function
- Drain pump

• Group control

system details)

- Inverter (variable speed fan)
- · Compatible with accessory Wi-Fi
- Compatible with applicable Single Zone Outdoor Units (see single zone literature for matching

# **Included Accessories:**

• Wireless Remote Controller — PWLSSB21H

# Required Accessories: (sold separately)

☐ Grille Kit - PT-QAGW0

# **Optional Accessories:**

- ☐ MultiSITE™ CRC2 Controller PREMTBVC2
- ☐ Program Remote Controller PREMTB100
- ☐ Delux Remote Controller PREMTB200
- ☐ Dry Contact for Third Party Thermostat PDRYCB320
- ☐ Remote Temperature Button Sensor ZRTBS01
- ☐ Auxiliary Heater Kit PRARH1
- ☐ Wi-Fi Module PWFMDD200



## **Entering Mixed Air:**

Cooling (°F WB)	57 ~ 77
Heating (°F DB)	59 ~ 81

### **Unit Data:**

Refrigerant Type	R410A
Refrigerant Control	EEV
Sound Pressure (H/M/L) dB(A) <sup>2</sup>	36 / 33 / 30
Primary Filter <sup>3</sup>	Washable Pre-filter
Net Weight (lbs.)	29
Shipping Weight (lbs.)	34
Grille Net Weight (lbs.)	7
Grille Shipping Weight (lbs.)	9

#### Fan:

Туре	Turbo
Quantity	1
Motor/Drive	Brushless Digitally Controlled/Direct
Air Flow H/M/L (CFM)	300 / 265 / 230

#### Notes:

- NOLES:

  1. Acceptable operating voltage: 187V-253V.

  2. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 3745.

  3. Removable Washable Filter size: 14" x 14" x 1".

  4. See Engineering Manual for sensible and latent capacities.

  5. All communication / connection (power) cable from the outdoor unit to the indoor unit is field supplied and must be a minimum of four-conductor, 18 AWG, stranded, shielded or unshielded (if shielded, it must be grounded to the chassis of the outdoor unit only), and must comply with applicable local and national codes.

  6. Power wiring cable size must comply with the applicable local and national code.

  7. The indoor unit comes with a dry helium charge.
- 8. Corresponding refrigerant piping length is in accordance with standard length of each outdoor unit and the level difference is 0 ft. All capacities are net with a combination ratio between 95 105%.

  9. Must follow installation instructions in the applicable LG installation manual.







# LCN098HV4

Multi F Ceiling Cassette Indoor Unit 9.000 Btu/h



PO No.:

