Job	Name/	Location:
-----	-------	-----------

Tag No.:

Date:		For:	File	Resubmit
<u>PO No.:</u>			Approval	Other
Architect:	GC:			
Engr:	Mec	h:		
Rep:				
(Company)	(Project I	Manager)		-
ARWM576CAS5	AR	WM1	92CAS5	
Multi V™ Water V 575V	AR	WM1	92CAS5	Life's Good
48 Ton Water Source Unit HP or HR	AR	WM1	92CAS5	

Performance:

Cooling Mode:

Nominal Capacity (Btu/h)

Heating Mode:

Nominal Capacity (Btu/h) ¹	642,000
---------------------------------------	---------

Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change without notice. Current certified ratings are available at www.ahridirectory.org.

Electrical: 5,6

Frame (a)	ARWM192CAS5 (b)	ARWM192CAS5 (c)	ARWM192CAS5
Power Supply (V/Hz/Ø)	575/60/3	575/60/3	575/60/3
MOP (A)	30	30	30
MCA (A)	17.8	17.8	17.8
Rated Amps (A)	14.2	14.2	14.2

Piping:⁷

Frame	(a) ARWM192CAS5 (b)	ARWM192CAS5 (c)	ARWM192CAS5
Refrigerant Charge (lbs	.) 9.9	9.9	9.9
Liquid (in., O.D.) High Pressure Vapor	5/8	5/8	5/8
(in., O.D.)	1-1/8	1-1/8	1-1/8
Low Pressure Vapor (in., O.D.)	1-1/8	1-1/8	1-1/8

Water Piping:

Frame	(a) ARWM192CAS5 (b)	ARWM192CAS5 (c)	ARWM192CAS5
Inlet / Outlet (inches)	1-1/2	1-1/2	1-1/2
Condenser Water:			

Frame (a) ARWM192CAS5 (b)	ARWM192CAS5 (c)	ARWM192CAS5
Flow Rate (gpm)	50.7	50.7	50.7
Pressure Drop (ftw.g.)*	10.8	10.8	10.8

* Pure water. See Propylene and Ethylene glycol tables in the MV Water 5 Engineering manual for adjustment if fluid mixture contains antifreeze.

Condensate Piping:

Frame	(a) ARWM192CAS5 (b)	ARWM192CAS5 (c)	ARWM192CAS5
Condensate Line (inche	es) 3/4	3/4	3/4
Standard Features:			

- Fault Detection and Diagnosis
- HiPOR (High Pressure Oil Return)
- Smart Oil Control
- Subcooling and Vapor Injection Control
- Internal Refrigerant Cooling Control

Required Accessories:

ARCNN21 or ARCNN31 (HP) / ARCNB21 or ARCNB31 (HR)-Frame Connector Y-branch PT / NPT Conversion Thread

Optional Accessories:

□ Variable Water Flow Valve Control Kit - PWFCKN000

For continual product development, LG reserves the right to change specifications without notice. © LG Electronics Canada, Inc., North York, ON. All rights reserved. "LG Life's Good" is a registered trademark of LG Corp. /www.lgvrf.ca



571,200





Water Operating Range:²

Cooling Mode Entering Water Range (°F)			50 - 113	
Heating Mod	e Entering Water	Range (°I	=)	23 - 113
Synchronous	Mode Entering V	Vater Ran	ge (°F)	23 - 113
Unit Data:				
Refrigerant T	уре			R410A
Refrigerant C	Control			EEV
Max. Number of Indoor Units				64
Sound Pressure dB(A) ³				
Cooling / H	eating			63
Weight				
Frame	(a) ARWM192	CAS5 (b)	ARWM192CAS5(c)	ARWM192CAS5
Net (lbs.)		348	348	348
Shipping (II	os.)	370	370	370
Communicat	Communication Cable (No x AWG) ^{5,6}			2 x 18
Heat Exchanger Type		Stai	nless Steel Plate	
1				

Compressor:

Inverter

Туре	Hermetic Scroll
Drive	Inverter
Quantity	3
Oil / Type	PVE / FVC68D

Notes:

1. Rated capacity is certified under AHRI Standard 1230. Ratings are subject to change.

2. When entering water temperature is lower than 59°F, variable water flow control kit PWFCKN000 is required. When entering water temperature is lower than 50°F, water solution must be minimum 45% antifreeze.

- 3. Sound pressure levels are tested in anechoic chamber under ISO 3745 standard.
- 4. Value is calculated as follows: Delta T= Total Heat of Rejection/(Nominal Flow Ratex500)
- 5. Communication cable between WSU, IDU(s) / HRU(s), and Central Controller must be a minimum of 2-conductor, 18 AWG, twisted, stranded, and shielded. Ensure the communication cable shield is properly grounded to the WSU chassis only. Do not ground the communication cable at any other point. Wiring must comply with all applicable local and national codes.
- 6. Power wiring is field provided, solid or stranded, and must comply with all applicable local and national codes.
- 7. LG requires that LATS software be used on all projects to ensure correct line sizing. Designer must verify the shop drawing design against as built design using LATS. Contractor must also use LG manufactured Y-Branch and Header Kits only.





ARWM576CAS5

Multi V™ Water 5 Heat Pump/Heat Recovery 48 Ton Water Source Unit

ARWM192CAS5 ARWM192CAS5 ARWM192CAS5



Tag No: Date:

PO No:

13-1/16' 19-11/16 -3/4' -7/8 -15/16 -9/16 00 44-1/8 -3/16 57-7/8 11-1/4' 1/2 30-3/ I 2 97 M2 M3 \mathbb{A}_{4} \geq Т 57 4 N 2 8 Σ 5 \times Ŀ Side View lsometric 20 Wring Ent 0006 0 6 ٩ Front View Top View ۵ **1000** 6 ŝ Ę

000

2

For continual product development, LG reserves the right to change specifications without notice.

τw

00